

HTE # 06-50013794

ARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

18207

OPERATIONS PERMIT

Name: (owner) JEFF AUSTIN New Installation Septic Tank Repair

Property Location: SR# HWY 2103 Nitrification Line Expansion
Subdivision _____ Lot # _____ Tax ID # _____ Quadrant # _____

Contractor: GERALD TEMPLE Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 2x1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 135 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain Required: _____ Linear feet

Date: 3/17/06

PERMIT NO. 22483

Inspected by: [Signature] RS

29.86 ac LOT

