



Fire Marshal Division

September 26, 2018

Jason Price
2323 Keith Hills Rd
Lillington, NC

Re: Campbell Pointe Town Homes

Application Number BCOM1808-0012

To Whom It May Concern,

Thank you for submitting the plans for the building. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

Plan Review Notes

- **906.1 Fire Extinguishers**
 - All fire extinguishers shall be properly mounted and tagged by a fire extinguisher company.

- **505.1 Address Numbers**
 - Determine the proper address numbers that need to be posted
 - Install physical address numbers on the building.
 - The numbers are to be visible from the street.

- **1008.1.2 Door Swing**
 - All Exit doors in an Assembly occupancy of over 50 must swing in the outward direction.

- **1008.1.10.1 Panic Hardware**
 - All doors servicing areas with an occupancy load of 50 or more, must be equipped with panic hardware.



- **1011.1 Exit Lights**

- Installation of additional exit lights may be required if lights indicated on plans are not clearly seen from all areas that exit is serving, this may be a result of equipment placement.
- Please note location on plans

Notes

- A fire final inspection is required.
- All fire inspection request should be made through the Fire Marshal's Office.
- (910) 984-4003

Thank you again for submitting the plans for the building. Please review the plan review notes and if you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal