



## Fire Marshal Division

November 26, 2018

**Re: Carolina Wildlife Park  
1096 Patterson Rd.  
Broadway, NC 27505**

**Application Number BCOM-1811-0005**

To Whom It May Concern,

Thank you for submitting the plans for the utility building. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **505.1 Physical Address**
  - The physical address of the site shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
  - The numbers used to make up the physical address shall be at least 5 inches in height.

Thank you again for submitting the plans for the tower site. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. If you have any questions, please do not hesitate to call this office. 910-984-4003

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal