



Permit Inspections Harnett County

Permit Number: BCOM1812-0001

Description: Carolina wildlife Park - Male and Female restroom facility

Applied: **12/4/2018**

Approved: **2/1/2024**

Site Address: **1096 PATTERSON RD**

Issued: **3/5/2024**

Finalized: **10/1/2024**

City, State Zip Code: **BROADWAY, NC 27505**

Status: **FINALED**

Applicant: **CWCP HOLDINGS LLC**

Parent Permit:

Owner: **CWCP HOLDINGS LLC**

Parent Project:

Contractor: **Carolina Wildlife Park**

Details:

Scheduled the zoning inspection today with Randy Baker.

Randy went out and failed the zoning for...

Front buffer has not been installed.

Replace required parking lot vegetation that has died.

I emailed Kurt to let him know status.

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	2/8/2019	2/8/2019	FOOTING	Scott Guy	APPROVED	
Notes:						
	2/28/2019	2/28/2019	ENVIR OPERATIONS PERMIT	Oliver Tolksdorf	APPROVED	
Notes:						
	6/19/2019	6/19/2019	ROUGH IN	Scott Guy	APPROVED	
Notes:						
	4/8/2024	4/8/2024	ROUGH IN	Brad Sutton	APPROVED	
Notes:						
	4/8/2024	4/8/2024	INSULATION	Brad Sutton	APPROVED	
Notes:						
	8/22/2024	8/22/2024	FINAL**	Brad Sutton	DISAPPROVED	
Notes: Close up all electrical in storage are upstairs. Covers missing, hanging wire must be in boxes and blanked off etc						
	8/22/2024	8/22/2024	10:45 AM ZONING	Randy Baker	DISAPPROVED	
Notes: This zoning inspection is for the entire park. Front buffer has not been installed. Replace required parking lot vegetation that has died.						





Permit Inspections Harnett County

	8/22/2024 AM	8/22/2024 AM	FM FINAL	Roger Sullivan	DISAPPROVED	see notes
Notes: Emergency light in womens bathroom did not illuminate during test.						
	9/17/2024	9/17/2024 10:00 AM	ZONING	Randy Baker	APPROVED	
Notes:						
	9/18/2024	9/23/2024	FM FINAL	Michael Heath	APPROVED	Approved
Notes: FM Final Completed. (MBH)						
	10/1/2024	10/1/2024	FINAL**	Brad Sutton	APPROVED	
Notes:						

