



Application for Plan Review

Application # B.COM1901.0001

Date Received: 9 Jan 19 Received By: djoulsm

Name of Project: Lions Den Power House Gym

Physical Address of Project: 4319 Ray Road

Spring Lake, NC 28390

Plans Submitted By: Amy & Mitchell Mazz

Project Phone: (910) 728-3983

Contact Person/Address: 601 Kentucky Derby Lane
Lillington NC 27546


Contact Email: aceelift@gmail.com

Contact Phone: (843) 901-7265 () - -


Contractor's Name/Info: _____

Contractor's Phone: () - -

- Plans that are submitted will be reviewed as quickly as possible with an average time of review between 7-10 working days.
- Status checks may be conducted on plan reviews by visiting the website <http://hteweb.harnett.org/Click2GovBP/Index.jsp> or by calling the Harnett County Central Permitting Office (910-893-7525, Option #2), or the Harnett County Fire Marshal's Office (910-893-7580).
- Approved plans must be picked up from the Central Permitting Office and all fees paid before any required inspections can be conducted.



Occupancy Load
Must Be
Designated



Current door is single out-swing door with panic hardware. If this door is to be changed, it must be out-swing with panic hardware.

Reviewed For Code Compliance By:
D. Banks Wallace
 Chief Deputy Fire Marshal
 01/18/2019 9:31:15 AM