



Fire Marshal Division

June 5, 2019

William Wade Vuncannon
101 Parker Drive
Fuquay-Varina, NC 27526

**Re: Whitey's Country Store
4298 Christian Light Rd.
Fuquay-Varina, NC 27526**

Application Number BCOM1904-0004

To Whom It May Concern,

Thank you for submitting the plans for the building addition. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the facility can be given. These items are outlined and described below.

- **Penetrations**
 - All penetrations in fire rated construction must be UL listed and inspected.

- **Fire Extinguishers**
 - Minimum of (1) 2A10:BC fire extinguisher shall be installed per 75' distance of travel.
 - All Fire extinguisher shall be properly mounted and tagged by a fire extinguisher company.

- **Knox Box**
 - The building owner has been required to install a Knox box.
 - Provide entry key to be placed in the complex Knox box.

- **Address Numbers**
 - Install physical address numbers on the building.
 - The numbers are to be visible from the street.



- **Means of Egress Illumination**

- The means of egress, including the exit discharge, shall be illuminated at all time the building space is served by the means of egress is occupied.
 - Means of egress consist of three separate and distinct parts: the exit access, the exit and the exit discharge.
- The means of egress illumination shall not be less than 1 foot-candle at the walking surface.

- **Notes**

- **The plans don't show an approved means of egress from the addition and/or the existing storage area. Please clarify as one is required.**
- **Please schedule all inspections through the Fire Marshal's Office. 910-984-4003.**

Thank you again for submitting the plans for the building alterations. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal