



## Fire Marshal Division

June 10, 2019

Phil Avilez

**Re: World Snow Daze  
5628 US 421 Hwy S.  
Lillington, NC 27546**

**Application Number BCOM1906-0001**

To Whom It May Concern,

Thank you for submitting the plans for the snoball business. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

### Plan Review Notes

- A Knox Box is required to be installed on the building.
- The physical address numbers shall be mounted on the building. They should be a minimum 6" in height and visible from the roadway.
- The fire extinguishers are required to be properly mounted and tagged by a fire extinguisher company.
- A Fire and Life Safety Plan should be added to the plans to designate existing and proposed features.
- **A fire final inspection is required. Call 910-984-4003 to schedule.**

Thank you again for submitting the plans for the building up-fit. Please review the plan review notes and if you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal