

July 24, 2019

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Good Hope Hospital, Inc.
PO Box 639
Erwin, NC 28339

ph: 910-893-7547
fax: 910-893-9371

Re: Good Hope Hospital Addition
410 Denim Drive
Erwin, NC 28339
Trakit# BCOM 1906-0004

Dear Sir or Madam:

The plans for the addition to the existing facility has been reviewed but not approved. The following items must be corrected before the plan can be approved.


1. The proposed two-compartment, one drainboard kitchen sink must be replaced with a three-compartment, two drainboard sink.

In addition, please submit equipment specification sheets for the proposed ice machine and kitchen refrigerator.

Please be advised that any changes or recommendations concerning the approval of this plan are to be addressed through this office. The review of this plan was made using 15A NCAC 18A .2600, "Rules Governing the Food Protection and Sanitation of Food Establishments," the "North Carolina Food Code Manual" and 15A NCAC 18A .1300, "Rules Governing the Sanitation of Hospitals, Nursing Homes, Adult Care Homes, and Other Institutions." This review does not cover any other aspects of construction regulated by other jurisdictions. Any changes to menu items, equipment or kitchen design voids this approval.

If you have comments or questions, please feel free to contact this office at (910) 893-7547 between 8-9 a.m. Monday-Friday.

Regards,



Gale Violette, REHS
Harnett County Health Department
Environmental Health Section