

Carolina Fire Protection, Inc.
4055 Hodges Chapel Road
P.O. Box 250 (28335)
Dunn, NC 28334
910-892-1700

Kevin W. Nelson

FS-23769

NICET # 152077

Job Name : GOOD HOPE 2020 Addition Area #2
Building : Remote area #2
Location : 410 Denim Drive
System :
Contract : 20K533
Data File : GOOD HOPE 2020 ADDITION MEZZ.wxtmp

Hydraulic Design Information Sheet

Name - GOOD HOPE 2020 Addition Area #2 Date - 12-3-2020
 Location - 410 Denim Drive
 Building - Remote area #2 System No. -
 Contractor - Carolina Fire Protection, Inc. Contract No. - 20K533
 Calculated By - Mark Ford Drawing No. -
 Construction: () Combustible (X) Non-Combustible Ceiling Height - Varies
 Occupancy - Mechanical Mezzanine

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E	Area of Sprinkler Operation	Density	System Type	Sprinkler/Nozzle
M	- Entire	- .15	() Wet	Make Reliable
D	Area Per Sprinkler	- 100	() Dry	Model Upright
E	Elevation at Highest Outlet	- 25.750	() Deluge	Size 1/2
S	Hose Allowance - Inside	- n/a	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- n/a	() Other	Temp.Rat.286
G	Hose Allowance - Outside	- 250		

N Note

Calculation Flow Required - 416.905 Press Required - 35.939 Test
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 20-19-2020 Cap. -
 T Time of Test - 4:10 pm Rated Cap.- Elev.-
 E Static Press - 54 @ Press -
 R Residual Press - 46 Elev. - Well
 Flow - 888 Proof Flow
 S Elevation - 0

U Location - 410 Denim Drive
 P Source of Information - Erwin Fire Department
 L
 Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	Solid Piled %	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf
O			
R	K Flue Spacing	Clearance:Storage to Ceiling	
A	Longitudinal	Transverse	
G			
E	Horizontal Barriers Provided:		

Water Supply Curve

Carolina Fire Protection, Inc.
 GOOD HOPE 2020 Addition Area #2


Page 2
 Date 12-3-2020

City Water Supply:

C1 - Static Pressure : 54
 C2 - Residual Pressure: 46
 C2 - Residual Flow : 888

Demand:

D1 - Elevation : 11.152
 D2 - System Flow : 166.905
 D2 - System Pressure : 35.939
 Hose (Demand) : 250
 D3 - System Demand : 416.905
 Safety Margin : 16.086



Fittings Used Summary

Carolina Fire Protection, Inc.
 GOOD HOPE 2020 Addition Area #2

Page 3
 Date 12-3-2020

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Rcr Reliable G Riser Ck					6.7	9.6	6	5.3		7.1		13.7	15.9	28.8						
T NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 4
Date 12-3-2020

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.0	46	888.0	52.025	416.9	35.939

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
1A	10.0		29.65			
2A	10.0		29.65			
3A	10.0		29.65			
4A	10.0		29.65			
5A	10.0		29.65			
6A	10.0		29.65			
7A	10.0		29.65			
8A	10.0		29.65			
9A	10.0		29.65			
10A	10.0		29.65			
11A	10.0		29.65			
12A	10.0		29.65			
13	25.75	5.6	7.98	15.82	0.15	100
14	23.0	5.6	9.24	17.02	0.15	100
15	21.167	5.6	10.23	17.91	0.15	100
16	23.333	5.6	8.03	15.87	0.15	100
17	25.75	5.6	7.17	15.0	0.15	100
18	23.0	5.6	8.6	16.42	0.15	100
19	21.167	5.6	9.78	17.51	0.15	100
20	25.75	5.6	8.19	16.03	0.15	100
21	23.0	5.6	9.45	17.22	0.15	100
22	21.167	5.6	10.45	18.1	0.15	100
M1	18.583		12.6			
M2	18.583		12.86			
M3	18.583		13.04			
F1	11.5		29.0			
1	11.5		29.0			
2	11.5		29.0			
3	11.5		29.0			
4	11.5		29.0			
5	11.5		29.0			
F2	11.5		29.0			
6	11.5		29.0			
7	11.5		29.0			
8	11.5		29.0			
9	11.5		29.0			
10	11.5		29.0			
F3	11.5		29.0			
11	11.5		29.0			
12	11.5		29.0			
F4	11.5		29.0			
F5	11.5		29.0			

Flow Summary - NFPA

Carolina Fire Protection, Inc.
 GOOD HOPE 2020 Addition Area #2

Page 5
 Date 12-3-2020

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
F6	11.5		28.99		
F7	11.5		28.99		
F8	11.5		28.99		
F9	11.5		28.99		
F10	11.5		29.0		
F11	11.5		29.02		
F12	11.5		29.02		
F13	11.5		29.04		
F14	11.5		29.05		
F15	11.5		29.05		
N1	11.5		29.0		
N2	11.5		29.0		
N3	11.5		29.0		
N4	11.5		29.01		
N5	11.5		29.01		
N6	11.5		28.95		
N7	11.5		28.92		
N8	11.5		28.87		
N9	11.5		28.84		
N10	11.5		28.77		
N11	11.5		29.02		
N12	11.5		29.04		
N13	11.5		29.1		
N14	11.5		29.19		
N16	11.5		29.25		
TASR	11.5		29.56		
BASR	1.0		34.36	250.0	
TEST	0.0		35.94		

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 6
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1A to 1	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.649 -0.650 0.001		Vel = 0	
1			0.0 0.0						29.000		K Factor = 0	
2A to 2	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.650 -0.650 0.0		Vel = 0	
2			0.0 0.0						29.000		K Factor = 0	
3A to 3	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.650 -0.650 0.001		Vel = 0	
3			0.0 0.0						29.001		K Factor = 0	
4A to 4	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.651 -0.650 0.0		Vel = 0	
4			0.0 0.0						29.001		K Factor = 0	
5A to 5	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.652 -0.650 0.0		Vel = 0	
5			0.0 0.0						29.002		K Factor = 0	
6A to 6	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.649 -0.650 0.001		Vel = 0	
6			0.0 0.0						29.000		K Factor = 0	
7A to 7	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.650 -0.650 0.0		Vel = 0	
7			0.0 0.0						29.000		K Factor = 0	
8A to 8	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.650 -0.650 0.001		Vel = 0	
8			0.0 0.0						29.001		K Factor = 0	
9A to 9	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.651 -0.650 0.0		Vel = 0	
9			0.0 0.0						29.001		K Factor = 0	
10A to 10	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.652 -0.650 0.0		Vel = 0	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 7
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10			0.0 0.0						29.002		K Factor = 0	
11A to 11	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.650 -0.650 0.0		Vel = 0	
11			0.0 0.0						29.000		K Factor = 0	
12A to 12	10 11.5		0.0 0.0	1 1.049	T Eq	5.0 36.0	1.000 41.000 42.000	120 0	29.651 -0.650 0.001		Vel = 0	
12			0.0 0.0						29.002		K Factor = 0	
13 to 14	25.750 23	5.60	15.82	1.5			8.000	120	7.982 1.191		Vel = 2.28	
14 to 15	23 21.167	5.60	17.02	1.5			6.000	120	9.241 0.794		Vel = 4.74	
15 to M1	21.167 18.583	5.60	17.92	1.5	E T	4.95 9.9	2.250 14.850 17.100	120	10.230 1.119 1.251		Vel = 7.33	
M1			0.0 50.76						12.600		K Factor = 14.30	
16 to 17	23.333 25.750	5.60	15.87	1.5	2E	9.9	13.000 9.900 22.900	120	8.027 -1.047 0.195		Vel = 2.29	
17 to 18	25.750 23	5.60	15.00	1.5			8.000	120	7.175 1.191		Vel = 4.46	
18 to 19	23 21.167	5.60	16.42	1.5			6.000	120	8.599 0.794		Vel = 6.83	
19 to M2	21.167 18.583	5.60	17.51	1.5	E T	4.95 9.9	2.250 14.850 17.100	120	9.778 1.119 1.964		Vel = 9.36	
M2			0.0 64.80						12.861		K Factor = 18.07	
20 to 21	25.750 23	5.60	16.03	1.5			8.000	120	8.194 1.191		Vel = 2.31	
21 to 22	23 21.167	5.60	17.22	1.5			6.000	120	9.455 0.794		Vel = 4.80	
22 to M4	21.167 0	5.60	18.10	1.5	E T	4.95 9.9	2.250 14.850 17.100	120	10.449 9.167 1.278		Vel = 7.41	
			0.0									

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 8
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M4			51.35						20.894		K Factor = 11.23	
M1 to M2	18.583 18.583		50.76	2			12.000	120	12.600 0.0			
M2 to M3	18.583 18.583		50.76	2.157			12.000	0.0218	0.261		Vel = 4.46	
M2 to M3	18.583 18.583		64.79	2			1.833	120	12.861 0.0			
M3 to M4	18.583 0		115.55	2.157			1.833	0.0998	0.183		Vel = 10.15	
M3 to M4	18.583 0		-166.90	2			8.917	120	13.044 8.048			
M4			-51.35	2.157			8.917	-0.0222	-0.198		Vel = 4.51	
M4			0.0 -51.35						20.894		K Factor = -11.23	
M3 to M5	18.583 0		166.90	2	2E 2T	12.307 24.613	27.167 36.920	120	13.044 8.048			
M5			166.9	2.157			64.087	0.1970	12.623		Vel = 14.65	
M5			0.0 166.90						33.715		K Factor = 28.74	
F1 to 1	11.5 11.5		2.35	2	T	12.307	11.583 12.307	120	28.998 0.0			
1 to 2	11.5 11.5		2.35	2.157			23.890	0.0001	0.002		Vel = 0.21	
1 to 2	11.5 11.5		0.0	2			7.667	120	29.000 0.0			
2 to 3	11.5 11.5		2.35	2.157			7.667	0	0.0		Vel = 0.21	
2 to 3	11.5 11.5		0.0	2			8.417	120	29.000 0.0			
3 to 4	11.5 11.5		2.35	2.157			8.417	0.0001	0.001		Vel = 0.21	
3 to 4	11.5 11.5		0.0	2			8.583	120	29.001 0.0			
4 to 5	11.5 11.5		2.35	2.157			8.583	0	0.0		Vel = 0.21	
4 to 5	11.5 11.5		0.0	2			8.583	120	29.001 0.0			
5 to N1	11.5 11.5		2.35	2.157			8.583	0.0001	0.001		Vel = 0.21	
5 to N1	11.5 11.5		0.0	2	T	12.307	26.583 12.307	120	29.002 0.0			
N1			2.35				38.890	0.0001	0.003		Vel = 0.21	
N1			0.0 2.35						29.005		K Factor = 0.44	
F2 to 6	11.5 11.5		2.37	2	T	12.307	11.083 12.307	120	28.998 0.0			
6 to 7	11.5 11.5		2.37	2.157			23.390	0.0001	0.002		Vel = 0.21	
6 to 7	11.5 11.5		0.0	2			8.167	120	29.000 0.0			
7 to 8	11.5 11.5		2.37	2.157			8.167	0	0.0		Vel = 0.21	
7 to 8	11.5 11.5		0.0	2			9.250	120	29.000 0.0			
8 to 9	11.5 11.5		2.37	2.157			9.250	0.0001	0.001		Vel = 0.21	
8 to 9	11.5 11.5		0.0	2			8.583	120	29.001 0.0			
9			2.37	2.157			8.583	0	0.0		Vel = 0.21	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 9
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
9 to 10	11.5 11.5		0.0 2.37	2 2.157			7.750 7.750	120 0.0001	29.001 0.0 0.001		Vel = 0.21	
10 to N2	11.5 11.5		0.0 2.37	2 2.157	T	12.307	26.583 12.307 38.890	120 0.0001	29.002 0.0 0.003		Vel = 0.21	
N2			0.0 2.37						29.005		K Factor = 0.44	
F3 to 11	11.5 11.5		2.43 2.43	2 2.157	T	12.307	26.750 12.307 39.057	120 0.0001	28.997 0.0 0.003		Vel = 0.21	
11 to 12	11.5 11.5		0.0 2.43	2 2.157			12.500 12.500	120 0.0002	29.000 0.0 0.002		Vel = 0.21	
12 to N3	11.5 11.5		0.0 2.43	2 2.157	T	12.307	32.167 12.307 44.474	120 0.0001	29.002 0.0 0.003		Vel = 0.21	
N3			0.0 2.43						29.005		K Factor = 0.45	
F4 to N4	11.5 11.5		2.62 2.62	2 2.157	2T	24.613	71.417 24.613 96.030	120 0.0001	28.997 0.0 0.008		Vel = 0.23	
N4			0.0 2.62						29.005		K Factor = 0.49	
F5 to N5	11.5 11.5		2.91 2.91	2 2.157	2T	24.613	71.417 24.613 96.030	120 0.0001	28.995 0.0 0.011		Vel = 0.26	
N5			0.0 2.91						29.006		K Factor = 0.54	
F6 to N6	11.5 11.5		-5.82 -5.82	2 2.157	2T	24.613	71.417 24.613 96.030	120 -0.0004	28.992 0.0 -0.038		Vel = 0.51	
N6			0.0 -5.82						28.954		K Factor = -1.08	
F7 to N7	11.5 11.5		-8.10 -8.1	2 2.157	2T	24.613	71.417 24.613 96.030	120 -0.0007	28.991 0.0 -0.070		Vel = 0.71	
N7			0.0 -8.10						28.921		K Factor = -1.51	
F8 to N8	11.5 11.5		-11.02 -11.02	2 2.157	2T	24.613	71.417 24.613 96.030	120 -0.0013	28.991 0.0 -0.124		Vel = 0.97	
N8			0.0 -11.02						28.867		K Factor = -2.05	
F9 to N9	11.5 11.5		-12.24 -12.24	2 2.157	2T	24.613	71.417 24.613 96.030	120 -0.0016	28.992 0.0 -0.150		Vel = 1.07	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 10
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
N9			0.0 -12.24						28.842		K Factor = -2.28	
F10 to N10	11.5 11.5		-13.00	2	4E 2T	24.613 24.613	81.917 49.226 131.143	120 -0.0018	29.000 0.0 -0.230		Vel = 1.14	
N10			0.0 -13.00						28.770		K Factor = -2.42	
F11 to N11	11.5 11.5		1.24	2	2T	24.613 24.613	71.417 24.613 96.030	120 0	29.016 0.0 0.002		Vel = 0.11	
N11			0.0 1.24						29.018		K Factor = 0.23	
F12 to N12	11.5 11.5		3.72	2	2T	24.613 24.613	71.417 24.613 96.030	120 0.0002	29.023 0.0 0.017		Vel = 0.33	
N12			0.0 3.72						29.040		K Factor = 0.69	
F13 to N13	11.5 11.5		7.45	2	2T	24.613 24.613	71.417 24.613 96.030	120 0.0006	29.039 0.0 0.060		Vel = 0.65	
N13			0.0 7.45						29.099		K Factor = 1.38	
F14 to N14	11.5 11.5		10.82	2	2E 2T	12.307 24.613	77.917 36.920 114.837	120 0.0012	29.048 0.0 0.143		Vel = 0.95	
N14			0.0 10.82						29.191		K Factor = 2.00	
F15 to N15	11.5 0		14.26	2	2T	24.613 24.613	71.417 24.613 96.030	120 0.0021	29.052 4.981 0.199		Vel = 1.25	
N15			0.0 14.26						34.232		K Factor = 2.44	
F1 to F2	11.5 11.5		-2.35	3			9.167 9.167	120 0	28.998 0.0 0.0		Vel = 0.09	
F2 to F3	11.5 11.5		-2.38	3			7.417 7.417	120 -0.0001	28.998 0.0 -0.001		Vel = 0.18	
F3 to F4	11.5 11.5		-4.73	3			11.333 11.333	120 0	28.997 0.0 0.0		Vel = 0.28	
F4 to F5	11.5 11.5		-7.16	3			10.667 10.667	120 -0.0002	28.997 0.0 -0.002		Vel = 0.38	
F5 to F6	11.5 11.5		-2.91	3			14.000 14.000	120 -0.0002	28.995 0.0 -0.003		Vel = 0.49	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 11
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftns Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
F6 to F7	11.5 11.5		5.82 -6.87	3 3.26		8.083 8.083	120 -0.0001	28.992 0.0 -0.001		Vel = 0.26	
F7 to F8	11.5 11.5		8.09 1.22	3 3.26		11.833 11.833	120 0	28.991 0.0 0.0		Vel = 0.05	
F8 to F9	11.5 11.5		11.03 12.25	3 3.26		4.667 4.667	120 0.0002	28.991 0.0 0.001		Vel = 0.47	
F9 to F10	11.5 11.5		12.24 24.49	3 3.26		9.667 9.667	120 0.0008	28.992 0.0 0.008		Vel = 0.94	
F10 to F11	11.5 11.5		13.00 37.49	3 3.26		9.667 9.667	120 0.0017	29.000 0.0 0.016		Vel = 1.44	
F11 to F12	11.5 11.5		-1.25 36.24	3 3.26		4.833 4.833	120 0.0014	29.016 0.0 0.007		Vel = 1.39	
F12 to F13	11.5 11.5		-3.72 32.52	3 3.26		12.333 12.333	120 0.0013	29.023 0.0 0.016		Vel = 1.25	
F13 to F14	11.5 11.5		-7.44 25.08	3 3.26		10.917 10.917	120 0.0008	29.039 0.0 0.009		Vel = 0.96	
F14 to F15	11.5 11.5		-10.82 14.26	3 3.26		14.500 14.500	120 0.0003	29.048 0.0 0.004		Vel = 0.55	
F15			0.0 14.26					29.052		K Factor = 2.65	
N1 to N2	11.5 11.5		2.35 2.35	4 4.26		9.167 9.167	120 0	29.005 0.0 0.0		Vel = 0.05	
N2 to N3	11.5 11.5		2.38 4.73	4 4.26		7.500 7.500	120 0	29.005 0.0 0.0		Vel = 0.11	
N3 to N4	11.5 11.5		2.43 7.16	4 4.26		11.333 11.333	120 0	29.005 0.0 0.0		Vel = 0.16	
N4 to N5	11.5 11.5		2.62 9.78	4 4.26		10.667 10.667	120 0.0001	29.005 0.0 0.001		Vel = 0.22	
N5 to N6	11.5 11.5		-126.50 -116.72	4 4.26		14.000 14.000	120 -0.0037	29.006 0.0 -0.052		Vel = 2.63	
N6 to N7	11.5 11.5		-5.82 -122.54	4 4.26		8.083 8.083	120 -0.0041	28.954 0.0 -0.033		Vel = 2.76	
N7 to N8	11.5 11.5		-8.10 -130.64	4 4.26		11.833 11.833	120 -0.0046	28.921 0.0 -0.054		Vel = 2.94	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
GOOD HOPE 2020 Addition Area #2

Page 12
Date 12-3-2020

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
N8 to N9	11.5 11.5		-11.02 -141.66	4 4.26			4.833 4.833	120 -0.0052	28.867 0.0 -0.025			Vel = 3.19
N9 to N10	11.5 11.5		-12.24 -153.9	4 4.26			11.667 11.667	120 -0.0062	28.842 0.0 -0.072			Vel = 3.46
N10 to M5	11.5 0		-13.00 -166.9	4 4.26			5.000 5.000	120 -0.0072	28.770 4.981 -0.036			Vel = 3.76
M5			0.0 -166.90						33.715			K Factor = -28.74
N5 to N11	11.5 11.5		129.42 129.42	4 4.26			2.750 2.750	120 0.0044	29.006 0.0 0.012			Vel = 2.91
N11 to N12	11.5 11.5		1.24 130.66	4 4.26			4.833 4.833	120 0.0046	29.018 0.0 0.022			Vel = 2.94
N12 to N13	11.5 11.5		3.72 134.38	4 4.26			12.333 12.333	120 0.0048	29.040 0.0 0.059			Vel = 3.02
N13 to N14	11.5 11.5		7.45 141.83	4 4.26			17.333 17.333	120 0.0053	29.099 0.0 0.092			Vel = 3.19
N14 to N16	11.5 11.5		10.82 152.65	4 4.26			10.000 10.000	120 0.0061	29.191 0.0 0.061			Vel = 3.44
N16 to N15	11.5 0		-166.91 -14.26	4 4.26			3.583 3.583	120 -0.0003	29.252 4.981 -0.001			Vel = 0.32
N15			0.0 -14.26						34.232			K Factor = -2.44
N16 to TASR	11.5 11.500		166.90 166.9	4 4.26	E T	13.167 26.334	4.250 39.501 43.751	120 0.0072	29.252 0.0 0.313			Vel = 3.76
TASR to BASR	11.500 1		0.0 166.9	4 4.26	B Rcr	15.8 9.349	10.000 25.149 35.149	120 0.0071	29.565 4.548 0.251			Vel = 3.76
BASR to TEST	1 0	H250	250.00 416.9	6 6.16			235.000 235.000	140 0.0049	34.364 0.433 1.142			Vel = 4.49
TEST			0.0 416.90						35.939			K Factor = 69.54

Erwin Fire Department And Rescue Squad

Flow Test for Hydrant 43070016

Start Time: 2020-10-19 08:00:00

End Time: 2020-10-19 08:10:00

Tested By: WARRICK, DAVID

Test Hydrant

Static Pressure:	54.0
Residual Pressure:	46.0
Desired Pressure:	20.0
Volume at Desired Pressure:	1939.0

Flow Hydrants

Downstream Hydrant ID	Port Diameter	Friction Coefficient	Pitot Pressure	Flow (Calculated)
43070017	2.5	0.90000000000000002	28.0	888.0

adorman@carolinafireprotection.com

From: Allen Monds <cfdfirecapt5@gmail.com>
Sent: Thursday, November 19, 2020 3:28 PM
To: adorman@carolinafireprotection.com
Subject: Hydrant information for Good Hope Hospital project
Attachments: Good Hope Hospital Hydrant # 16.pdf

Andrew,


My map is showing hydrant # 16 on Denim Drive to be on a 6 inch main, however, the line on 8th street is 8 inch and the line on 10th street is 10 inch. At the end of the day it is on a looped system. Attached you will find the 2 most recent flow tests.

Allen Monds-Asst.Fire Chief
Erwin Fire Department

PRODUCT DESCRIPTION -


UNBRAIDED FLEXIBLE HOSE

No	Item Description
1	Flexible Hose / Bellow
2	Isolation Ring
3	Gasket
4	Nut
5	Branch Line Nipple (1")
6	Reducer




BRAIDED FLEXIBLE HOSE

No	Item Description
1	Flexible Hose / Bellow
2	Isolation Ring
3	Gasket
4	Nut
5	Branch Line Nipple (1")
6	Reducer
7	Braid
8	Welded Collar Fitting



UL FRICTION LOSS DATA - BRAIDED FLEXIBLE HOSE US

Length of Flexible Hose (inch)	Outlet Size		Sprinkler K-Factor	Maximum Ambient Temperature °F (°C)	Maximum Working Pressure psi (bar)	Maximum Number of 90° Bends at 3" (76mm) Bend Radius	Equivalent Length of 1" (33.7mm) Sch. 40 Pipe (C=120), ft (m)
	Size (inch)	Type					
24	1/2	Straight	5.6 (80)	300°F (149°C)	175 (12.07)	2	10 (3)
	3/4	Straight	14.0 (200)	300°F (149°C)	175 (12.07)	2	13 (4)
31	1/2	Straight	5.6 (80)	300°F (149°C)	175 (12.07)	3	14 (4.3)
	3/4	Straight	14.0 (200)	300°F (149°C)	175 (12.07)	3	16 (3.9)
40	1/2	Straight	5.6 (80)	300°F (149°C)	175 (12.07)	4	21 (6.4)
	3/4	Straight	14.0 (200)	300°F (149°C)	175 (12.07)	4	23 (7)
48	1/2	Straight	5.6 (80)	300°F (149°C)	175 (12.07)	4	24 (7.3)
	3/4	Straight	14.0 (200)	300°F (149°C)	175 (12.07)	4	26 (7.9)
60	1/2	Straight	5.6 (80)	300°F (149°C)	175 (12.07)	4	25 (7.6)
	3/4	Straight	14.0 (200)	300°F (149°C)	175 (12.07)	4	30 (9.1)
72 	1/2	Straight	5.6 (80)	300°F (149°C)	175 (12.07)	5	36 (11)
	3/4	Straight	14.0 (200)	300°F (149°C)	175 (12.07)	5	33 (10.1)

Reliable®

Product Description

RASCOFLEX® Sprinkler Connections are intended to connect a branch line to a sprinkler using a flexible stainless steel hose assembly. RASCOFLEX® Sprinkler Connections are suitable for use in suspended and hard ceiling applications such as T-Bar ceiling grids, wood, metal stud, or hat furring channel hard lid ceilings. Every package contains one (1) fully assembled stainless steel flexible sprinkler system complete with hose, branch line connection, and sprinkler connection, as well as the pre-assembled bracket assembly to attach to the ceiling.

RASCOFLEX® Sprinkler Connections are designed for use in hydraulically calculated wet, preaction, or dry sprinkler systems per NFPA 13, 13R, 13D, and FM Global Loss Prevention Data Sheets.

Technical Data

Table A

Maximum Working Pressure		FM: 200 psi (13.8 bar) UL: 175 psi (12.1 bar)
Maximum Working Temperature		300°F (149°C)
Connections	Inlet/Branch Line	1" NPT
	Outlet/Reducer	1/2" or 3/4" NPT
Minimum Bending Radius		UL: 3" (76 mm) FM: 7" (178 mm)
Maximum Number of Bends		See Friction Loss Chart
Maximum K-Factor	1/2" Outlet	5.6 (80 metric)
	3/4" Outlet	14.0 (200 metric)

Maintenance

RASCOFLEX® Sprinkler Connections should be inspected and the sprinkler system maintained in accordance with NFPA 25, as well as the requirements of any Authorities Having Jurisdiction.

Patents

RASCOFLEX® Sprinkler Connections may be covered by one or more of the following US Patent Nos. 10,173,088 and 10,328,296.


Listings and Approvals

FM Approved Class No. 1637 (FM)

UL Listed and UL Certified for Canada to ANSI/UL 2443 (cULus)

RASCOFLEX® Sprinkler Connections

cULus Listed, FM Approved



RASCOFLEX® Sprinkler Connections

Ordering Information

Specify:

Model Name

- Model RFB

Nominal Hose Length

- 24" (610 mm)
- 31" (790 mm)
- 40" (1015 mm)
- 48" (1220 mm)
- 60" (1525 mm)
- 72" (1830 mm)

Reducer Outlet: 1/2" NPT or 3/4" NPT

Reducer Type

Standard:

- 6-1/8" (155 mm) straight

Optional:

- 4-5/16" (110 mm) straight
- 5-5/16" (135 mm) straight
- 11-3/4" (300 mm) straight
- 5-5/8" (143 mm) elbow
- 7-3/8" (187 mm) elbow

Bracket Assembly Length


- 24" (610 mm) standard
- 48" (1220 mm) optional

Accessories

- See Table F


Bracket Dimensions


Figure 1



Reducer Dimensions

Figure 2





Nominal 1-11/16" (43mm) ceiling grid shown for reference only. Verify actual ceiling grid dimensions and ceiling tile reveal prior to ordering.

Minimum and Maximum Face of Fitting to Bottom of Ceiling Grid for Each Reducer

Table B

	6-1/8" (155mm) Straight Standard	4-5/16" (110mm) Straight	5-5/16" (135mm) Straight	11-13/16" (300mm) Straight	5-5/8" (143mm) Elbow	7-3/8" (187mm) Elbow
Fig. 3 Dimension A Max. Face of Fitting Distance above Bottom of Ceiling Grid	3" (77mm)	3" (7mm)	3" (7mm)	3" (7mm)	3" (7mm)	3" (7mm)
Fig. 3 Dimension B Max. Face of Fitting Distance from Bottom of Ceiling Grid	1/8" (3mm) below	1-5/8" (42mm) above	11/16" (17mm) above	6-3/8" (148mm) below	1-7/16" (36mm) above	5/16" (60mm) below

Note: Based on 1-11/16" (43mm) tall ceiling grid.

Fig. 3 Dimension C - Clearance Above Ceiling Required at Max. Sprinkler Recess

Table C


Recessed Escutcheon or Concealed/Flush Sprinkler	Reducer	
	5-5/8" (143mm) Elbow	7-3/8" (187mm) Elbow
F1 recessed escutcheon	NC	5-5/8" (144mm)
F2 or FV recessed escutcheon	NC	5-3/8" (138mm)
FP recessed escutcheon	NC	6-1/4" (160mm)
CCP conical concealed cover plate	NC	6-1/4" (160mm)
G4 series concealed sprinklers	5-5/8" (144mm)	7-3/8" (188mm)
G5 series concealed sprinklers	5-1/4" (134mm)	7" (179mm)
RFC series concealed sprinklers	5-1/4" (134mm)	7" (179mm)
XL commercial flush sprinkler with flat escutcheon	4-7/8" (125mm)	6-5/8" (169mm)
XL commercial flush sprinkler with conical escutcheon	4-3/8" (112mm)	6-1/8" (157mm)

Note: NC - Reducer not compatible with sprinkler adjustment range.
Based on 1-11/16" (43mm) tall ceiling grid and flush ceiling tile.

Materials

Figure 4

Number	Item Description	Material
1	Flexible Hose/Bellow	AISI Type 304 Stainless Steel
2	Isolation Ring	Nylon 66
3	Gasket	EPDM
4	Nut	Zinc Plated Carbon Steel
5	Branch Line Nipple (1")	Zinc Plated Carbon Steel
6	Reducer	Zinc Plated Carbon Steel
7	Braid	AISI Type 304 Stainless Steel
8	Welded Collar Fitting	AISI Type 304 Stainless Steel
-	Bar Stock	Zinc Plated SGCC Steel
-	Brackets: Center and Side	Zinc Plated SPCC Steel



Flexible Hose Number of Bends

Figure 5






Table D

cULus Friction Loss Data

Nominal Length of Flexible Hose in (mm)	Reducer		Maximum Sprinkler K-Factor gpm/psi ^{1/2} (lpm/bar ^{1/2})	Maximum Number of 90° Bends at 3" (76mm) Bend Radius	Equivalent Length of 1" (33.7mm) Sch. 40 Pipe (C=120), ft (m)
	NPT Threads	Type			
24 (610)	1/2	Straight	5.6 (80)	2	10 (3)
	3/4	Straight	14.0 (200)	2	13 (4)
31 (790)	1/2	Straight	5.6 (80)	3	14 (4.3)
	3/4	Straight	14.0 (200)	3	16 (4.9)
40 (1015)	1/2	Straight	5.6 (80)	4	21 (6.4)
	3/4	Straight	14.0 (200)	4	23 (7)
48 (1219)	1/2	Straight	5.6 (80)	4	24 (7.3)
	3/4	Straight	14.0 (200)	4	26 (7.9)
60 (1525)	1/2	Straight	5.6 (80)	4	25 (7.6)
	3/4	Straight	14.0 (200)	4	30 (9.1)
72 (1830)	1/2	Straight	5.6 (80)	5	36 (11)
	3/4	Straight	14.0 (200)	5	33 (10.1)

UL Notes:

1. Available data for use with 6.1" straight reducers.
2. Sprinkler K-Factor: 5.6 (80 metric) for 1/2-inch reducer and 14.0 (200 metric) for 3/4-inch reducer.
3. RASCOFLEX® Sprinkler Connections have been tested and approved by Underwriter's Laboratories, Inc. for use in wet, preaction, and dry sprinkler systems per NFPA 13, 13D, 13R and UL2443.



FM Friction Loss Data

Table E

Nominal Length of Flexible Hose in (mm)	Reducer		Maximum Sprinkler K-Factor gpm/psi ^{1/2} (lpm/bar ^{1/2})	Maximum Number of 90° Bends at 7" 178mm) Bend Radius	Equivalent Length of 1" (33.7mm) Sch. 40 Pipe (C=120), ft (m)
	NPT Threads	Type			
24 (610)	1/2	Straight	5.6 (80)	1	9.7 (2.9)
	1/2	90° Elbow	5.6 (80)	0	11.5 (3.5)
	3/4	Straight	8.0 (115)	1	9.9 (3)
			11.2 (160)	1	9.8 (2.9)
			14.0 (200)	1	9.6 (2.9)
	3/4	90° Elbow	8.0 (115)	0	10.2 (3.1)
			11.2 (160)	0	10 (3)
			14.0 (200)	0	9.8 (2.9)
	31 (790)	1/2	Straight	5.6 (80)	2
1/2		90° Elbow	5.6 (80)	2	15.8 (4.8)
3/4		Straight	8.0 (115)	2	13.7 (4.1)
			11.2 (160)	2	12.9 (3.9)
			14.0 (200)	2	12.2 (3.7)
3/4		90° Elbow	8.0 (115)	2	14.5 (4.4)
			11.2 (160)	2	13.7 (4.1)
			14.0 (200)	2	13 (3.9)
40 (1015)		1/2	Straight	5.6 (80)	2
	1/2	90° Elbow	5.6 (80)	2	21.6 (6.6)
	3/4	Straight	8.0 (115)	2	18.5 (5.6)
			11.2 (160)	2	17.4 (5.3)
			14.0 (200)	2	16.3 (4.9)
	3/4	90° Elbow	8.0 (115)	2	20 (6)
			11.2 (160)	2	18.9 (5.7)
			14.0 (200)	2	20 (6)
	48 (1220)	1/2	Straight	5.6 (80)	3
1/2		90° Elbow	5.6 (80)	3	25.9 (7.9)
3/4		Straight	8.0 (115)	3	22.7 (6.9)
			11.2 (160)	3	21.5 (6.5)
			14.0 (200)	3	20.5 (6.2)
3/4		90° Elbow	8.0 (115)	3	24.8 (7.5)
			11.2 (160)	3	23.6 (7.2)
			14.0 (200)	3	22.6 (6.8)

FM Friction Loss Data (cont.)

Table E

Nominal Length of Flexible Hose in (mm)	Reducer		Maximum Sprinkler K-Factor gpm/psi ^{1/2} (lpm/bar ^{1/2})	Maximum Number of 90° Bends at 7" (178mm) Bend Radius	Equivalent Length of 1" (33.7mm) Sch. 40 Pipe (C=120), ft (m)
	NPT Threads	Type			
60 (1525)	1/2	Straight	5.6 (80)	4	23.7 (7.2)
	1/2	90° Elbow	5.6 (80)	4	33.1 (10)
	3/4	Straight	8.0 (115)	4	29.1 (8.8)
			11.2 (160)	4	28 (8.5)
			14.0 (200)	4	27 (8.2)
	3/4	90° Elbow	8.0 (115)	4	32.2 (9.8)
			11.2 (160)	4	31.1 (9.5)
			14.0 (200)	4	30 (9.1)
	72 (1830)	1/2	Straight	5.6 (80)	4
1/2		90° Elbow	5.6 (80)	4	40.4 (12.3)
3/4		Straight	8.0 (115)	4	35.5 (10.8)
			11.2 (160)	4	34.3 (10.4)
			14.0 (200)	4	33.2 (10.1)
3/4		90° Elbow	8.0 (115)	4	39.5 (12)
			11.2 (160)	4	38.3 (11.6)
			14.0 (200)	4	37.2 (11.3)

FM Notes:

1. RASCOFLEX® Sprinkler Connections have been tested and approved by FM Approvals for use in wet, preaction, and dry sprinkler systems per FM data sheets 2-0, 2-5, and 2-8 per FM1637.
2. Maximum sprinkler K-Factor: 5.6 (80 metric) for 1/2-inch reducer and 14.0 (200 metric) for 3/4-inch reducer.
3. Differences in equivalent lengths are due to varying test methods, per FM 1637 standards.
4. Above data of friction loss for use with 6.1" straight reducers.

Accessories List

Table F

 <p>5-5/8" (143mm) Elbow Reducer-Short 1/2": 7M99003303 3/4": 7M99003305</p>	 <p>7-3/8" (187mm) Elbow Reducer-Long 1/2": 7M99003302 3/4": 7M99003304</p>	 <p>4-5/16" (110mm) Straight Reducer 1/2": 7M99003306 3/4": 7M99003325</p>
 <p>5-5/16" (135mm) Straight Reducer 1/2": 7M99003307 3/4": 7M99003326</p>	 <p>Replacement 6-1/8" (155mm) Standard Straight Reducer 1/2": 7M99003308 3/4": 7M99003327</p>	 <p>11-13/16" (300mm) Straight Reducer 1/2": 7M99003309 3/4": 7M99003328</p>
 <p>Hat Channel End Bracket- Short 3" (76mm) 7M99003310</p>	 <p>Hat Channel End Bracket- Long 3-3/4" (95mm) 7M99003311</p>	 <p>Metal Stud End Bracket-Short 1-1/2" (38mm) 7M99003312</p>
 <p>Metal Stud End Bracket-Long 2-1/16" (53mm) 7M99003313</p>	 <p>T-Bar End Bracket- Short 2-5/8" (68mm) 7M99003314</p>	 <p>T-Bar End Bracket- Long 4-1/8" (105mm) 7M99003316</p>
 <p>Wood Beam Stud End Bracket 7M99003317</p>	 <p>Replacement Center Bracket 7M99003321</p>	 <p>3" (76 mm) Bend Radius Indicator 7M99004179</p>
 <p>Replacement 1" NPT Inlet Adapter 7M99003322</p>	 <p>#2 Square Drive Bit 7M99004539</p>	 <p>Replacement Gasket 7M99004319</p>
 <p>48" (1220mm) Bracket Assembly 7M99003301</p>		

P/N 9999970560

Job Name _____

Contractor _____

Job Location _____

Approval _____

Engineer _____

Contractor's P.O. No. _____

Approval _____

Representative _____

Colt™ Series C500 (Colt 500), C500N (Colt 500N), C500Z (Colt 500Z) Reduced Pressure Detector Assemblies

Sizes: 2½" – 10"

The Colt C500, C500N, C500Z Reduced Pressure Detector Assemblies are designed to protect drinking water supplies from dangerous cross-connections in accordance with national plumbing codes and water authority requirements for health-hazard non-potable service applications such as irrigation, fire line, or industrial processing. The Colt C500, C500N, C500Z are used to monitor unauthorized use of water from the fire protection system.


Features

- Extremely Compact Design
- 70% Lighter than Traditional Designs
- 304 (Schedule 40) Stainless Steel Housing & Sleeve
- Groove Fittings Allow Integral Pipeline Adjustment
- Patented Link Check Provides Lowest Pressure Loss
- Unmatched Ease of Serviceability
- Replaceable Check Disc Rubber
- Available with Grooved Butterfly Valve Shutoffs
- Bottom Mounted Cast Stainless Steel Relief Valve
- Metered Bypass to Detect Leakage or Theft of Water from the Fire Sprinkler System


Specifications

The Colt C500, C500N, C500Z Reduced Pressure Detector Assemblies shall consist of two independent Link Check modules, a differential pressure relief valve located between and below the two modules, two drip tight shutoff valves, and required test cocks. Link Check modules and relief valve shall be contained within a sleeve accessible single housing constructed from 304 (Schedule 40) stainless steel pipe with groove end connections. Link Checks shall have reversible elastomer discs and in operation produce drip tight closure against the reverse flow of liquid caused by backpressure or backsiphonage. The bypass assembly consists of a meter registering either gallon or cubic measurements, a reduced pressure zone assembly and required test cocks. Assembly shall be Colt C500, C500N, C500Z as manufactured by the Ames Fire & Waterworks.

C500N OSY
(Colt 500N GV)



C500 OSY
(Colt 500 GV)




⚠ WARNING

It is illegal to use this product in any plumbing system providing water for human consumption, such as drinking or dishwashing, in the United States. Before installing standard material product, consult your local water authority, building and plumbing codes.

NOTICE

The information contained herein is not intended to replace the full product installation and safety information available or the experience of a trained product installer. You are required to thoroughly read all installation instructions and product safety information before beginning the installation of this product.

Ames Fire & Waterworks product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Ames Fire & Waterworks Technical Service. Ames Fire & Waterworks reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Ames Fire & Waterworks products previously or subsequently sold.


AMES
 FIRE & WATERWORKS
 A WATTS Brand

Configurations

- Horizontal
- "Z" pattern horizontal
- "N" pattern horizontal

Materials

- Housing & Sleeve: 304 (Schedule 40) Stainless Steel
- Elastomers: EPDM, Silicone and Buna 'N'
- Link Checks: Noryl®, Stainless Steel
- Check Discs: Reversible Silicone or EPDM
- Test Cocks: Lead Free* Bronze Body
- Pins & Fasteners: 300 Series Stainless Steel
- Springs: Stainless Steel

*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

Pressure – Temperature

Temperature Range: 33°F – 140°F (0.5°C – 60°C)
 Maximum Working Pressure: 175 psi (12.1 bar)

Available Models

Suffix:

OSY — UL/FM outside stem and yoke resilient seated gate valves

BFG — UL/FM grooved gear operated butterfly valves w/ tamper switch

*OSY FxG — Flanged inlet gate connection and grooved outlet gate connection

*OSY GxF — Grooved inlet gate connection and flanged outlet gate connection


*OSY GxG — Grooved inlet gate connection and grooved outlet gate connection

Available with grooved NRS gate valves — consult factory*

Post indicator plate and operating nut available — consult factory*


*Consult factory for dimensions

Dimensions – Weights



C500, C500N, C500Z

SIZE		DIMENSIONS														WEIGHT							
in.	mm	A	C (OSY)		D		G		H		I		J		M		P		C500		C500N		
in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kgs.	lbs.	kgs.
2½	781	30¾	16¾	416	6½	165	29¼	738	21½	546	15½	393	8¼	223	21¼	540	13¾	335	118	54	126	57	
3	806	31¾	18¾	479	6½	170	30¼	768	22¼	565	17¼	435	9¼	233	23	584	14½	368	134	61	147	67	
4	857	33¾	22¾	578	7	178	35¾	905	23½	597	18½	470	9¼	252	26¼	667	15¼	386	164	74	187	85	
6	1105	43½	30¾	765	8½	216	44¾	1137	33¼	845	23¾	589	13¼	332	34¼	870	19	483	276	125	317	144	
8	1264	49¾	37¾	959	9½	246	54¾	1375	40¾	1019	27¼	697	15¼	399	36¾	937	21¼	538	441	200	516	234	
10	1467	57¾	45¾	1162	11¼	285	66	1676	49¾	1257	32½	826	17¼	440	44¾	1124	24	610	723	328	893	405	



C500NBFG/C500ZBFG

SIZE		DIMENSIONS										WEIGHT			
in.	mm	G	H		I		J		M		P		C500NBFG		
in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kgs.
2½	826	32½	23	584	15½	394	9½	241	19¾	502	15¼	402	81	37	
3	864	34	24	610	16¼	414	10¼	256	21¼	540	16¼	410	84	38	
4	905	35¾	25½	648	17¼	437	10¼	279	23½	597	16¾	422	101	46	
6	1181	46½	35¼	895	20½	521	13½	343	27¼	692	19	483	174	79	

Noryl® is a registered trademark of SABIC Innovative Plastics™.

Approvals

- Approved by the Foundation for Cross-Connection Control and Hydraulic Research at The University of Southern California (FCCCHR-USC) (Excluding 10" 'N' and 'Z' configurations)
- AWWA C551-92



1047



B64.4



(**BFG & OSY Only)



Approved

For additional approval information please contact the factory or visit our website at www.amesfirewater.com

Capacity







UL/FM Certified Flow Characteristics

N&Z Flow characteristics collected using butterfly shutoff valves.

Flow capacity chart identifies valve performance based upon rated water velocity up to 25fps


- Service Flow is typically determined by a rated velocity of 7.5fps based upon schedule 40 pipe.
- Rated Flow identifies maximum continuous duty performance determined by AWWA.
- UL Flow Rate is 150% of Rated Flow and is not recommended for continuous duty.
- AWWA Manual M22 [Appendix C] recommends that the maximum water velocity in services be not more than 10fps.

— Horizontal — N - Pattern - - - - Z - Pattern



NOTICE

Inquire with governing authorities for local installation requirements



A WATTS Brand

USA: Backflow Tel: (978) 689-6066 • Fax: (978) 975-8350 • AmesFireWater.com
USA: Control Valves Tel: (713) 943-0688 • Fax: (713) 944-9445 • AmesFireWater.com
Canada: Tel: (905) 332-4090 • Fax: (905) 332-7068 • AmesFireWater.ca
Latin America: Tel: (52) 55-4122-0138 • AmesFireWater.com