

Inspection Notice
Town of Erwin
Inspection Department
897-5648

Approved

Rejected

New

HTG. & A/C

Building

Mobile Home

Electrical

Energy

Plumbing

Gas

Existing

Zoning

Date: 6-5-09 Permit# 5515

Owner: Guillermo Morales

Address: 1204 DENIM DRIVE

The Following Conditions Need Correcting:

FRAMING & ELECTRICAL

1. 2x8 Ceiling joists have a maximum span of 16', these joists span 20'6". Will need an engineer letter on method of correction.

2. Need nailguards on studs where holes for wiring are closer than 1 1/4" from edge.

Inspector: Mike Blackman

DO NOT REMOVE THIS NOTICE

3. Need to DRAFT STOP HOLES in Top plate