

Harnett County

Inspections
108 East Front Street
Lillington , NC 27546

Phone: 910-893-7525
Fax: 910-893-2793

Inspection Report

Permit: BCOM1911-0007

OWNER: HARNETT COUNTY

Site Address: 2495 RAY RD SPRING LAKE, NC 28390

Harnett County Inspections Department

Inspection Type: FINAL**

Inspection Date: 09/22/2020

Result: DISAPPROVED

Remarks:

Notes: Could not access hut closest to main school building. All receptacles located in elementary school areas must be tamper resistant.

All violations are subject to reinspection fees at the inspectors discretion.

Brad Sutton
Inspector