



**Fire Marshal Division**

November 21, 2019

**Re: Swaggert Jason**  
**308 Jarco Dr.**  
**Fuquay-Varina, NC 27526**

**Application Number BCOM1911-0011**

To Whom It May Concern,

Thank you for submitting the plans for the new building. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Fire Extinguishers**

- All Fire extinguisher shall be properly mounted and tagged by a fire extinguisher company.
- Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

- **Address Numbers**

- The physical address shall be installed on the building so that it is visible from the street.

- **Knox Box**

- A Knox Box installation is required for this building
- An order form can be obtained from this office or the box can be order online at [www.knoxbox.com](http://www.knoxbox.com).

- **Means of Egress Illumination**

- The means of egress illumination shall not be less than 1 foot-candle at the walking surface.



- Notes
  - Provide a Knox Box on the building if not present currently.
  - A final fire inspection is required.
  - Schedule all fire inspections through the Fire Marshal's Office.  
(910) 893-0742

Thank you again for submitting the plans for the new building. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



Leslie Jackson  
Deputy Fire Marshal