

- NOTES FIELD PIPE DROPS AS SHOWN
- SLEEVING, ELBOWS, TEES, AND NOZZLES SUPPLIED BY CAS
 RELOCATE NOZZLES IF FLOW PATTERN IS BLOCKED BY SHELVING, SALAMANDERS, ETC.
- MAXIMUM 9 ELBOWS IN SUPPLY LINE.
- MINIMUM 72 INCHES OF AGENT LINE FROM TANK TO FIRST NOZZLE.
- IF APPLICABLE, PRE-PIPED CHARBRUILER DROPS ARE SHIPPED LOOSE
- FACTORY PIPING EXTENDS A MAXIMUM OF 6" ABOVE THE TOP OF THE HOOD.
- APPLIANCE DIMENSIONS LISTED REPRESENT THE COOKING SURFACE SIZE, NOT THE OVERALL APPLIANCE SIZE.
- THIS FIRE SYSTEM COMPLIES WITH U.L. 300 REQUIREMENTS

Job #: 4155759

Job Name: HARDEE'S 2471 NC 87 S., CAMERON, NC 28326

Fire System Co.: BFPE International, 115 Best Wood Dr., Clayton, NC 27520

Drawn By: CAS & MWE

System Size: ANSUL-1.5 Total FP required: 4 Hood # 4 3' 1.00" Long x 48" Wide x 30" High

Riser # 1 Size: 8" Dia.

Hood # 4 Metal Blow-Off Caps included.

<u>LEGEND - WALL MOUNTED ANSUL SYSTEM</u>

- 1.5 GALLON TANK
- 3.0 GALLON TANK 1B
- AUTOMAN RELEASE
- 3 3 GALLON TANK ENCLOSURE
- ЗА 6 GALLON TANK ENCLOSURE
- REGULATED ACTUATOR
- 5 ANSULEX LIQUID AGENT (3 GAL.)
- ANSULEX LIQUID AGENT (1.5 GAL.)
- CARTRIDGE (101-20)
- CARTRIDGE (101-10)
- 9 CARTRIDGE (101-30)
- CARTRIDGE (LT-A-101-30)
- DOUBLE TANK CARTRIDGE
- 10 TEST LINK 11
 - DOUBLE MICROSWITCH
- 2W DUCT NOZZLE (419337)
- NUZZLE ASSEMBLY (419336) 1W
- 1F NOZZLE ASSEMBLY (419333)
- NOZZLE ASSEMBLY (419335) 1N
- NOZZLE ASSEMBLY (419334)
- ЗN NOZZLE ASSEMBLY (419338)
- NOZZLE ASSEMBLY (419340) 245
- NOZZLE ASSEMBLY (419339)
- 2120 NOZZLE ASSEMBLY (419343)
- 290 NOZZLE ASSEMBLY (419342)
- 260 NOZZLE ASSEMBLY (419341)
- 28 DETECTOR BRACKET
- 29 LOW TEMP FUSIBLE LINK
- HIGH TEMP FUSIBLE LINK 30 MGV
- MECHANICAL GAS VALVE EGV ELECTRICAL GAS VALVE
- REMOTE MANUAL PULL STATION 34
- SWIVEL ADAPTOR