



## Fire Marshal Division

February 13, 2020

Ryan Homes  
Nick Chapman  
5734 Trinity Road  
Suite 200  
Raleigh, NC 27607

Re: Ryan Homes Model Home  
43 Bark Way  
Angier, NC 27501

Application Number BCOM2002-0006

To whom it may concern,

Thank you for submitting the plans for the model home. The plans have been carefully reviewed by a qualified code enforcement official to examine for full compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **505.1 Physical Address**
  - The physical address of the building shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
  - The numbers used to make up the physical address shall be at least 6 inches in height.
  
- **Fire Extinguishers**
  - Fire Extinguishers shall be 2A:20BC and shall be placed with a travel distance to not exceed 75'
  - Fire extinguishers are to be mounted no higher than 5' above the finished floor.



- **1008.1.1 Size of Doors**
  - The minimum width of each door opening shall be sufficient for the occupant load thereof and shall provide a clear width of 32 inches.
  
- Notes
  - **A final fire inspection is required. Please contact this office direct to schedule fire inspection at 910-893-0743.**

Thank you again for submitting the plans for the model home. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal