



Fire Marshal Division

August 12, 2020

McNeill Calvin Allen
110 S. Railroad St.
Coats, NC 27521

**Re: Hair Salon with Bathroom
110 S. Railroad St.
Coats, NC 27521**

Application Number BCOM2003-0002

To Whom It May Concern,

Thank you for submitting the plans for the new building. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

Plan Review Notes

- **906.1 Fire Extinguishers**
 - Minimum of (1) 2A10:BC fire extinguisher shall be installed per 75' distance of travel.
 - All Fire extinguisher shall be properly mounted and tagged by a fire extinguisher company.

Notes:

- Fire Final Inspection required.
- Any additions or alterations to the fire alarm or sprinkler system will require separate submittal and permits.

***Please schedule all fire inspections with the Fire Marshal's office*
910-893-0742**



Thank you again for submitting the plans for the new building. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal