



## Fire Marshal Division

May 5, 2020

Alexander Design Build, Inc.  
205 W. Main St.  
Clayton, NC 27520

**Re: Neills Creek Baptist Church**  
**4200 Neills Creek Rd.**  
**Angier, NC 27501**

**Application Number BCOM2004-0003**

To Whom It May Concern,

Thank you for submitting the plans for the new church. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Fire Extinguishers**

- Minimum of (1) 2A10:BC fire extinguisher shall be installed per 75' distance of travel.
- All Fire extinguisher shall be properly mounted and tagged by a fire extinguisher company.

- **Panic Hardware**

- UL 305 listed panic hardware is required on exit doors serving a room/space with an occupant load >50, also indicated on Building code summary. Panic hardware is not included on door schedule sheet B8 of Drawings.

- **Occupant Load Posting**

- The occupant load posting shall be provided by the Fire Marshal's Office at fire final inspection.



- **Means of Egress Illumination**
  - The means of egress, including the exit discharge, shall be illuminated at all time the building space is served by the means of egress is occupied.
    - Means of egress consist of three separate and distinct parts: the exit access, the exit and the exit discharge.
  - The means of egress illumination shall not be less than 1 foot-candle at the walking surface.
  
- **Rated Wall Identification**
  - Rated walls shall be permanently identified with signs or stenciling.
  - **Example: "1 Hour Fire Barrier Protect All Openings"**
  
- **Notes**
  - A final fire inspection is required.
  - **Schedule all fire inspections through the Fire Marshal's Office. (910) 893-0742**

Thank you again for submitting the plans for the new church. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal