

RELIABLE **FIRE PROTECTION, LLC**

32 Partin Rd.

Dunn, North Carolina 28334


Phone (910) 980-1234

Fax (919) 980-1235

North Carolina State License #26806-FS Class I

South Carolina State License #1520

FIRE SPRINKLER
HYDRAULIC CALCULATIONS
For
ERWIN ELEMENTARY
At
ERWIN, NORTH CAROLINA



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - 2ND FLR CLASSROOMS AREA 1
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 1
Contract : 2020-098
Data File : EE AREA 1 - PEAKED.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 1
Remote area location: 2ND FLR CLASSROOMS
Occupancy classification: LIGHT HAZARD
Density: 0.10 - Gpm/SqFt
Area of application: 1,500 - SqFt
Coverage per sprinkler: 225 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 14
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 315.529 - GPM @ 31.461 - Psi
Type of system: WET - GRID
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C





Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 2
 Date 08-19-20

City Water Supply: C1 - Static Pressure : 47 C2 - Residual Pressure: 38 C2 - Residual Flow : 750 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 32.812 A2 - Adj Resid : 24.456 @ 500 A3 - Adj Resid : 13.864 @ 750	Pump Data: P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 750 City Residual Flow @ 0 = 1832.70 City Residual Flow @ 20 = 1358.20 City Water @ 150% of Pump = 38.00	Demand: D1 - Elevation : 12.235 D2 - System Flow : 215.529 D2 - System Pressure : 61.243 Hose (Demand) : _____ D3 - System Demand : 215.529 Hose (Adj City) : 100 Safety Margin : 13.725
---	---	--




Flow Diagram



Flow Diagram

Reliable Fire Protection LLC
EE - 2ND FLR CLASSROOMS AREA 1

Page 4
Date 08-19-20



Fittings Used Summary

Reliable Fire Protection LLC
EE - 2ND FLR CLASSROOMS AREA 1

Page 5
Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 6
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P1	28.25	5.6	7.2	na	15.03	0.1	140	7.0
P2	28.25	5.6	7.03	na	14.84	0.1	140	7.0
P3	28.25	5.6	7.0	na	14.82	0.1	140	7.0
P4	28.25	5.6	7.03	na	14.85	0.1	140	7.0
P5	28.25	5.6	7.21	na	15.04	0.1	140	7.0
P6	27.125	5.6	7.46	na	15.3	0.1	120	7.0
P7	27.125	5.6	7.28	na	15.11	0.1	120	7.0
P8	27.125	5.6	7.25	na	15.08	0.1	120	7.0
P9	27.125	5.6	7.28	na	15.1	0.1	120	7.0
P10	27.125	5.6	7.46	na	15.3	0.1	120	7.0
P11	25.958	5.6	8.46	na	16.29	0.1	120	7.0
P12	25.958	5.6	8.38	na	16.21	0.1	120	7.0
P13	25.958	5.6	8.38	na	16.22	0.1	120	7.0
P14	25.958	5.6	8.53	na	16.36	0.1	120	7.0
M1	30.333		13.36	na				
1	30.333		10.9	na				
2	30.333		10.62	na				
3	30.333		10.58	na				
4	30.333		10.63	na				
5	30.333		10.92	na				
M3	30.333		13.42	na				
6	30.333		10.83	na				
7	30.333		10.53	na				
8	30.333		10.49	na				
9	30.333		10.53	na				
10	30.333		10.82	na				
M5	30.333		13.62	na				
11	30.333		11.91	na				
12	30.333		11.78	na				
13	30.333		11.79	na				
14	30.333		12.02	na				
M7	30.333		14.02	na				
M9	30.333		14.21	na				
M11	30.333		14.31	na				
M13	30.333		14.34	na				
M2	30.333		21.61	na				
M4	30.333		21.67	na				
M6	30.333		21.87	na				
M8	30.333		22.31	na				
M15	30.333		23.17	na				
M10	30.333		23.02	na				
M12	30.333		22.92	na				
M16	30.333		26.1	na				
M17	13.208		36.55	na				
M18	13.208		38.97	na				
M19	13.208		50.15	na				
M20	13.208		52.13	na				
TR2	13.208		52.61	na				
BR2	2.5		61.14	na				
PD	2.5		61.24	na				
PS	2.5		30.98	na				
FLG	1.0		31.68	na				
UG1	0.0		32.28	na	100.0			
UG3	0.0		32.38	na				
UG2	0.0		32.42	na				
BF1	2.5		31.64	na				
BF2	0.0		44.28	na				
UG4	0.0		44.37	na				
TAP	0.0		44.64	na				
TEST	0.0		45.19	na				

The maximum velocity is 12.68 and it occurs in the pipe between nodes M15 and M16

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 7
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P1 to 1	28.250 30.333	5.60	15.03 15.03	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0767	7.201 -0.902 4.601		Vel = 5.58	
1			0.0 15.03					10.900		K Factor = 4.55	
P2 to 2	28.250 30.333	5.60	14.84 14.84	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0750	7.026 -0.902 4.497		Vel = 5.51	
2			0.0 14.84					10.621		K Factor = 4.55	
P3 to 3	28.250 30.333	5.60	14.82 14.82	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0747	7.000 -0.902 4.482		Vel = 5.50	
3			0.0 14.82					10.580		K Factor = 4.56	
P4 to 4	28.250 30.333	5.60	14.85 14.85	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0750	7.030 -0.902 4.499		Vel = 5.51	
4			0.0 14.85					10.627		K Factor = 4.56	
P5 to 5	28.250 30.333	5.60	15.04 15.04	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0768	7.214 -0.902 4.608		Vel = 5.58	
5			0.0 15.04					10.920		K Factor = 4.55	
P6 to 6	27.125 30.333	5.60	15.30 15.3	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0792	7.463 -1.389 4.755		Vel = 5.68	
6			0.0 15.30					10.829		K Factor = 4.65	
P7 to 7	27.125 30.333	5.60	15.10 15.1	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0774	7.276 -1.389 4.645		Vel = 5.61	
7			0.0 15.10					10.532		K Factor = 4.65	
P8 to 8	27.125 30.333	5.60	15.08 15.08	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0771	7.247 -1.389 4.628		Vel = 5.60	
8			0.0 15.08					10.486		K Factor = 4.66	
P9 to 9	27.125 30.333	5.60	15.10 15.1	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0774	7.275 -1.389 4.644		Vel = 5.61	
9			0.0 15.10					10.530		K Factor = 4.65	
P10 to 10	27.125 30.333	5.60	15.30 15.3	1 1.049	1T 0.0 0.0	55.000 5.000 60.000	120 0.0792	7.460 -1.389 4.753		Vel = 5.68	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 8
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10			0.0 15.30					10.824		K Factor = 4.65	
P11 to 11	25.958 30.333	5.60	16.29	1	1T 5.0	55.000 0.0 5.000	120	8.460 -1.895		Vel = 6.05	
11			0.0 16.29					11.906		K Factor = 4.72	
P12 to 12	25.958 30.333	5.60	16.21	1	1T 5.0	55.000 0.0 5.000	120	8.382 -1.895		Vel = 6.02	
12			0.0 16.21					11.782		K Factor = 4.72	
P13 to 13	25.958 30.333	5.60	16.22	1	1T 5.0	55.000 0.0 5.000	120	8.385 -1.895		Vel = 6.02	
13			0.0 16.22					11.787		K Factor = 4.72	
P14 to 14	25.958 30.333	5.60	16.36	1	1T 5.0	55.000 0.0 5.000	120	8.533 -1.895		Vel = 6.07	
14			0.0 16.36					12.021		K Factor = 4.72	
*											
M1 to 1	30.333 30.333		-36.99	1.25	1T 7.432	21.125 0.0 7.432	120	13.362 0.0		Vel = 7.27	
1 to 2	30.333 30.333		-36.99	1.442	0.0	28.557 0.0 8.500	-0.0862	-2.462		Vel = 4.32	
2 to 3	30.333 30.333		15.02	1.25	0.0	8.500 0.0 10.000	120	10.900 0.0			
3 to 4	30.333 30.333		-21.97	1.442	0.0	8.500 0.0 10.000	-0.0328	-0.279		Vel = 1.40	
4 to 5	30.333 30.333		14.85	1.25	0.0	10.000 0.0 10.000	120	10.621 0.0			
5 to M2	30.333 30.333		-7.12	1.442	0.0	10.000 0.0 113.000	-0.0041	-0.041		Vel = 1.51	
M2			0.0 37.58					21.609		K Factor = 8.08	
*											
M3 to 6	30.333 30.333		-38.01	1.25	1T 7.432	21.125 0.0 7.432	120	13.417 0.0		Vel = 7.47	
			-38.01	1.442	0.0	28.557	-0.0906	-2.588			

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 9
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
6 to 7	30.333 30.333		15.30 -22.71	1.25 1.442	0.0 0.0	8.500 0.0	120 -0.0349	10.829 0.0			
						8.500		-0.297	Vel =	4.46	
7 to 8	30.333 30.333		15.11 -7.6	1.25 1.442	0.0 0.0	10.000 0.0	120 -0.0046	10.532 0.0			
						10.000		-0.046	Vel =	1.49	
8 to 9	30.333 30.333		15.07 7.47	1.25 1.442	0.0 0.0	10.000 0.0	120 0.0044	10.486 0.0			
						10.000		0.044	Vel =	1.47	
9 to 10	30.333 30.333		15.11 22.58	1.25 1.442	0.0 0.0	8.500 0.0	120 0.0346	10.530 0.0			
						8.500		0.294	Vel =	4.44	
10 to M4	30.333 30.333		15.29 37.87	1.25 1.442	1T 7.432	7.432 0.0	113.000 0.0	120 10.824			
						120.432		0.0900	Vel =	7.44	
M4 *			0.0 37.87						21.666	K Factor =	8.14
M5 to 11	30.333 30.333		-30.42 -30.42	1.25 1.442	1T 7.432	7.432 0.0	21.125 7.432	120 0.0			
						28.557		-0.0600	Vel =	5.98	
11 to 12	30.333 30.333		16.29 -14.13	1.25 1.442	0.0 0.0	8.500 0.0	120 -0.0146	11.906 0.0			
						8.500		-0.124	Vel =	2.78	
12 to 13	30.333 30.333		16.21 2.08	1.25 1.442	0.0 0.0	10.000 0.0	120 0.0005	11.782 0.0			
						10.000		0.005	Vel =	0.41	
13 to 14	30.333 30.333		16.22 18.3	1.25 1.442	0.0 0.0	10.000 0.0	120 0.0234	11.787 0.0			
						10.000		0.234	Vel =	3.60	
14 to M6	30.333 30.333		16.36 34.66	1.25 1.442	1T 7.432	7.432 0.0	121.500 0.0	120 12.021			
						128.932		0.0764	Vel =	6.81	
M6 *			0.0 34.66						21.871	K Factor =	7.41
M7 to M8	30.333 30.333		25.89 25.89	1.25 1.442	2T 14.864	14.864 0.0	171.083 14.864	120 0.0			
						185.947		0.0446	Vel =	5.09	
M8			0.0 25.89						22.310	K Factor =	5.48
M9 to M10	30.333 30.333		26.78 26.78	1.25 1.442	2T 14.864	14.864 0.0	171.083 14.864	120 0.0			
						185.947		0.0474	Vel =	5.26	
M10			0.0 26.78						23.021	K Factor =	5.58
M11 to M12	30.333 30.333		26.42 26.42	1.25 1.442	2T 14.864	14.864 0.0	171.083 14.864	120 0.0			
						185.947		0.0463	Vel =	5.19	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 10
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M12			0.0 26.42					22.916		K Factor = 5.52	
M13 to M14	30.333 0		26.33	1.25	2T 14.864	171.083 0.0 14.864	120	14.342 13.137		Vel = 5.17	
M14			0.0 26.33					36.023		K Factor = 4.39	
*											
M1 to M3	30.333 30.333		36.99	2.5	0.0	12.000 0.0 0.0	120	13.362 0.0		Vel = 2.18	
M3 to M5	30.333 30.333		38.01	2.5	0.0	12.000 0.0 0.0	120	13.417 0.0		Vel = 4.41	
M5 to M7	30.333 30.333		75.0	2.635	0.0	12.000 0.0 0.0	0.0169	0.203		Vel = 6.20	
M7 to M9	30.333 30.333		30.42	2.5	0.0	12.750 0.0 0.0	120	13.620 0.0		Vel = 4.68	
M9 to M11	30.333 30.333		105.42	2.635	0.0	12.750 0.0 0.0	0.0318	0.405		Vel = 3.10	
M11 to M13	30.333 30.333		-25.89	2.5	0.0	9.667 0.0 0.0	120	14.025 0.0		Vel = 4.68	
M13			79.53	2.635	0.0	9.667	0.0188	0.182		Vel = 1.55	
M9 to M11	30.333 30.333		-26.78	2.5	0.0	12.000 0.0 0.0	120	14.207 0.0		Vel = 3.10	
M11 to M13	30.333 30.333		52.75	2.635	0.0	12.000 0.0 0.0	0.0088	0.106		Vel = 1.55	
M13			-26.42	2.5	0.0	12.000 0.0 0.0	120	14.313 0.0		Vel = 1.55	
M13			0.0 26.33					14.342		K Factor = 6.95	
*											
M2 to M4	30.333 30.333		37.58	2.5	0.0	12.000 0.0 0.0	120	21.609 0.0		Vel = 2.21	
M4 to M6	30.333 30.333		37.58	2.635	0.0	12.000 0.0 0.0	0.0048	0.057		Vel = 4.44	
M6 to M8	30.333 30.333		37.87	2.5	0.0	12.000 0.0 0.0	120	21.666 0.0		Vel = 6.48	
M8 to M15	30.333 30.333		75.45	2.635	0.0	12.000 0.0 0.0	0.0171	0.205		Vel = 8.00	
M15 to M10	30.333 30.333		34.66	2.5	0.0	12.750 0.0 0.0	120	21.871 0.0		Vel = 6.48	
M10 to M12	30.333 30.333		110.11	2.635	0.0	12.750 0.0 0.0	0.0344	0.439		Vel = 3.10	
M12 to M14	30.333 0		25.89	2.5	1J 14.827	2.000 0.0 14.827	120	22.310 0.0		Vel = 8.00	
M14			136.0	2.635	0.0	16.827	0.0509	0.856		Vel = 4.68	
M15 to M10	30.333 30.333		-215.53	2.5	0.0	7.667 0.0 0.0	120	23.166 0.0		Vel = 4.68	
M10 to M12	30.333 30.333		-79.53	2.635	0.0	7.667	-0.0189	-0.145		Vel = 3.10	
M12 to M14	30.333 0		26.78	2.5	0.0	12.000 0.0 0.0	120	23.021 0.0		Vel = 1.55	
M14			-52.75	2.635	0.0	12.000	-0.0087	-0.105		Vel = 1.55	
M12 to M14	30.333 0		26.42	2.5	0.0	12.000 0.0 0.0	120	22.916 13.137		Vel = 1.55	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 11
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M14			0.0 -26.33					36.023		K Factor = -4.39	
*											
M15 to M16	30.333 30.333		215.53	2.5	2I 16.474 0.0	8.167 16.474	120	23.166 0.0			
M16 to M17	30.333 13.208		215.53	2.635	0.0	24.641	0.1192	2.938		Vel = 12.68	
M16 to M17	30.333 13.208		0.0	2.5	1I 8.237 0.0	17.167 8.237	120	26.104 7.417			
M17 to M18	13.208 13.208		215.53	2.635	0.0	25.404	0.1192	3.029		Vel = 12.68	
M17 to M18	13.208 13.208		0.0	2.5	1J 14.827 0.0	5.500 14.827	120	36.550 0.0			
M18 to M19	13.208 13.208		215.53	2.635	0.0	20.327	0.1193	2.424		Vel = 12.68	
M18 to M19	13.208 13.208		0.0	3	1I 6.72 0.0	257.542 6.720	120	38.974 0.0			
M19 to M20	13.208 13.208		215.53	3.26	0.0	264.262	0.0423	11.177		Vel = 8.28	
M19 to M20	13.208 13.208		0.0	3	1I 6.72 0.0	40.000 6.720	120	50.151 0.0			
M20 to TR2	13.208 13.208		215.53	3.26	0.0	46.720	0.0423	1.975		Vel = 8.28	
M20 to TR2	13.208 13.208		0.0	3	1I 6.72 0.0	4.667 6.720	120	52.126 0.0			
TR2			0.0 215.53					52.608		K Factor = 29.72	
*											
TR2 to BR2	13.208 2.500		215.53	4	1B 1Fsp 0.0	15.8 67.151	120	52.608 7.638		** Fixed Loss = 3	
BR2			215.53	4.26	1Aty 1J 30.284 21.067	77.859	0.0115	0.894		Vel = 4.85	
*											
BR2			0.0 215.53					61.140		K Factor = 27.56	
*											
BR2 to PD	2.500 2.500		215.53	6	1B 1S 12.573 40.235	10.000 52.808	120	61.140 0.0			
PD			215.53	6.357	0.0	62.808	0.0016	0.103		Vel = 2.18	
*											
PD			0.0 215.53					61.243		K Factor = 27.54	
*											
System Demand Pressure								61.243			
Safety Margin								13.725			
Continuation Pressure								74.968			
Pressure @ Pump Outlet								74.968			
Pressure From Pump Curve								-43.992			
Pressure @ Pump Inlet								30.976			
*											
PS to FLG	2.5 1		0.0	6	1G 1E 3.772 17.603	10.500 21.375	120	30.976 0.650			
FLG			215.53	6.357	0.0	31.875	0.0016	0.052		Vel = 2.18	
*											
			0.0								

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 12
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
FLG			215.53					31.678		K Factor = 38.29	
*											
FLG	1		215.53	6	1E	20.084	50.000	140	31.678		
to					1G	4.304	67.425		0.433		
UG1	0		215.53	6.16	1T	43.037	117.425	0.0014	0.168	Vel = 2.32	
			0.0								
UG1			215.53						32.279	K Factor = 37.94	
*											
UG1	0	H100	210.32	8	2F	28.468	394.000	140	32.279		
to						0.0	28.468		0.0		
UG2	0		210.32	8.27		0.0	422.468	0.0003	0.138	Vel = 1.26	
			0.0								
UG2			210.32						32.417	K Factor = 36.94	
UG1	0		105.20	8	5F	71.17	988.000	140	32.279		
to					3E	85.404	181.879		0.0		
UG3	0		105.2	8.27	4G	25.305	1169.879	0.0001	0.106	Vel = 0.63	
UG3	0		0.0	8	3F	42.702	303.000	140	32.385		
to					1G	6.326	49.028		0.0		
UG2	0		105.2	8.27		0.0	352.028	0.0001	0.032	Vel = 0.63	
			0.0								
UG2			105.20						32.417	K Factor = 18.48	
*											
UG2	0		315.53	8	2E	56.936	381.000	140	32.417		
to						0.0	56.936		-1.083		
BF1	2.500		315.53	8.27		0.0	437.936	0.0007	0.303	Vel = 1.88	
BF1	2.500		0.0	8	1Zai	0.0	6.000	120	31.637		
to						0.0	0.0		12.632	** Fixed Loss = 11.549	
BF2	0		315.53	8.249		0.0	6.000	0.0010	0.006	Vel = 1.89	
BF2	0		0.0	8	2E	56.936	26.000	140	44.275		
to					1T	55.354	112.290		0.0		
UG4	0		315.53	8.27		0.0	138.290	0.0007	0.095	Vel = 1.88	
UG4	0		0.0	8	1T	55.354	321.000	140	44.370		
to					1G	6.326	61.680		0.0		
TAP	0		315.53	8.27		0.0	382.680	0.0007	0.265	Vel = 1.88	
TAP	0		0.0	8	1Eq	297.332	500.000	140	44.635		
to						0.0	297.332		0.0		
TEST	0		315.53	8.27		0.0	797.332	0.0007	0.551	Vel = 1.88	
			0.0								
TEST			315.53						45.186	K Factor = 46.94	

AutoPeaking Summary

Reliable Fire Protection LLC
 EE - 2ND FLR CLASSROOMS AREA 1

Page 13
 Date 08-19-20


Auto Peaking Summary - List of Pipes for Area Calculated

Left Side			Right Side		
From	To	Length	From	To	Length
5	M2	113.000	M1	1	21.125
10	M4	113.000	M3	6	21.125
14	M6	121.500	M5	11	21.125
5	M2	113.000	M1	1	21.125
10	M4	113.000	M3	6	21.125
14	M6	121.500	M5	11	21.125

Flow	Safety	Pressure
Required	Margin	Differential

Left	10.000		315.719	13.730	-0.005
Area Calculated			315.529	13.725	0.000
Right	10.000		315.282	13.832	-0.107

Typical Distance Between Heads = 10.000
 Split Point Used in Worst Area Peaked = P3
 Split Point Used in Area Calculated = P3



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - MECHANICAL PLATFORM AREA 2
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 2
Contract : 2020-098
Data File : EE AREA 2.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 2
Remote area location: MECHANICAL PLATFORM
Occupancy classification: ORDINARY HAZARD GROUP II
Density: 0.20 - Gpm/SqFt
Area of application: 1,500 - SqFt
Coverage per sprinkler: 130 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 16
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 644.359 - GPM @ 26.636 - Psi
Type of system: WET - TREE
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 2
 Date 08-19-20

City Water Supply:	Pump Data:	Demand:
C1 - Static Pressure : 47	P1 - Pump Churn Pressure : 44	D1 - Elevation : 10.629
C2 - Residual Pressure: 38	P2 - Pump Rated Pressure : 40	D2 - System Flow : 394.359
C2 - Residual Flow : 750	P2 - Pump Rated Flow : 500	D2 - System Pressure : 53.146
City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow	P3 - Pump Pressure @ Max Flow : 26	Hose (Demand) :
A1 - Adjusted Static: 31.849	P3 - Pump Max Flow : 750	D3 - System Demand : 394.359
A2 - Adj Resid : 21.412 @ 500	City Residual Flow @ 0 = 1832.70	Hose (Adj City) : 250
A3 - Adj Resid : 9.885 @ 750	City Residual Flow @ 20 = 1358.20	Safety Margin : 13.568
	City Water @ 150% of Pump = 38.00	



Flow Diagram

27.6
U1 ← **M21**

26.7
U4 ← **M23**

25.6
U7 ← **M25**

26.7
U2 ← **U3** ← **M22**
53.6

25.6
U5 ← **U6** ← **M24**
51.3

23.2 70.7
U8 ← **U9** ← **U10** ← **M26**
46.6 ↑
 | 255.5
22.3 67.8
U11 ← **U12** ← **U13** ← **M27**
44.7

23.4 71.1
U14 ← **U15** ← **U16** ← **M28**
46.9

27.6 107.9 184.8 323.3
M21 ← **M22** ← **M23** ← **M24** ← **M25** ← **M26** ← **M27** ← **M29**
81.2 159.2 255.5

71.1 394.4 394.4 394.4 394.4 394.4 394.4
M28 ← **M29** ← **M48** ← **M30** ← **M31** ← **M32** ← **M33** ← **M34** ← **M35** ← **M36** ← **M37** ← **TR1** ← **BR1** ← **BR2** ← **PD**
394.4 394.4 394.4 394.4 394.4 394.4 394.4

394.4 329.5
PS ← **FLG** ← **UG1** ← **UG2**
394.4 ↑

164.8 329.5 494.4
 | 494.4
UG1 ← **UG3** ← **UG2** ← **BF1** ← **BF2** ← **UG4** ← **TAP** ← **TEST**
164.8 494.4 494.4

Fittings Used Summary

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 4
 Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 5
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
U1	21.833	8	11.91	na	27.61	0.2	94	7.0
U4	23.667	8	11.12	na	26.68	0.2	94	7.0
U7	25.5	8	10.26	na	25.63	0.2	94	7.0
U2	22.167	8	11.12	na	26.68	0.2	127	10.2
U3	22.167	8	11.32	na	26.92	0.2	127	10.2
U5	24.542	8	10.2	na	25.55	0.2	127	10.2
U6	24.542	8	10.38	na	25.78	0.2	127	10.2
U8	25.917	8	8.43	na	23.22	0.2	107	7.3
U9	25.917	8	8.56	na	23.4	0.2	107	7.3
U10	25.917	8	9.02	na	24.03	0.2	107	7.3
U11	29.333	8	7.76	na	22.28	0.2	107	7.3
U12	29.333	8	7.88	na	22.45	0.2	107	7.3
U13	29.333	8	8.31	na	23.06	0.2	107	7.3
U14	31.583	8	8.53	na	23.36	0.2	107	7.3
U15	31.583	8	8.66	na	23.54	0.2	107	7.3
U16	31.583	8	9.13	na	24.17	0.2	107	7.3
M21	21.833		13.37	na				
M22	21.833		13.37	na				
M23	21.833		13.43	na				
M24	21.833		13.49	na				
M25	21.833		13.63	na				
M26	21.833		13.9	na				
M27	21.833		14.73	na				
M28	21.833		17.13	na				
M29	21.833		17.25	na				
M48	20.5		20.26	na				
M30	20.5		26.42	na				
M31	20.5		30.08	na				
M32	20.5		31.88	na				
M33	20.5		32.71	na				
M34	13.208		36.44	na				
M35	13.208		37.45	na				
M36	13.208		40.28	na				
M37	13.208		41.94	na				
TR1	13.208		42.39	na				
BR1	2.5		52.76	na				
BR2	2.5		52.83	na				
PD	2.5		53.15	na				
PS	2.5		24.75	na				
FLG	1.0		25.56	na				
UG1	0.0		26.51	na	100.0			
UG3	0.0		26.75	na				
UG2	0.0		26.83	na				
BF1	2.5		26.44	na				
BF2	0.0		38.11	na				
UG4	0.0		38.33	na				
TAP	0.0		38.94	na				
TEST	0.0		40.2	na	150.0			

The maximum velocity is 15.16 and it occurs in the pipe between nodes M29 and M48

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 6
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
U1 to M21	21.833 21.833	8.00	27.61 27.61	1 1.049	1T	5.0 0.0 0.0	1.167 5.000 6.167	120 0.2363	11.912 0.0 1.457		Vel = 10.25	
M21			0.0 27.61						13.369		K Factor = 7.55	
U4 to M23	23.667 21.833	8.00	26.68 26.68	1 1.049	1T	5.0 0.0 0.0	1.833 5.000 6.833	120 0.2219	11.124 0.794 1.516		Vel = 9.90	
M23			0.0 26.68						13.434		K Factor = 7.28	
U7 to M25	25.500 21.833	8.00	25.63 25.63	1 1.049	1T	5.0 0.0 0.0	3.667 5.000 8.667	120 0.2058	10.261 1.588 1.784		Vel = 9.51	
M25			0.0 25.63						13.633		K Factor = 6.94	
U2 to U3	22.167 22.167	8.00	26.68 26.68	1.5 1.682		0.0 0.0 0.0	8.875 0.0 8.875	120 0.0223	11.123 0.0 0.198		Vel = 3.85	
U3 to M22	22.167 21.833	8.00	26.92 53.6	1.5 1.682	1I 1T	4.95 9.9 0.0	8.708 14.850 23.558	120 0.0809	11.321 0.145 1.905		Vel = 7.74	
M22			0.0 53.60						13.371		K Factor = 14.66	
U5 to U6	24.542 24.542	8.00	25.55 25.55	1.5 1.682		0.0 0.0 0.0	8.875 0.0 8.875	120 0.0205	10.200 0.0 0.182		Vel = 3.69	
U6 to M24	24.542 21.833	8.00	25.78 51.33	1.5 1.682	1I 1T	4.95 9.9 0.0	11.125 14.850 25.975	120 0.0746	10.382 1.173 1.939		Vel = 7.41	
M24			0.0 51.33						13.494		K Factor = 13.97	
U8 to U9	25.917 25.917	8.00	23.22 23.22	1.5 1.682		0.0 0.0 0.0	7.458 0.0 7.458	120 0.0172	8.428 0.0 0.128		Vel = 3.35	
U9 to U10	25.917 25.917	8.00	23.40 46.62	1.5 1.682		0.0 0.0 0.0	7.458 0.0 7.458	120 0.0625	8.556 0.0 0.466		Vel = 6.73	
U10 to M26	25.917 21.833	8.00	24.03 70.65	1.5 1.682	1I 1T	4.95 9.9 0.0	8.250 14.850 23.100	120 0.1348	9.022 1.769 3.114		Vel = 10.20	
M26			0.0 70.65						13.905		K Factor = 18.95	
U11 to U12	29.333 29.333	8.00	22.28 22.28	1.5 1.682		0.0 0.0 0.0	7.458 0.0 7.458	120 0.0160	7.758 0.0 0.119		Vel = 3.22	
U12 to U13	29.333 29.333	8.00	22.46 44.74	1.5 1.682		0.0 0.0 0.0	7.458 0.0 7.458	120 0.0578	7.877 0.0 0.431		Vel = 6.46	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 7
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
U13 to M27	29.333 21.833	8.00	23.05 67.79	1.5 1.682	1I 1T 4.95 9.9 0.0	10.583 14.850 25.433	120 0.1249	8.308 3.248 3.177		Vel = 9.79	
M27			0.0 67.79					14.733		K Factor = 17.66	
U14 to U15	31.583 31.583	8.00	23.36	1.5 1.682	0.0 0.0 0.0	7.458 0.0 7.458	120 0.0174	8.526 0.0 0.130		Vel = 3.37	
U15 to U16	31.583 31.583	8.00	23.54	1.5 1.682	0.0 0.0 0.0	7.458 0.0 7.458	120 0.0632	8.656 0.0 0.471		Vel = 6.77	
U16 to M28	31.583 21.833	8.00	24.17 71.07	1.5 1.682	1I 1T 4.95 9.9 0.0	12.917 14.850 27.767	120 0.1363	9.127 4.223 3.784		Vel = 10.26	
M28			0.0 71.07					17.134		K Factor = 17.17	
*											
M21 to M22	21.833 21.833		27.61	3 3.26	0.0 0.0 0.0	1.708 0.0 1.708	120 0.0012	13.369 0.0 0.002		Vel = 1.06	
M22 to M23	21.833 21.833		53.60	3 3.26	0.0 0.0 0.0	9.167 0.0 9.167	120 0.0069	13.371 0.0 0.063		Vel = 3.12	
M23 to M24	21.833 21.833		26.68	3 3.26	0.0 0.0 0.0	5.125 0.0 5.125	120 0.0117	13.434 0.0 0.060		Vel = 4.15	
M24 to M25	21.833 21.833		51.33	3 3.26	0.0 0.0 0.0	5.750 0.0 5.750	120 0.0242	13.494 0.0 0.139		Vel = 6.12	
M25 to M26	21.833 21.833		25.62	3 3.26	0.0 0.0 0.0	8.542 0.0 8.542	120 0.0318	13.633 0.0 0.272		Vel = 7.10	
M26 to M27	21.833 21.833		70.66	3 3.26	0.0 0.0 0.0	14.292 0.0 14.292	120 0.0579	13.905 0.0 0.828		Vel = 9.82	
M27 to M29	21.833 21.833		67.79	3 3.26	1J 17.471 0.0 0.0	10.625 17.471 28.096	120 0.0896	14.733 0.0 2.516		Vel = 12.43	
M29			0.0 323.29					17.249		K Factor = 77.84	
M28 to M29	21.833 21.833		71.07	3 3.26	1J 17.471 0.0 0.0	3.708 17.471 21.179	120 0.0054	17.134 0.0 0.115		Vel = 2.73	
M29 to M48	21.833 20.500		323.29	3 3.26	1J 17.471 0.0 0.0	1.333 17.471 18.804	120 0.1293	17.249 0.577 2.432		Vel = 15.16	
M48 to M30	20.500 20.500		0.0	3 3.26	0.0 0.0 0.0	47.625 0.0 47.625	120 0.1293	20.258 0.0 6.160		Vel = 15.16	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 8
 Date 08-19-20


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M30 to M31	20.500 20.500		0.0 394.36	4 4.26	1J 0.0	21.067 21.067	83.042 104.109	120 0.0351	26.418 0.0 3.658	Vel = 8.88	
M31 to M32	20.500 20.500		0.0 394.36	4 4.26	1J 0.0	21.067 21.067	30.208 51.275	120 0.0351	30.076 0.0 1.802	Vel = 8.88	
M32 to M33	20.500 20.500		0.0 394.36	4 4.26	1J 0.0	21.067 21.067	2.500 23.567	120 0.0351	31.878 0.0 0.828	Vel = 8.88	
M33 to M34	20.500 13.208		0.0 394.36	4 4.26	1I 0.0	9.217 9.217	7.292 16.509	120 0.0351	32.706 3.158 0.580	Vel = 8.88	
M34 to M35	13.208 13.208		0.0 394.36	4 4.26	1J 0.0	21.067 21.067	7.500 28.567	120 0.0351	36.444 0.0 1.004	Vel = 8.88	
M35 to M36	13.208 13.208		0.0 394.36	4 4.26	1I 0.0	9.217 9.217	71.250 80.467	120 0.0351	37.448 0.0 2.828	Vel = 8.88	
M36 to M37	13.208 13.208		0.0 394.36	4 4.26	1I 0.0	9.217 9.217	38.000 47.217	120 0.0352	40.276 0.0 1.660	Vel = 8.88	
M37 to TR1	13.208 13.208		0.0 394.36	4 4.26	1I 0.0	9.217 9.217	3.667 12.884	120 0.0351	41.936 0.0 0.452	Vel = 8.88	
TR1			0.0 394.36						42.388	K Factor = 60.57	
* TR1 to BR1	13.208 2.500		394.36 394.36	4 4.26	1B 1Fsp 1Aty 1J	15.8 0.0 30.284 21.067	10.708 67.151 77.859	120 0.0351	42.388 7.638 2.736	** Fixed Loss = 3 Vel = 8.88	
BR1 to BR2	2.500 2.500		0.0 394.36	4 4.26		0.0 0.0	2.000 2.000	120 0.0350	52.762 0.0 0.070	Vel = 8.88	
BR2			0.0 394.36						52.832	K Factor = 54.26	
* BR2 to PD	2.500 2.500		394.36 394.36	6 6.357	1B 1S	12.573 40.235	10.000 52.808	120 0.0050	52.832 0.0 0.314	Vel = 3.99	
PD			0.0 394.36						53.146	K Factor = 54.10	
System Demand Pressure									53.146		
Safety Margin									13.568		
Continuation Pressure									66.714		
Pressure @ Pump Outlet									66.714		
Pressure From Pump Curve									-41.962		
Pressure @ Pump Inlet									24.752		

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MECHANICAL PLATFORM AREA 2

Page 9
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*											
PS to FLG	2.5 1		0.0 394.36	6 6.357	1G 1E 3.772 17.603	10.500 21.375 31.875	120 0.0050	24.752 0.650 0.159			Vel = 3.99
FLG			0.0 394.36					25.561		K Factor = 78.00	
*											
FLG to UG1	1 0		394.36 394.36	6 6.16	1E 1G 20.084 4.304	50.000 67.425 117.425	140 0.0044	25.561 0.433 0.515			Vel = 4.25
UG1			0.0 394.36					26.509		K Factor = 76.59	
*											
UG1 to UG2	0 0	H100	329.53 329.53	8 8.27	2F 0.0 28.468	394.000 28.468 422.468	140 0.0008	26.509 0.0 0.317			Vel = 1.97
UG2			0.0 329.53					26.826		K Factor = 63.62	
UG1 to UG3	0 0		164.83 164.83	8 8.27	5F 3E 71.17 85.404	988.000 181.879 1169.879	140 0.0002	26.509 0.0 0.244			Vel = 0.98
UG3 to UG2	0 0		0.0 164.83	8 8.27	3F 1G 42.702 6.326	303.000 49.028 352.028	140 0.0002	26.753 0.0 0.073			Vel = 0.98
UG2			0.0 164.83					26.826		K Factor = 31.82	
*											
UG2 to BF1	0 2.500		494.36 494.36	8 8.27	2E 0.0 56.936	381.000 56.936 437.936	140 0.0016	26.826 -1.083 0.695			Vel = 2.95
BF1 to BF2	2.500 0		0.0 494.36	8 8.249	1Zai 0.0 0.0	6.000 0.0 6.000	120 0.0022	26.438 11.661 0.013		** Fixed Loss = 10.578	Vel = 2.97
BF2 to UG4	0 0		0.0 494.36	8 8.27	2E 1T 56.936 55.354	26.000 112.290 138.290	140 0.0016	38.112 0.0 0.219			Vel = 2.95
UG4 to TAP	0 0		0.0 494.36	8 8.27	1T 1G 55.354 6.326	321.000 61.680 382.680	140 0.0016	38.331 0.0 0.607			Vel = 2.95
TAP to TEST	0 0		0.0 494.36	8 8.27	1Eq 297.332 0.0	500.000 297.332 797.332	140 0.0016	38.938 0.0 1.266			Vel = 2.95
TEST			150.00 644.36					40.204		Qa = 150.00 K Factor = 101.62	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - GYM AREA 3
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 3
Contract : 2020-098
Data File : EE AREA 3.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 3
Remote area location: GYMNASIUM
Occupancy classification: LIGHT HAZARD
Density: 0.10 - Gpm/SqFt
Area of application: 1,500 - SqFt
Coverage per sprinkler: 225 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 8
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 262.480 - GPM @ 21.814 - Psi
Type of system: WET - TREE
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
EE - GYM AREA 3

Page 2
Date 08-19-20





City Water Supply: C1 - Static Pressure : 47 C2 - Residual Pressure: 38 C2 - Residual Flow : 750 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 32.812 A2 - Adj Resid : 24.456 @ 500 A3 - Adj Resid : 13.864 @ 750	Pump Data: P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 750 City Residual Flow @ 0 = 1832.70 City Residual Flow @ 20 = 1358.20 City Water @ 150% of Pump = 38.00	Demand: D1 - Elevation : 12.416 D2 - System Flow : 162.48 D2 - System Pressure : 51.786 Hose (Demand) : _____ D3 - System Demand : 162.48 Hose (Adj City) : 100 Safety Margin : 23.896
--	---	--



Flow Diagram

Reliable Fire Protection LLC
EE - GYM AREA 3

Page 3
Date 08-19-20



Fittings Used Summary

Reliable Fire Protection LLC
EE - GYM AREA 3

Page 4
Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - GYM AREA 3

Page 5
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
U20	26.5	5.6	12.03	na	19.42	0.1	191	11.6
U21	26.5	5.6	12.42	na	19.73	0.1	191	11.6
U22	26.5	5.6	13.84	na	20.83	0.1	191	11.6
U23	28.667	5.6	11.63	na	19.1	0.1	191	11.6
U24	28.667	5.6	12.01	na	19.41	0.1	191	11.6
U25	28.667	5.6	13.39	na	20.49	0.1	191	11.6
U26	30.792	5.6	14.85	na	21.58	0.1	191	11.6
U27	30.792	5.6	15.32	na	21.92	0.1	191	11.6
M55	26.667		17.37	na				
M56	28.667		16.88	na				
M57	30.792		17.31	na				
M60	36.458		23.94	na				
M30	21.0		37.69	na				
M31	21.0		38.4	na				
M32	21.0		38.75	na				
M33	21.0		38.91	na				
M34	13.208		42.4	na				
M35	13.208		42.6	na				
M36	13.208		43.15	na				
M37	13.208		43.47	na				
TR1	13.208		43.56	na				
BR1	2.5		51.72	na				
BR2	2.5		51.73	na				
PD	2.5		51.79	na				
PS	2.5		31.69	na				
FLG	1.0		32.37	na				
UG1	0.0		32.9	na	100.0			
UG3	0.0		32.98	na				
UG2	0.0		33.0	na				
BF1	2.5		32.13	na				
BF2	0.0		45.06	na				
UG4	0.0		45.13	na				
TAP	0.0		45.32	na				
TEST	0.0		45.71	na				

The maximum velocity is 14.27 and it occurs in the pipe between nodes M57 and M60

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - GYM AREA 3

Page 6
Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
U20 to U21	26.500 26.500	5.60	19.42 19.42	1.25 1.442		0.0 0.0	14.833 14.833	120 0.0262	12.027 0.0 0.388		Vel = 3.82	
U21 to U22	26.500 26.500	5.60	19.73 39.15	1.25 1.442		0.0 0.0	14.833 14.833	120 0.0957	12.415 0.0 1.420		Vel = 7.69	
U22 to M55	26.500 26.667	5.60	20.83 59.98	1.25 1.442	1T	7.432 0.0	9.667 7.432 17.099	120 0.2108	13.835 -0.072 3.604		Vel = 11.78	
M55 *			0.0 59.98						17.367		K Factor = 14.39	
U23 to U24	28.667 28.667	5.60	19.10 19.1	1.25 1.442		0.0 0.0	14.833 14.833	120 0.0253	11.633 0.0 0.376		Vel = 3.75	
U24 to U25	28.667 28.667	5.60	19.41 38.51	1.25 1.442		0.0 0.0	14.833 14.833	120 0.0928	12.009 0.0 1.377		Vel = 7.57	
U25 to M56	28.667 28.667	5.60	20.49 59.0	1.25 1.442	1T	7.432 0.0	9.667 7.432 17.099	120 0.2045	13.386 0.0 3.496		Vel = 11.59	
M56 *			0.0 59.00						16.882		K Factor = 14.36	
U26 to U27	30.792 30.792	5.60	21.58 21.58	1.25 1.442		0.0 0.0	14.833 14.833	120 0.0318	14.852 0.0 0.471		Vel = 4.24	
U27 to M57	30.792 30.792	5.60	21.92 43.5	1.25 1.442	1T	7.432 0.0	9.667 7.432 17.099	120 0.1164	15.323 0.0 1.990		Vel = 8.55	
M57 *			0.0 43.50						17.313		K Factor = 10.45	
M55 to M56	26.667 28.667		59.98 59.98	2 2.157		0.0 0.0	12.833 12.833	120 0.0297	17.367 -0.866 0.381		Vel = 5.27	
M56 to M57	28.667 30.792		59.00 118.98	2 2.157		0.0 0.0	12.833 12.833	120 0.1053	16.882 -0.920 1.351		Vel = 10.45	
M57 to M60	30.792 36.458		43.50 162.48	2 2.157	3I	12.922 0.0	35.542 12.922 48.464	120 0.1874	17.313 -2.454 9.082		Vel = 14.27	
M60 to M30	36.458 21		0.0 162.48	2 2.157	1I 1T	4.307 12.307	21.042 16.614 37.656	120 0.1874	23.941 6.695 7.057		Vel = 14.27	
M30 *			0.0 162.48						37.693		K Factor = 26.46	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - GYM AREA 3

Page 7
Date 08-19-20


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M30 to M31	21 21		162.48	4	1J	21.067 0.0	83.042 21.067	120	37.693 0.0		
			162.48	4.26		0.0	104.109	0.0068	0.709	Vel = 3.66	
M31 to M32	21 21		0.0	4	1J	21.067 0.0	30.208 21.067	120	38.402 0.0		
			162.48	4.26		0.0	51.275	0.0068	0.350	Vel = 3.66	
M32 to M33	21 21		0.0	4	1J	21.067 0.0	2.500 21.067	120	38.752 0.0		
			162.48	4.26		0.0	23.567	0.0068	0.160	Vel = 3.66	
M33 to M34	21 13.208		0.0	4	1I	9.217 0.0	7.292 9.217	120	38.912 3.375		
			162.48	4.26		0.0	16.509	0.0068	0.113	Vel = 3.66	
M34 to M35	13.208 13.208		0.0	4	1J	21.067 0.0	8.000 21.067	120	42.400 0.0		
			162.48	4.26		0.0	29.067	0.0068	0.198	Vel = 3.66	
M35 to M36	13.208 13.208		0.0	4	1I	9.217 0.0	71.250 9.217	120	42.598 0.0		
			162.48	4.26		0.0	80.467	0.0068	0.548	Vel = 3.66	
M36 to M37	13.208 13.208		0.0	4	1I	9.217 0.0	38.000 9.217	120	43.146 0.0		
			162.48	4.26		0.0	47.217	0.0068	0.322	Vel = 3.66	
M37 to TR1	13.208 13.208		0.0	4	1I	9.217 0.0	3.667 9.217	120	43.468 0.0		
			162.48	4.26		0.0	12.884	0.0068	0.088	Vel = 3.66	
TR1			0.0 162.48						43.556	K Factor = 24.62	
* TR1 to BR1	13.208 2.500		162.48	4	1B 1Fsp 1Aty 1J	15.8 0.0 30.284 21.067	10.708 67.151 77.859	120	43.556 7.638 0.530	** Fixed Loss = 3 Vel = 3.66	
BR1 to BR2	2.500 2.500		0.0	6		0.0 0.0	2.000 0.0	120	51.724 0.0		
			162.48	6.357		0.0	2.000	0.0010	0.002	Vel = 1.64	
BR2			0.0 162.48						51.726	K Factor = 22.59	
* BR2 to PD	2.500 2.500		162.48	6	1B 1S	12.573 40.235	10.000 52.808	120	51.726 0.0		
			162.48	6.357		0.0	62.808	0.0010	0.060	Vel = 1.64	
PD			0.0 162.48						51.786	K Factor = 22.58	
System Demand Pressure									51.786		
Safety Margin									23.896		
Continuation Pressure									75.682		
Pressure @ Pump Outlet									75.682		
Pressure From Pump Curve									-43.995		
Pressure @ Pump Inlet									31.686		

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - GYM AREA 3

Page 8
Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*											
PS to FLG	2.5 1		0.0 162.48	6 6.357	1G 1E	3.772 17.603	10.500 21.375	120	31.686 0.650		
			0.0			0.0	31.875	0.0010	0.032	Vel = 1.64	
FLG			162.48						32.368	K Factor = 28.56	
*											
FLG to UG1	1 0		162.48	6 6.16	1E 1G 1T	20.084 4.304 43.037	50.000 67.425 117.425	140	32.368 0.433		
			0.0					0.0008	0.099	Vel = 1.75	
UG1			162.48						32.900	K Factor = 28.33	
*											
UG1 to UG2	0 0	H100	174.96	8 8.27	2F	28.468 0.0	394.000 28.468	140	32.900 0.0		
			0.0			0.0	422.468	0.0002	0.098	Vel = 1.05	
UG2			174.96						32.998	K Factor = 30.46	
UG1 to UG3	0 0		87.52	8 8.27	5F 3E 4G	71.17 85.404 25.305	988.000 181.879 1169.879	140	32.900 0.0		
			0.0					0.0001	0.076	Vel = 0.52	
UG3 to UG2	0 0		87.52	8 8.27	3F 1G	42.702 6.326	303.000 49.028	140	32.976 0.0		
			0.0			0.0	352.028	0.0001	0.022	Vel = 0.52	
UG2			87.52						32.998	K Factor = 15.24	
*											
UG2 to BF1	0 2.500		262.48	8 8.27	2E	56.936 0.0	381.000 56.936	140	32.998 -1.083		
			0.0			0.0	437.936	0.0005	0.215	Vel = 1.57	
BF1 to BF2	2.500 0		0.0	8 8.249	1Zai	0.0 0.0	6.000 0.0	120	32.130 12.926	** Fixed Loss = 11.844	
			262.48			0.0	6.000	0.0008	0.005	Vel = 1.58	
BF2 to UG4	0 0		0.0	8 8.27	2E 1T	56.936 55.354	26.000 112.290	140	45.061 0.0		
			262.48			0.0	138.290	0.0005	0.069	Vel = 1.57	
UG4 to TAP	0 0		0.0	8 8.27	1T 1G	55.354 6.326	321.000 61.680	140	45.130 0.0		
			262.48			0.0	382.680	0.0005	0.187	Vel = 1.57	
TAP to TEST	0 0		0.0	8	1Eq	297.332 0.0	500.000 297.332	140	45.317 0.0		
			262.48	8.27		0.0	797.332	0.0005	0.393	Vel = 1.57	
TEST			0.0						45.710	K Factor = 38.82	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - AUDITORIUM AREA 4
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 4
Contract : 2020-098
Data File : EE AREA 4.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 4
Remote area location: AUDITORIUM
Occupancy classification: LIGHT HAZARD
Density: 0.10 - Gpm/SqFt
Area of application: 1,500 - SqFt
Coverage per sprinkler: 225 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 17
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 414.007 - GPM @ 23.174 - Psi
Type of system: WET - TREE
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 2
Date 08-19-20

City Water Supply:	Pump Data:	Demand:
C1 - Static Pressure : 47	P1 - Pump Churn Pressure : 44	D1 - Elevation : 9.239
C2 - Residual Pressure: 38	P2 - Pump Rated Pressure : 40	D2 - System Flow : 314.007
C2 - Residual Flow : 750	P2 - Pump Rated Flow : 500	D2 - System Pressure : 51.576
City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow	P3 - Pump Pressure @ Max Flow : 26	Hose (Demand) :
A1 - Adjusted Static: 32.812	P3 - Pump Max Flow : 750	D3 - System Demand : 314.007
A2 - Adj Resid : 24.456 @ 500	City Residual Flow @ 0 = 1832.70	Hose (Adj City) : 100
A3 - Adj Resid : 13.864 @ 750	City Residual Flow @ 20 = 1358.20	Safety Margin : 20.828
	City Water @ 150% of Pump = 38.00	



Flow Diagram

16.8
P21 ← 21
↑
/ 16.8
17.7
P22 ← 22

18.3
P23 ← 23

20.2
P24 ← 24

16.8
P25 ← 25
↑
/ 16.8
17.8
P26 ← 26

18.4
P27 ← 27

20.2
P28 ← 28

19.5
P29 ← 29

19.7
P30 ← 30

21
P31 ← 31

16.8 51.6 88.3
21 ← 22 ← U30 ← 23 ← U31 ← 24 ← M49
34.5 69.9 108.5
/ 108.5
16.8 51 87.2
25 ← 26 ← U32 ← 27 ← U33 ← 28 ← M50
34.6 69.4 107.4

19.5 57.7 98.1
29 ← U34 ← 30 ← U35 ← 31 ← M51
38 77.1

108.5 314 314 314 314 314 314 314
M49 ← M50 ← M51 ← M54 ← M30 ← M31 ← M32 ← M33 ← M34 ← M35 ← M36 ← M37 ← TR1 ← BR1 ← BR2 ← PD
215.9 314 314 314 314 314 314 314

314 276
PS ← FLG ← UG1 ← UG2
314 ↑ ↑
/ 276 414
138 / 414 414 414
UG1 ← UG3 ← UG2 ← BF1 ← BF2 ← UG4 ← TAP ← TEST
138 414 414

Fittings Used Summary

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 4
Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	65	78	88	98	120	120
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 5
Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P21	21.333	5.6	9.0	na	16.8	0.1	168	9.0
P22	21.333	5.6	10.04	na	17.75	0.1	120	7.0
P23	21.333	5.6	10.7	na	18.32	0.1	120	7.0
P24	21.333	5.6	13.04	na	20.22	0.1	120	7.0
P25	21.333	5.6	9.01	na	16.81	0.1	120	7.0
P26	21.333	5.6	10.13	na	17.82	0.1	150	7.3
P27	21.333	5.6	10.77	na	18.38	0.1	120	7.0
P28	21.333	5.6	13.02	na	20.2	0.1	120	7.0
P29	21.333	5.6	12.08	na	19.47	0.1	150	7.3
P30	21.333	5.6	12.41	na	19.72	0.1	120	7.0
P31	21.333	5.6	14.08	na	21.01	0.1	120	7.0
21	25.917		8.99	na				
22	25.917		9.06	na				
U30	25.917	5.6	9.25	na	17.03	0.1	120	7.0
23	25.917		9.77	na				
U31	25.917	5.6	10.83	na	18.43	0.1	120	7.0
24	25.917		12.33	na				
25	28.375		8.16	na				
26	28.375		8.35	na				
U32	28.375	5.6	8.54	na	16.37	0.1	120	7.0
27	28.375		9.06	na				
U33	28.375	5.6	10.1	na	17.8	0.1	120	7.0
28	28.375		11.56	na				
29	28.375		10.86	na				
U34	28.375	5.6	10.93	na	18.51	0.1	120	7.0
30	28.375		11.23	na				
U35	28.375	5.6	11.97	na	19.37	0.1	120	7.0
31	28.375		13.13	na				
M49	25.917		18.49	na				
M50	28.375		17.6	na				
M51	28.375		18.24	na				
M54	36.25		19.62	na				
M30	21.0		30.14	na				
M31	21.0		32.54	na				
M32	21.0		33.72	na				
M33	21.0		34.26	na				
M34	13.208		38.02	na				
M35	13.208		38.69	na				
M36	13.208		40.54	na				
M37	13.208		41.63	na				
TR1	13.208		41.93	na				
BR1	2.5		51.36	na				
BR2	2.5		51.37	na				
PD	2.5		51.58	na				
PS	2.5		29.22	na				
FLG	1.0		29.97	na				
UG1	0.0		30.74	na	100.0			
UG3	0.0		30.92	na				
UG2	0.0		30.97	na				
BF1	2.5		30.39	na				
BF2	0.0		42.5	na				
UG4	0.0		42.65	na				
TAP	0.0		43.09	na				
TEST	0.0		44.0	na				

The maximum velocity is 15.67 and it occurs in the pipe between nodes 24 and M49

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 6
Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P21 to 21	21.333 25.917	5.60	16.80 16.8	1 1.049	1T	5.0 0.0 0.0	15.917 5.000 20.917	120 0.0942	9.000 -1.985 1.971		Vel = 6.24	
21			0.0 16.80						8.986		K Factor = 5.60	
P22 to 22	21.333 25.917	5.60	17.75 17.75	1 1.049	1T	5.0 0.0 0.0	4.583 5.000 9.583	120 0.1042	10.042 -1.985 0.999		Vel = 6.59	
22			0.0 17.75						9.056		K Factor = 5.90	
P23 to 23	21.333 25.917	5.60	18.32 18.32	1 1.049	1T	5.0 0.0 0.0	4.583 5.000 9.583	120 0.1105	10.700 -1.985 1.059		Vel = 6.80	
23			0.0 18.32						9.774		K Factor = 5.86	
P24 to 24	21.333 25.917	5.60	20.22 20.22	1 1.049	1T	5.0 0.0 0.0	4.583 5.000 9.583	120 0.1327	13.039 -1.985 1.272		Vel = 7.51	
24			0.0 20.22						12.326		K Factor = 5.76	
P25 to 25	21.333 28.375	5.60	16.80 16.8	1 1.049	1T	5.0 0.0 0.0	18.375 5.000 23.375	120 0.0943	9.006 -3.050 2.204		Vel = 6.24	
25			0.0 16.80						8.160		K Factor = 5.88	
P26 to 26	21.333 28.375	5.60	17.82 17.82	1 1.049	1T	5.0 0.0 0.0	7.042 5.000 12.042	120 0.1051	10.130 -3.050 1.266		Vel = 6.62	
26			0.0 17.82						8.346		K Factor = 6.17	
P27 to 27	21.333 28.375	5.60	18.38 18.38	1 1.049	1T	5.0 0.0 0.0	7.042 5.000 12.042	120 0.1113	10.770 -3.050 1.340		Vel = 6.82	
27			0.0 18.38						9.060		K Factor = 6.11	
P28 to 28	21.333 28.375	5.60	20.20 20.2	1 1.049	1T	5.0 0.0 0.0	7.042 5.000 12.042	120 0.1326	13.015 -3.050 1.597		Vel = 7.50	
28			0.0 20.20						11.562		K Factor = 5.94	
P29 to 29	21.333 28.375	5.60	19.47 19.47	1 1.049	1T	5.0 0.0 0.0	9.750 5.000 14.750	120 0.1238	12.083 -3.050 1.826		Vel = 7.23	
29			0.0 19.47						10.859		K Factor = 5.91	
P30 to 30	21.333 28.375	5.60	19.72 19.72	1 1.049	1T	5.0 0.0 0.0	9.750 5.000 14.750	120 0.1268	12.406 -3.050 1.870		Vel = 7.32	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 7
Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 19.72						11.226		K Factor = 5.89	
P31 to 31	21.333 28.375	5.60	21.01	1	1T	5.0	9.750	120	14.077			
			21.01	1.049		0.0	5.000		-3.050		Vel = 7.80	
			0.0 21.01						13.129		K Factor = 5.80	
*												
21 to 22	25.917 25.917		16.80	1.5		0.0	7.375	120	8.986			
			16.8	1.682		0.0	7.375	0.0095	0.070		Vel = 2.43	
22 to U30	25.917 25.917		17.75	1.5		0.0	5.333	120	9.056			
			34.55	1.682		0.0	5.333	0.0358	0.191		Vel = 4.99	
U30 to 23	25.917 25.917	5.60	17.03	1.5		0.0	7.000	120	9.247			
			51.58	1.682		0.0	7.000	0.0753	0.527		Vel = 7.45	
23 to U31	25.917 25.917		18.31	1.5		0.0	8.000	120	9.774			
			69.89	1.682		0.0	8.000	0.1322	1.058		Vel = 10.09	
U31 to 24	25.917 25.917	5.60	18.43	1.5		0.0	7.333	120	10.832			
			88.32	1.682		0.0	7.333	0.2037	1.494		Vel = 12.75	
24 to M49	25.917 25.917		20.22	1.5	1T	9.9	10.750	120	12.326			
			108.54	1.682		0.0	9.900		0.0		Vel = 15.67	
			0.0 108.54						18.487		K Factor = 25.24	
*												
25 to 26	28.375 28.375		16.80	1.5	2I	9.9	9.708	120	8.160			
			16.8	1.682		0.0	9.900		0.0		Vel = 2.43	
26 to U32	28.375 28.375		17.83	1.5		0.0	5.500	120	8.346			
			34.63	1.682		0.0	5.500	0.0360	0.198		Vel = 5.00	
U32 to 27	28.375 28.375	5.60	16.37	1.5		0.0	7.000	120	8.544			
			51.0	1.682		0.0	7.000	0.0737	0.516		Vel = 7.36	
27 to U33	28.375 28.375		18.38	1.5		0.0	8.000	120	9.060			
			69.38	1.682		0.0	8.000	0.1304	1.043		Vel = 10.02	
U33 to 28	28.375 28.375	5.60	17.80	1.5		0.0	7.333	120	10.103			
			87.18	1.682		0.0	7.333	0.1990	1.459		Vel = 12.59	
28 to M50	28.375 28.375		20.20	1.5	1T	9.9	10.750	120	11.562			
			107.38	1.682		0.0	9.900		0.0		Vel = 15.50	
			0.0				20.650	0.2924	6.039			

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 8
Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M50			107.38					17.601		K Factor = 25.59	
*											
29 to U34	28.375 28.375		19.47	1.5	0.0	5.500	120	10.859			
U34 to 30	28.375 28.375	5.60	19.47	1.682	0.0	5.500	0.0124	0.068	Vel = 2.81		
30 to U35	28.375 28.375		18.51	1.5	0.0	7.000	120	10.927			
U35 to 31	28.375 28.375	5.60	37.98	1.682	0.0	7.000	0.0427	0.299	Vel = 5.48		
31 to M51	28.375 28.375		19.72	1.5	0.0	8.000	120	11.226			
M51			57.7	1.682	0.0	8.000	0.0928	0.742	Vel = 8.33		
31 to M51	28.375 28.375		19.38	1.5	0.0	7.333	120	11.968			
M51			77.08	1.682	0.0	7.333	0.1583	1.161	Vel = 11.13		
31 to M51	28.375 28.375		21.00	1.5	1T	9.9	10.750	120	13.129		
M51			98.08	1.682	0.0	20.650	0.2474	5.109	Vel = 14.16		
M51			0.0								
M51			98.08					18.238		K Factor = 22.97	
*											
M49 to M50	25.917 28.375		108.54	3	0.0	15.000	120	18.487			
M50 to M51	28.375 28.375		108.54	3.26	0.0	15.000	0.0119	0.179	Vel = 4.17		
M51 to M54	28.375 36.250		107.38	3	0.0	15.000	120	17.601			
M54 to M30	36.250 21		215.92	3.26	0.0	15.000	0.0425	0.637	Vel = 8.30		
M30			98.09	3	3I	20.159	36.333	120	18.238		
M30			0.0			0.0	20.159		-3.411		
M30 to M34	21 13.208		314.01	3.26	0.0	56.492	0.0848	4.793	Vel = 12.07		
M34 to M35	13.208 13.208		0.0	3	1I	6.72	19.250	120	19.620		
M35			314.01	3.26	0.0	46.129	0.0848	3.913	Vel = 12.07		
M35			0.0								
M35			314.01					30.138		K Factor = 57.20	
*											
M30 to M31	21 21		314.01	4	1J	21.067	83.042	120	30.138		
M31 to M32	21 21		314.01	4.26		0.0	21.067	0.0231	0.0	Vel = 7.07	
M32 to M33	21 21		0.0	4	1J	21.067	30.208	120	32.539		
M33 to M34	21 13.208		314.01	4.26		0.0	21.067	0.0231	0.0	Vel = 7.07	
M34 to M35	13.208 13.208		0.0	4	1J	21.067	51.275	120	1.182	Vel = 7.07	
M35			0.0	4	1J	21.067	2.500	120	33.721		
M35			0.0			0.0	21.067		0.0		
M35 to M35	13.208 13.208		314.01	4.26		0.0	23.567	0.0230	0.543	Vel = 7.07	
M35			0.0	4	1I	9.217	7.292	120	34.264		
M35			0.0			0.0	9.217		3.375		
M35 to M35	13.208 13.208		314.01	4.26		0.0	16.509	0.0231	0.381	Vel = 7.07	
M35			0.0	4	1J	21.067	8.000	120	38.020		
M35			0.0			0.0	21.067		0.0		
M35 to M35	13.208 13.208		314.01	4.26		0.0	29.067	0.0231	0.670	Vel = 7.07	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
EE - AUDITORIUM AREA 4

Page 9
Date 08-19-20


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M35 to M36	13.208 13.208		0.0 314.01	4 4.26	1I 0.0	9.217 9.217	71.250 80.467	120 0.0231	38.690 0.0	Vel = 7.07	
M36 to M37	13.208 13.208		0.0 314.01	4 4.26	1I 0.0	9.217 9.217	38.000 47.217	120 0.0230	40.545 0.0	Vel = 7.07	
M37 to TR1	13.208 13.208		0.0 314.01	4 4.26	1I 0.0	9.217 9.217	3.667 12.884	120 0.0231	41.633 0.0	Vel = 7.07	
TR1			0.0 314.01						41.930	K Factor = 48.49	
* TR1 to BR1	13.208 2.500		314.01 314.01	4 4.26	1B 1Fsp 1Aty 1J	15.8 0.0 30.284 21.067	10.708 67.151 77.859	120 0.0231	41.930 7.638 1.795	** Fixed Loss = 3 Vel = 7.07	
BR1 to BR2	2.500 2.500		0.0 314.01	6 6.357		0.0 0.0 0.0	2.000 0.0 2.000	120 0.0035	51.363 0.0 0.007	Vel = 3.17	
BR2			0.0 314.01						51.370	K Factor = 43.81	
* BR2 to PD	2.500 2.500		314.01 314.01	6 6.357	1B 1S	12.573 40.235 0.0	10.000 52.808 62.808	120 0.0033	51.370 0.0 0.206	Vel = 3.17	
PD			0.0 314.01						51.576	K Factor = 43.72	
System Demand Pressure									51.576		
Safety Margin									20.828		
Continuation Pressure									72.404		
Pressure @ Pump Outlet									72.404		
Pressure From Pump Curve									-43.187		
Pressure @ Pump Inlet									29.217		
* PS to FLG	2.5 1		0.0 314.01	6 6.357	1G 1E	3.772 17.603 0.0	10.500 21.375 31.875	120 0.0033	29.217 0.650 0.105	Vel = 3.17	
FLG			0.0 314.01						29.972	K Factor = 57.36	
* FLG to UG1	1 0		314.01 314.01	6 6.16	1E 1G 1T	20.084 4.304 43.037	50.000 67.425 117.425	140 0.0029	29.972 0.433 0.338	Vel = 3.38	
UG1			0.0 314.01						30.743	K Factor = 56.63	
* UG1 to UG2	0 0	H100	275.97 275.97	8 8.27	2F	28.468 0.0 0.0	394.000 28.468 422.468	140 0.0005	30.743 0.0 0.227	Vel = 1.65	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - AUDITORIUM AREA 4

Page 10
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0								
UG2			275.97					30.970		K Factor = 49.59	
UG1	0		138.04	8	5F	71.17	988.000	140	30.743		
to					3E	85.404	181.879		0.0		
UG3	0		138.04	8.27	4G	25.305	1169.879	0.0001	0.175	Vel = 0.82	
UG3	0		0.0	8	3F	42.702	303.000	140	30.918		
to					1G	6.326	49.028		0.0		
UG2	0		138.04	8.27		0.0	352.028	0.0001	0.052	Vel = 0.82	
			0.0								
UG2			138.04					30.970		K Factor = 24.80	
*											
UG2	0		414.01	8	2E	56.936	381.000	140	30.970		
to						0.0	56.936		-1.083		
BF1	2.500		414.01	8.27		0.0	437.936	0.0011	0.501	Vel = 2.47	
BF1	2.500		0.0	8	1Zai	0.0	6.000	120	30.388		
to						0.0	0.0		12.097	** Fixed Loss = 11.014	
BF2	0		414.01	8.249		0.0	6.000	0.0017	0.010	Vel = 2.49	
BF2	0		0.0	8	2E	56.936	26.000	140	42.495		
to					1T	55.354	112.290		0.0		
UG4	0		414.01	8.27		0.0	138.290	0.0011	0.158	Vel = 2.47	
UG4	0		0.0	8	1T	55.354	321.000	140	42.653		
to					1G	6.326	61.680		0.0		
TAP	0		414.01	8.27		0.0	382.680	0.0011	0.437	Vel = 2.47	
TAP	0		0.0	8	1Eqi	297.332	500.000	140	43.090		
to						0.0	297.332		0.0		
TEST	0		414.01	8.27		0.0	797.332	0.0011	0.912	Vel = 2.47	
			0.0								
TEST			414.01						44.002	K Factor = 62.41	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - OFFICE - AREA 5 - A100
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 5
Contract : 2020-098
Data File : EE AREA 5.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 5
Remote area location: 1ST FLOOR OFFICE AREAS
Occupancy classification: LIGHT HAZARD
Density: 0.10 - Gpm/SqFt
Area of application: 1,500 - SqFt
Coverage per sprinkler: 225 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 18
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 472.149 - GPM @ 27.544 - Psi
Type of system: WET - TREE
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 2
 Date 08-19-20

City Water Supply:	Pump Data:	Demand:
C1 - Static Pressure : 47	P1 - Pump Churn Pressure : 44	D1 - Elevation : 3.898
C2 - Residual Pressure: 38	P2 - Pump Rated Pressure : 40	D2 - System Flow : 372.149
C2 - Residual Flow : 750	P2 - Pump Rated Flow : 500	D2 - System Pressure : 54.620
City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow	P3 - Pump Pressure @ Max Flow : 26	Hose (Demand) :
A1 - Adjusted Static: 32.812	P3 - Pump Max Flow : 750	D3 - System Demand : 372.149
A2 - Adj Resid : 24.456 @ 500	City Residual Flow @ 0 = 1832.70	Hose (Adj City) : 100
A3 - Adj Resid : 13.864 @ 750	City Residual Flow @ 20 = 1358.20	Safety Margin : 15.633
	City Water @ 150% of Pump = 38.00	



Flow Diagram

Reliable Fire Protection LLC
EE - OFFICE - AREA 5 - A100

Page 3
Date 08-19-20

19.2
P51 ← 51
↑
/ 19.2
19.4
P52 ← 52
↑
/ 38.6
19.9
P53 ← 53
↑
/ 58.4
21.2
P54 ← 54

22.9
P55 ← 55

22.1
P56 ← 56

19.5
P57 ← 57
↑
/ 19.5
19.6
P58 ← 58
↑
/ 39.1
20.3
P59 ← 59
↑
/ 59.4
21.5
P60 ← 60


19.6
P61 ← 61
↑
/ 19.6
19.8
P62 ← 62
↑
/ 39.4
20.3
P63 ← 63
↑
/ 59.7
21.2
P64 ← 64

23.6
P65 ← 65

Flow Diagram

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 4
 Date 08-19-20



Fittings Used Summary

Reliable Fire Protection LLC
EE - OFFICE - AREA 5 - A100

Page 5
Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	65	78	88	98	120	120
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 6
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P51	9.0	5.6	11.79	na	19.23	0.1	103	7.0
P52	9.0	5.6	11.95	na	19.36	0.1	103	7.0
P53	9.0	5.6	12.57	na	19.85	0.1	165	8.4
P54	9.0	5.6	14.35	na	21.21	0.1	165	8.4
P55	9.0	5.6	16.67	na	22.86	0.1	54	7.0
P56	9.0	5.6	15.59	na	22.11	0.1	54	7.0
P57	9.0	5.6	12.13	na	19.51	0.1	133	7.0
P58	9.0	5.6	12.28	na	19.62	0.1	157	7.8
P59	9.0	5.6	13.17	na	20.32	0.1	100	7.0
P60	9.0	5.6	14.74	na	21.5	0.1	56	7.0
P61	9.0	5.6	12.3	na	19.64	0.1	196	12.3
P62	9.0	5.6	12.51	na	19.8	0.1	45	7.0
P63	9.0	5.6	13.1	na	20.27	0.1	100	7.0
P64	9.0	5.6	14.27	na	21.15	0.1	130	7.0
P65	9.0	5.6	17.83	na	23.65	0.1	100	7.0
P66	9.0	5.6	13.16	na	20.32	0.1	74	7.0
P67	9.0	5.6	13.56	na	20.62	0.1	32	7.0
P68	9.0	5.6	14.23	na	21.13	0.1	130	7.0
51	12.5		13.42	na				
52	12.5		13.62	na				
53	12.5		14.39	na				
54	12.5		16.61	na				
55	12.5		19.49	na				
56	12.5		18.14	na				
57	12.5		13.85	na				
58	12.5		14.03	na				
59	12.5		15.13	na				
60	12.5		17.09	na				
61	12.5		14.06	na				
62	12.5		14.31	na				
63	12.5		15.05	na				
64	12.5		16.5	na				
65	12.5		20.93	na				
66	12.5		15.13	na				
67	12.5		15.63	na				
68	12.5		16.46	na				
M38	12.5		20.53	na				
M39	12.5		20.57	na				
M40	12.5		20.58	na				
M41	12.5		20.65	na				
M42	12.5		20.96	na				
M43	12.5		21.37	na				
M44	12.5		24.01	na				
M45	12.5		24.55	na				
M46	12.5		25.36	na				
M47	12.5		26.29	na				
M48	12.5		26.67	na				
M49	20.5		28.06	na				
M30	20.5		29.56	na				
M31	20.5		32.85	na				
M32	20.5		34.47	na				
M33	20.5		35.21	na				
M34	13.208		38.89	na				
M35	13.208		39.8	na				
M36	13.208		42.34	na				
M37	13.208		43.83	na				
TR1	13.208		44.23	na				
BR1	2.5		54.33	na				
BR2	2.5		54.34	na				
PD	2.5		54.62	na				
PS	2.5		27.93	na				

Flow Summary - Standard

Reliable Fire Protection LLC
EE - OFFICE - AREA 5 - A100

Page 7
Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
FLG	1.0		28.72	na				
UG1	0.0		29.62	na	100.0			
UG3	0.0		29.84	na				
UG2	0.0		29.91	na				
BF1	2.5		29.46	na				
BF2	0.0		41.26	na				
UG4	0.0		41.46	na				
TAP	0.0		42.01	na				
TEST	0.0		43.18	na				

The maximum velocity is 15.9 and it occurs in the pipe between nodes 60 and M41

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 8
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P51 to 51	9 12.500	5.60	19.23 19.23	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1210	11.788 -1.516 3.146		Vel = 7.14	
51			0.0 19.23					13.418		K Factor = 5.25	
P52 to 52	9 12.500	5.60	19.36 19.36	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1226	11.953 -1.516 3.187		Vel = 7.19	
52			0.0 19.36					13.624		K Factor = 5.25	
P53 to 53	9 12.500	5.60	19.85 19.85	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1284	12.567 -1.516 3.338		Vel = 7.37	
53			0.0 19.85					14.389		K Factor = 5.23	
P54 to 54	9 12.500	5.60	21.21 21.21	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1451	14.350 -1.516 3.773		Vel = 7.87	
54			0.0 21.21					16.607		K Factor = 5.20	
P55 to 55	9 12.500	5.60	22.86 22.86	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1667	16.671 -1.516 4.334		Vel = 8.49	
55			0.0 22.86					19.489		K Factor = 5.18	
P56 to 56	9 12.500	5.60	22.11 22.11	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1567	15.586 -1.516 4.073		Vel = 8.21	
56			0.0 22.11					18.143		K Factor = 5.19	
P57 to 57	9 12.500	5.60	19.50 19.5	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1242	12.132 -1.516 3.230		Vel = 7.24	
57			0.0 19.50					13.846		K Factor = 5.24	
P58 to 58	9 12.500	5.60	19.62 19.62	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1256	12.276 -1.516 3.266		Vel = 7.28	
58			0.0 19.62					14.026		K Factor = 5.24	
P59 to 59	9 12.500	5.60	20.32 20.32	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1340	13.166 -1.516 3.484		Vel = 7.54	
59			0.0 20.32					15.134		K Factor = 5.22	
P60 to 60	9 12.500	5.60	21.50 21.5	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1488	14.742 -1.516 3.868		Vel = 7.98	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 9
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 21.50					17.094		K Factor = 5.20	
P61 to 61	9 12.500	5.60	19.64	1	1T 5.0	21.000 0.0 5.000 26.000	120	12.300 -1.516 3.272		Vel = 7.29	
			0.0 19.64					14.056		K Factor = 5.24	
P62 to 62	9 12.500	5.60	19.80	1	1T 5.0	21.000 0.0 5.000 26.000	120	12.506 -1.516 3.322		Vel = 7.35	
			0.0 19.80					14.312		K Factor = 5.23	
P63 to 63	9 12.500	5.60	20.27	1	1T 5.0	21.000 0.0 5.000 26.000	120	13.096 -1.516 3.468		Vel = 7.52	
			0.0 20.27					15.048		K Factor = 5.23	
P64 to 64	9 12.500	5.60	21.15	1	1T 5.0	21.000 0.0 5.000 26.000	120	14.266 -1.516 3.752		Vel = 7.85	
			0.0 21.15					16.502		K Factor = 5.21	
P65 to 65	9 12.500	5.60	23.65	1	1T 5.0	21.000 0.0 5.000 26.000	120	17.832 -1.516 4.613		Vel = 8.78	
			0.0 23.65					20.929		K Factor = 5.17	
P66 to 66	9 12.500	5.60	20.32	1	1T 5.0	21.000 0.0 5.000 26.000	120	13.162 -1.516 3.483		Vel = 7.54	
			0.0 20.32					15.129		K Factor = 5.22	
P67 to 67	9 12.500	5.60	20.62	1	1T 5.0	21.000 0.0 5.000 26.000	120	13.564 -1.516 3.582		Vel = 7.65	
			0.0 20.62					15.630		K Factor = 5.22	
P68 to 68	9 12.500	5.60	21.13	1	1T 5.0	21.000 0.0 5.000 26.000	120	14.233 -1.516 3.744		Vel = 7.84	
			0.0 21.13					16.461		K Factor = 5.21	
* 51 to 52	12.500 12.500		19.23	1.25	0.0	8.000 0.0 0.0	120	13.418 0.0			
			19.23	1.442	0.0	8.000	0.0258	0.206		Vel = 3.78	
52 to 53	12.500 12.500		19.36	1.25	0.0	8.208 0.0 0.0	120	13.624 0.0			
			38.59	1.442	0.0	8.208	0.0932	0.765		Vel = 7.58	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 10
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
53 to 54	12.500 12.500		19.85 58.44	1.25 1.442	0.0 0.0	11.042 0.0	120	14.389 0.0			
										Vel = 11.48	
54 to M38	12.500 12.500		21.21 79.65	1.25 1.442	1T 0.0	7.432 7.432	120	16.607 0.0			
										Vel = 15.65	
M38			0.0 79.65					20.531		K Factor = 17.58	
*											
55 to M39	12.500 12.500		22.86 22.86	1 1.049	1T 0.0	5.0 5.000	120	19.489 0.0			
										Vel = 8.49	
M39			0.0 22.86					20.573		K Factor = 5.04	
*											
56 to M40	12.500 12.500		22.11 22.11	1 1.049	1T 0.0	5.0 5.000	120	18.143 0.0			
										Vel = 8.21	
M40			0.0 22.11					20.584		K Factor = 4.87	
*											
57 to 58	12.500 12.500		19.50 19.5	1.25 1.442	0.0 0.0	6.833 0.0	120	13.846 0.0			
										Vel = 3.83	
58 to 59	12.500 12.500		19.63 39.13	1.25 1.442	0.0 0.0	11.583 0.0	120	14.026 0.0			
										Vel = 7.69	
59 to 60	12.500 12.500		20.31 59.44	1.25 1.442	0.0 0.0	9.458 0.0	120	15.134 0.0			
										Vel = 11.68	
60 to M41	12.500 12.500		21.51 80.95	1.25 1.442	1T 0.0	7.432 7.432	120	17.094 0.0			
										Vel = 15.90	
M41			0.0 80.95					20.648		K Factor = 17.81	
*											
61 to 62	12.500 12.500		19.64 19.64	1.25 1.442	0.0 0.0	9.583 0.0	120	14.056 0.0			
										Vel = 3.86	
62 to 63	12.500 12.500		19.80 39.44	1.25 1.442	0.0 0.0	7.583 0.0	120	14.312 0.0			
										Vel = 7.75	
63 to 64	12.500 12.500		20.27 59.71	1.25 1.442	0.0 0.0	6.958 0.0	120	15.048 0.0			
										Vel = 11.73	
64 to M42	12.500 12.500		21.15 80.86	1.25 1.442	1T 0.0	7.432 7.432	120	16.502 0.0			
										Vel = 15.89	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 11
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M42			0.0 80.86					20.964		K Factor = 17.66	
*											
65 to M43	12.500 12.500		23.65 23.65	1.25 1.442	0.0 0.0 0.0	11.708 0.0 11.708	120 0.0377	20.929 0.0 0.441		Vel = 4.65	
M43			0.0 23.65					21.370		K Factor = 5.12	
*											
66 to 67	12.500 12.500		20.32 20.32	1.25 1.442	0.0 0.0 0.0	17.583 0.0 17.583	120 0.0285	15.129 0.0 0.501		Vel = 3.99	
67 to 68	12.500 12.500		20.62 40.94	1.25 1.442	0.0 0.0 0.0	8.000 0.0 8.000	120 0.1039	15.630 0.0 0.831		Vel = 8.04	
68 to M45	12.500 12.500		21.13 62.07	1.25 1.442	1T 7.432 0.0 0.0	28.583 7.432 36.015	120 0.2245	16.461 0.0 8.087		Vel = 12.19	
M45			0.0 62.07					24.548		K Factor = 12.53	
*											
M38 to M39	12.500 12.500		79.65 79.65	3 3.26	0.0 0.0 0.0	6.292 0.0 6.292	120 0.0067	20.531 0.0 0.042		Vel = 3.06	
M39 to M40	12.500 12.500		22.87 102.52	3 3.26	0.0 0.0 0.0	1.000 0.0 1.000	120 0.0110	20.573 0.0 0.011		Vel = 3.94	
M40 to M41	12.500 12.500		22.11 124.63	3 3.26	0.0 0.0 0.0	4.167 0.0 4.167	120 0.0154	20.584 0.0 0.064		Vel = 4.79	
M41 to M42	12.500 12.500		80.94 205.57	3 3.26	0.0 0.0 0.0	8.167 0.0 8.167	120 0.0387	20.648 0.0 0.316		Vel = 7.90	
M42 to M43	12.500 12.500		80.86 286.43	3 3.26	0.0 0.0 0.0	5.667 0.0 5.667	120 0.0716	20.964 0.0 0.406		Vel = 11.01	
M43 to M44	12.500 12.500		23.65 310.08	3 3.26	11 6.72 0.0 0.0	25.125 6.720 31.845	120 0.0829	21.370 0.0 2.639		Vel = 11.92	
M44 to M45	12.500 12.500		0.0 310.08	3 3.26	0.0 0.0 0.0	6.500 0.0 6.500	120 0.0829	24.009 0.0 0.539		Vel = 11.92	
M45 to M46	12.500 12.500		62.07 372.15	3 3.26	0.0 0.0 0.0	7.000 0.0 7.000	120 0.1161	24.548 0.0 0.813		Vel = 14.30	
M46 to M47	12.500 12.500		0.0 372.15	3 3.26	0.0 0.0 0.0	8.000 0.0 8.000	120 0.1162	25.361 0.0 0.930		Vel = 14.30	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 12
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M47 to M48	12.500 12.500		0.0 372.15	3 3.26	0.0 0.0 0.0	3.292 0.0 3.292	120 0.1160	26.291 0.0 0.382		Vel = 14.30	
M48 to M49	12.500 20.500		0.0 372.15	3 3.26	1I 1J 17.471 0.0	6.72 17.471 24.191 41.774	120 0.1162	26.673 -3.465 4.854		Vel = 14.30	
M49			0.0 372.15					28.062		K Factor = 70.25	
*											
M49 to M30	20.500 20.500		372.15	4 4.26	0.0 0.0 0.0	47.625 0.0 47.625	120 0.0316	28.062 0.0 1.503		Vel = 8.38	
M30 to M31	20.500 20.500		0.0 372.15	4 4.26	1J 0.0 0.0	21.067 21.067 104.109	120 0.0316	29.565 0.0 3.287		Vel = 8.38	
M31 to M32	20.500 20.500		0.0 372.15	4 4.26	1J 0.0 0.0	21.067 21.067 51.275	120 0.0316	32.852 0.0 1.618		Vel = 8.38	
M32 to M33	20.500 20.500		0.0 372.15	4 4.26	1J 0.0 0.0	21.067 21.067 23.567	120 0.0316	34.470 0.0 0.744		Vel = 8.38	
M33 to M34	20.500 13.208		0.0 372.15	4 4.26	1I 0.0 0.0	9.217 9.217 16.509	120 0.0316	35.214 3.158 0.522		Vel = 8.38	
M34 to M35	13.208 13.208		0.0 372.15	4 4.26	1J 0.0 0.0	21.067 21.067 28.567	120 0.0315	38.894 0.0 0.901		Vel = 8.38	
M35 to M36	13.208 13.208		0.0 372.15	4 4.26	1I 0.0 0.0	9.217 9.217 80.467	120 0.0316	39.795 0.0 2.541		Vel = 8.38	
M36 to M37	13.208 13.208		0.0 372.15	4 4.26	1I 0.0 0.0	9.217 9.217 47.217	120 0.0316	42.336 0.0 1.490		Vel = 8.38	
M37 to TR1	13.208 13.208		0.0 372.15	4 4.26	1I 0.0 0.0	9.217 9.217 12.884	120 0.0316	43.826 0.0 0.407		Vel = 8.38	
TR1			0.0 372.15					44.233		K Factor = 55.96	
*											
TR1 to BR1	13.208 2.500		372.15	4 4.26	1B 1Fsp 1Aty 1J 15.8 0.0 30.284 21.067	10.708 67.151 77.859	120 0.0316	44.233 7.638 2.457		** Fixed Loss = 3 Vel = 8.38	
BR1 to BR2	2.500 2.500		0.0 372.15	6 6.357	0.0 0.0 0.0	2.000 0.0 2.000	120 0.0045	54.328 0.0 0.009		Vel = 3.76	
BR2			0.0 372.15					54.337		K Factor = 50.49	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 13
 Date 08-19-20


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*											
BR2 to PD	2.500 2.500		372.15 372.15	6 6.357	1B 1S	12.573 40.235	10.000 52.808	120 0.0	54.337 0.283	Vel = 3.76	
PD			0.0 372.15						54.620	K Factor = 50.35	
System Demand Pressure								54.620			
Safety Margin								15.633			
Continuation Pressure								70.253			
Pressure @ Pump Outlet								70.253			
Pressure From Pump Curve								-42.325			
Pressure @ Pump Inlet								27.928			
*											
PS to FLG	2.5 1		0.0 372.15	6 6.357	1G 1E	3.772 17.603	10.500 21.375	120 0.650	27.928 0.143	Vel = 3.76	
FLG			0.0 372.15						28.721	K Factor = 69.44	
*											
FLG to UG1	1 0		372.15 372.15	6 6.16	1E 1G 1T	20.084 4.304 43.037	50.000 67.425 117.425	140 0.433 0.0039	28.721 0.463	Vel = 4.01	
UG1			0.0 372.15						29.617	K Factor = 68.38	
*											
UG1 to UG2	0 0	H100	314.73 314.73	8 8.27	2F	28.468 0.0	394.000 28.468	140 0.0	29.617 0.291	Vel = 1.88	
UG2			0.0 314.73						29.908	K Factor = 57.55	
UG1 to UG3	0 0		157.42 157.42	8 8.27	5F 3E 4G	71.17 85.404 25.305	988.000 181.879 1169.879	140 0.0 0.0002	29.617 0.223	Vel = 0.94	
UG3 to UG2	0 0		0.0 157.42	8 8.27	3F 1G	42.702 6.326	303.000 49.028	140 0.0	29.840 0.068	Vel = 0.94	
UG2			0.0 157.42						29.908	K Factor = 28.78	
*											
UG2 to BF1	0 2.500		472.15 472.15	8 8.27	2E	56.936 0.0	381.000 56.936	140 0.0015	29.908 -1.083 0.638	Vel = 2.82	
BF1 to BF2	2.500 0		0.0 472.15	8 8.249	1Zai	0.0 0.0	6.000 0.0	120 0.0020	29.463 11.781 0.012	** Fixed Loss = 10.698 Vel = 2.83	
BF2 to UG4	0 0		0.0 472.15	8 8.27	2E 1T	56.936 55.354	26.000 112.290	140 0.0015	41.256 0.0 0.201	Vel = 2.82	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - OFFICE - AREA 5 - A100

Page 14
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG4 to TAP	0 0		0.0 472.15	8 8.27	1T 1G	55.354 6.326	321.000 61.680	140 0.0	41.457 0.0	Vel = 2.82	
TAP to TEST	0 0		0.0 472.15	8 8.27	1Eq	297.332 0.0	500.000 297.332	140 0.0	42.015 0.0	Vel = 2.82	
TEST			0.0 472.15						43.177	K Factor = 71.85	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - MUSIC/DANCE - AREA 6 - B100
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 6
Contract : 2020-098
Data File : EE AREA 6.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL

Location: DENIM DR., ERWIN, NC 28339

Drawing no: FP1,2,3,4

Date: 08-19-20

Design

Remote area number: 6

Remote area location: MUSIC/DANCE CLASSROOMS

Occupancy classification: LIGHT HAZARD

Density: 0.10 - Gpm/SqFt

Area of application: 1,500 - SqFt

Coverage per sprinkler: 225 MAX - SqFt

Type of sprinklers calculated: STANDARD SPRAY PENDANT

No. of sprinklers calculated: 10

In-rack demand: N/A - GPM

Hose streams: 100 - GPM

Total water required (including hose streams): 337.578 - GPM @ 29.647 - Psi

Type of system: WET - TREE

Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20

Location: DENIM DR.

Source: LKC ENGINEERING, LLC

Name of contractor: RELIABLE FIRE PROTECTION, LLC

Address: 32 PARTIN RD., DUNN, NC 28334

Phone number: 910-980-1234

Name of designer: ROBERT LAWLEY 26806-FS1

Authority having jurisdiction: HARNETT COUNTY


Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 2
 Date 08-19-20

City Water Supply:	Pump Data:	Demand:
C1 - Static Pressure : 47	P1 - Pump Churn Pressure : 44	D1 - Elevation : 5.197
C2 - Residual Pressure: 38	P2 - Pump Rated Pressure : 40	D2 - System Flow : 237.578
C2 - Residual Flow : 750	P2 - Pump Rated Flow : 500	D2 - System Pressure : 59.324
City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow	P3 - Pump Pressure @ Max Flow : 26	Hose (Demand) :
A1 - Adjusted Static: 32.812	P3 - Pump Max Flow : 750	D3 - System Demand : 237.578
A2 - Adj Resid : 24.456 @ 500	City Residual Flow @ 0 = 1832.70	Hose (Adj City) : 100
A3 - Adj Resid : 13.864 @ 750	City Residual Flow @ 20 = 1358.20	Safety Margin : 15.297
	City Water @ 150% of Pump = 38.00	



Fittings Used Summary

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 4
 Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	65	78	88	98	120	120
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 5
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P41	12.0	5.6	14.4	na	21.25	0.1	210	14.4
P42	12.0	5.6	14.7	na	21.47	0.1	210	14.4
P43	12.0	5.6	15.78	na	22.25	0.1	210	14.4
P44	12.0	5.6	18.74	na	24.24	0.1	210	14.4
P45	12.0	5.6	14.5	na	21.32	0.1	210	14.4
P46	12.0	5.6	14.8	na	21.54	0.1	210	14.4
P47	12.0	5.6	15.9	na	22.33	0.1	210	14.4
P48	12.0	5.6	18.87	na	24.33	0.1	210	14.4
P49	12.0	5.6	27.27	na	29.24	0.1	210	14.4
P50	12.0	5.6	27.94	na	29.6	0.1	210	14.4
41	13.0		17.75	na				
42	13.0		18.12	na				
43	13.0		19.47	na				
44	13.0		23.14	na				
45	13.0		17.88	na				
46	13.0		18.25	na				
47	13.0		19.61	na				
48	13.0		23.3	na				
49	13.0		33.66	na				
50	13.0		34.5	na				
M71	13.208		41.81	na				
M72	13.208		42.09	na				
M73	13.208		43.1	na				
M74	13.208		47.02	na				
M35	13.208		48.55	na				
M36	13.208		49.66	na				
M37	13.208		50.31	na				
TR1	13.208		50.49	na				
BR1	2.5		59.2	na				
BR2	2.5		59.2	na				
PD	2.5		59.32	na				
PS	2.5		30.63	na				
FLG	1.0		31.34	na				
UG1	0.0		31.98	na	100.0			
UG3	0.0		32.1	na				
UG2	0.0		32.13	na				
BF1	2.5		31.39	na				
BF2	0.0		43.91	na				
UG4	0.0		44.02	na				
TAP	0.0		44.32	na				
TEST	0.0		44.95	na				

The maximum velocity is 17.59 and it occurs in the pipe between nodes 48 and M72

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 6
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P41 to 41	12 13	5.60	21.25 21.25	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1456	14.400 -0.433 3.785		Vel = 7.89	
41			0.0 21.25					17.752		K Factor = 5.04	
P42 to 42	12 13	5.60	21.47 21.47	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1484	14.698 -0.433 3.858		Vel = 7.97	
42			0.0 21.47					18.123		K Factor = 5.04	
P43 to 43	12 13	5.60	22.25 22.25	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1585	15.785 -0.433 4.121		Vel = 8.26	
43			0.0 22.25					19.473		K Factor = 5.04	
P44 to 44	12 13	5.60	24.24 24.24	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1858	18.741 -0.433 4.830		Vel = 9.00	
44			0.0 24.24					23.138		K Factor = 5.04	
P45 to 45	12 13	5.60	21.32 21.32	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1465	14.500 -0.433 3.810		Vel = 7.91	
45			0.0 21.32					17.877		K Factor = 5.04	
P46 to 46	12 13	5.60	21.54 21.54	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1493	14.801 -0.433 3.882		Vel = 8.00	
46			0.0 21.54					18.250		K Factor = 5.04	
P47 to 47	12 13	5.60	22.33 22.33	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1595	15.895 -0.433 4.147		Vel = 8.29	
47			0.0 22.33					19.609		K Factor = 5.04	
P48 to 48	12 13	5.60	24.33 24.33	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1870	18.870 -0.433 4.861		Vel = 9.03	
48			0.0 24.33					23.298		K Factor = 5.04	
P49 to 49	12 13	5.60	29.24 29.24	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2627	27.266 -0.433 6.831		Vel = 10.85	
49			0.0 29.24					33.664		K Factor = 5.04	
P50 to 50	12 13	5.60	29.60 29.6	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2688	27.945 -0.433 6.989		Vel = 10.99	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 7
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 29.60					34.501		K Factor = 5.04	
41 to 42	13 13		21.25 21.25	1.25 1.442	0.0 0.0	12.000 0.0	120 0.0309	17.752 0.0		Vel = 4.17	
42 to 43	13 13		21.47 42.72	1.25 1.442	0.0 0.0	12.000 12.000	120 0.1125	18.123 0.0		Vel = 8.39	
43 to 44	13 13		22.25 64.97	1.25 1.442	0.0 0.0	15.000 15.000	120 0.2443	19.473 3.665		Vel = 12.76	
44 to M71	13 13.208		24.24 89.21	1.25 1.442	2I 1T 7.432 7.432 0.0	27.833 14.864 42.697	120 0.4393	23.138 -0.090 18.758		Vel = 17.53	
M71			0.0 89.21					41.806		K Factor = 13.80	
45 to 46	13 13		21.32 21.32	1.25 1.442	0.0 0.0	12.000 12.000	120 0.0311	17.877 0.0		Vel = 4.19	
46 to 47	13 13		21.55 42.87	1.25 1.442	0.0 0.0	12.000 12.000	120 0.1132	18.250 0.0		Vel = 8.42	
47 to 48	13 13		22.32 65.19	1.25 1.442	0.0 0.0	15.000 15.000	120 0.2459	19.609 0.0		Vel = 12.81	
48 to M72	13 13.208		24.33 89.52	1.25 1.442	2I 1T 7.432 7.432 0.0	27.833 14.864 42.697	120 0.4421	23.298 -0.090 18.878		Vel = 17.59	
M72			0.0 89.52					42.086		K Factor = 13.80	
49 to 50	13 13		29.24 29.24	1.25 1.442	0.0 0.0	15.000 15.000	120 0.0558	33.664 0.0		Vel = 5.74	
50 to M73	13 13.208		29.60 58.84	1.25 1.442	2I 1T 7.432 7.432 0.0	27.833 14.864 42.697	120 0.2035	34.501 -0.090 8.687		Vel = 11.56	
M73			0.0 58.84					43.098		K Factor = 8.96	
M71 to M72	13.208 13.208		89.21 89.21	2.5 2.635	0.0 0.0	12.000 12.000	120 0.0233	41.806 0.0		Vel = 5.25	
M72 to M73	13.208 13.208		89.52 178.73	2.5 2.635	0.0 0.0	12.000 12.000	120 0.0843	42.086 0.0		Vel = 10.52	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 8
 Date 08-19-20


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M73 to M74	13.208 13.208		58.85 237.58	2.5 2.635	1J 14.827 0.0	12.667 14.827 27.494	120 0.1428	43.098 0.0 3.925		Vel = 13.98	
M74			0.0 237.58					47.023		K Factor = 34.65	
* M74 to M35	13.208 13.208		237.58 237.58	3 3.26	0.0 0.0	30.208 0.0	120 0.0506	47.023 0.0 1.530		Vel = 9.13	
M35			0.0 237.58					48.553		K Factor = 34.10	
* M35 to M36	13.208 13.208		237.58 237.58	4 4.26	1I 9.217 0.0	71.250 9.217 80.467	120 0.0138	48.553 0.0 1.108		Vel = 5.35	
M36 to M37	13.208 13.208		0.0 237.58	4 4.26	1I 9.217 0.0	38.000 9.217 47.217	120 0.0137	49.661 0.0 0.649		Vel = 5.35	
M37 to TR1	13.208 13.208		0.0 237.58	4 4.26	1I 9.217 0.0	3.667 9.217 12.884	120 0.0138	50.310 0.0 0.178		Vel = 5.35	
TR1			0.0 237.58					50.488		K Factor = 33.44	
* TR1 to BR1	13.208 2.500		237.58 237.58	4 4.26	1B 1Fsp 1Aty 1J 15.8 0.0 30.284 21.067	10.708 67.151 77.859	120 0.0138	50.488 7.638 1.071		** Fixed Loss = 3 Vel = 5.35	
BR1 to BR2	2.500 2.500		0.0 237.58	6 6.357	0.0 0.0	2.000 0.0	120 0.0020	59.197 0.0 0.004		Vel = 2.40	
BR2			0.0 237.58					59.201		K Factor = 30.88	
* BR2 to PD	2.500 2.500		237.58 237.58	6 6.357	1B 1S 12.573 40.235 0.0	10.000 52.808 62.808	120 0.0020	59.201 0.0 0.123		Vel = 2.40	
PD			0.0 237.58					59.324		K Factor = 30.85	
System Demand Pressure								59.324			
Safety Margin								15.297			
Continuation Pressure								74.621			
Pressure @ Pump Outlet								74.621			
Pressure From Pump Curve								-43.991			
Pressure @ Pump Inlet								30.630			
* PS to FLG	2.5 1		0.0 237.58	6 6.357	1G 1E 3.772 17.603 0.0	10.500 21.375 31.875	120 0.0019	30.630 0.650 0.062		Vel = 2.40	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - MUSIC/DANCE - AREA 6 - B100

Page 9
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
FLG			0.0 237.58					31.342		K Factor = 42.44	
* FLG to UG1	1 0		237.58	6	1E 1G 1T	20.084 4.304 43.037	50.000 67.425 117.425	140	31.342 0.433 0.202	Vel = 2.56	
UG1			0.0 237.58					31.977		K Factor = 42.01	
* UG1 to UG2	0 0	H100	225.02	8	2F	28.468 0.0 0.0	394.000 28.468 422.468	140	31.977 0.0 0.156	Vel = 1.34	
UG2			0.0 225.02					32.133		K Factor = 39.70	
UG1 to UG3	0 0		112.56	8	5F 3E 4G	71.17 85.404 25.305	988.000 181.879 1169.879	140	31.977 0.0 0.120	Vel = 0.67	
UG3 to UG2	0 0		0.0	8	3F 1G	42.702 6.326 0.0	303.000 49.028 352.028	140	32.097 0.0 0.036	Vel = 0.67	
UG2			0.0 112.56					32.133		K Factor = 19.86	
* UG2 to BF1	0 2.500		337.58	8	2E	56.936 0.0 0.0	381.000 56.936 437.936	140	32.133 -1.083 0.343	Vel = 2.02	
BF1 to BF2	2.500 0		0.0	8	1Zai	0.0 0.0 0.0	6.000 0.0 6.000	120	31.393 12.512 0.007	** Fixed Loss = 11.429 Vel = 2.03	
BF2 to UG4	0 0		0.0	8	2E 1T	56.936 55.354 0.0	26.000 112.290 138.290	140	43.912 0.0 0.108	Vel = 2.02	
UG4 to TAP	0 0		0.0	8	1T 1G	55.354 6.326 0.0	321.000 61.680 382.680	140	44.020 0.0 0.300	Vel = 2.02	
TAP to TEST	0 0		0.0	8	1Eq	297.332 0.0 0.0	500.000 297.332 797.332	140	44.320 0.0 0.625	Vel = 2.02	
TEST			0.0 337.58					44.945		K Factor = 50.35	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - KITCHEN - AREA 7 - B100
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 7
Contract : 2020-098
Data File : EE AREA 7 - OH2.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 7
Remote area location: KITCHEN AREA
Occupancy classification: ORDINARY HAZARD GROUP 2
Density: 0.20 - Gpm/SqFt
Area of application: 1,065 - SqFt
Coverage per sprinkler: 130 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 11
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 544.485 - GPM @ 25.685 - Psi
Type of system: WET - TREE
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 2
 Date 08-19-20

City Water Supply:	Pump Data:	Demand:
C1 - Static Pressure : 47	P1 - Pump Churn Pressure : 44	D1 - Elevation : 4.331
C2 - Residual Pressure: 38	P2 - Pump Rated Pressure : 40	D2 - System Flow : 294.485
C2 - Residual Flow : 750	P2 - Pump Rated Flow : 500	D2 - System Pressure : 54.481
City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow	P3 - Pump Pressure @ Max Flow : 26	Hose (Demand) :
A1 - Adjusted Static: 31.849	P3 - Pump Max Flow : 750	D3 - System Demand : 294.485
A2 - Adj Resid : 21.412 @ 500	City Residual Flow @ 0 = 1832.70	Hose (Adj City) : 250
A3 - Adj Resid : 9.885 @ 750	City Residual Flow @ 20 = 1358.20	Safety Margin : 16.338
	City Water @ 150% of Pump = 38.00	



Fittings Used Summary

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 4
 Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	65	78	88	98	120	120
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 5
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P29	10.0	5.6	18.37	na	24.0	0.2	120	10.2
P30	10.0	5.6	18.94	na	24.37	0.2	120	10.2
P31	10.0	5.6	20.54	na	25.38	0.2	120	10.2
P32	10.0	5.6	23.55	na	27.17	0.2	112	9.0
P33	10.0	5.6	29.86	na	30.6	0.2	70	7.0
P34	10.0	5.6	29.86	na	30.6	0.2	105	7.8
P35	10.0	5.6	30.02	na	30.68	0.2	105	7.8
P36	10.0	5.6	18.64	na	24.18	0.2	120	10.2
P37	10.0	5.6	19.22	na	24.55	0.2	84	7.0
P38	10.0	5.6	20.85	na	25.57	0.2	84	7.0
P39	10.0	5.6	23.89	na	27.37	0.2	84	7.0
29	13.208		21.72	na				
30	13.208		22.43	na				
31	13.208		24.41	na				
32	13.208		28.12	na				
33	13.208		35.9	na				
34	13.208		35.9	na				
35	13.208		36.1	na				
36	13.208		22.06	na				
37	13.208		22.78	na				
38	13.208		24.79	na				
39	13.208		28.55	na				
M66	13.208		36.71	na				
M67	13.208		36.84	na				
M68	13.208		37.04	na				
M69	13.208		37.25	na				
M63	13.208		40.39	na				
M35	13.208		43.83	na				
M36	13.208		43.83	na				
M37	13.208		44.8	na				
TR1	13.208		45.06	na				
BR1	2.5		54.29	na				
BR2	2.5		54.3	na				
PD	2.5		54.48	na				
PS	2.5		27.37	na				
FLG	1.0		28.11	na				
UG1	0.0		28.85	na	100.0			
UG3	0.0		29.01	na				
UG2	0.0		29.06	na				
BF1	2.5		28.43	na				
BF2	0.0		40.64	na				
UG4	0.0		40.79	na				
TAP	0.0		41.19	na				
TEST	0.0		42.02	na	150.0			

The maximum velocity is 19.97 and it occurs in the pipe between nodes 39 and M69

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 6
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P29 to 29	10 13.208	5.60	24.00 24.0	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1823	18.367 -1.389 4.741		Vel = 8.91	
29			0.0 24.00					21.719		K Factor = 5.15	
P30 to 30	10 13.208	5.60	24.37 24.37	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1876	18.944 -1.389 4.877		Vel = 9.05	
30			0.0 24.37					22.432		K Factor = 5.15	
P31 to 31	10 13.208	5.60	25.38 25.38	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2022	20.545 -1.389 5.258		Vel = 9.42	
31			0.0 25.38					24.414		K Factor = 5.14	
P32 to 32	10 13.208	5.60	27.17 27.17	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2294	23.546 -1.389 5.965		Vel = 10.09	
32			0.0 27.17					28.122		K Factor = 5.12	
P33 to 33	10 13.208	5.60	30.60 30.6	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2858	29.860 -1.389 7.431		Vel = 11.36	
33			0.0 30.60					35.902		K Factor = 5.11	
P34 to 34	10 13.208	5.60	30.60 30.6	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2858	29.860 -1.389 7.430		Vel = 11.36	
34			0.0 30.60					35.901		K Factor = 5.11	
P35 to 35	10 13.208	5.60	30.68 30.68	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2872	30.018 -1.389 7.467		Vel = 11.39	
35			0.0 30.68					36.096		K Factor = 5.11	
P36 to 36	10 13.208	5.60	24.18 24.18	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1848	18.640 -1.389 4.805		Vel = 8.98	
36			0.0 24.18					22.056		K Factor = 5.15	
P37 to 37	10 13.208	5.60	24.55 24.55	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.1902	19.224 -1.389 4.944		Vel = 9.11	
37			0.0 24.55					22.779		K Factor = 5.14	
P38 to 38	10 13.208	5.60	25.57 25.57	1 1.049	1T 0.0 0.0	5.0 0.0 26.000	120 0.2050	20.848 -1.389 5.330		Vel = 9.49	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 7
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 25.57					24.789		K Factor = 5.14	
P39 to 39	10 13.208	5.60	27.37	1	1T 5.0	21.000 0.0 5.000	120	23.891 -1.389		Vel = 10.16	
39			0.0 27.37					28.547		K Factor = 5.12	
*											
29 to 30	13.208 13.208		24.00	1.25	2I 7.432	11.000 0.0 7.432	120	21.719 0.0		Vel = 4.71	
30 to 31	13.208 13.208		24.0 24.37	1.442 1.25	0.0	18.432 0.0 0.0	0.0387	0.713		Vel = 9.50	
31 to 32	13.208 13.208		48.37 25.39	1.442 1.25	0.0	14.000 0.0 0.0	0.1416	1.982		Vel = 14.49	
32 to M66	13.208 13.208		73.76 27.17	1.442 1.25	1T 7.432	12.000 0.0 7.432	120	24.414 0.0		Vel = 19.83	
M66			0.0 100.93	1.442	0.0	8.125 15.557	0.5520	8.588		K Factor = 16.66	
*											
33 to M66	13.208 13.208		30.60	1.25	1T 7.432	5.875 0.0 7.432	120	35.902 0.0		Vel = 6.01	
M66			0.0 30.6	1.442	0.0	13.307	0.0607	0.808		K Factor = 5.05	
*											
34 to M67	13.208 13.208		30.60	1.25	1T 7.432	8.125 0.0 7.432	120	35.901 0.0		Vel = 6.01	
M67			0.0 30.6	1.442	0.0	15.557	0.0607	0.944		K Factor = 5.04	
*											
35 to M68	13.208 13.208		30.68	1.25	1T 7.432	8.125 0.0 7.432	120	36.096 0.0		Vel = 6.03	
M68			0.0 30.68	1.442	0.0	15.557	0.0610	0.949		K Factor = 5.04	
*											
36 to 37	13.208 13.208		24.18	1.25	2I 7.432	11.000 0.0 7.432	120	22.056 0.0		Vel = 4.75	
37 to 38	13.208 13.208		24.18 24.55	1.442 1.25	0.0	18.432 0.0 0.0	0.0392	0.723		Vel = 9.57	
38			48.73	1.442	0.0	14.000	0.1436	2.010			

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 8
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
38 to 39	13.208 13.208		25.57 74.3	1.25 1.442	0.0 0.0	12.000 0.0	120 0.3132	24.789 0.0		Vel = 14.60	
39 to M69	13.208 13.208		27.37 101.67	1.25 1.442	1T 0.0	7.432 7.432	120 0.5596	28.547 0.0		Vel = 19.97	
M69			0.0 101.67					37.252		K Factor = 16.66	
*											
M66 to M67	13.208 13.208		131.53 131.53	3 3.26	0.0 0.0	8.000 0.0	120 0.0169	36.710 0.0		Vel = 5.06	
M67 to M68	13.208 13.208		30.60 162.13	3 3.26	0.0 0.0	8.000 0.0	120 0.0250	36.845 0.0		Vel = 6.23	
M68 to M69	13.208 13.208		30.68 192.81	3 3.26	0.0 0.0	6.000 6.000	120 0.0345	37.045 0.0		Vel = 7.41	
M69 to M63	13.208 13.208		101.67 294.48	3 3.26	1J 0.0	17.471 17.471	120 0.0753	37.252 0.0		Vel = 11.32	
M63 to M36	13.208 13.208		0.0 294.48	3 3.26	1J 0.0	17.471 17.471	120 0.0753	40.389 0.0		Vel = 11.32	
M36			0.0 294.48					43.830		K Factor = 44.48	
*											
M35 to M36	13.208 13.208	.0	0.0 0.0	4 4.26	1I 0.0	9.217 9.217	120 0	43.830 0.0		Vel = 0	
M36 to M37	13.208 13.208		294.48 294.48	4 4.26	1I 0.0	9.217 9.217	120 0.0205	43.830 0.0		Vel = 6.63	
M37 to TR1	13.208 13.208		0.0 294.48	4 4.26	1I 0.0	9.217 9.217	120 0.0205	44.797 0.0		Vel = 6.63	
TR1			0.0 294.48					45.061		K Factor = 43.87	
*											
TR1 to BR1	13.208 2.500		294.48 294.48	4 4.26	1B 1Fsp 1Aty 1J	15.8 0.0 30.284 21.067	120 0.0205	45.061 7.638 1.593		** Fixed Loss = 3 Vel = 6.63	
BR1 to BR2	2.500 2.500		0.0 294.48	6 6.357	0.0 0.0	2.000 0.0	120 0.0030	54.292 0.0		Vel = 2.98	
BR2			0.0 294.48					54.298		K Factor = 39.96	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 9
 Date 08-19-20


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*											
BR2 to PD	2.500 2.500		294.48 294.48	6 6.357	1B 1S	12.573 40.235	10.000 52.808	120 0.0	54.298 0.183	Vel = 2.98	
PD			0.0 294.48						54.481	K Factor = 39.90	
System Demand Pressure								54.481			
Safety Margin								16.338			
Continuation Pressure								70.819			
Pressure @ Pump Outlet								70.819			
Pressure From Pump Curve								-43.448			
Pressure @ Pump Inlet								27.371			
*											
PS to FLG	2.5 1		0.0 294.48	6 6.357	1G 1E	3.772 17.603	10.500 21.375	120 0.650	27.371 0.093	Vel = 2.98	
FLG			0.0 294.48						28.114	K Factor = 55.54	
*											
FLG to UG1	1 0		294.48 294.48	6 6.16	1E 1G 1T	20.084 4.304 43.037	50.000 67.425 117.425	140 0.433 0.0026	28.114 0.300	Vel = 3.17	
UG1			0.0 294.48						28.847	K Factor = 54.83	
*											
UG1 to UG2	0 0	H100	262.96 262.96	8 8.27	2F	28.468 0.0	394.000 28.468	140 0.0	28.847 0.209	Vel = 1.57	
UG2			0.0 262.96						29.056	K Factor = 48.78	
UG1 to UG3	0 0		131.53 131.53	8 8.27	5F 3E 4G	71.17 85.404 25.305	988.000 181.879 1169.879	140 0.0 0.0001	28.847 0.160	Vel = 0.79	
UG3 to UG2	0 0		0.0 131.53	8 8.27	3F 1G	42.702 6.326	303.000 49.028	140 0.0	29.007 0.049	Vel = 0.79	
UG2			0.0 131.53						29.056	K Factor = 24.40	
*											
UG2 to BF1	0 2.500		394.48 394.48	8 8.27	2E	56.936 0.0	381.000 56.936	140 0.0010	29.056 -1.083 0.458	Vel = 2.36	
BF1 to BF2	2.500 0		0.0 394.48	8 8.249	1Zai	0.0 0.0	6.000 0.0	120 0.0013	28.431 12.206 0.008	** Fixed Loss = 11.124 Vel = 2.37	
BF2 to UG4	0 0		0.0 394.48	8 8.27	2E 1T	56.936 55.354	26.000 112.290	140 0.0010	40.645 0.145	Vel = 2.36	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - KITCHEN - AREA 7 - B100

Page 10
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG4 to TAP	0 0		0.0 394.48	8 8.27	1T 1G	55.354 6.326	321.000 61.680	140 0.0	40.790 0.0	Vel = 2.36	
TAP to TEST	0 0		0.0 394.48	8 8.27	1Eq	297.332 0.0	500.000 297.332	140 0.0	41.190 0.0	Vel = 2.36	
TEST			150.00 544.48						42.023	Qa = 150.00 K Factor = 83.99	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : EE - AUDITORIUM PLATFORM AREA 8 - A100
Building : FP1,2,3,4
Location : DENIM DR., ERWIN, NC 28339
System : 8
Contract : 2020-098
Data File : EE AREA 8.WXF

HYDRAULIC CALCULATIONS
for

Project name: ERWIN ELEMENTARY SCHOOL
Location: DENIM DR., ERWIN, NC 28339
Drawing no: FP1,2,3,4
Date: 08-19-20

Design

Remote area number: 8
Remote area location: AUDITORIUM - PLATFORM OVERHEAD
Occupancy classification: ORDINARY HAZARD 2
Density: 0.20 - Gpm/SqFt
Area of application: 986 - SqFt
Coverage per sprinkler: 225 MAX - SqFt
Type of sprinklers calculated: STANDARD SPRAY PENDANT
No. of sprinklers calculated: 10
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 504.902 - GPM @ 11.038 - Psi
Type of system: WET - TREE
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 08-23-20
Location: DENIM DR.
Source: LKC ENGINEERING, LLC


Name of contractor: RELIABLE FIRE PROTECTION, LLC
Address: 32 PARTIN RD., DUNN, NC 28334
Phone number: 910-980-1234
Name of designer: ROBERT LAWLEY 26806-FS1
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 2
 Date 08-19-20


City Water Supply: C1 - Static Pressure : 47 C2 - Residual Pressure: 38 C2 - Residual Flow : 750 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 31.849 A2 - Adj Resid : 21.412 @ 500 A3 - Adj Resid : 9.885 @ 750	Pump Data: P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 750 City Residual Flow @ 0 = 1832.70 City Residual Flow @ 20 = 1358.20 City Water @ 150% of Pump = 38.00	Demand: D1 - Elevation : 15.556 D2 - System Flow : 254.902 D2 - System Pressure : 40.564 Hose (Demand) : _____ D3 - System Demand : 254.902 Hose (Adj City) : 250 Safety Margin : 31.634
---	---	--



Flow Diagram

Reliable Fire Protection LLC
EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 3
Date 08-19-20



Fittings Used Summary

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 4
 Date 08-19-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1							14			23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 5
 Date 08-19-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
U1	25.917	8	11.46	na	27.08	0.2	120	9.0
U2	25.917	8	11.64	na	27.3	0.2	120	9.0
U3	28.417	8	10.66	na	26.12	0.2	120	9.0
U4	28.417	8	10.83	na	26.32	0.2	120	9.0
U5	30.917	8	9.95	na	25.23	0.2	120	9.0
U6	30.917	8	10.11	na	25.44	0.2	120	9.0
U7	33.417	8	9.38	na	24.51	0.2	120	9.0
U8	33.417	8	9.54	na	24.71	0.2	120	9.0
U9	35.917	8	9.0	na	24.0	0.2	120	9.0
U10	35.917	8	9.15	na	24.19	0.2	120	9.0
M49	25.917		14.98	na				
M50	28.417		13.95	na				
M51	30.917		13.04	na				
M52	33.417		12.31	na				
M53	35.917		11.81	na				
M54	36.25		13.2	na				
M30	21.0		22.46	na				
M31	21.0		24.1	na				
M32	21.0		24.9	na				
M33	21.0		25.27	na				
M34	13.208		28.9	na				
M35	13.208		29.36	na				
M36	13.208		30.62	na				
M37	13.208		31.36	na				
TR1	13.208		31.56	na				
BR1	2.5		40.42	na				
BR2	2.5		40.42	na				
PD	2.5		40.56	na				
PS	2.5		28.26	na				
FLG	1.0		28.98	na				
UG1	0.0		29.65	na	100.0			
UG3	0.0		29.78	na				
UG2	0.0		29.82	na				
BF1	2.5		29.11	na				
BF2	0.0		41.54	na				
UG4	0.0		41.66	na				
TAP	0.0		41.99	na				
TEST	0.0		42.67	na	150.0			

The maximum velocity is 9.8 and it occurs in the pipe between nodes M53 and M54

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 6
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
U1 to U2	25.917 25.917	8.00	27.08	1.5		0.0	8.000	120	11.461			
						0.0	0.0		0.0			
			27.08	1.682		0.0	8.000	0.0229	0.183	Vel =	3.91	
U2 to M49	25.917 25.917	8.00	27.30	1.5	1T	9.9	30.250	120	11.644			
						0.0	9.900		0.0			
			54.38	1.682		0.0	40.150	0.0831	3.336	Vel =	7.85	
			0.0									
M49			54.38						14.980	K Factor =	14.05	
*												
U3 to U4	28.417 28.417	8.00	26.12	1.5		0.0	8.000	120	10.657			
						0.0	0.0		0.0			
			26.12	1.682		0.0	8.000	0.0214	0.171	Vel =	3.77	
U4 to M50	28.417 28.417	8.00	26.32	1.5	1T	9.9	30.250	120	10.828			
						0.0	9.900		0.0			
			52.44	1.682		0.0	40.150	0.0777	3.119	Vel =	7.57	
			0.0									
M50			52.44						13.947	K Factor =	14.04	
*												
U5 to U6	30.917 30.917	8.00	25.24	1.5		0.0	8.000	120	9.950			
						0.0	0.0		0.0			
			25.24	1.682		0.0	8.000	0.0200	0.160	Vel =	3.64	
U6 to M51	30.917 30.917	8.00	25.43	1.5	1T	9.9	30.250	120	10.110			
						0.0	9.900		0.0			
			50.67	1.682		0.0	40.150	0.0729	2.927	Vel =	7.32	
			0.0									
M51			50.67						13.037	K Factor =	14.03	
*												
U7 to U8	33.417 33.417	8.00	24.51	1.5		0.0	8.000	120	9.385			
						0.0	0.0		0.0			
			24.51	1.682		0.0	8.000	0.0190	0.152	Vel =	3.54	
U8 to M52	33.417 33.417	8.00	24.70	1.5	1T	9.9	30.250	120	9.537			
						0.0	9.900		0.0			
			49.21	1.682		0.0	40.150	0.0690	2.772	Vel =	7.11	
			0.0									
M52			49.21						12.309	K Factor =	14.03	
*												
U9 to U10	35.917 35.917	8.00	24.00	1.5		0.0	8.000	120	9.000			
						0.0	0.0		0.0			
			24.0	1.682		0.0	8.000	0.0182	0.146	Vel =	3.47	
U10 to M53	35.917 35.917	8.00	24.19	1.5	1T	9.9	30.250	120	9.146			
						0.0	9.900		0.0			
			48.19	1.682		0.0	40.150	0.0665	2.668	Vel =	6.96	
			0.0									
M53			48.19						11.814	K Factor =	14.02	
*												
M49 to M50	25.917 28.417		54.38	3		0.0	15.000	120	14.980			
						0.0	0.0		-1.083			
			54.38	3.26		0.0	15.000	0.0033	0.050	Vel =	2.09	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 7
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M50 to M51	28.417 30.917		52.44 106.82	3 3.26		0.0 0.0	15.000 0.0	120 0.0115	13.947 -1.083 0.173		Vel = 4.11	
M51 to M52	30.917 33.417		50.68 157.5	3 3.26		0.0 0.0	15.000 0.0	120 0.0237	13.037 -1.083 0.355		Vel = 6.05	
M52 to M53	33.417 35.917		49.21 206.71	3 3.26		0.0 0.0	15.000 0.0	120 0.0392	12.309 -1.083 0.588		Vel = 7.95	
M53 to M54	35.917 36.250		48.19 254.9	3 3.26	3I	20.159 0.0	6.333 20.159	120 0.0577	11.814 -0.144 1.528		Vel = 9.80	
M54 to M30	36.250 21		0.0 254.9	3 3.26	1I 1T	6.72 20.159	19.250 26.879	120 0.0577	13.198 6.605 2.661		Vel = 9.80	
M30			0.0 254.90						22.464		K Factor = 53.78	
*												
M30 to M31	21 21		254.90 254.9	4 4.26	1J	21.067 0.0	83.042 21.067	120 0.0157	22.464 0.0 1.632		Vel = 5.74	
M31 to M32	21 21		0.0 254.9	4 4.26	1J	21.067 0.0	30.208 21.067	120 0.0157	24.096 0.0 0.803		Vel = 5.74	
M32 to M33	21 21		0.0 254.9	4 4.26	1J	21.067 0.0	2.500 21.067	120 0.0157	24.899 0.0 0.370		Vel = 5.74	
M33 to M34	21 13.208		0.0 254.9	4 4.26	1I	9.217 0.0	7.292 9.217	120 0.0156	25.269 3.375 0.258		Vel = 5.74	
M34 to M35	13.208 13.208		0.0 254.9	4 4.26	1J	21.067 0.0	8.000 21.067	120 0.0157	28.902 0.0 0.456		Vel = 5.74	
M35 to M36	13.208 13.208		0.0 254.9	4 4.26	1I	9.217 0.0	71.250 9.217	120 0.0157	29.358 0.0 1.261		Vel = 5.74	
M36 to M37	13.208 13.208		0.0 254.9	4 4.26	1I	9.217 0.0	38.000 9.217	120 0.0157	30.619 0.0 0.741		Vel = 5.74	
M37 to TR1	13.208 13.208		0.0 254.9	4 4.26	1I	9.217 0.0	3.667 9.217	120 0.0156	31.360 0.0 0.201		Vel = 5.74	
TR1			0.0 254.90						31.561		K Factor = 45.37	
*												
TR1 to BR1	13.208 2.500		254.90 254.9	4 4.26	1B 1Fsp 1Aty	15.8 0.0 30.284	10.708 67.151 77.859	120 0.0157	31.561 7.638 1.221		** Fixed Loss = 3 Vel = 5.74	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 8
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
					1J	21.067					
BR1 to BR2	2.500 2.500		0.0 254.9	6 6.357		0.0 0.0 2.000	120 0.0020	40.420 0.0 0.004		Vel = 2.58	
BR2			0.0 254.90					40.424		K Factor = 40.09	
*											
BR2 to PD	2.500 2.500		254.90 254.9	6 6.357	1B 1S	12.573 40.235 0.0	10.000 52.808 62.808	120 0.0 0.0022	40.424 0.0 0.140	Vel = 2.58	
PD			0.0 254.90					40.564		K Factor = 40.02	
								40.564			
								31.634			
								72.198			
								72.198			
								-43.934			
								28.264			
*											
PS to FLG	2.5 1		0.0 254.9	6 6.357	1G 1E	3.772 17.603 0.0	10.500 21.375 31.875	120 0.0022	28.264 0.650 0.071	Vel = 2.58	
FLG			0.0 254.90					28.985		K Factor = 47.35	
*											
FLG to UG1	1 0		254.90 254.9	6 6.16	1E 1G 1T	20.084 4.304 43.037	50.000 67.425 117.425	140 0.0020	28.985 0.433 0.230	Vel = 2.74	
UG1			0.0 254.90					29.648		K Factor = 46.81	
*											
UG1 to UG2	0 0	H100	236.57 236.57	8 8.27	2F	28.468 0.0 0.0	394.000 28.468 422.468	140 0.0004	29.648 0.0 0.171	Vel = 1.41	
UG2			0.0 236.57					29.819		K Factor = 43.32	
UG1 to UG3	0 0		118.33 118.33	8 8.27	5F 3E 4G	71.17 85.404 25.305	988.000 181.879 1169.879	140 0.0001	29.648 0.0 0.132	Vel = 0.71	
UG3 to UG2	0 0		0.0 118.33	8 8.27	3F 1G	42.702 6.326 0.0	303.000 49.028 352.028	140 0.0001	29.780 0.0 0.039	Vel = 0.71	
UG2			0.0 118.33					29.819		K Factor = 21.67	
*											
UG2 to BF1	0 2.500		354.90 354.9	8 8.27	2E	56.936 0.0 0.0	381.000 56.936 437.936	140 0.0009	29.819 -1.083 0.377	Vel = 2.12	

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
 EE - AUDITORIUM PLATFORM AREA 8 - A100

Page 9
 Date 08-19-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BF1 to BF2	2.500 0		0.0 354.9	8 8.249	1Zai 0.0 0.0	6.000 0.0 6.000	120 0.0012	29.113 12.419 0.007		** Fixed Loss = 11.336 Vel = 2.13	
BF2 to UG4	0 0		0.0 354.9	8 8.27	2E 1T 56.936 55.354	26.000 112.290 0.0 138.290	140 0.0009	41.539 0.0 0.119		Vel = 2.12	
UG4 to TAP	0 0		0.0 354.9	8 8.27	1T 1G 55.354 6.326	321.000 61.680 0.0 382.680	140 0.0009	41.658 0.0 0.329		Vel = 2.12	
TAP to TEST	0 0		0.0 354.9	8 8.27	1Eq 297.332 0.0 297.332	500.000 0.0 297.332 797.332	140 0.0009	41.987 0.0 0.685		Vel = 2.12	
TEST			150.00 504.90					42.672		Qa = 150.00 K Factor = 77.29	



LKC Engineering, PLLC
 140 Aqua Shed Court
 Aberdeen, NC 28315
 PH: (910) 420-1437
 FAX: (910) 637-0096
 License #P-1095

FIRE FLOW TEST RESULTS:

Test Number 3
 Test Date & Time 8/23/20 2:15 PM
 Client _____
 Location Ewrin, NC
 Performed by J Maples Logan Willams
Scottie Scott

Static Pressure	47	psi	Location: <u>S 10th St & Old Post Rd</u>
Residual Pressure	38	psi	Location: _____
Nozzle inside Diameter		inches	(measure nozzle used)
Pitot Tube Pressure	20	psi	Location: <u>S 10th St & E D St</u>
Discharge rate (measured)	750	gpm	Flow Measuring Device: <u>PollardWater Pitot Gauge</u>
Required Residual Pressure	30	psi	(varies - 20psi minimum)

Formula: $Q_R = Q_F \times \left(\frac{H_R}{H_F}\right)^{0.54}$

Q(R) = Rated Capacity (in gpm) at 20 psi residual
 Q(F) = Total test flow (gpm) from at pitot pressure
 H(R) = Static Pressure - Required Pressure (psi)
 H(F) = Static Pressure - Residual Pressure

Q(R) =

750	17	9
Q(F)	H(R)	H(F)

Available Fire Flow Q(R) = **1,057** gpm at 30 psi residual (calculated)

Performed By: Jackson Maples 8/27/2020
 Date
 Certified By: Tim Carpenter 8/27/2020
 Date

Notes:

FIRE HYDRANT FLOW TESTING FIELD FORM

Project: ~~Erwin Elementary~~
 Owner: Erwin Elementary
 Date: 8/26/20

LKC Engineering, PLLC
 140 Aqua Shed Court
 Aberdeen, NC 28315
 (910) 420-1437




Test No.	Time	Gauge Hydrant			Flow Hydrant		
		Hydrant No.	Static Pressure (psi)	Residual Pressure (psi)	Hydrant No.	Pitot Pressure (psi)	Measured Flow (gpm)
1	1:45	2 S	51	96	1 L	30	970
		6 J	48	44			
2		2 S	52	49	5 L	35	1000
		6 J	48	45-46			
3		2 S	52	49	3 L	20	750
		4 J	47	38			

Performed By: LKC Engineering, PLLC

Witnessed By: Jackson / Scottie Scott / Logan

NOTES:



Res

Test 2

FH #5

FH #6

Flow

1-8 PLUG TAPPED 2"
1-2 PLUG
100' OF 20" CASING
BORED UNDER RAILWAY
1-1/2" TAPPING SADDLE
I-15
1-8" X 6" CROSS
3-6" G.V. BOX
1-8" X 6" TEE
1-F.H.

(ABANDON) PLUG
1-2" X 6" TEE
1-6" G.V. BOX
1-F.H.

2-6" X 6" TEE
1-6" G.V. BOX
1-6" X 4" RED
1-6" X 6" BEND
2-4" G.V. BOX
1-F.H.

(ABANDON) PLUG
1-6" X 6" TEE
1-6" G.V. BOX
1-F.H.

2-6" X 6" TEE
1-6" G.V. BOX
1-6" X 4" RED
1-6" X 6" BEND
2-4" G.V. BOX
1-F.H.

1-6" X 6" TEE
1-6" G.V. BOX
1-F.H.

FH #1

1-8" X 6" TEE
1-6" G.V. BOX
1-F.H.

EX. 16" (DUNN) WATER

2-6" X 6" TEE
3-6" G.V. BOX
1-6" X 4" RED
1-6" X 6" BEND
2-4" G.V. BOX
1-F.H.

FH #2

Res
1-8" X 6" TEE
1-6" G.V. BOX
1-F.H.

2-6" X 4" RED.
1-6" X 6" TEE
1-6" G.V. BOX
1-6" X 4" RED
1-6" X 6" BEND
2-4" G.V. BOX
1-F.H.

FH #3

1-8" X 6" CROSS
2-6" G.V. BOX
1-6" X 6" TEE
1-6" G.V. BOX
1-2" PLUG TAP 2"
1-F.H.

1-6" X 6" BEND
1-8" X 6" TEE
1-6" X 6" TEE
2-6" G.V. BOX
1-6" X 6" TEE
1-F.H.

FH #4

1-6" X 6" TEE
1-6" G.V. BOX
1-F.H.

1-8" X 6" TEE
1-6" G.V. BOX
1-F.H.

1-8" X 6" TEE
1-8" X 6" TEE
1-6" G.V. BOX
1-6" X 6" TEE
1-6" X 1/2" BEND
1-F.H.

2-8" X 6" TEE
2-6" G.V. BOX
1-8" G.V. BOX
1-F.H.

1-8" X 6" TEE
1-6" G.V. BOX
1-6" X 6" TEE
1-6" X 6" TEE
1-6" X 6" TEE
1-F.H.

1-8" X 6" TEE
1-6" G.V. BOX
1-F.H.

ROAD

