Building Inspectio	HARNETT ons Department
	Services Temporary
Certificate of Compliance:	Occupancy: x
Certificate issued pursuant to the requirements of North Carolina Ge This certifies at the time of issuance, this structure was in compliand North Carolina State Building Codes. For the following:	
Use Classification: Group E K-5	Permit Numbers
Name:Erwin Elementary School	Building: BCOM2006-0001
£	Electrical: ECOM2006-0004
Address: 405 Denim Drive	Insulation:
	PCOM2006-0001
Erwin, NC 28339	Mechanical: MCOM2006-0002
	icial:
	Plumbing: PCOM2006-0001 Mechanical: MCOM2006-0002

This temporary CO is issued for 90 days for all portions of the building with the exception of the auditorium and gymnasium, which shall be secured from entry by all persons with the exception of construction personnel. It is contingent upon the currently placed mobile generator remaining permanently connected and maintained in a ready manner at all times.