



MIKE CAUSEY
INSURANCE COMMISSIONER & STATE FIRE MARSHAL

BRIAN TAYLOR, CHIEF STATE FIRE MARSHAL
May 29, 2020

Mr. Thomas Hughes
sfl+a Architects
333 Fayetteville Street, Suite 225
Raleigh, NC, 27601

**RE: Erwin Elementary School
Erwin, NC – Harnett County**

Dear Mr. Hughes,

Plans relative to the above referenced project have been reviewed for general compliance with the 2018 North Carolina Building Code with the following comment.

1. When available, provide sprinkler plans, hydraulic calculations and a current water flow test report. Plans and cover sheets of hydraulic calculations must be legibly signed, certified and dated by a NICET Level III fire sprinkler designer or NC Professional Engineer.

Approval is given to issue footing, foundation and shell permits. Final approval is pending resolution of the above listed items.

We will await further information from you concerning this project.

Sincerely,

A handwritten signature in black ink that reads "Travis L. Crabtree".

Travis L. Crabtree
Building and Fire Code Consultant

TC/Imm

CC: Harnett County
School Planning

OFFICE OF STATE FIRE MARSHAL • ENGINEERING

1202 MAIL SERVICE CENTER | RALEIGH, NC 27699-1202 | Tel 919.647.0000 | Fax 919.715.0067