



Fire Marshal Division

August 3, 2020

George M. Rose
P.O. Box 53441
Fayetteville, NC 28305

RE: WH Place Retail and Business Center
NC 210 South at Sandclay Rd.
Bunnlevel, NC

Application Number BCOM2007-0007

To Whom It May Concern,

Thank you for submitting the plans for the new business center and building. The plans have been carefully reviewed by a qualified code enforcement official to examine for full compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Physical Address**
 - The physical address of the building shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
 - The numbers used to make up the physical address shall be at least 6 inches in height.

- **Fire Extinguishers**
 - Fire Extinguishers shall be 2A:10BC and shall be placed with a travel distance to not exceed 75'
 - Fire extinguishers are to be mounted no higher than 5' above the finished floor.

- **Fire Department Access**
 - The fire department access shall extend to within 150 feet of all portions of the facility.



- **Notes**
 - The building plans have been approved as a shell. Any future occupancy deviating or making ANY changes to the floorplan **MUST** re-submit for approval based on the specific occupancy use/type.

Thank you again for submitting the plans for the new building. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent.

These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal