

# GREG BAGLEY ENGINEER

Engineering ♦ Planning ♦ Design

805 Cokesbury Road Fuquay Varina, NC 27526

Phone: 919-609-0300

Email: gdb.greg@gmail.com

12-24-2020

Mike Freeman  
4792 Rawls Church Road  
Fuquay Varina, NC.27526

Ref: Inspection for Fire Wall  
MacVann

Dear Mr. Freeman:

Per your request we have inspected the erection of the required firewall.


The wall was installed per UL W415 and was installed with 4 layers as per UL detail. The proper materials and workmanship were used during construction. The wall meets requirements of the 2018 NCBC.

If you have questions regarding this matter, please do not hesitate to contact this office.

Sincerely,



C. Gregory Bagley, PE  
Greg Bagley Engineer



**DESIGN PROFESSIONAL INSPECTION FORM**RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER**Project Information:**

Residential Single-Family Project: Y N x	Commercial Project: Y x N
Code Enforcement Project No:	Permit No: BCOM2008-0004
Project Name: MACVANN WAREHOUSE	Owner: MIKE FREEMAN
Project Address: 4792 RAWLS CHURCH ROAD, FUQUAY VARINA	Suite No:
Date Inspected: DEC 15TH, 16TH, 22ND, 23RD	Contractor Name: DANIEL VUNCANNON
Component Inspected: EXTERIOR FIREWALL ON SOUTHSIDE OF BUILDING	

**Responsible Licensed NC Architect or NC Engineer**

Name:	C. GREGORY BAGLEY
Firm Name:	GREG BAGLEY ENGINEERING
Phone Numbers:	Office: Mobile: 919-609-0300
Email Address:	GDB.GREG@GMAIL.COM
Mailing Address:	805 COKESBURY ROAD, FUQUAY VARINA, NC 27526

2018 NCBC

**APPLICABLE CODE:**

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

**Describe Element/Component/Type of Inspection: \***


FIREWALL CONSTRUCTED PER UL DESIGN W415.

\*(subgrade form/letter may also be required)

**Attestation/Signature:**

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

  
 \_\_\_\_\_  
 Licensed Architect or Engineer

**Inspection Department disclaimer:**

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.