



**MIKE CAUSEY**  
INSURANCE COMMISSIONER & STATE FIRE MARSHAL

**BRIAN TAYLOR**, CHIEF STATE FIRE MARSHAL

May 13, 2021

Tom Hughes  
sfL+a Architects  
333 Fayetteville St., Suite 225  
Raleigh, NC 27603

**RE: Northwest Harnett Elementary School  
Fuquay Varina, NC - Harnett County**

Dear Mr. Hughes,

Plans relative to the above referenced project have received a review in accordance with the 2018 North Carolina Building Code with the following comments:

1. Please provide the steel shop drawings when available.
2. When available, provide sprinkler plans, hydraulic calculations, and a current water flow test report. Plans and cover sheets of hydraulic calculations are to be legibly signed, certified, and dated by a NICET Level III sprinkler designer.
3. Please provide a written response to the review comments and submit revised signed, sealed plans as necessary.

This project is approved for foundation and shell permits only. We will await further information from you regarding this project.

Sincerely,

A handwritten signature in black ink, appearing to read "Natalia Santiago".

Natalia Santiago, PE  
Code Consultant

NS/Imm

CC: Harnett County  
School Planning

**OFFICE OF STATE FIRE MARSHAL • ENGINEERING**

1202 MAIL SERVICE CENTER | RALEIGH, NC 27699-1202 | Tel 919.647.0000 | Fax 919.715.0067