

## Submittal #21 13 00-3.0 - 211300 - Automatic Sprinkler Systems 21 13 00 - Automatic Sprinkler Systems


<b>Revision</b>	0	<b>Submittal Manager</b>	Marquis Mason (Metcon, Inc.)
<b>Status</b>	Open	<b>Date Created</b>	Jul 28, 2021
<b>Issue Date</b>		<b>Spec Section</b>	21 13 00 - Automatic Sprinkler Systems
<b>Responsible Contractor</b>	ABL Fire Protection	<b>Received From</b>	
<b>Received Date</b>		<b>Submit By</b>	Sep 30, 2021
<b>Final Due Date</b>	May 20, 2022	<b>Lead Time</b>	
		<b>Cost Code</b>	
<b>Location</b>		<b>Type</b>	Calculations
<b>Owner Review</b>			
<b>Approvers</b>	Troy Ganus Jr. (Metcon, Inc.), Marquis Mason (Metcon, Inc.), Scott Drew (Optima Engineering, PA), Drew Landen (Optima Engineering, PA), Tom Hughes (SfL+a Architects), Mahan Kick (SfL+a Architects), Jaclin Wawak (SfL+a Architects), Troy Ganus Jr. (Metcon, Inc.), Marquis Mason (Metcon, Inc.)		
<b>Ball in Court</b>	Troy Ganus Jr. (Metcon, Inc.), Marquis Mason (Metcon, Inc.)		
<b>Distribution</b>	Denis Escobar (Metcon, Inc.)		
<b>Description</b>	<p>D. Submit hydraulic calculations in accordance with the following: 1. Hydraulic calculations shall be prepared on form sheets that include a summary sheet, a graph sheet, a water supply analysis, a node analysis, and detailed worksheets. 2. The data shall be presented in the order shown in Figure 23.3.5.1.2(a) through Figure 23.3.5.1.2(d) of NFPA 13. a. Only the order of information shall be maintained. Standard formats provided by approved calculation software shall be permitted so long as they include all required information listed in each subsequent section. Automatic Sprinkler Systems 21 13 00 - 4 3. The summary sheet shall contain the following information, where applicable: a. Project name and date. b. Location, including street address. c. Drawing number. d. Remote area number. e. Remote area location. f. Occupancy or commodity classification. g. System design requirements, as follows: 1) Design area of water application in square feet. 2) Minimum rate of water application in gpm/sf. 3) Area per sprinkler in square feet. h. Total water requirements as calculated, including allowance for inside hose and outside hydrants in gpm. i. Type of system. j. Water supply information, including the following: 1) Date. 2) Location. 3) Source. 4) Elevation relative to finished floor. k. Name and address of installing contractor. l. Name of designer. m. Authority having jurisdiction. n. Notes that include items such as peaking information for calculations performed by a computer program, limitations (dimension, flow, and pressure) on extended coverage or other listed special sprinklers. 4. A graphic representation of the complete hydraulic calculation shall be plotted on semiexponential graph paper (Q 1.85 ) and shall include the following: a. Water supply curve. b. Sprinkler system demand. c. Hose demand. d. Additional pressures supplied by a fire pump or other source. 5. Information summarized from the graph sheet shall include the following: a. Node tag at the source. b. Static pressure available at the source in psi. c. Residual pressure available at the source in psi. d. Total flow available at the source in gpm. e. Available pressure at the source when the total calculated demand is flowing in psi. Automatic Sprinkler Systems 21 13 00 - 5 f. Total calculated demand at the source in gpm. g. Required pressure when flowing total calculated demand in psi. 6. Organized information regarding the node tags given to each hydraulic reference point on the system as indicated on the shop drawings shall include the following information: a. Node tag for each specific point on the system used in the hydraulic calculations. b. Elevation of each node tag in feet. c. K-factor of flowing nodes. d. Hose allowance requirements for the node tag in gpm. e. Pressure at the node in psi. f. Discharge calculated at the node in gpm. g. Notes that indicate any special requirements for the node. 7. Detailed worksheets shall contain the following information: a. Sheet number. b. Hydraulic reference points used in each step. c. Elevation at each hydraulic reference point in feet. d. Sprinkler description and discharge constant for the flowing reference point. e. Flow for the flowing reference point in gpm. f. Total flow through each step in gpm. g. Nominal pipe size in inches. h. Actual internal diameter of pipe in inches. i. Quantity and length of each type of fitting and device in feet. j. Pipe lengths from center-to-center of fittings in feet. k. Equivalent pipe lengths of fittings and devices for the step in feet. l. Total equivalent length of pipes and fittings for the step in feet. m. C-factor used in each step. n. Friction loss of pipe in psi/ft. o. Sum of the pressures from the previous step (starting pressure at beginning). p. Elevation head between reference points in psi. q. Total friction loss between reference points in psi. r. Required pressure at each reference point in psi. s. Notes and other information shall include the following: 1) Velocity pressure and normal pressure if included in calculations. Automatic Sprinkler Systems 21 13 00 - 6 2) Notes to indicate starting points or reference to other sheets or to clarify data shown. 3) Diagram to</p>		

accompany gridded system calculations to indicate flow quantities and directions for lines with sprinklers operating in the remote area. 4) Combined K-factor calculations for sprinklers on drops, armovers, or sprigs where calculations do not begin at the sprinkler. 5) The pressure loss assigned to the backflow device when included on a system in psi. 6) Friction factor and Reynold's number when the Darcy-Weibach equation is used. 8. Water allowance for outside hose shall be added to the sprinkler and inside hose requirement at the connection to the city water main or a yard hydrant, whichever is closer to the system riser.

**Submittal Workflow**

Name	Sent Date	Due Date	Returned Date	Response	Attachments
General Information Attachments					
Art Lamson		Oct 11, 2021		Pending	
Gail Lamson		Oct 11, 2021	Apr 28, 2022	Submitted	<a href="#">NWHES FP HYDRAULIC CALC.pdf (Current)</a>
Troy Ganus Jr.	May 2, 2022	Apr 29, 2022		Pending	
Marquis Mason	May 2, 2022	Apr 29, 2022	May 2, 2022	Pending	
Scott Drew	Apr 29, 2022	May 20, 2022		Pending	
Drew Landen	Apr 29, 2022	May 20, 2022		Pending	
Tom Hughes		May 20, 2022		Pending	
Mahan Kick		May 20, 2022		Pending	
Jaclin Wawak		May 20, 2022		Pending	
Troy Ganus Jr.		May 20, 2022		Pending	
Marquis Mason		May 20, 2022		Pending	

SHOP DRAWING / SUBMITTAL REVIEW	
<input type="checkbox"/> APPROVED	<input type="checkbox"/> APPROVE WITH CHANGES NOTED
<input type="checkbox"/> REVISE & RESUBMIT	<input type="checkbox"/> REJECTED
<input checked="" type="checkbox"/> REVIEWED	
SUBMITTAL WAS REVIEWED FOR DESIGN CONFORMITY AND GENERAL CONFORMANCE TO CONTRACT DOCUMENTS. ONLY THE SUBCONTRACTOR IS RESPONSIBLE FOR CONFIRMING AND CORRELATING DIMENSIONS AT JOBSITE FOR TOLERANCE, CLEARANCE, QUANTITIES, FABRICATION, PROCESSES AND TECHNIQUES OF CONSTRUCTION. COORDINATION OF HIS/HER WORK WITH OTHER TRADES AND FULL COMPLIANCE WITH CONTRACT DOCUMENTS.	
BY: <u>Marquis Mason</u>	<u>05/02/22</u>
Metcon Construction, Inc. Pembroke, NC 28372	



*Art Johnson*  
*Nicet III*  
*License #20462*  
*5/2/22*

## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-1  
Drawing : FP14  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-1  
Contract : 4070  
Data File : NWHES 01 SYS-1 ZONE1 419 LH EC.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP14  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-1  
**Remote area location** 1ST GRADE 419  
**Occupancy classification** LH  
**Density** 0.10 - Gpm/SqFt  
**Area of application** 1037 - SqFt  
**Coverage/sprinkler** 324 SF MAX - SqFt  
**Type of sprinkler calculated** QR EC PENDENT 1/2" 155F 5.6K  
**# Sprinklers calculated** 8  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 340.085 - GPM @ 45.721 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC

**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**


REDUCE AREA FOR HYDRAULIC CALCULATION PER NFPA13 2013 SECTION 11.2.3.2.3

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-1

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 6.478 D2 - System Flow : 240.085 D2 - System Pressure : 70.790 Hose ( Demand ) : _____ D3 - System Demand : 240.085 Hose ( Adj City ) : 100 Safety Margin : 10.454
--	--	---



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-1

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
PD	See Information on Pump Curve			81.244	240.08	70.79
TEST	58.0	50	756.0	56.175	340.08	56.175

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
1H	12.833	5.6	23.5	27.14	0.1 144
2H	12.833	5.6	23.76	27.3	0.1 120
3H	12.833	5.6	24.54	27.74	0.1 140.81
4H	12.833	5.6	25.35	28.19	0.1 141.757
5H	12.833	5.6	28.6	29.95	0.1 120
6H	11.958	5.6	34.25	32.78	0.1 168
7H	11.958	5.6	34.7	32.99	0.1 306.243
8H	11.958	5.6	36.86	34.0	0.1 246.167
1	13.375		25.42		
2	13.375		25.7		
3	13.375		26.63		
4	13.375		27.51		
5	13.375		30.95		
6	12.5		37.16		
7	12.5		37.64		
8	12.5		39.98		
400	13.375		50.64		
401	12.5		51.72		
402	11.333		57.99		
403B	11.333		61.16		
403T	16.917		59.0		
E3	16.917		59.46		
E2	9.5		63.26		
E1	9.5		63.38		
TOR1	10.0		63.49		
BOR1	2.0		70.47		
PD	2.0		70.79		
PS	2.0		37.25		
FLG	1.0		37.86		
UG1	-3.0		39.63		
UG2	-3.0		39.84		
UG0	-3.0		39.85		
UG3	-3.0		39.89		
BF1	2.0		37.98		
BF2	-3.0		52.68		
UG4	-3.0		52.74		
UG5	-3.0		54.35		
UG6	-3.0		55.69		
UG7	-3.0		55.7		
UG8	-3.0		55.83		
UG9	-3.0		56.04		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-1

Page 5  
Date 4/19/22

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
TEST	-3.0		56.18	100.0	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-1

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	12.833 13.375	5.60	27.14 27.14	1 1.049	2E T	4.0 5.0	0.417 9.000 9.417	120	23.495 -0.235 2.157		Vel = 10.08	
1			0.0 27.14						25.417		K Factor = 5.38	
2H to 2	12.833 13.375	5.60	27.30 27.3	1 1.049	2E T	4.0 5.0	0.417 9.000 9.417	120	23.757 -0.235 2.179		Vel = 10.13	
2			0.0 27.30						25.701		K Factor = 5.39	
3H to 3	12.833 13.375	5.60	27.74 27.74	1 1.049	2E T	4.0 5.0	0.750 9.000 9.750	120	24.543 -0.235 2.324		Vel = 10.30	
3			0.0 27.74						26.632		K Factor = 5.38	
4H to 4	12.833 13.375	5.60	28.19 28.19	1 1.049	2E T	4.0 5.0	0.750 9.000 9.750	120	25.346 -0.235 2.395		Vel = 10.46	
4			0.0 28.19						27.506		K Factor = 5.38	
5H to 5	12.833 13.375	5.60	29.95 29.95	1 1.049	2E T	4.0 5.0	0.417 9.000 9.417	120	28.598 -0.235 2.586		Vel = 11.12	
5			0.0 29.95						30.949		K Factor = 5.38	
6H to 6	11.958 12.500	5.60	32.78 32.78	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120	34.254 -0.235 3.138		Vel = 12.17	
6			0.0 32.78						37.157		K Factor = 5.38	
7H to 7	11.958 12.500	5.60	32.99 32.99	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120	34.700 -0.235 3.175		Vel = 12.25	
7			0.0 32.99						37.640		K Factor = 5.38	
8H to 8	11.958 12.500	5.60	34.00 34.0	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120	36.861 -0.235 3.358		Vel = 12.62	
8			0.0 34.00						39.984		K Factor = 5.38	
1 to 2	13.375 13.375		27.14 27.14	1.5 1.61			10.000 10.000	120	25.417 0.0 0.284		Vel = 4.28	
2 to 3	13.375 13.375		27.30 54.44	1.5 1.61			9.042 9.042	120	25.701 0.0 0.931		Vel = 8.58	
3 to 4	13.375 13.375		27.74 82.18	1.5 1.61			3.958 3.958	120	26.632 0.0 0.874		Vel = 12.95	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-1

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
4 to 5	13.375 13.375		28.20 110.38	1.5 1.61			9.042 9.042	120 0.3808	27.506 0.0 3.443		Vel = 17.40	
5 to 400	13.375 13.375		29.94 140.32	1.5 1.61	T	8.0	25.167 8.000 33.167	120 0.5938	30.949 0.0 19.693		Vel = 22.11	
400			0.0 140.32						50.642		K Factor = 19.72	
6 to 7	12.500 12.500		32.78 32.78	1.5 1.61			12.000 12.000	120 0.0402	37.157 0.0 0.483		Vel = 5.17	
7 to 8	12.500 12.500		32.98 65.76	1.5 1.61			16.042 16.042	120 0.1461	37.640 0.0 2.344		Vel = 10.36	
8 to 401	12.500 12.500		34.00 99.76	1.5 1.61	T	8.0	29.167 8.000 37.167	120 0.3159	39.984 0.0 11.740		Vel = 15.72	
401			0.0 99.76						51.724		K Factor = 13.87	
400 to 401	13.375 12.500		140.32 140.32	2.5 2.635			13.042 13.042	120 0.0539	50.642 0.379 0.703		Vel = 8.26	
401 to 402	12.500 11.333		99.76 240.08	2.5 2.635	2E	16.474	23.083 16.474 39.557	120 0.1456	51.724 0.505 5.759		Vel = 14.12	
402			0.0 240.08						57.988		K Factor = 31.53	
402 to 403B	11.333 11.333		240.08 240.08	4 4.26	E	13.167	212.542 13.167 225.709	120 0.0140	57.988 0.0 3.167		Vel = 5.40	
403B			0.0 240.08						61.155		K Factor = 30.70	
403B to 403T	11.333 16.917		240.08 240.08	4 4.26	E	13.167	5.333 13.167 18.500	120 0.0140	61.155 -2.418 0.259		Vel = 5.40	
403T to E3	16.917 16.917		0.0 240.08	4 4.26	T	26.334	6.750 26.334 33.084	120 0.0141	58.996 0.0 0.465		Vel = 5.40	
E3			0.0 240.08						59.461		K Factor = 31.13	
E3 to E2	16.917 9.500		240.08 240.08	4 4.26	2E	26.334	15.667 26.334 42.001	120 0.0140	59.461 3.212 0.589		Vel = 5.40	
E2 to E1	9.500 9.500		0.0 240.08	4 4.26			8.667 8.667	120 0.0141	63.262 0.0 0.122		Vel = 5.40	
			0.0									

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-1

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
E1			240.08						63.384		K Factor = 30.16	
E1 to TOR1	9.500 10		240.08	4	E	13.167	9.708 13.167 22.875	120	63.384 -0.217 0.321		Vel = 5.40	
TOR1			0.0 240.08						63.488		K Factor = 30.13	
TOR1 to BOR1	10 2		240.08	4	E B Fsp	13.167 15.8 0.0	8.042 28.967 37.009	120	63.488 6.465 0.519		* * Fixed Loss = 3 Vel = 5.40	
BOR1			0.0 240.08						70.472		K Factor = 28.60	
BOR1 to PD	2 2		240.08	6	E 2T B S	17.603 75.44 12.573 40.235	13.292 145.851 159.143	120	70.472 0.0 0.318		Vel = 2.43	
PD			0.0 240.08						70.790		K Factor = 28.53	
System Demand Pressure									70.790			
Safety Margin									10.454			
Continuation Pressure									81.244			
Pressure @ Pump Outlet									81.244			
Pressure From Pump Curve									-43.990			
Pressure @ Pump Inlet									37.254			
PS to FLG	2 1		0.0 240.08	6	2T G	75.44 3.772	5.458 79.212 84.670	120	37.254 0.433 0.169		Vel = 2.43	
FLG			0.0 240.08						37.856		K Factor = 39.02	
FLG to UG1	1 -3		240.08	6	E	20.084	4.000 20.084 24.084	140	37.856 1.732 0.042		Vel = 2.58	
UG1			0.0 240.08						39.630		K Factor = 38.14	
UG1 to UG2	-3 -3		240.08	6	T	43.037	77.000 43.037 120.037	140	39.630 0.0 0.210		Vel = 2.58	
UG2 to UG3	-3 -3		-50.70	8			179.000	140	39.840 0.0 0.049		Vel = 1.13	
UG3			0.0 189.38						39.889		K Factor = 29.99	
UG2 to UG0	-3 -3		50.70	8	V	20.56	261.000 20.560 281.560	140	39.840 0.0 0.007		Vel = 0.30	
UG0 to UG3	-3 -3		0.0	8	10V T	205.602 55.354	1507.000 260.956 1767.956	140	39.847 0.0 0.042		Vel = 0.30	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-1

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG3			0.0 50.70					39.889		K Factor = 8.03	
UG3 to BF1	-3 2		240.08	8	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140	39.889 -2.166		Vel = 1.43
BF1 to BF2	2 -3		0.0 240.08	8	2E	56.936	15.000 56.936 71.936	140	37.984 14.666	** Fixed Loss = 12.5	Vel = 1.43
BF2 to UG4	-3 -3		0.0 240.08	8	V T	20.56 55.354	75.000 75.914 150.914	140	52.679 0.0		Vel = 1.43
UG4			0.0 240.08					52.742		K Factor = 33.06	
UG4 to UG5	-3 -3		240.08	8	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150	52.742 0.0		Vel = 1.43
UG5 to UG6	-3 -3		0.0 240.08	8	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150	54.347 0.0		Vel = 1.43
UG6			0.0 240.08					55.690		K Factor = 32.17	
UG6 to UG7	-3 -3		240.08	12	T	106.533	47.000 106.533 153.533	150	55.690 0.0		Vel = 0.64
UG7			0.0 240.08					55.698		K Factor = 32.17	
UG7 to UG8	-3 -3		240.08	6	E T	22.818 48.896	13.000 71.714 84.714	150	55.698 0.0		Vel = 2.58
UG8			0.0 240.08					55.828		K Factor = 32.13	
UG8 to UG9	-3 -3		240.08	6	T	43.037	77.000 43.037 120.037	140	55.828 0.0		Vel = 2.58
UG9 to TEST	-3 -3		0.0 240.08	12	2V T G E	15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140	56.038 0.0		Vel = 0.64
TEST			100.00 340.08					56.175		Qa = 100.00 K Factor = 45.37	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-2  
Drawing : FP11  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-2  
Contract : 4070  
Data File : NWHES 02 SYS-1 ZONE1 KITCHEN108 OH1.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP11  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-2  
**Remote area location** KITCHEN 108  
**Occupancy classification** OH-1  
**Density** 0.15 - Gpm/SqFt  
**Area of application** 993 - SqFt  
**Coverage/sprinkler** 130 SF MAX - SqFt  
**Type of sprinkler calculated** QR PENDENT 1/2" 155F 5.6K  
**# Sprinklers calculated** 10  
**In-rack demand** N/A - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 477.155 - GPM @ 37.872 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC

**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**


REDUCE AREA FOR HYDRAULIC CALCULATION PER NFPA13 2013 SECTION 11.2.3.2.3

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-2

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 42.302 A2 - Adj Resid : 18.917 @ 500 A3 - Adj Resid : 0 @ 719.14	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 719.14 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.71 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 6.063 D2 - System Flow : 227.155 D2 - System Pressure : 63.356 Hose ( Demand ) : _____ D3 - System Demand : 227.155 Hose ( Adj City ) : 250 Safety Margin : 16.714
--	--	---



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-2

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.



# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-2

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			80.07	227.16	63.356
TEST	58.0	50	756.0	54.585	477.16	54.585

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	11.0	5.6	14.14	21.06	0.15 122.5
2H	11.0	5.6	16.23	22.56	0.15 126.667
3H	11.0	5.6	20.27	25.21	0.15 101.333
4H	11.0	5.6	28.78	30.04	0.15 99
5H	11.0	5.6	10.77	18.38	0.15 122.5
6H	11.0	5.6	11.03	18.6	0.15 122.5
7H	11.0	5.6	12.67	19.93	0.15 109.229
8H	11.0	5.6	15.27	21.88	0.15 80
9H	11.0	5.6	17.65	23.53	0.15 80
10H	11.0	5.6	21.5	25.96	0.15 76
1	12.5		14.88		
2	12.5		17.15		
3	12.5		21.55		
4	12.5		30.8		
5	12.083		11.37		
6	12.083		11.67		
N6	12.5		13.23		
7	12.5		13.3		
8	12.5		16.15		
9	12.5		18.74		
10	12.5		22.95		
F10	12.5		33.13		
F9	12.5		33.3		
F8	12.5		33.65		
F7	10.667		37.71		
F6	10.667		43.32		
F4	9.5		49.81		
E1	9.5		56.06		
TOR1	10.0		56.14		
BOR1	2.0		63.07		
PD	2.0		63.36		
PS	2.0		36.08		
FLG	1.0		36.66		
UG1	-3.0		38.43		
UG2	-3.0		38.62		
UG0	-3.0		38.63		
UG3	-3.0		38.67		
BF1	2.0		36.74		
BF2	-3.0		51.43		
UG4	-3.0		51.49		
UG5	-3.0		52.94		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-2

Page 5  
Date 4/19/22

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG6	-3.0		54.15		
UG7	-3.0		54.15		
UG8	-3.0		54.27		
UG9	-3.0		54.46		
TEST	-3.0		54.59	250.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-2

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	11 12.500	5.60	21.06 21.06	1 1.049	2E T	4.0 5.0	0.708 9.000 9.708	120 0.1432	14.140 -0.650 1.390		Vel = 7.82	
1			0.0 21.06						14.880		K Factor = 5.46	
2H to 2	11 12.500	5.60	22.56 22.56	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120 0.1626	16.225 -0.650 1.572		Vel = 8.37	
2			0.0 22.56						17.147		K Factor = 5.45	
3H to 3	11 12.500	5.60	25.21 25.21	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120 0.1998	20.270 -0.650 1.931		Vel = 9.36	
3			0.0 25.21						21.551		K Factor = 5.43	
4H to 4	11 12.500	5.60	30.04 30.04	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120 0.2764	28.782 -0.650 2.672		Vel = 11.15	
4			0.0 30.04						30.804		K Factor = 5.41	
5H to 5	11 12.083	5.60	18.38 18.38	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120 0.1112	10.767 -0.469 1.075		Vel = 6.82	
5			0.0 18.38						11.373		K Factor = 5.45	
6H to 6	11 12.083	5.60	18.60 18.6	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120 0.1139	11.034 -0.469 1.101		Vel = 6.90	
6			0.0 18.60						11.666		K Factor = 5.45	
7H to 7	11 12.500	5.60	19.93 19.93	1 1.049	2E T	4.0 5.0	0.917 9.000 9.917	120 0.1294	12.670 -0.650 1.283		Vel = 7.40	
7			0.0 19.93						13.303		K Factor = 5.46	
8H to 8	11 12.500	5.60	21.88 21.88	1 1.049	2E T	4.0 5.0	0.917 9.000 9.917	120 0.1538	15.271 -0.650 1.525		Vel = 8.12	
8			0.0 21.88						16.146		K Factor = 5.45	
9H to 9	11 12.500	5.60	23.52 23.52	1 1.049	2E T	4.0 5.0	0.917 9.000 9.917	120 0.1758	17.648 -0.650 1.743		Vel = 8.73	
9			0.0 23.52						18.741		K Factor = 5.43	
10H to 10	11 12.500	5.60	25.96 25.96	1 1.049	2E T	4.0 5.0	0.958 9.000 9.958	120 0.2109	21.498 -0.650 2.100		Vel = 9.64	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-2

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 25.96					22.948		K Factor =	5.42
1 to 2	12.500 12.500		21.06	1	2E 4.0	11.833 4.000	120	14.880 0.0			
			21.06	1.049		15.833	0.1432	2.267		Vel =	7.82
2 to 3	12.500 12.500		22.56	1		8.000	120	17.147 0.0			
			43.62	1.049		8.000	0.5505	4.404		Vel =	16.19
3 to F10	12.500 12.500		25.21	1	T 5.0	4.042 5.000	120	21.551 0.0			
			68.83	1.049		9.042	1.2804	11.577		Vel =	25.55
F10			0.0 68.83					33.128		K Factor =	11.96
4 to F9	12.500 12.500		30.04	1	T 5.0	4.042 5.000	120	30.804 0.0			
			30.04	1.049		9.042	0.2762	2.497		Vel =	11.15
F9			0.0 30.04					33.301		K Factor =	5.21
5 to 6	12.083 12.083		18.38	1.25		10.000	120	11.373 0.0			
			18.38	1.38		10.000	0.0293	0.293		Vel =	3.94
6 to N6	12.083 12.500		18.60	1.25	E T 3.0 6.0	7.375 9.000	120	11.666 -0.181			
			36.98	1.38		16.375	0.1067	1.747		Vel =	7.93
N6			0.0 36.98					13.232		K Factor =	10.17
N6 to 7	12.500 12.500		36.98	1.25		0.667	120	13.232 0.0			
			36.98	1.38		0.667	0.1064	0.071		Vel =	7.93
7 to 8	12.500 12.500		19.93	1.25	T 6.0	6.000 6.000	120	13.303 0.0			
			56.91	1.38		12.000	0.2369	2.843		Vel =	12.21
8 to 9	12.500 12.500		21.88	1.25		6.000	120	16.146 0.0			
			78.79	1.38		6.000	0.4325	2.595		Vel =	16.90
9 to 10	12.500 12.500		23.53	1.25		6.000	120	18.741 0.0			
			102.32	1.38		6.000	0.7012	4.207		Vel =	21.95
10 to F8	12.500 12.500		25.96	1.25	T 6.0	4.042 6.000	120	22.948 0.0			
			128.28	1.38		10.042	1.0655	10.700		Vel =	27.52
F8			0.0 128.28					33.648		K Factor =	22.11
F10 to F9	12.500 12.500		68.83	2.5		12.000	120	33.128 0.0			
			68.83	2.635		12.000	0.0144	0.173		Vel =	4.05
F9 to F8	12.500 12.500		30.04	2.5		12.292	120	33.301 0.0			
			98.87	2.635		12.292	0.0282	0.347		Vel =	5.82

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-2

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
F8 to F7	12.500 10.667		128.29 227.16	2.5 2.635	2E	16.474	8.375 16.474 24.849	120 0.1314	33.648 0.794 3.266		Vel = 13.36	
F7 to F6	10.667 10.667		0.0 227.16	2.5 2.635	T	16.474	26.208 16.474 42.682	120 0.1314	37.708 0.0 5.609		Vel = 13.36	
F6 to F4	10.667 9.500		0.0 227.16	2.5 2.635	3E	24.711	20.833 24.711 45.544	120 0.1314	43.317 0.505 5.985		Vel = 13.36	
F4 to E1	9.500 9.500		0.0 227.16	2.5 2.635	T	16.474	31.125 16.474 47.599	120 0.1314	49.807 0.0 6.256		Vel = 13.36	
E1			0.0 227.16						56.063		K Factor = 30.34	
E1 to TOR1	9.500 10		227.16 227.16	4 4.26	E	13.167	9.708 13.167 22.875	120 0.0127	56.063 -0.217 0.290		Vel = 5.11	
TOR1			0.0 227.16						56.136		K Factor = 30.32	
TOR1 to BOR1	10 2		227.16 227.16	4 4.26	E B Fsp	13.167 15.8 0.0	8.042 28.967 37.009	120 0.0126	56.136 6.465 0.468		* * Fixed Loss = 3 Vel = 5.11	
BOR1			0.0 227.16						63.069		K Factor = 28.60	
BOR1 to PD	2 2		227.16 227.16	6 6.357	E 2T B S	17.603 75.44 12.573 40.235	13.292 145.851 159.143	120 0.0018	63.069 0.0 0.287		Vel = 2.30	
PD			0.0 227.16						63.356		K Factor = 28.54	
System Demand Pressure									63.356			
Safety Margin									16.714			
Continuation Pressure									80.070			
Pressure @ Pump Outlet									80.070			
Pressure From Pump Curve									-43.991			
Pressure @ Pump Inlet									36.079			
PS to FLG	2 1		0.0 227.16	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0018	36.079 0.433 0.152		Vel = 2.30	
FLG			0.0 227.16						36.664		K Factor = 37.52	
FLG to UG1	1 -3		227.16 227.16	6 6.16	E	20.084	4.000 20.084 24.084	140 0.0016	36.664 1.732 0.039		Vel = 2.45	
UG1			0.0 227.16						38.435		K Factor = 36.64	
UG1 to UG2	-3 -3		227.16 227.16	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0016	38.435 0.0 0.189		Vel = 2.45	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-2

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG2 to UG3	-3 -3		-47.98 179.18	8 8.27			179.000 179.000	140 0.0002	38.624 0.0 0.044			Vel = 1.07
UG3			0.0 179.18						38.668			K Factor = 28.81
UG2 to UG0	-3 -3		47.97 47.97	8 8.27	V	20.56	261.000 20.560 281.560	140 0	38.624 0.0 0.006			Vel = 0.29
UG0 to UG3	-3 -3		0.0 47.97	8 8.27	10V T	205.602 55.354	1507.000 260.956 1767.956	140 0	38.630 0.0 0.038			Vel = 0.29
UG3			0.0 47.97						38.668			K Factor = 7.71
UG3 to BF1	-3 2		227.16 227.16	8 8.27	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140 0.0004	38.668 -2.166 0.236			Vel = 1.36
BF1 to BF2	2 -3		0.0 227.16	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0004	36.738 14.666 0.026			* * Fixed Loss = 12.5 Vel = 1.36
BF2 to UG4	-3 -3		0.0 227.16	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0004	51.430 0.0 0.057			Vel = 1.36
UG4			0.0 227.16						51.487			K Factor = 31.66
UG4 to UG5	-3 -3		227.16 227.16	8 8.27	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150 0.0003	51.487 0.0 1.449			Vel = 1.36
UG5 to UG6	-3 -3		0.0 227.16	8 8.27	8V E T	186.874 32.344 62.89	3360.000 296.483 3656.483	150 0.0003	52.936 0.0 1.212			Vel = 1.36
UG6			0.0 227.16		2G	14.375			54.148			K Factor = 30.87
UG6 to UG7	-3 -3		227.16 227.16	12 12.34	T	106.533	47.000 106.533 153.533	150 0	54.148 0.0 0.007			Vel = 0.61
UG7			0.0 227.16						54.155			K Factor = 30.87
UG7 to UG8	-3 -3		227.16 227.16	6 6.16	E T	22.818 48.896	13.000 71.714 84.714	150 0.0014	54.155 0.0 0.118			Vel = 2.45
UG8			0.0 227.16						54.273			K Factor = 30.83
UG8 to UG9	-3 -3		227.16 227.16	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0016	54.273 0.0 0.189			Vel = 2.45
UG9 to TEST	-3 -3		0.0 227.16	12 12.34	2V T G	15.94 93.767 9.377	2136.000 161.279 2297.279	140 0.0001	54.462 0.0 0.124			Vel = 0.61

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
 NWHES AREA-2

Page 10  
 Date 4/19/22

Node1	Elev1	K	Qa	Nom	Fitting		Pipe	CFact	Pt			
to					or		Ftngs		Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			
					E	42.195						
			250.00							Qa = 250.00		
TEST			477.16						54.586	K Factor = 64.58		



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-3  
Drawing : FP11  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-3  
Contract : 4070  
Data File : NWHES 03 SYS-1 ZONE1 DINING101 LH.WXF



---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP11  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-3  
**Remote area location** DINING 101  
**Occupancy classification** LH  
**Density** 0.1 - Gpm/SqFt  
**Area of application** 1597 - SqFt  
**Coverage/sprinkler** 225 SF MAX - SqFt  
**Type of sprinkler calculated** QR UPRIGHT 1/2" 155F 5.6K  
**# Sprinklers calculated** 11  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 283.656 - GPM @ 26.831 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES


**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC  
**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL  
**NOTES:**

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-3

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 14.274 D2 - System Flow : 183.656 D2 - System Pressure : 53.567 Hose ( Demand ) : _____ D3 - System Demand : 183.656 Hose ( Adj City ) : 100 Safety Margin : 29.865
--	--	--



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-3

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                 Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-3

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			83.432	183.66	53.567
TEST	58.0	50	756.0	56.695	283.66	56.695

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	22.604	5.6	7.74	15.58	0.1 138.715
2H	22.604	5.6	8.0	15.84	0.1 138.715
3H	22.604	5.6	8.97	16.78	0.1 138.715
4H	22.604	5.6	11.12	18.67	0.1 138.715
5H	24.854	5.6	7.03	14.85	0.1 138.715
6H	24.854	5.6	7.29	15.12	0.1 138.715
7H	24.854	5.6	8.24	16.08	0.1 138.715
8H	24.854	5.6	10.35	18.02	0.1 138.715
9H	29.958	5.6	9.22	17.0	0.1 170
10H	29.958	5.6	9.56	17.31	0.1 170
11H	29.958	5.6	10.8	18.4	0.1 170
1	21.729		9.39		
2	21.729		9.69		
3	21.729		10.81		
4	21.729		13.28		
F14	12.5		24.74		
5	22.938		8.45		
6	22.938		8.73		
7	22.938		9.76		
8	22.938		12.02		
F12	12.5		25.82		
F13	12.5		32.08		
F11	12.5		32.18		
F7	10.667		35.82		
9	29.042		10.18		
10	29.042		10.54		
11	29.042		11.86		
G3	29.042		17.44		
G2	21.333		32.87		
G1	10.667		37.74		
F6	10.667		37.85		
F4	9.5		42.39		
E1	9.5		46.61		
TOR1	10.0		46.59		
BOR1	2.0		53.37		
PD	2.0		53.57		
PS	2.0		39.44		
FLG	1.0		39.97		
UG1	-3.0		41.73		
UG2	-3.0		41.86		
UG0	-3.0		41.86		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-3

Page 5  
Date 4/19/22

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG3	-3.0		41.89		
BF1	2.0		39.88		
BF2	-3.0		54.57		
UG4	-3.0		54.6		
UG5	-3.0		55.58		
UG6	-3.0		56.4		
UG7	-3.0		56.4		
UG8	-3.0		56.48		
UG9	-3.0		56.61		
TEST	-3.0		56.69	100.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-3

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	22.604 21.729	5.60	15.58 15.58	1 1.049	T 5.0	10.500 5.000 15.500	120 0.0819	7.737 0.379 1.270		Vel = 5.78	
1			0.0 15.58					9.386		K Factor = 5.09	
2H to 2	22.604 21.729	5.60	15.84 15.84	1 1.049	T 5.0	10.500 5.000 15.500	120 0.0845	8.002 0.379 1.310		Vel = 5.88	
2			0.0 15.84					9.691		K Factor = 5.09	
3H to 3	22.604 21.729	5.60	16.77 16.77	1 1.049	T 5.0	10.500 5.000 15.500	120 0.0940	8.974 0.379 1.457		Vel = 6.23	
3			0.0 16.77					10.810		K Factor = 5.10	
4H to 4	22.604 21.729	5.60	18.68 18.68	1 1.049	T 5.0	10.500 5.000 15.500	120 0.1146	11.121 0.379 1.777		Vel = 6.93	
4			0.0 18.68					13.277		K Factor = 5.13	
5H to 5	24.854 22.938	5.60	14.85 14.85	1 1.049	T 5.0	2.833 5.000 7.833	120 0.0751	7.033 0.830 0.588		Vel = 5.51	
5			0.0 14.85					8.451		K Factor = 5.11	
6H to 6	24.854 22.938	5.60	15.12 15.12	1 1.049	T 5.0	2.833 5.000 7.833	120 0.0775	7.293 0.830 0.607		Vel = 5.61	
6			0.0 15.12					8.730		K Factor = 5.12	
7H to 7	24.854 22.938	5.60	16.08 16.08	1 1.049	T 5.0	2.833 5.000 7.833	120 0.0868	8.245 0.830 0.680		Vel = 5.97	
7			0.0 16.08					9.755		K Factor = 5.15	
8H to 8	24.854 22.938	5.60	18.02 18.02	1 1.049	T 5.0	2.833 5.000 7.833	120 0.1072	10.354 0.830 0.840		Vel = 6.69	
8			0.0 18.02					12.024		K Factor = 5.20	
9H to 9	29.958 29.042	5.60	17.00 17.0	1 1.049	T 5.0	0.917 5.000 5.917	120 0.0962	9.216 0.397 0.569		Vel = 6.31	
9			0.0 17.00					10.182		K Factor = 5.33	
10H to 10	29.958 29.042	5.60	17.31 17.31	1 1.049	T 5.0	0.917 5.000 5.917	120 0.0995	9.555 0.397 0.589		Vel = 6.43	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-3

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10			0.0 17.31						10.541		K Factor = 5.33	
11H to 11	29.958 29.042	5.60	18.40 18.4	1 1.049	T	5.0	0.917 5.000 5.917	120 0.1115	10.800 0.397 0.660		Vel = 6.83	
11			0.0 18.40						11.857		K Factor = 5.34	
1 to 2	21.729 21.729		15.58 15.58	1.25 1.38			14.167 14.167	120 0.0215	9.386 0.0 0.305		Vel = 3.34	
2 to 3	21.729 21.729		15.84 31.42	1.25 1.38			14.167 14.167	120 0.0790	9.691 0.0 1.119		Vel = 6.74	
3 to 4	21.729 21.729		16.77 48.19	1.25 1.38			14.167 14.167	120 0.1741	10.810 0.0 2.467		Vel = 10.34	
4 to F14	21.729 12.500		18.68 66.87	1.25 1.38	2E	6.0	17.375 6.000 23.375	120 0.3192	13.277 3.997 7.462		Vel = 14.34	
F14 to F13	12.500 12.500		0.0 66.87	1.25 1.38	T	6.0	17.000 6.000 23.000	120 0.3192	24.736 0.0 7.342		Vel = 14.34	
F13			0.0 66.87						32.078		K Factor = 11.81	
5 to 6	22.938 22.938		14.85 14.85	1.25 1.38			14.167 14.167	120 0.0197	8.451 0.0 0.279		Vel = 3.19	
6 to 7	22.938 22.938		15.12 29.97	1.25 1.38			14.167 14.167	120 0.0724	8.730 0.0 1.025		Vel = 6.43	
7 to 8	22.938 22.938		16.08 46.05	1.25 1.38			14.167 14.167	120 0.1602	9.755 0.0 2.269		Vel = 9.88	
8 to F12	22.938 12.500		18.02 64.07	1.25 1.38	3E	9.0	22.458 9.000 31.458	120 0.2950	12.024 4.521 9.279		Vel = 13.74	
F12 to F11	12.500 12.500		0.0 64.07	1.25 1.38	T	6.0	15.542 6.000 21.542	120 0.2950	25.824 0.0 6.355		Vel = 13.74	
F11			0.0 64.07						32.179		K Factor = 11.29	
F13 to F11	12.500 12.500		66.87 66.87	2.5 2.635			7.333 7.333	120 0.0138	32.078 0.0 0.101		Vel = 3.93	
F11 to F7	12.500 10.667		64.07 130.94	2.5 2.635	2E	16.474	43.625 16.474 60.099	120 0.0474	32.179 0.794 2.850		Vel = 7.70	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-3

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
F7 to F6	10.667 10.667		0.0 130.94	2.5 2.635	T	16.474	26.208 16.474 42.682	120 0.0474	35.823 0.0 2.024		Vel = 7.70	
F6			0.0 130.94						37.847		K Factor = 21.28	
9 to 10	29.042 29.042		17.00 17.0	1.25 1.38			14.167 14.167	120 0.0253	10.182 0.0 0.359		Vel = 3.65	
10 to 11	29.042 29.042		17.31 34.31	1.25 1.38			14.167 14.167	120 0.0929	10.541 0.0 1.316		Vel = 7.36	
11 to G3	29.042 29.042		18.40 52.71	1.25 1.38	E	3.0	24.167 3.000 27.167	120 0.2056	11.857 0.0 5.586		Vel = 11.31	
G3			0.0 52.71						17.443		K Factor = 12.62	
G3 to G2	29.042 21.333		52.71 52.71	1.25 1.38	T	6.0	52.792 6.000 58.792	120 0.2056	17.443 3.339 12.087		Vel = 11.31	
G2			0.0 52.71						32.869		K Factor = 9.19	
G2 to G1	21.333 10.667		52.71 52.71	2.5 2.635	2E	16.474	12.667 16.474 29.141	120 0.0088	32.869 4.619 0.257		Vel = 3.10	
G1 to F6	10.667 10.667		0.0 52.71	2.5 2.635			11.625 11.625	120 0.0088	37.745 0.0 0.102		Vel = 3.10	
F6			0.0 52.71						37.847		K Factor = 8.57	
F6 to F4	10.667 9.500		183.66 183.66	2.5 2.635	3E	24.711	20.833 24.711 45.544	120 0.0887	37.847 0.505 4.040		Vel = 10.81	
F4 to E1	9.500 9.500		0.0 183.66	2.5 2.635	T	16.474	31.125 16.474 47.599	120 0.0887	42.392 0.0 4.221		Vel = 10.81	
E1			0.0 183.66						46.613		K Factor = 26.90	
E1 to TOR1	9.500 10		183.66 183.66	4 4.26	E	13.167	9.708 13.167 22.875	120 0.0086	46.613 -0.217 0.196		Vel = 4.13	
TOR1			0.0 183.66						46.592		K Factor = 26.91	
TOR1 to BOR1	10 2		183.66 183.66	4 4.26	E B Fsp	13.167 15.8 0.0	8.042 28.967 37.009	120 0.0085	46.592 6.465 0.316		** Fixed Loss = 3 Vel = 4.13	
BOR1			0.0 183.66						53.373		K Factor = 25.14	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-3

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BOR1 to PD	2 2		183.66 183.66	6 6.357	E 2T B S	17.603 75.44 12.573 40.235	13.292 145.851 159.143	120 0.0012	53.373 0.0 0.194		Vel = 1.86	
PD			0.0 183.66						53.567		K Factor = 25.09	
System Demand Pressure									53.567			
Safety Margin									29.865			
Continuation Pressure									83.432			
Pressure @ Pump Outlet									83.432			
Pressure From Pump Curve									-43.994			
Pressure @ Pump Inlet									39.438			
PS to FLG	2 1		0.0 183.66	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0012	39.438 0.433 0.103		Vel = 1.86	
FLG			0.0 183.66						39.974		K Factor = 29.05	
FLG to UG1	1 -3		183.66 183.66	6 6.16	E	20.084	4.000 20.084 24.084	140 0.0011	39.974 1.732 0.026		Vel = 1.98	
UG1			0.0 183.66						41.732		K Factor = 28.43	
UG1 to UG2	-3 -3		183.66 183.66	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0011	41.732 0.0 0.128		Vel = 1.98	
UG2 to UG3	-3 -3		-38.79 144.87	8 8.27			179.000 179.000	140 0.0002	41.860 0.0 0.029		Vel = 0.87	
UG3			0.0 144.87						41.889		K Factor = 22.38	
UG2 to UG0	-3 -3		38.78 38.78	8 8.27	V	20.56	261.000 20.560 281.560	140 0	41.860 0.0 0.004		Vel = 0.23	
UG0 to UG3	-3 -3		0.0 38.78	8 8.27	10V T	205.602 55.354	1507.000 260.956 1767.956	140 0	41.864 0.0 0.025		Vel = 0.23	
UG3			0.0 38.78						41.889		K Factor = 5.99	
UG3 to BF1	-3 2		183.66 183.66	8 8.27	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140 0.0003	41.889 -2.166 0.160		Vel = 1.10	
BF1 to BF2	2 -3		0.0 183.66	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0002	39.883 14.666 0.017		** Fixed Loss = 12.5 Vel = 1.10	
BF2 to UG4	-3 -3		0.0 183.66	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0003	54.566 0.0 0.039		Vel = 1.10	
UG4			0.0									

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-3

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG4			183.66					54.605		K Factor = 24.85	
UG4 to UG5	-3 -3		183.66	8	4G 8V	28.75 186.874	4156.000 215.624	150	54.605 0.0		
			183.66	8.27		4371.624		0.0002	0.977	Vel = 1.10	
UG5 to UG6	-3 -3		0.0	8	8V E	186.874 32.344	3360.000 296.483	150	55.582 0.0		
			183.66	8.27	T 2G	62.89 14.375	3656.483	0.0002	0.818	Vel = 1.10	
UG6			0.0 183.66						56.400	K Factor = 24.46	
UG6 to UG7	-3 -3		183.66	12	T	106.533	47.000 106.533	150	56.400 0.0		
			183.66	12.34		153.533		0	0.005	Vel = 0.49	
UG7			0.0 183.66						56.405	K Factor = 24.45	
UG7 to UG8	-3 -3		183.66	6	E T	22.818 48.896	13.000 71.714	150	56.405 0.0		
			183.66	6.16		84.714		0.0009	0.079	Vel = 1.98	
UG8			0.0 183.66						56.484	K Factor = 24.44	
UG8 to UG9	-3 -3		183.66	6	T	43.037	77.000 43.037	140	56.484 0.0		
			183.66	6.16		120.037		0.0011	0.128	Vel = 1.98	
UG9 to TEST	-3 -3		0.0	12	2V T	15.94 93.767	2136.000 161.279	140	56.612 0.0		
			183.66	12.34	G E	9.377 42.195	2297.279	0	0.083	Vel = 0.49	
TEST			100.00 283.66						56.695	Qa = 100.00 K Factor = 37.67	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-4  
Drawing : FP12  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-4  
Contract : 4070  
Data File : NWHES 04 SYS-1 ZONE1 MECH ABV 227 OH1.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP12  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-4  
**Remote area location** MECH PLATFORM ABOVE TEACHER LOUGNE 227  
**Occupancy classification** OH-1  
**Density** 0.15 - Gpm/SqFt  
**Area of application** WHOLE ROOM - SqFt  
**Coverage/sprinkler** 130 SF MAX - SqFt  
**Type of sprinkler calculated** QR UPRIGHT 1/2" 155F 5.6K  
**# Sprinklers calculated** 11  
**In-rack demand** N/A - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 483.17 - GPM @ 49.229 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO**

ABL FIRE PROTECTION, LLC  
**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL


**NOTES:**

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-4

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 42.302 A2 - Adj Resid : 18.917 @ 500 A3 - Adj Resid : 0 @ 719.14	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 719.14 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.71 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 9.420 D2 - System Flow : 233.17 D2 - System Pressure : 74.523 Hose ( Demand ) : _____ D3 - System Demand : 233.17 Hose ( Adj City ) : 250 Safety Margin : 5.276
--	--	--



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-4

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-4

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			79.799	233.17	74.523
TEST	58.0	50	756.0	54.505	483.17	54.505

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	18.75	5.6	10.69	18.31	0.15 122.08
2H	18.75	5.6	10.96	18.54	0.15 112.08
3H	18.75	5.6	11.96	19.37	0.15 112.08
4H	18.75	5.6	10.49	18.14	0.15 80.56
5H	18.75	5.6	11.15	18.7	0.15 102.08
6H	18.75	5.6	15.82	22.28	0.15 122.08
7H	18.75	5.6	16.76	22.93	0.15 112.08
8H	18.75	5.6	18.23	23.91	0.15 112.08
9H	18.75	5.6	12.22	19.58	0.15 72.83
10H	18.75	5.6	12.52	19.82	0.15 72.83
11H	18.75	5.6	31.86	31.61	0.15 97.4
1	18.25		11.56		
2	18.25		11.85		
3	18.25		12.91		
4	17.75		11.57		
5	17.75		12.27		
6	20.0		16.22		
7	17.75		18.2		
8	17.75		19.74		
9	19.75		12.54		
10	19.75		12.86		
152T	19.75		13.82		
152B	17.75		16.51		
150	17.75		17.38		
151	17.75		22.57		
153	17.75		23.12		
11	17.75		36.47		
154	17.75		43.74		
155	10.583		63.81		
E5	11.25		64.06		
E4	16.917		63.1		
E3	16.917		63.29		
E2	9.5		67.06		
E1	9.5		67.18		
TOR1	10.0		67.26		
BOR1	2.0		74.22		
PD	2.0		74.52		
PS	2.0		35.81		
FLG	1.0		36.4		
UG1	-3.0		38.17		
UG2	-3.0		38.37		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-4

Page 5  
Date 4/19/22

---

## NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG0	-3.0		38.38		
UG3	-3.0		38.42		
BF1	2.0		36.5		
BF2	-3.0		51.19		
UG4	-3.0		51.25		
UG5	-3.0		52.77		
UG6	-3.0		54.05		
UG7	-3.0		54.05		
UG8	-3.0		54.18		
UG9	-3.0		54.38		
TEST	-3.0		54.5	250.0	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-4

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	18.750 18.250	5.60	18.31 18.31	1 1.049	2E 4.0	1.917 4.000 5.917	120	10.693 0.217 0.654		Vel = 6.80	
1			0.0 18.31					11.564		K Factor = 5.38	
2H to 2	18.750 18.250	5.60	18.54 18.54	1 1.049	T 5.0	1.000 5.000 6.000	120	10.959 0.217 0.678		Vel = 6.88	
2			0.0 18.54					11.854		K Factor = 5.38	
3H to 3	18.750 18.250	5.60	19.37 19.37	1 1.049	T 5.0	1.000 5.000 6.000	120	11.962 0.217 0.735		Vel = 7.19	
3			0.0 19.37					12.914		K Factor = 5.39	
4H to 4	18.750 17.750	5.60	18.14 18.14	1 1.049	T 5.0	1.000 5.000 6.000	120	10.488 0.433 0.652		Vel = 6.73	
4			0.0 18.14					11.573		K Factor = 5.33	
5H to 5	18.750 17.750	5.60	18.70 18.7	1 1.049	T 5.0	1.000 5.000 6.000	120	11.152 0.433 0.689		Vel = 6.94	
5			0.0 18.70					12.274		K Factor = 5.34	
6H to 6	18.750 20	5.60	22.28 22.28	1 1.049	2E 4.0	1.917 4.000 5.917	120	15.825 -0.541 0.940		Vel = 8.27	
6			0.0 22.28					16.224		K Factor = 5.53	
7H to 7	18.750 17.750	5.60	22.92 22.92	1 1.049	T 5.0	1.000 5.000 6.000	120	16.759 0.433 1.006		Vel = 8.51	
7			0.0 22.92					18.198		K Factor = 5.37	
8H to 8	18.750 17.750	5.60	23.91 23.91	1 1.049	T 5.0	1.000 5.000 6.000	120	18.225 0.433 1.087		Vel = 8.88	
8			0.0 23.91					19.745		K Factor = 5.38	
9H to 9	18.750 19.750	5.60	19.58 19.58	1 1.049	T 5.0	1.000 5.000 6.000	120	12.223 -0.433 0.750		Vel = 7.27	
9			0.0 19.58					12.540		K Factor = 5.53	
10H to 10	18.750 19.750	5.60	19.82 19.82	1 1.049	T 5.0	1.000 5.000 6.000	120	12.523 -0.433 0.768		Vel = 7.36	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-4

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10			0.0 19.82					12.858		K Factor = 5.53	
11H to 11	18.750 17.750	5.60	31.61	1 1.049	2E T 4.0 5.0	4.750 9.000 13.750	120 0.3035	31.859 0.433 4.173		Vel = 11.73	
11			0.0 31.61					36.465		K Factor = 5.23	
1 to 2	18.250 18.250		18.31	1.25 1.38		10.000 10.000	120 0.0290	11.564 0.0 0.290		Vel = 3.93	
2 to 3	18.250 18.250		18.54	1.25 1.38		10.000 10.000	120 0.1060	11.854 0.0 1.060		Vel = 7.90	
3 to 150	18.250 17.750		19.37	1.25 1.38	3E T 9.0 6.0	3.333 15.000 18.333	120 0.2316	12.914 0.217 4.246		Vel = 12.06	
150			0.0 56.22					17.377		K Factor = 13.49	
4 to 5	17.750 17.750		18.14	1 1.049		6.458 6.458	120 0.1085	11.573 0.0 0.701		Vel = 6.73	
5 to 150	17.750 17.750		18.70	1 1.049	T 5.0	7.667 5.000 12.667	120 0.4029	12.274 0.0 5.103		Vel = 13.68	
150			0.0 36.84					17.377		K Factor = 8.84	
6 to 7	20 17.750		22.28	1.25 1.38	3E 9.0	14.917 9.000 23.917	120 0.0418	16.224 0.974 1.000		Vel = 4.78	
7 to 8	17.750 17.750		22.92	1.25 1.38		10.000 10.000	120 0.1547	18.198 0.0 1.547		Vel = 9.70	
8 to 151	17.750 17.750		23.91	1.25 1.38	T 6.0	2.333 6.000 8.333	120 0.3393	19.745 0.0 2.827		Vel = 14.82	
151			0.0 69.11					22.572		K Factor = 14.55	
9 to 152T	19.750 19.750		19.58	1 1.049	T 5.0	5.208 5.000 10.208	120 0.1252	12.540 0.0 1.278		Vel = 7.27	
152T			0.0 19.58					13.818		K Factor = 5.27	
10 to 152T	19.750 19.750		19.82	1 1.049	T 5.0	2.500 5.000 7.500	120 0.1280	12.858 0.0 0.960		Vel = 7.36	
152T to 152B	19.750 17.750		19.58	1 1.049	E 2.0	2.000 2.000 4.000	120 0.4560	13.818 0.866 1.824		Vel = 14.63	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-4

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
152B to 153	17.750 17.750		0.0 39.4	1 1.049	T	5.0	9.500 5.000 14.500	120 0.4561	16.508 0.0 6.614		Vel = 14.63	
153			0.0 39.40						23.122		K Factor = 8.19	
150 to 151	17.750 17.750		93.06 93.06	1.5 1.61	T	8.0	10.708 8.000 18.708	120 0.2777	17.377 0.0 5.195		Vel = 14.67	
151 to 153	17.750 17.750		69.11 162.17	1.5 1.61			0.708 0.708	120 0.7768	22.572 0.0 0.550		Vel = 25.56	
153 to 11	17.750 17.750		39.39 201.56	1.5 1.61	E	4.0	7.500 4.000 11.500	120 1.1603	23.122 0.0 13.343		Vel = 31.76	
11 to 154	17.750 17.750		31.61 233.17	1.5 1.61	E	4.0	0.792 4.000 4.792	120 1.5192	36.465 0.0 7.280		Vel = 36.75	
154			0.0 233.17						43.745		K Factor = 35.25	
154 to 155	17.750 10.583		233.17 233.17	1.5 1.61	E	4.0	7.167 4.000 11.167	120 1.5191	43.745 3.104 16.964		Vel = 36.75	
155			0.0 233.17						63.813		K Factor = 29.19	
155 to E5	10.583 11.250		233.17 233.17	4 4.26	2E	26.334	14.042 26.334 40.376	120 0.0133	63.813 -0.289 0.537		Vel = 5.25	
E5 to E4	11.250 16.917		0.0 233.17	4 4.26	2E	26.334	86.333 26.334 112.667	120 0.0133	64.061 -2.454 1.497		Vel = 5.25	
E4 to E3	16.917 16.917		0.0 233.17	4 4.26			14.125 14.125	120 0.0133	63.104 0.0 0.188		Vel = 5.25	
E3			0.0 233.17						63.292		K Factor = 29.31	
E3 to E2	16.917 9.500		233.17 233.17	4 4.26	2E	26.334	15.667 26.334 42.001	120 0.0133	63.292 3.212 0.559		Vel = 5.25	
E2 to E1	9.500 9.500		0.0 233.17	4 4.26			8.667 8.667	120 0.0133	67.063 0.0 0.115		Vel = 5.25	
E1			0.0 233.17						67.178		K Factor = 28.45	
E1 to TOR1	9.500 10		233.17 233.17	4 4.26	E	13.167	9.708 13.167 22.875	120 0.0133	67.178 -0.217 0.304		Vel = 5.25	
			0.0									

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-4

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
TOR1			233.17						67.265		K Factor = 28.43	
TOR1 to BOR1	10 2		233.17	4	E B Fsp	13.167 15.8 0.0	8.042 28.967 37.009	120 0.0133	67.265 6.465 0.492		** Fixed Loss = 3 Vel = 5.25	
BOR1			0.0 233.17						74.222		K Factor = 27.06	
BOR1 to PD	2 2		233.17	6	E 2T B S	17.603 75.44 12.573 40.235	13.292 145.851 159.143	120 0.0019	74.222 0.0 0.301		Vel = 2.36	
PD			0.0 233.17						74.523		K Factor = 27.01	
System Demand Pressure									74.523			
Safety Margin									5.276			
Continuation Pressure									79.799			
Pressure @ Pump Outlet									79.799			
Pressure From Pump Curve									-43.991			
Pressure @ Pump Inlet									35.808			
PS to FLG	2 1		0.0 233.17	6	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0019	35.808 0.433 0.161		Vel = 2.36	
FLG			0.0 233.17						36.402		K Factor = 38.65	
FLG to UG1	1 -3		233.17	6	E	20.084	4.000 20.084 24.084	140 0.0017	36.402 1.732 0.040		Vel = 2.51	
UG1			0.0 233.17						38.174		K Factor = 37.74	
UG1 to UG2	-3 -3		233.17	6	T	43.037	77.000 43.037 120.037	140 0.0017	38.174 0.0 0.199		Vel = 2.51	
UG2 to UG3	-3 -3		-49.24	8			179.000	140	38.373 0.0		Vel = 1.10	
UG3			0.0 183.93						0.045		K Factor = 29.67	
UG2 to UG0	-3 -3		49.24	8	V	20.56	261.000 20.560 281.560	140 0	38.373 0.0 0.006		Vel = 0.29	
UG0 to UG3	-3 -3		0.0	8	10V T	205.602 55.354	1507.000 260.956 1767.956	140 0	38.379 0.0 0.039		Vel = 0.29	
UG3			0.0 49.24						38.418		K Factor = 7.94	
UG3 to BF1	-3 2		233.17	8	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140 0.0004	38.418 -2.166 0.248		Vel = 1.39	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-4

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BF1 to BF2	2 -3		0.0 233.17	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0004	36.500 14.666 0.028		** Fixed Loss = 12.5 Vel = 1.39	
BF2 to UG4	-3 -3		0.0 233.17	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0004	51.194 0.0 0.060		Vel = 1.39	
UG4			0.0 233.17						51.254		K Factor = 32.57	
UG4 to UG5	-3 -3		233.17 233.17	8 8.27	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150 0.0003	51.254 0.0 1.520		Vel = 1.39	
UG5 to UG6	-3 -3		0.0 233.17	8 8.27	8V E T	186.874 32.344 62.89	3360.000 296.483 3656.483	150 0.0003	52.774 0.0 1.272		Vel = 1.39	
UG6			0.0 233.17		2G	14.375			54.046		K Factor = 31.72	
UG6 to UG7	-3 -3		233.17 233.17	12 12.34	T	106.533	47.000 106.533 153.533	150 0	54.046 0.0 0.007		Vel = 0.63	
UG7			0.0 233.17						54.053		K Factor = 31.71	
UG7 to UG8	-3 -3		233.17 233.17	6 6.16	E T	22.818 48.896	13.000 71.714 84.714	150 0.0015	54.053 0.0 0.124		Vel = 2.51	
UG8			0.0 233.17						54.177		K Factor = 31.68	
UG8 to UG9	-3 -3		233.17 233.17	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0017	54.177 0.0 0.199		Vel = 2.51	
UG9 to TEST	-3 -3		0.0 233.17	12 12.34	2V T G E	15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140 0.0001	54.376 0.0 0.129		Vel = 0.63	
TEST			250.00 483.17						54.505		Qa = 250.00 K Factor = 65.45	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-5  
Drawing : FP11  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-5  
Contract : 4070  
Data File : NWHES 05 SYS-1 ZONE1 M100 OH2.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP11  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-5  
**Remote area location** MECH M100  
**Occupancy classification** OH-2  
**Density** 0.2 - Gpm/SqFt  
**Area of application** WHOLE AREA - SqFt  
**Coverage/sprinkler** 130 SF MAX - SqFt  
**Type of sprinkler calculated** QR PENDENT & UPRIGHT 1/2" 155F 5.6K  
**# Sprinklers calculated** 12  
**In-rack demand** N/A - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 582.363 - GPM @ 39.38 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES


**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC  
**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL  
**NOTES:**

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-5

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 42.302 A2 - Adj Resid : 18.917 @ 500 A3 - Adj Resid : 0 @ 719.14	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 719.14 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.71 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 6.172 D2 - System Flow : 332.363 D2 - System Pressure : 59.875 Hose ( Demand ) : _____ D3 - System Demand : 332.363 Hose ( Adj City ) : 250 Safety Margin : 13.683
--	--	---





# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-5

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                 Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-5

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			73.558	332.36	59.875
TEST	58.0	50	756.0	53.063	582.36	53.063

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	9.0	5.6	40.43	35.61	0.2 44
2H	9.0	5.6	39.56	35.22	0.2 120
3H	9.0	5.6	40.2	35.5	0.2 120
4H	9.0	5.6	40.02	35.43	0.2 120
5H	9.0	5.6	40.52	35.65	0.2 120
6H	9.0	5.6	40.66	35.71	0.2 120
7H	9.0	5.6	41.32	36.0	0.2 120
8H	11.25	5.6	7.0	14.82	0.2 60
9H	11.25	5.6	7.5	15.33	0.2 60
10H	11.25	5.6	9.44	17.2	0.2 76.67
11H	11.25	5.6	10.09	17.79	0.2 76.67
12H	11.25	5.6	10.46	18.11	0.2 26
1	9.5		42.73		
2	9.5		42.99		
3	9.5		43.68		
4	10.5		43.06		
5	9.5		44.03		
6	9.5		44.19		
7	9.5		44.9		
8	10.5		7.53		
9	10.5		8.28		
10	10.5		10.04		
11	10.5		11.02		
12	10.5		11.08		
J1	10.5		11.85		
J2	10.5		12.18		
J3	10.5		16.16		
J4	10.5		41.42		
F5	10.667		46.47		
F4	9.5		47.05		
F3	9.5		47.07		
F2	9.5		47.44		
F1	9.5		48.37		
E1	9.5		51.76		
TOR1	10.0		51.88		
BOR1	2.0		59.3		
PD	2.0		59.88		
PS	2.0		30.63		
FLG	1.0		31.37		
UG1	-3.0		33.18		
UG2	-3.0		33.56		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-5

Page 5  
Date 4/19/22

---

## NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG0	-3.0		33.58		
UG3	-3.0		33.65		
BF1	2.0		31.96		
BF2	-3.0		46.68		
UG4	-3.0		46.8		
UG5	-3.0		49.73		
UG6	-3.0		52.18		
UG7	-3.0		52.19		
UG8	-3.0		52.43		
UG9	-3.0		52.81		
TEST	-3.0		53.06	250.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-5

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	9 9.500	5.60	35.61 35.61	1 1.049	3E	6.0	0.667 6.000 6.667	120	40.427 -0.217 2.522		Vel = 13.22	
1			0.0 35.61						42.732		K Factor = 5.45	
2H to 2	9 9.500	5.60	35.22 35.22	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	39.559 -0.217 3.646		Vel = 13.07	
2			0.0 35.22						42.988		K Factor = 5.37	
3H to 3	9 9.500	5.60	35.50 35.5	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	40.196 -0.217 3.701		Vel = 13.18	
3			0.0 35.50						43.680		K Factor = 5.37	
4H to 4	9 10.500	5.60	35.43 35.43	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	40.021 -0.650 3.685		Vel = 13.15	
4			0.0 35.43						43.056		K Factor = 5.40	
5H to 5	9 9.500	5.60	35.65 35.65	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	40.518 -0.217 3.728		Vel = 13.23	
5			0.0 35.65						44.029		K Factor = 5.37	
6H to 6	9 9.500	5.60	35.71 35.71	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	40.663 -0.217 3.740		Vel = 13.26	
6			0.0 35.71						44.186		K Factor = 5.37	
7H to 7	9 9.500	5.60	36.00 36.0	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	41.317 -0.217 3.795		Vel = 13.36	
7			0.0 36.00						44.895		K Factor = 5.37	
8H to 8	11.250 10.500	5.60	14.82 14.82	1 1.049	E	2.0	0.750 2.000 2.750	120	7.000 0.325 0.205		Vel = 5.50	
8			0.0 14.82						7.530		K Factor = 5.40	
9H to 9	11.250 10.500	5.60	15.33 15.33	1 1.049	T	5.0	0.750 5.000 5.750	120	7.495 0.325 0.457		Vel = 5.69	
9			0.0 15.33						8.277		K Factor = 5.33	
10H to 10	11.250 10.500	5.60	17.20 17.2	1 1.049	E	2.0	0.750 2.000 2.750	120	9.439 0.325 0.271		Vel = 6.39	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-5

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 17.20					10.035		K Factor =	5.43
11H to 11	11.250 10.500	5.60	17.79	1	T 5.0	0.750 5.000 5.750	120	10.093 0.325 0.602		Vel =	6.60
			0.0 17.79					11.020		K Factor =	5.36
12H to 12	11.250 10.500	5.60	18.11	1	E 2.0	0.750 2.000 2.750	120	10.458 0.325 0.297		Vel =	6.72
			0.0 18.11					11.080		K Factor =	5.44
1 to F5	9.500 10.667		35.61	1	T 5.0	6.208 5.000 11.208	120	42.732 -0.505 4.239		Vel =	13.22
			0.0 35.61					46.466		K Factor =	5.22
2 to F3	9.500 9.500		35.22	1	T 5.0	6.000 5.000 11.000	120	42.988 0.0 4.078		Vel =	13.07
			0.0 35.22					47.066		K Factor =	5.13
3 to F3	9.500 9.500		35.50	1	T 5.0	4.000 5.000 9.000	120	43.680 0.0 3.386		Vel =	13.18
			0.0 35.50					47.066		K Factor =	5.17
4 to F2	10.500 9.500		35.43	1	2E 4.0	6.542 4.000 10.542	120	43.056 0.433 3.951		Vel =	13.15
			0.0 35.43					47.440		K Factor =	5.14
5 to F2	9.500 9.500		35.65	1	T 5.0	4.000 5.000 9.000	120	44.029 0.0 3.411		Vel =	13.23
			0.0 35.65					47.440		K Factor =	5.18
6 to F1	9.500 9.500		35.71	1	T 5.0	6.000 5.000 11.000	120	44.186 0.0 4.183		Vel =	13.26
			0.0 35.71					48.369		K Factor =	5.13
7 to F1	9.500 9.500		36.00	1	T 5.0	4.000 5.000 9.000	120	44.895 0.0 3.474		Vel =	13.36
			0.0 36.00					48.369		K Factor =	5.18

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-5

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
8 to 9	10.500 10.500		14.82	1			10.000	120	7.530 0.0			
				1.049			10.000	0.0747	0.747	Vel =	5.50	
9 to J2	10.500 10.500		15.33	1	T	5.0	9.042 5.000	120	8.277 0.0			
				1.049			14.042	0.2780	3.904	Vel =	11.19	
J2			0.0 30.15						12.181	K Factor =	8.64	
10 to 11	10.500 10.500		17.20	1			10.000	120	10.035 0.0			
				1.049			10.000	0.0985	0.985	Vel =	6.39	
11 to J3	10.500 10.500		17.80	1	T	5.0	9.042 5.000	120	11.020 0.0			
				1.049			14.042	0.3663	5.144	Vel =	12.99	
J3			0.0 35.00						16.164	K Factor =	8.71	
12 to J1	10.500 10.500		18.11	1	E	2.0	5.083 2.000	120	11.080 0.0			
				1.049			7.083	0.1084	0.768	Vel =	6.72	
J1			0.0 18.11						11.848	K Factor =	5.26	
J1 to J2	10.500 10.500		18.11	1			3.083	120	11.848 0.0			
				1.049			3.083	0.1080	0.333	Vel =	6.72	
J2 to J3	10.500 10.500		30.15	1			6.000	120	12.181 0.0			
				1.049			6.000	0.6638	3.983	Vel =	17.92	
J3 to J4	10.500 10.500		34.99	1	E T	2.0 5.0	6.875 7.000	120	16.164 0.0			
				1.049			13.875	1.8206	25.261	Vel =	30.90	
J4 to TOR1	10.500 10		0.0	1	T	5.0	0.625 5.000	120	41.425 0.217			
				1.049			5.625	1.8204	10.240	Vel =	30.90	
TOR1			0.0 83.25						51.882	K Factor =	11.56	
F5 to F4	10.667 9.500		35.61	2.5	2E	16.474	2.542 16.474	120	46.466 0.505			
				2.635			19.016	0.0043	0.082	Vel =	2.10	
F4 to F3	9.500 9.500		0.0	2.5			3.125	120	47.053 0.0			
				2.635			3.125	0.0042	0.013	Vel =	2.10	
F3 to F2	9.500 9.500		35.61	2.5			11.583	120	47.066 0.0			
				2.635			11.583	0.0323	0.374	Vel =	6.26	
F2 to F1	9.500 9.500		71.07	2.5			11.167	120	47.440 0.0			
				2.635			11.167	0.0832	0.929	Vel =	10.44	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-5

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
F1 to E1	9.500 9.500		71.71 249.11	2.5 2.635	T	16.474	5.250 16.474 21.724	120	48.369 0.0 3.386			Vel = 14.66
E1			0.0 249.11						51.755			K Factor = 34.63
E1 to TOR1	9.500 10		249.11 249.11	4 4.26	E	13.167	9.708 13.167 22.875	120	51.755 -0.217 0.344			Vel = 5.61
TOR1			0.0 249.11						51.882			K Factor = 34.58
TOR1 to BOR1	10 2		332.36 332.36	4 4.26	E B Fsp	13.167 15.8 0.0	8.042 28.967 37.009	120	51.882 6.465 0.948		** Fixed Loss = 3	Vel = 7.48
BOR1			0.0 332.36						59.295			K Factor = 43.16
BOR1 to PD	2 2		332.36 332.36	6 6.357	E 2T B S	17.603 75.44 12.573 40.235	13.292 145.851 159.143	120	59.295 0.0 0.580			Vel = 3.36
PD			0.0 332.36						59.875			K Factor = 42.95
System Demand Pressure									59.875			
Safety Margin									13.683			
Continuation Pressure									73.558			
Pressure @ Pump Outlet									73.558			
Pressure From Pump Curve									-42.928			
Pressure @ Pump Inlet									30.630			
PS to FLG	2 1		0.0 332.36	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120	30.630 0.433 0.309			Vel = 3.36
FLG			0.0 332.36						31.372			K Factor = 59.34
FLG to UG1	1 -3		332.36 332.36	6 6.16	E	20.084	4.000 20.084 24.084	140	31.372 1.732 0.077			Vel = 3.58
UG1			0.0 332.36						33.181			K Factor = 57.70
UG1 to UG2	-3 -3		332.36 332.36	6 6.16	T	43.037	77.000 43.037 120.037	140	33.181 0.0 0.384			Vel = 3.58
UG2 to UG3	-3 -3		-70.19 262.17	8 8.27			179.000 179.000	140	33.565 0.0 0.088			Vel = 1.57
UG3			0.0 262.17						33.653			K Factor = 45.19
UG2 to UG0	-3 -3		70.19 70.19	8 8.27	V	20.56	261.000 20.560 281.560	140	33.565 0.0 0.012			Vel = 0.42

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-5

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG0 to UG3	-3 -3		0.0 70.19	8 8.27	10V T	205.602 55.354 1767.956	140 0	33.577 0.0 0.076			Vel = 0.42
UG3			0.0 70.19					33.653			K Factor = 12.10
UG3 to BF1	-3 2		332.36 332.36	8 8.27	G 2V 2E	6.326 41.12 56.936 625.382	140 0.0008	33.653 -2.166 0.476			Vel = 1.99
BF1 to BF2	2 -3		0.0 332.36	8 8.27	2E	56.936 15.000 56.936 71.936	140 0.0008	31.963 14.666 0.055			** Fixed Loss = 12.5 Vel = 1.99
BF2 to UG4	-3 -3		0.0 332.36	8 8.27	V T	20.56 55.354 75.914 150.914	140 0.0008	46.684 0.0 0.115			Vel = 1.99
UG4			0.0 332.36					46.799			K Factor = 48.58
UG4 to UG5	-3 -3		332.36 332.36	8 8.27	4G 8V	28.75 186.874 215.624 4371.624	150 0.0007	46.799 0.0 2.929			Vel = 1.99
UG5 to UG6	-3 -3		0.0 332.36	8 8.27	8V E T 2G	186.874 32.344 296.483 62.89 3656.483 14.375	150 0.0007	49.728 0.0 2.450			Vel = 1.99
UG6			0.0 332.36					52.178			K Factor = 46.01
UG6 to UG7	-3 -3		332.36 332.36	12 12.34	T	106.533 47.000 106.533 153.533	150 0.0001	52.178 0.0 0.014			Vel = 0.89
UG7			0.0 332.36					52.192			K Factor = 46.01
UG7 to UG8	-3 -3		332.36 332.36	6 6.16	E T	22.818 13.000 48.896 71.714 84.714	150 0.0028	52.192 0.0 0.239			Vel = 3.58
UG8			0.0 332.36					52.431			K Factor = 45.90
UG8 to UG9	-3 -3		332.36 332.36	6 6.16	T	43.037 77.000 43.037 120.037	140 0.0032	52.431 0.0 0.383			Vel = 3.58
UG9 to TEST	-3 -3		0.0 332.36	12 12.34	2V T G E	15.94 2136.000 93.767 161.279 9.377 2297.279 42.195	140 0.0001	52.814 0.0 0.249			Vel = 0.89
TEST			250.00 582.36					53.063			Qa = 250.00 K Factor = 79.95





## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-6  
Drawing : FP15  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-6  
Contract : 4070  
Data File : NWHES 06 SYS-2 ZONE2 517 LH EC.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP15  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-6  
**Remote area location** 2ND-3RD GRADE 517  
**Occupancy classification** LH  
**Density** 0.10 - Gpm/SqFt  
**Area of application** 991 - SqFt  
**Coverage/sprinkler** 324 SF MAX - SqFt  
**Type of sprinkler calculated** QR EC CONCEALED PENDENT 1/2" 155F 5.6K  
**# Sprinklers calculated** 6  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 297.747 - GPM @ 53.452 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC  
**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**


REDUCE AREA FOR HYDRAULIC CALCULATION PER NFPA13 2013 SECTION 11.2.3.2.3

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-6

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 6.226 D2 - System Flow : 198.747 D2 - System Pressure : 79.780 Hose ( Demand ) : _____ D3 - System Demand : 198.747 Hose ( Adj City ) : 100 Safety Margin : 3.112
--	--	--



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-6

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-6

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			82.892	198.75	79.78
TEST	58.0	50	756.0	56.564	298.75	56.564

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	12.083	5.6	33.8	32.56	0.1 168
2H	12.083	5.6	34.31	32.8	0.1 168
3H	12.083	5.6	36.08	33.64	0.1 168
4H	11.375	5.6	34.27	32.78	0.1 196
5H	11.375	5.6	34.7	32.99	0.1 236
6H	11.375	5.6	36.82	33.98	0.1 236
1	12.792		36.67		
2	12.792		37.23		
3	12.792		39.15		
4	12.125		37.19		
5	12.125		37.66		
6	12.125		39.95		
500	12.792		53.5		
501	12.125		54.13		
B5	10.917		61.58		
B4	10.917		63.55		
B3	7.0		66.56		
B1	7.0		70.19		
A8	11.75		68.43		
A7	13.625		68.3		
A6	12.292		69.38		
A5	17.417		67.84		
A4	16.75		68.62		
A3	12.833		71.94		
A2	16.833		71.19		
A1	10.5		74.48		
TOR2	10.5		74.79		
BOR2	2.0		79.56		
PD	2.0		79.78		
PS	2.0		38.9		
FLG	1.0		39.45		
UG1	-3.0		41.21		
UG2	-3.0		41.36		
UG0	-3.0		41.37		
UG3	-3.0		41.39		
BF1	2.0		39.41		
BF2	-3.0		54.1		
UG4	-3.0		54.14		
UG5	-3.0		55.28		
UG6	-3.0		56.22		
UG7	-3.0		56.23		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-6

Page 5  
Date 4/19/22

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG8	-3.0		56.32		
UG9	-3.0		56.47		
TEST	-3.0		56.56	100.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-6

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	12.083 12.792	5.60	32.56 32.56	1 1.049	2E T	4.0 5.0	0.917 9.000 9.917	120	33.799 -0.307 3.178		Vel = 12.09	
1			0.0 32.56						36.670		K Factor = 5.38	
2H to 2	12.083 12.792	5.60	32.80 32.8	1 1.049	2E T	4.0 5.0	0.917 9.000 9.917	120	34.311 -0.307 3.224		Vel = 12.18	
2			0.0 32.80						37.228		K Factor = 5.38	
3H to 3	12.083 12.792	5.60	33.64 33.64	1 1.049	2E T	4.0 5.0	0.917 9.000 9.917	120	36.084 -0.307 3.377		Vel = 12.49	
3			0.0 33.64						39.154		K Factor = 5.38	
4H to 4	11.375 12.125	5.60	32.78 32.78	1 1.049	2E T	4.0 5.0	1.000 9.000 10.000	120	34.268 -0.325 3.246		Vel = 12.17	
4			0.0 32.78						37.189		K Factor = 5.38	
5H to 5	11.375 12.125	5.60	32.99 32.99	1 1.049	2E T	4.0 5.0	1.000 9.000 10.000	120	34.700 -0.325 3.284		Vel = 12.25	
5			0.0 32.99						37.659		K Factor = 5.38	
6H to 6	11.375 12.125	5.60	33.98 33.98	1 1.049	2E T	4.0 5.0	0.958 9.000 9.958	120	36.819 -0.325 3.455		Vel = 12.61	
6			0.0 33.98						39.949		K Factor = 5.38	
1 to 2	12.792 12.792		32.56 32.56	1.5 1.61			14.000 14.000	120	36.670 0.0 0.558		Vel = 5.13	
2 to 3	12.792 12.792		32.80 65.36	1.5 1.61			13.333 13.333	120	37.228 0.0 1.926		Vel = 10.30	
3 to 500	12.792 12.792		33.64 99.0	1.5 1.61	T	8.0	38.083 8.000 46.083	120	39.154 0.0 14.350		Vel = 15.60	
500			0.0 99.00						53.504		K Factor = 13.53	
4 to 5	12.125 12.125		32.78 32.78	1.5 1.61			11.667 11.667	120	37.189 0.0 0.470		Vel = 5.17	
5 to 6	12.125 12.125		32.99 65.77	1.5 1.61			15.667 15.667	120	37.659 0.0 2.290		Vel = 10.36	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-6

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
6 to 501	12.125 12.125		33.98 99.75	1.5 1.61	T	8.0	36.917 8.000 44.917	120 0.3158	39.949 0.0 14.184			Vel = 15.72
501			0.0 99.75						54.133			K Factor = 13.56
500 to 501	12.792 12.125		99.00 99.0	2.5 2.635			12.042 12.042	120 0.0282	53.504 0.289 0.340			Vel = 5.82
501 to B5	12.125 10.917		99.75 198.75	2.5 2.635	2E T	16.474 16.474	34.542 32.948 67.490	120 0.1026	54.133 0.523 6.927			Vel = 11.69
B5			0.0 198.75						61.583			K Factor = 25.33
B5 to B4	10.917 10.917		198.75 198.75	4 4.26	E	13.167	185.917 13.167 199.084	120 0.0099	61.583 0.0 1.970			Vel = 4.47
B4 to B3	10.917 7		0.0 198.75	4 4.26	6E	79.002	53.750 79.002 132.752	120 0.0099	63.553 1.696 1.313			Vel = 4.47
B3			0.0 198.75						66.562			K Factor = 24.36
B3 to B1	7 7		198.75 198.75	4 4.26	E B S Fsp	13.167 15.8 28.968 0.0	5.917 57.935 63.852	120 0.0099	66.562 3.000 0.632		** Fixed Loss = 3	Vel = 4.47
B1			0.0 198.75						70.194			K Factor = 23.72
B1 to A8	7 11.750		198.75 198.75	4 4.26	2E	26.334	2.875 26.334 29.209	120 0.0099	70.194 -2.057 0.289			Vel = 4.47
A8 to A7	11.750 13.625		0.0 198.75	4 4.26	3E	39.501	29.750 39.501 69.251	120 0.0099	68.426 -0.812 0.685			Vel = 4.47
A7 to A6	13.625 12.292		0.0 198.75	4 4.26	2E	26.334	24.167 26.334 50.501	120 0.0099	68.299 0.577 0.500			Vel = 4.47
A6 to A5	12.292 17.417		0.0 198.75	4 4.26	2E	26.334	42.792 26.334 69.126	120 0.0099	69.376 -2.220 0.684			Vel = 4.47
A5 to A4	17.417 16.750		0.0 198.75	4 4.26	2E	26.334	23.333 26.334 49.667	120 0.0099	67.840 0.289 0.491			Vel = 4.47
A4			0.0 198.75						68.620			K Factor = 23.99
A4 to A3	16.750 12.833		198.75 198.75	4 4.26	4E	52.668	111.000 52.668 163.668	120 0.0099	68.620 1.696 1.619			Vel = 4.47
A3 to A2	12.833 16.833		0.0 198.75	4 4.26	2E	26.334	73.875 26.334 100.209	120 0.0099	71.935 -1.732 0.991			Vel = 4.47



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-6

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A2 to A1	16.833 10.500		0.0 198.75	4 4.26	2E 26.334	28.708 26.334 55.042	120 0.0099	71.194 2.743 0.545		Vel = 4.47	
A1 to TOR2	10.500 10.500		0.0 198.75	4 4.26	E 13.167	18.375 13.167 31.542	120 0.0099	74.482 0.0 0.312		Vel = 4.47	
TOR2			0.0 198.75					74.794		K Factor = 22.98	
TOR2 to BOR2	10.500 2		198.75 198.75	6 6.357	T B Fsp	37.72 12.573 0.0 59.335	120 0.0014	74.794 4.681 0.083		** Fixed Loss = 1 Vel = 2.01	
BOR2			0.0 198.75					79.558		K Factor = 22.28	
BOR2 to PD	2 2		198.75 198.75	6 6.357	E 2T B S	17.603 75.44 12.573 40.235 145.851 157.393	120 0.0014	79.558 0.0 0.222		Vel = 2.01	
PD			0.0 198.75					79.780		K Factor = 22.25	
System Demand Pressure								79.780			
Safety Margin								3.112			
Continuation Pressure								82.892			
Pressure @ Pump Outlet								82.892			
Pressure From Pump Curve								-43.993			
Pressure @ Pump Inlet								38.899			
PS to FLG	2 1		0.0 198.75	6 6.357	2T G	75.44 3.772 84.670	120 0.0014	38.899 0.433 0.119		Vel = 2.01	
FLG			0.0 198.75					39.451		K Factor = 31.64	
FLG to UG1	1 -3		198.75 198.75	6 6.16	E	20.084 4.000 20.084 24.084	140 0.0012	39.451 1.732 0.030		Vel = 2.14	
UG1			0.0 198.75					41.213		K Factor = 30.96	
UG1 to UG2	-3 -3		198.75 198.75	6 6.16	T	43.037 77.000 43.037 120.037	140 0.0012	41.213 0.0 0.148		Vel = 2.14	
UG2 to UG3	-3 -3		-41.97 156.78	8 8.27		179.000 179.000	140 0.0002	41.361 0.0 0.034		Vel = 0.94	
UG3			0.0 156.78					41.395		K Factor = 24.37	
UG2 to UG0	-3 -3		41.97 41.97	8 8.27	V	20.56 261.000 20.560 281.560	140 0	41.361 0.0 0.005		Vel = 0.25	
UG0 to UG3	-3 -3		0.0 41.97	8 8.27	10V T	205.602 55.354 1767.956	140 0	41.366 0.0 0.029		Vel = 0.25	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-6

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG3			0.0 41.97					41.395		K Factor = 6.52	
UG3 to BF1	-3 2		198.75	8	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140	41.395 -2.166 0.185	Vel = 1.19	
BF1 to BF2	2 -3		0.0 198.75	8	2E	56.936	15.000 56.936 71.936	140	39.414 14.666 0.020	** Fixed Loss = 12.5 Vel = 1.19	
BF2 to UG4	-3 -3		0.0 198.75	8	V T	20.56 55.354	75.000 75.914 150.914	140	54.100 0.0 0.045	Vel = 1.19	
UG4			0.0 198.75					54.145		K Factor = 27.01	
UG4 to UG5	-3 -3		198.75	8	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150	54.145 0.0 1.131	Vel = 1.19	
UG5 to UG6	-3 -3		0.0 198.75	8	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150	55.276 0.0 0.946	Vel = 1.19	
UG6			0.0 198.75					56.222		K Factor = 26.51	
UG6 to UG7	-3 -3		198.75	12	T	106.533	47.000 106.533 153.533	150	56.222 0.0 0.006	Vel = 0.53	
UG7			0.0 198.75					56.228		K Factor = 26.51	
UG7 to UG8	-3 -3		198.75	6	E T	22.818 48.896	13.000 71.714 84.714	150	56.228 0.0 0.092	Vel = 2.14	
UG8			0.0 198.75					56.320		K Factor = 26.48	
UG8 to UG9	-3 -3		198.75	6	T	43.037	77.000 43.037 120.037	140	56.320 0.0 0.148	Vel = 2.14	
UG9 to TEST	-3 -3		0.0 198.75	12	2V T G E	15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140	56.468 0.0 0.096	Vel = 0.53	
TEST			100.00 298.75					56.564		Qa = 100.00 K Factor = 39.72	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-7  
Drawing : FP13  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-7  
Contract : 4070  
Data File : NWHES 07 SYS-2 ZONE2 MUSIC238 LH.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP13  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-7  
**Remote area location** MUSIC 238  
**Occupancy classification** LH  
**Density** 0.10 - Gpm/SqFt  
**Area of application** 1059 - SqFt  
**Coverage/sprinkler** 225 SF MAX - SqFt  
**Type of sprinkler calculated** QR CONCEALED PENDENT 1/2" 155F 5.6K  
**# Sprinklers calculated** 9  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 295.959 - GPM @ 46.173 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC

**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**


REDUCE AREA FOR HYDRAULIC CALCULATION PER NFPA13 2013 SECTION 11.2.3.2.3

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-7

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 6.424 D2 - System Flow : 195.959 D2 - System Pressure : 72.578 Hose ( Demand ) : _____ D3 - System Demand : 195.959 Hose ( Adj City ) : 100 Safety Margin : 10.416
--	--	---



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-7

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
PD	See Information on Pump Curve			82.994	195.96	72.578
TEST	58.0	50	756.0	56.589	295.96	56.589

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
1H	11.833	5.6	7.0	14.82	0.1 120
2H	11.833	5.6	7.0	14.82	0.1 140.416
3H	11.833	5.6	9.62	17.36	0.1 140
4H	13.667	5.6	12.87	20.09	0.1 168
5H	13.667	5.6	15.48	22.04	0.1 168.5
6H	13.667	5.6	17.47	23.41	0.1 168
7H	13.667	5.6	17.18	23.21	0.1 168
8H	13.667	5.6	28.76	30.03	0.1 144
9H	13.667	5.6	29.05	30.18	0.1 144
1	15.5		6.13		
2	15.5		8.99		
3	15.5		15.23		
4	15.5		13.34		
5	15.5		16.2		
6	15.5		18.36		
7	17.667		17.14		
8	15.5		30.68		
9	15.5		30.99		
390	15.5		14.76		
391	15.5		15.23		
392	15.5		16.41		
393	15.5		18.07		
394	15.5		20.02		
395	15.5		23.33		
D12	15.5		32.64		
D11	15.0		33.88		
D10	15.0		34.1		
D9	11.958		39.02		
D8	11.125		45.44		
D7	11.125		46.48		
D6	10.542		49.75		
D5	10.417		51.21		
D4	12.083		54.74		
D3	12.75		55.04		
D2	11.125		56.3		
D1	7.0		59.1		
B2	7.0		59.38		
B1	7.0		63.11		
A9	7.0		63.12		
A8	11.75		61.38		
A7	13.625		61.24		

---

**NODE ANALYSIS (cont.)**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
A6	12.292		62.3		
A5	17.417		60.75		
A4	16.75		61.52		
A3	12.833		64.79		
A2	16.833		64.02		
A1	10.5		67.3		
TOR2	10.5		67.6		
BOR2	2.0		72.36		
PD	2.0		72.58		
PS	2.0		39.0		
FLG	1.0		39.55		
UG1	-3.0		41.31		
UG2	-3.0		41.46		
UG0	-3.0		41.46		
UG3	-3.0		41.49		
BF1	2.0		39.5		
BF2	-3.0		54.19		
UG4	-3.0		54.23		
UG5	-3.0		55.33		
UG6	-3.0		56.26		
UG7	-3.0		56.26		
UG8	-3.0		56.35		
UG9	-3.0		56.5		
TEST	-3.0		56.59	100.0	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-7

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	11.833 15.500	5.60	14.82 14.82	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.0747	7.000 -1.588 0.722			Vel = 5.50
1			0.0 14.82					6.134			K Factor = 5.98
2H to 1	11.833 15.500	5.60	14.82 14.82	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.0747	7.000 -1.588 0.722			Vel = 5.50
1			0.0 14.82					6.134			K Factor = 5.98
3H to 2	11.833 15.500	5.60	17.36 17.36	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1001	9.615 -1.588 0.968			Vel = 6.44
2			0.0 17.36					8.995			K Factor = 5.79
4H to 4	13.667 15.500	5.60	20.09 20.09	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1313	12.870 -0.794 1.269			Vel = 7.46
4			0.0 20.09					13.345			K Factor = 5.50
5H to 5	13.667 15.500	5.60	22.04 22.04	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1558	15.485 -0.794 1.506			Vel = 8.18
5			0.0 22.04					16.197			K Factor = 5.48
6H to 6	13.667 15.500	5.60	23.41 23.41	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1742	17.474 -0.794 1.684			Vel = 8.69
6			0.0 23.41					18.364			K Factor = 5.46
7H to 7	13.667 17.667	5.60	23.22 23.22	1 1.049	2E T 4.0 5.0	0.833 9.000 9.833	120 0.1714	17.185 -1.732 1.685			Vel = 8.62
7			0.0 23.22					17.138			K Factor = 5.61
8H to 8	13.667 15.500	5.60	30.03 30.03	1 1.049	2E T 4.0 5.0	0.833 9.000 9.833	120 0.2760	28.756 -0.794 2.714			Vel = 11.15
8			0.0 30.03					30.676			K Factor = 5.42
9H to 9	13.667 15.500	5.60	30.18 30.18	1 1.049	2E T 4.0 5.0	0.833 9.000 9.833	120 0.2787	29.048 -0.794 2.740			Vel = 11.20
9			0.0 30.18					30.994			K Factor = 5.42
1 to 2	15.500 15.500		29.63 29.63	1 1.049		10.625 10.625	120 0.2693	6.134 0.0 2.861			Vel = 11.00

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-7

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
2 to 390	15.500 15.500		17.37 47.0	1 1.049	T 5.0	4.125 5.000 9.125	120 0.6322	8.995 0.0 5.769			Vel = 17.45
390			0.0 47.00					14.764			K Factor = 12.23
3 to 391	15.500 15.500	.0	0.0 0.0	1 1.049	T 5.0	4.917 5.000 9.917	120 0	15.228 0.0 0.0			Vel = 0
391			0.0 0.0					15.228			K Factor = 0
4 to 392	15.500 15.500		20.09 20.09	1 1.049	T 5.0	18.375 5.000 23.375	120 0.1312	13.345 0.0 3.067			Vel = 7.46
392			0.0 20.09					16.412			K Factor = 4.96
5 to 393	15.500 15.500		22.04 22.04	1 1.049	T 5.0	7.042 5.000 12.042	120 0.1557	16.197 0.0 1.875			Vel = 8.18
393			0.0 22.04					18.072			K Factor = 5.18
6 to 394	15.500 15.500		23.41 23.41	1 1.049	T 5.0	4.500 5.000 9.500	120 0.1741	18.364 0.0 1.654			Vel = 8.69
394			0.0 23.41					20.018			K Factor = 5.23
7 to 395	17.667 15.500		23.22 23.22	1 1.049	E T 5.0	23.625 7.000 30.625	120 0.1715	17.138 0.939 5.251			Vel = 8.62
395			0.0 23.22					23.328			K Factor = 4.81
8 to D10	15.500 15		30.03 30.03	1 1.049	T 5.0	6.625 5.000 11.625	120 0.2760	30.676 0.217 3.208			Vel = 11.15
D10			0.0 30.03					34.101			K Factor = 5.14
9 to D10	15.500 15		30.18 30.18	1 1.049	T 5.0	5.375 5.000 10.375	120 0.2786	30.994 0.217 2.890			Vel = 11.20
D10			0.0 30.18					34.101			K Factor = 5.17
390 to 391	15.500 15.500		47.00 47.0	1.25 1.38		2.792 2.792	120 0.1662	14.764 0.0 0.464			Vel = 10.08
391 to 392	15.500 15.500		0.0 47.0	1.25 1.38		7.125 7.125	120 0.1662	15.228 0.0 1.184			Vel = 10.08
392 to 393	15.500 15.500		20.09 67.09	1.25 1.38		5.167 5.167	120 0.3213	16.412 0.0 1.660			Vel = 14.39

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-7

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
393 to 394	15.500 15.500		22.03 89.12	1.25 1.38			3.583 3.583	120 0.5431	18.072 0.0 1.946			Vel = 19.12
394 to 395	15.500 15.500		23.41 112.53	1.25 1.38			3.958 3.958	120 0.8363	20.018 0.0 3.310			Vel = 24.14
395 to D12	15.500 15.500		23.22 135.75	1.25 1.38	T	6.0	1.875 6.000 7.875	120 1.1830	23.328 0.0 9.316			Vel = 29.12
D12			0.0 135.75						32.644			K Factor = 23.76
D12 to D11	15.500 15		135.75 135.75	2.5 2.635	2E	16.474	3.708 16.474 20.182	120 0.0507	32.644 0.217 1.023			Vel = 7.99
D11 to D10	15 15		0.0 135.75	2.5 2.635			4.292 4.292	120 0.0506	33.884 0.0 0.217			Vel = 7.99
D10 to D9	15 11.958		60.21 195.96	2.5 2.635	2E	16.474	19.542 16.474 36.016	120 0.1000	34.101 1.317 3.602			Vel = 11.53
D9 to D8	11.958 11.125		0.0 195.96	2.5 2.635	E T	8.237 16.474	35.833 24.711 60.544	120 0.1000	39.020 0.361 6.054			Vel = 11.53
D8 to D7	11.125 11.125		0.0 195.96	2.5 2.635	E	8.237	2.250 8.237 10.487	120 0.0999	45.435 0.0 1.048			Vel = 11.53
D7 to D6	11.125 10.542		0.0 195.96	2.5 2.635	2E	16.474	13.708 16.474 30.182	120 0.1000	46.483 0.252 3.019			Vel = 11.53
D6			0.0 195.96						49.754			K Factor = 27.78
D6 to D5	10.542 10.417		195.96 195.96	2.5 2.635	E	8.237	5.750 8.237 13.987	120 0.0999	49.754 0.054 1.398			Vel = 11.53
D5 to D4	10.417 12.083		0.0 195.96	2.5 2.635	2E	16.474	26.125 16.474 42.599	120 0.1000	51.206 -0.722 4.260			Vel = 11.53
D4			0.0 195.96						54.744			K Factor = 26.48
D4 to D3	12.083 12.750		195.96 195.96	4 4.26	2E	26.334	34.833 26.334 61.167	120 0.0096	54.744 -0.289 0.590			Vel = 4.41
D3 to D2	12.750 11.125		0.0 195.96	4 4.26	2E	26.334	31.042 26.334 57.376	120 0.0096	55.045 0.704 0.553			Vel = 4.41
D2 to D1	11.125 7		0.0 195.96	4 4.26	4E	52.668	52.583 52.668 105.251	120 0.0096	56.302 1.787 1.013			Vel = 4.41

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-7

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 195.96						59.102		K Factor = 25.49	
D1 to B2	7 7		195.96	4	T	26.334	2.333 26.334 28.667	120	59.102 0.0 0.277		Vel = 4.41	
			0.0 195.96						59.379		K Factor = 25.43	
B2 to B1	7 7		195.96	4	T B S Fsp	26.334 15.8 28.968 0.0	4.958 71.102 76.060	120	59.379 3.000 0.733		** Fixed Loss = 3 Vel = 4.41	
			0.0 195.96						63.112		K Factor = 24.67	
B1 to A9	7 7		195.96	4			1.417 1.417	120	63.112 0.0 0.013		Vel = 4.41	
A9 to A8	7 11.750		0.0 195.96	4	2E	26.334	6.208 26.334 32.542	120	63.125 -2.057 0.314		Vel = 4.41	
			0.0 195.96						61.382		K Factor = 25.01	
A8 to A7	11.750 13.625		195.96	4	3E	39.501	29.750 39.501 69.251	120	61.382 -0.812 0.667		Vel = 4.41	
A7 to A6	13.625 12.292		0.0 195.96	4	2E	26.334	24.167 26.334 50.501	120	61.237 0.577 0.487		Vel = 4.41	
A6 to A5	12.292 17.417		0.0 195.96	4	2E	26.334	42.792 26.334 69.126	120	62.301 -2.220 0.667		Vel = 4.41	
A5 to A4	17.417 16.750		0.0 195.96	4	2E	26.334	23.333 26.334 49.667	120	60.748 0.289 0.478		Vel = 4.41	
			0.0 195.96						61.515		K Factor = 24.98	
A4 to A3	16.750 12.833		195.96	4	4E	52.668	111.000 52.668 163.668	120	61.515 1.696 1.578		Vel = 4.41	
A3 to A2	12.833 16.833		0.0 195.96	4	2E	26.334	73.875 26.334 100.209	120	64.789 -1.732 0.965		Vel = 4.41	
A2 to A1	16.833 10.500		0.0 195.96	4	2E	26.334	28.708 26.334 55.042	120	64.022 2.743 0.530		Vel = 4.41	
A1 to TOR2	10.500 10.500		0.0 195.96	4	E	13.167	18.375 13.167 31.542	120	67.295 0.0 0.304		Vel = 4.41	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-7

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
TOR2			0.0 195.96						67.599		K Factor = 23.83	
TOR2 to BOR2	10.500 2		195.96	6	T B	37.72 12.573	9.042 50.293	120	67.599 4.681		** Fixed Loss = 1	
BOR2			0.0 195.96		Fsp	0.0	59.335	0.0014	0.082		Vel = 1.98	
BOR2			0.0 195.96						72.362		K Factor = 23.04	
BOR2 to PD	2 2		195.96	6	E 2T B S	17.603 75.44 12.573 40.235	11.542 145.851	120	72.362 0.0		Vel = 1.98	
PD			0.0 195.96						72.578		K Factor = 23.00	
System Demand Pressure									72.578			
Safety Margin									10.416			
Continuation Pressure									82.994			
Pressure @ Pump Outlet									82.994			
Pressure From Pump Curve									-43.994			
Pressure @ Pump Inlet									39.000			
PS to FLG	2 1		0.0 195.96	6	2T G	75.44 3.772	5.458 79.212	120	39.000 0.433		Vel = 1.98	
FLG			0.0 195.96						39.550		K Factor = 31.16	
FLG to UG1	1 -3		195.96	6	E	20.084	4.000 20.084	140	39.550 1.732		Vel = 2.11	
UG1			0.0 195.96						41.311		K Factor = 30.49	
UG1 to UG2	-3 -3		195.96	6	T	43.037	77.000 43.037	140	41.311 0.0		Vel = 2.11	
UG2 to UG3	-3 -3		-41.38	8			179.000	140	41.455 0.0		Vel = 0.92	
UG3			0.0 154.58						41.488		K Factor = 24.00	
UG2 to UG0	-3 -3		41.38	8	V	20.56	261.000 20.560	140	41.455 0.0		Vel = 0.25	
UG0 to UG3	-3 -3		0.0	8	10V T	205.602 55.354	1507.000 260.956	140	41.460 0.0		Vel = 0.25	
UG3			0.0 41.38						41.488		K Factor = 6.42	
UG3 to BF1	-3 2		195.96	8	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140	41.488 -2.166		Vel = 1.17	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-7

Page 11  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BF1 to BF2	2 -3		0.0 195.96	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0003	39.502 14.666 0.020		** Fixed Loss = 12.5 Vel = 1.17	
BF2 to UG4	-3 -3		0.0 195.96	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0003	54.188 0.0 0.043		Vel = 1.17	
UG4			0.0 195.96						54.231		K Factor = 26.61	
UG4 to UG5	-3 -3		195.96	8 8.27	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150 0.0003	54.231 0.0 1.103		Vel = 1.17	
UG5 to UG6	-3 -3		0.0 195.96	8 8.27	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150 0.0003	55.334 0.0 0.921		Vel = 1.17	
UG6			0.0 195.96						56.255		K Factor = 26.13	
UG6 to UG7	-3 -3		195.96	12 12.34	T	106.533	47.000 106.533 153.533	150 0	56.255 0.0 0.006		Vel = 0.53	
UG7			0.0 195.96						56.261		K Factor = 26.13	
UG7 to UG8	-3 -3		195.96	6 6.16	E T	22.818 48.896	13.000 71.714 84.714	150 0.0011	56.261 0.0 0.090		Vel = 2.11	
UG8			0.0 195.96						56.351		K Factor = 26.10	
UG8 to UG9	-3 -3		195.96	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0012	56.351 0.0 0.144		Vel = 2.11	
UG9 to TEST	-3 -3		0.0 195.96	12 12.34	2V T G E	15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140 0	56.495 0.0 0.094		Vel = 0.53	
TEST			100.00 295.96						56.589		Qa = 100.00 K Factor = 39.34	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-8  
Drawing : FP12  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-8  
Contract : 4070  
Data File : NWHES 08 SYS-2 ZONE2 MECH ABV 213 OH1.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP12  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-8  
**Remote area location** MECH PLATFORM ABOVE OFFICE 213  
**Occupancy classification** OH-1  
**Density** 0.15 - Gpm/SqFt  
**Area of application** WHOLE AREA - SqFt  
**Coverage/sprinkler** 130 SF MAX - SqFt  
**Type of sprinkler calculated** QR UPRIGHT 1/2" 155F 5.6K  
**# Sprinklers calculated** 9  
**In-rack demand** N/A - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 429.199 - GPM @ 45.198 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC

**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL  
**NOTES:**




# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-8

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 42.302 A2 - Adj Resid : 18.917 @ 500 A3 - Adj Resid : 0 @ 719.14	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 719.14 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.71 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 9.817 D2 - System Flow : 179.199 D2 - System Pressure : 72.049 Hose ( Demand ) : _____ D3 - System Demand : 179.199 Hose ( Adj City ) : 250 Safety Margin : 9.995
--	--	--



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-8

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                 Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
PD	See Information on Pump Curve			82.044	179.2	72.049
TEST	58.0	50	756.0	55.193	429.2	55.193

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
1H	19.667	5.6	7.0	14.82	0.15 96.45
2H	19.667	5.6	7.0	14.82	0.15 74.06
3H	19.667	5.6	9.62	17.37	0.15 114.17
4H	20.5	5.6	13.12	20.28	0.15 72.08
5H	21.083	5.6	14.04	20.98	0.15 107.92
6H	21.208	5.6	10.03	17.73	0.15 70
7H	21.208	5.6	10.77	18.38	0.15 114.17
8H	21.167	5.6	23.77	27.3	0.15 106.16
9H	21.167	5.6	24.15	27.52	0.15 106.57
1	18.417		8.01		
2	18.417		10.79		
3	18.417		16.01		
4	19.375		14.42		
5	19.833		15.47		
6	20.125		11.13		
7	19.833		12.3		
8	20.333		25.48		
9	20.333		25.64		
210	18.333		16.04		
211	19.25		16.17		
212	19.833		16.64		
213	19.958		16.8		
214	20.333		25.07		
215	19.333		28.79		
216	19.333		29.25		
217	19.333		38.31		
218	12.083		55.72		
D3	12.75		55.87		
D2	11.125		57.04		
D1	7.0		59.69		
B2	7.0		59.92		
B1	7.0		63.54		
A9	7.0		63.56		
A8	11.75		61.76		
A7	13.625		61.52		
A6	12.292		62.51		
A5	17.417		60.85		
A4	16.75		61.55		
A3	12.833		64.58		
A2	16.833		63.67		
A1	10.5		66.86		

---

**NODE ANALYSIS (cont.)**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
TOR2	10.5		67.12		
BOR2	2.0		71.87		
PD	2.0		72.05		
PS	2.0		38.05		
FLG	1.0		38.58		
UG1	-3.0		40.34		
UG2	-3.0		40.46		
UG0	-3.0		40.47		
UG3	-3.0		40.49		
BF1	2.0		38.48		
BF2	-3.0		53.16		
UG4	-3.0		53.2		
UG5	-3.0		54.13		
UG6	-3.0		54.91		
UG7	-3.0		54.92		
UG8	-3.0		54.99		
UG9	-3.0		55.11		
TEST	-3.0		55.19	250.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-8

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	19.667 18.417	5.60	14.82 14.82	1 1.049	T 5.0	1.250 5.000 6.250	120 0.0747	7.000 0.541 0.467			Vel = 5.50
1			0.0 14.82					8.008			K Factor = 5.24
2H to 1	19.667 18.417	5.60	14.82 14.82	1 1.049	T 5.0	1.250 5.000 6.250	120 0.0747	7.000 0.541 0.467			Vel = 5.50
1			0.0 14.82					8.008			K Factor = 5.24
3H to 2	19.667 18.417	5.60	17.37 17.37	1 1.049	T 5.0	1.250 5.000 6.250	120 0.1003	9.623 0.541 0.627			Vel = 6.45
2			0.0 17.37					10.791			K Factor = 5.29
4H to 4	20.500 19.375	5.60	20.28 20.28	1 1.049	T 5.0	1.125 5.000 6.125	120 0.1336	13.117 0.487 0.818			Vel = 7.53
4			0.0 20.28					14.422			K Factor = 5.34
5H to 5	21.083 19.833	5.60	20.98 20.98	1 1.049	T 5.0	1.250 5.000 6.250	120 0.1422	14.036 0.541 0.889			Vel = 7.79
5			0.0 20.98					15.466			K Factor = 5.33
6H to 6	21.208 20.125	5.60	17.73 17.73	1 1.049	T 5.0	1.083 5.000 6.083	120 0.1042	10.026 0.469 0.634			Vel = 6.58
6			0.0 17.73					11.129			K Factor = 5.31
7H to 7	21.208 19.833	5.60	18.38 18.38	1 1.049	E T 2.0 5.0	1.375 7.000 8.375	120 0.1112	10.770 0.596 0.931			Vel = 6.82
7			0.0 18.38					12.297			K Factor = 5.24
8H to 8	21.167 20.333	5.60	27.30 27.3	1 1.049	T 5.0	0.833 5.000 5.833	120 0.2314	23.773 0.361 1.350			Vel = 10.13
8			0.0 27.30					25.484			K Factor = 5.41
9H to 9	21.167 20.333	5.60	27.52 27.52	1 1.049	2E 4.0	0.833 4.000 4.833	120 0.2348	24.149 0.361 1.135			Vel = 10.22
9			0.0 27.52					25.645			K Factor = 5.43
1 to 2	18.417 18.417		29.63 29.63	1 1.049		10.333 10.333	120 0.2693	8.008 0.0 2.783			Vel = 11.00

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-8

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
2 to 210	18.417 18.333		17.37 47.0	1 1.049	T	5.0	3.250 5.000 8.250	120 0.6324	10.791 0.036 5.217		Vel = 17.45	
210			0.0 47.00						16.044		K Factor = 11.73	
3 to 210	18.417 18.333	.0	0.0 0.0	1 1.049	T	5.0	6.750 5.000 11.750	120 0	16.008 0.036 0.0		Vel = 0	
210			0.0 0.0						16.044		K Factor = 0	
4 to 211	19.375 19.250		20.28 20.28	1 1.049	T	5.0	7.708 5.000 12.708	120 0.1335	14.422 0.054 1.697		Vel = 7.53	
211			0.0 20.28						16.173		K Factor = 5.04	
5 to 212	19.833 19.833		20.98 20.98	1 1.049	T	5.0	3.250 5.000 8.250	120 0.1421	15.466 0.0 1.172		Vel = 7.79	
212			0.0 20.98						16.638		K Factor = 5.14	
6 to 7	20.125 19.833		17.73 17.73	1 1.049			10.000 10.000	120 0.1042	11.129 0.126 1.042		Vel = 6.58	
7 to 213	19.833 19.958		18.38 36.11	1 1.049	T	5.0	6.750 5.000 11.750	120 0.3883	12.297 -0.054 4.562		Vel = 13.40	
213			0.0 36.11						16.805		K Factor = 8.81	
8 to 215	20.333 19.333		27.30 27.3	1 1.049	E T	2.0 5.0	5.417 7.000 12.417	120 0.2315	25.484 0.433 2.875		Vel = 10.13	
215			0.0 27.30						28.792		K Factor = 5.09	
9 to 216	20.333 19.333		27.52 27.52	1 1.049	E T	2.0 5.0	6.500 7.000 13.500	120 0.2349	25.645 0.433 3.171		Vel = 10.22	
216			0.0 27.52						29.249		K Factor = 5.09	
210 to 211	18.333 19.250		47.00 47.0	1.5 1.61			6.708 6.708	120 0.0784	16.044 -0.397 0.526		Vel = 7.41	
211 to 212	19.250 19.833		20.29 67.29	1.5 1.61			4.708 4.708	120 0.1523	16.173 -0.252 0.717		Vel = 10.60	
212 to 213	19.833 19.958		20.98 88.27	1.5 1.61			0.875 0.875	120 0.2526	16.638 -0.054 0.221		Vel = 13.91	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-8

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
213 to 214	19.958 20.333		36.11 124.38	1.5 1.61	3E	12.0	5.750 12.000 17.750	120 0.4749	16.805 -0.162 8.430			Vel = 19.60
214 to 215	20.333 19.333		0.0 124.38	1.5 1.61			6.917 6.917	120 0.4751	25.073 0.433 3.286			Vel = 19.60
215 to 216	19.333 19.333		27.30 151.68	1.5 1.61			0.667 0.667	120 0.6852	28.792 0.0 0.457			Vel = 23.90
216 to 217	19.333 19.333		27.52 179.2	1.5 1.61	E	4.0	5.708 4.000 9.708	120 0.9335	29.249 0.0 9.062			Vel = 28.24
217			0.0 179.20						38.311			K Factor = 28.95
217 to 218	19.333 12.083		179.20 179.2	1.5 1.61	T	8.0	7.292 8.000 15.292	120 0.9334	38.311 3.140 14.274			Vel = 28.24
218			0.0 179.20						55.725			K Factor = 24.01
218 to D3	12.083 12.750		179.20 179.2	4 4.26	2E	26.334	26.792 26.334 53.126	120 0.0082	55.725 -0.289 0.434			Vel = 4.03
D3 to D2	12.750 11.125		0.0 179.2	4 4.26	2E	26.334	31.042 26.334 57.376	120 0.0082	55.870 0.704 0.468			Vel = 4.03
D2 to D1	11.125 7		0.0 179.2	4 4.26	4E	52.668	52.583 52.668 105.251	120 0.0082	57.042 1.787 0.859			Vel = 4.03
D1			0.0 179.20						59.688			K Factor = 23.20
D1 to B2	7 7		179.20 179.2	4 4.26	T	26.334	2.333 26.334 28.667	120 0.0082	59.688 0.0 0.234			Vel = 4.03
B2			0.0 179.20						59.922			K Factor = 23.15
B2 to B1	7 7		179.20 179.2	4 4.26	T B S Fsp	26.334	4.958 15.8 28.968 0.0	120 0.0082	59.922 3.000 0.622			* * Fixed Loss = 3 Vel = 4.03
B1			0.0 179.20						63.544			K Factor = 22.48
B1 to A9	7 7		179.20 179.2	4 4.26			1.417 1.417	120 0.0078	63.544 0.0 0.011			Vel = 4.03
A9 to A8	7 11.750		0.0 179.2	4 4.26	2E	26.334	6.208 26.334 32.542	120 0.0082	63.555 -2.057 0.266			Vel = 4.03

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-8

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A8			0.0 179.20						61.764		K Factor = 22.80	
A8 to A7	11.750 13.625		179.20 179.2	4 4.26	3E	39.501	29.750 39.501 69.251	120 0.0082	61.764 -0.812 0.565		Vel = 4.03	
A7 to A6	13.625 12.292		0.0 179.2	4 4.26	2E	26.334	24.167 26.334 50.501	120 0.0082	61.517 0.577 0.413		Vel = 4.03	
A6 to A5	12.292 17.417		0.0 179.2	4 4.26	2E	26.334	42.792 26.334 69.126	120 0.0082	62.507 -2.220 0.565		Vel = 4.03	
A5 to A4	17.417 16.750		0.0 179.2	4 4.26	2E	26.334	23.333 26.334 49.667	120 0.0082	60.852 0.289 0.406		Vel = 4.03	
A4			0.0 179.20						61.547		K Factor = 22.84	
A4 to A3	16.750 12.833		179.20 179.2	4 4.26	4E	52.668	111.000 52.668 163.668	120 0.0082	61.547 1.696 1.337		Vel = 4.03	
A3 to A2	12.833 16.833		0.0 179.2	4 4.26	2E	26.334	73.875 26.334 100.209	120 0.0082	64.580 -1.732 0.818		Vel = 4.03	
A2 to A1	16.833 10.500		0.0 179.2	4 4.26	2E	26.334	28.708 26.334 55.042	120 0.0082	63.666 2.743 0.449		Vel = 4.03	
A1 to TOR2	10.500 10.500		0.0 179.2	4 4.26	E	13.167	18.375 13.167 31.542	120 0.0082	66.858 0.0 0.258		Vel = 4.03	
TOR2			0.0 179.20						67.116		K Factor = 21.87	
TOR2 to BOR2	10.500 2		179.20 179.2	6 6.357	T B Fsp	37.72 12.573 0.0	9.042 50.293 59.335	120 0.0012	67.116 4.681 0.069		** Fixed Loss = 1 Vel = 1.81	
BOR2			0.0 179.20						71.866		K Factor = 21.14	
BOR2 to PD	2 2		179.20 179.2	6 6.357	E 2T B S	17.603 75.44 12.573 40.235	11.542 145.851 157.393	120 0.0012	71.866 0.0 0.183		Vel = 1.81	
PD			0.0 179.20						72.049		K Factor = 21.11	
System Demand Pressure									72.049			
Safety Margin									9.995			
Continuation Pressure									82.044			
Pressure @ Pump Outlet									82.044			
Pressure From Pump Curve									-43.994			
Pressure @ Pump Inlet									38.050			
PS to FLG	2 1		0.0 179.2	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0012	38.050 0.433 0.098		Vel = 1.81	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-8

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 179.20					38.581		K Factor = 28.85	
FLG to UG1	1 -3		179.20 179.2	6 6.16	E 20.084	4.000 20.084 24.084	140	38.581 1.732 0.025		Vel = 1.93	
			0.0 179.20					40.338		K Factor = 28.22	
UG1 to UG2	-3 -3		179.20 179.2	6 6.16	T 43.037	77.000 43.037 120.037	140	40.338 0.0 0.123		Vel = 1.93	
UG2 to UG3	-3 -3		-37.84 141.36	8 8.27		179.000 179.000	140	40.461 0.0 0.028		Vel = 0.84	
			0.0 141.36					40.489		K Factor = 22.22	
UG2 to UG0	-3 -3		37.84 37.84	8 8.27	V 20.56	261.000 20.560 281.560	140	40.461 0.0 0.004		Vel = 0.23	
UG0 to UG3	-3 -3		0.0 37.84	8 8.27	10V T 55.354	205.602 55.354 1767.956	140	40.465 0.0 0.024		Vel = 0.23	
			0.0 37.84					40.489		K Factor = 5.95	
UG3 to BF1	-3 2		179.20 179.2	8 8.27	G 2V 41.12	521.000 41.12 104.382 56.936	140	40.489 -2.166 0.152		Vel = 1.07	
BF1 to BF2	2 -3		0.0 179.2	8 8.27	2E	56.936 15.000 56.936 71.936	140	38.475 14.666 0.017		** Fixed Loss = 12.5 Vel = 1.07	
BF2 to UG4	-3 -3		0.0 179.2	8 8.27	V T 55.354	20.56 75.000 55.354 75.914 150.914	140	53.158 0.0 0.037		Vel = 1.07	
			0.0 179.20					53.195		K Factor = 24.57	
UG4 to UG5	-3 -3		179.20 179.2	8 8.27	4G 8V 186.874	4156.000 215.624 4371.624	150	53.195 0.0 0.934		Vel = 1.07	
UG5 to UG6	-3 -3		0.0 179.2	8 8.27	8V E T 2G 32.344	186.874 32.344 296.483 62.89 14.375 3656.483	150	54.129 0.0 0.781		Vel = 1.07	
			0.0 179.20					54.910		K Factor = 24.18	
UG6 to UG7	-3 -3		179.20 179.2	12 12.34	T	106.533 47.000 106.533 153.533	150	54.910 0.0 0.005		Vel = 0.48	
			0.0								

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-8

Page 11  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			179.20							54.915	K Factor = 24.18	
UG7 to UG8	-3 -3		179.20 179.2	6 6.16	E T	22.818 48.896	13.000 71.714	150	54.915 0.0		Vel = 1.93	
			0.0 179.20							54.991	K Factor = 24.17	
UG8 to UG9	-3 -3		179.20 179.2	6 6.16	T	43.037 43.037	77.000 120.037	140	54.991 0.0		Vel = 1.93	
UG9 to TEST	-3 -3		0.0 179.2	12 12.34	2V T G E	15.94 93.767 9.377 42.195	2136.000 161.279	140	55.113 0.0		Vel = 0.48	
			250.00 429.20							55.193	Qa = 250.00 K Factor = 57.77	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-9  
Drawing : FP17  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-9  
Contract : 4070  
Data File : NWHES 09 SYS-2 ZONE3 617 LH EC.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP17  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-9  
**Remote area location** 4TH-5TH GRADE 617  
**Occupancy classification** LH  
**Density** 0.10 - Gpm/SqFt  
**Area of application** 1035 - SqFt  
**Coverage/sprinkler** 324 SF MAX - SqFt  
**Type of sprinkler calculated** QR EC PENDENT 1/2" 155F 5.6K  
**# Sprinklers calculated** 6  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 258.623 - GPM @ 48.547 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC

**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**


REDUCE AREA FOR HYDRAULIC CALCULATION PER NFPA13 2013 SECTION 11.2.3.2.3

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-9

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 13.932 D2 - System Flow : 158.623 D2 - System Pressure : 75.900 Hose ( Demand ) : _____ D3 - System Demand : 158.623 Hose ( Adj City ) : 100 Safety Margin : 8.354
--	--	---



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-9

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-9

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			84.254	158.62	75.9
TEST	58.0	50	756.0	56.9	258.62	56.9

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	29.167	5.6	21.6	26.03	0.1 224
2H	29.167	5.6	21.94	26.23	0.1 224
3H	29.167	5.6	23.11	26.92	0.1 224
4H	29.167	5.6	21.75	26.12	0.1 196
5H	29.167	5.6	22.09	26.32	0.1 196
6H	29.167	5.6	23.27	27.01	0.1 196
1	29.104		23.68		
2	29.104		24.04		
3	29.104		25.32		
4	28.167		24.28		
5	28.167		24.65		
6	28.167		25.93		
600	29.104		34.14		
601	28.167		34.81		
A16	26.917		39.36		
A15	26.917		52.52		
A14T	26.917		54.48		
A14B	23.0		56.29		
A13T	23.0		56.46		
A13B	12.917		60.98		
A12	11.167		62.13		
A11	11.167		62.8		
A10	11.167		63.19		
A9	7.0		68.48		
A8	11.75		66.64		
A7	13.625		66.28		
A6	12.292		67.18		
A5	17.417		65.42		
A4	16.75		66.03		
A3	12.833		68.79		
A2	16.833		67.71		
A1	10.5		70.81		
TOR2	10.5		71.02		
BOR2	2.0		75.75		
PD	2.0		75.9		
PS	2.0		40.26		
FLG	1.0		40.77		
UG1	-3.0		42.52		
UG2	-3.0		42.62		
UG0	-3.0		42.62		
UG3	-3.0		42.64		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-9

Page 5  
Date 4/19/22

---

## NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
BF1	2.0		40.6		
BF2	-3.0		55.28		
UG4	-3.0		55.31		
UG5	-3.0		56.05		
UG6	-3.0		56.68		
UG7	-3.0		56.68		
UG8	-3.0		56.74		
UG9	-3.0		56.84		
TEST	-3.0		56.9	100.0	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-9

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	29.167 29.104	5.60	26.03 26.03	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120	21.600 0.027 2.048		Vel = 9.66	
1			0.0 26.03						23.675		K Factor = 5.35	
2H to 2	29.167 29.104	5.60	26.23 26.23	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120	21.938 0.027 2.078		Vel = 9.74	
2			0.0 26.23						24.043		K Factor = 5.35	
3H to 3	29.167 29.104	5.60	26.92 26.92	1 1.049	2E T	4.0 5.0	0.667 9.000 9.667	120	23.109 0.027 2.180		Vel = 9.99	
3			0.0 26.92						25.316		K Factor = 5.35	
4H to 4	29.167 28.167	5.60	26.12 26.12	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	21.749 0.433 2.096		Vel = 9.70	
4			0.0 26.12						24.278		K Factor = 5.30	
5H to 5	29.167 28.167	5.60	26.32 26.32	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	22.089 0.433 2.127		Vel = 9.77	
5			0.0 26.32						24.649		K Factor = 5.30	
6H to 6	29.167 28.167	5.60	27.01 27.01	1 1.049	2E T	4.0 5.0	0.833 9.000 9.833	120	23.266 0.433 2.231		Vel = 10.03	
6			0.0 27.01						25.930		K Factor = 5.30	
1 to 2	29.104 29.104		26.03 26.03	1.5 1.61			14.000 14.000	120	23.675 0.0 0.368		Vel = 4.10	
2 to 3	29.104 29.104		26.23 52.26	1.5 1.61			13.333 13.333	120	24.043 0.0 1.273		Vel = 8.24	
3 to 600	29.104 29.104		26.92 79.18	1.5 1.61	T	8.0	34.833 8.000 42.833	120	25.316 0.0 8.823		Vel = 12.48	
600			0.0 79.18						34.139		K Factor = 13.55	
4 to 5	28.167 28.167		26.12 26.12	1.5 1.61			14.000 14.000	120	24.278 0.0 0.371		Vel = 4.12	
5 to 6	28.167 28.167		26.32 52.44	1.5 1.61			13.333 13.333	120	24.649 0.0 1.281		Vel = 8.26	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-9

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
6 to 601	28.167 28.167		27.01 79.45	1.5 1.61	T	8.0	34.833 8.000 42.833	120 0.2073	25.930 0.0 8.878			Vel = 12.52
601			0.0 79.45						34.808			K Factor = 13.47
600 to 601	29.104 28.167		79.18 79.18	2.5 2.635			14.083 14.083	120 0.0187	34.139 0.406 0.263			Vel = 4.66
601 to A16	28.167 26.917		79.44 158.62	2.5 2.635	2E T	16.474 16.474	26.375 32.948 59.323	120 0.0676	34.808 0.541 4.012			Vel = 9.33
A16			0.0 158.62						39.361			K Factor = 25.28
A16 to A15	26.917 26.917		158.62 158.62	2.5 2.635	T	16.474	178.042 16.474 194.516	120 0.0676	39.361 0.0 13.155			Vel = 9.33
A15 to A14T	26.917 26.917		0.0 158.62	2.5 2.635	T	16.474	12.542 16.474 29.016	120 0.0676	52.516 0.0 1.962			Vel = 9.33
A14T			0.0 158.62						54.478			K Factor = 21.49
A14T to A14B	26.917 23		158.62 158.62	4 4.26	E	13.167	4.000 13.167 17.167	120 0.0066	54.478 1.696 0.113			Vel = 3.57
A14B to A13T	23 23		0.0 158.62	4 4.26	E	13.167	13.750 13.167 26.917	120 0.0065	56.287 0.0 0.175			Vel = 3.57
A13T			0.0 158.62						56.462			K Factor = 21.11
A13T to A13B	23 12.917		158.62 158.62	4 4.26	E	13.167	10.083 13.167 23.250	120 0.0065	56.462 4.367 0.152			Vel = 3.57
A13B			0.0 158.62						60.981			K Factor = 20.31
A13B to A12	12.917 11.167		158.62 158.62	4 4.26	3E	39.501	20.708 39.501 60.209	120 0.0065	60.981 0.758 0.392			Vel = 3.57
A12 to A11	11.167 11.167		0.0 158.62	4 4.26	4E	52.668	49.375 52.668 102.043	120 0.0065	62.131 0.0 0.665			Vel = 3.57
A11 to A10	11.167 11.167		0.0 158.62	4 4.26	2E	26.334	33.750 26.334 60.084	120 0.0065	62.796 0.0 0.392			Vel = 3.57
A10			0.0 158.62						63.188			K Factor = 19.95
A10 to A9	11.167 7		158.62 158.62	4 4.26	T B Fsp	26.334 15.8 0.0	3.833 71.102 74.935	120 0.0065	63.188 4.805 0.488			* * Fixed Loss = 3 Vel = 3.57

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-9

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
					S	28.968						
A9 to A8	7 11.750		0.0 158.62	4 4.26	2E	26.334	6.208 26.334 32.542	120 0.0065	68.481 -2.057 0.212		Vel = 3.57	
A8			0.0 158.62						66.636		K Factor = 19.43	
A8 to A7	11.750 13.625		158.62 158.62	4 4.26	3E	39.501	30.292 39.501 69.793	120 0.0065	66.636 -0.812 0.455		Vel = 3.57	
A7 to A6	13.625 12.292		0.0 158.62	4 4.26	2E	26.334	24.167 26.334 50.501	120 0.0065	66.279 0.577 0.329		Vel = 3.57	
A6 to A5	12.292 17.417		0.0 158.62	4 4.26	2E	26.334	42.792 26.334 69.126	120 0.0065	67.185 -2.220 0.451		Vel = 3.57	
A5 to A4	17.417 16.750		0.0 158.62	4 4.26	2E	26.334	23.333 26.334 49.667	120 0.0065	65.416 0.289 0.324		Vel = 3.57	
A4			0.0 158.62						66.029		K Factor = 19.52	
A4 to A3	16.750 12.833		158.62 158.62	4 4.26	4E	52.668	110.458 52.668 163.126	120 0.0065	66.029 1.696 1.063		Vel = 3.57	
A3 to A2	12.833 16.833		0.0 158.62	4 4.26	2E	26.334	74.083 26.334 100.417	120 0.0065	68.788 -1.732 0.654		Vel = 3.57	
A2 to A1	16.833 10.500		0.0 158.62	4 4.26	2E	26.334	28.708 26.334 55.042	120 0.0065	67.710 2.743 0.359		Vel = 3.57	
A1 to TOR2	10.500 10.500		0.0 158.62	4 4.26	E	13.167	18.375 13.167 31.542	120 0.0065	70.812 0.0 0.206		Vel = 3.57	
TOR2			0.0 158.62						71.018		K Factor = 18.82	
TOR2 to BOR2	10.500 2		158.62 158.62	6 6.357	T B Fsp	37.72 12.573 0.0	9.042 50.293 59.335	120 0.0009	71.018 4.681 0.055		** Fixed Loss = 1 Vel = 1.60	
BOR2			0.0 158.62						75.754		K Factor = 18.22	
BOR2 to PD	2 2		158.62 158.62	6 6.357	E 2T B S	17.603 75.44 12.573 40.235	11.542 145.851 157.393	120 0.0009	75.754 0.0 0.146		Vel = 1.60	
PD			0.0 158.62						75.900		K Factor = 18.21	
System Demand Pressure									75.900			
Safety Margin									8.354			
Continuation Pressure									84.254			

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-9

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
Pressure @ Pump Outlet									84.254			
Pressure From Pump Curve									-43.996			
Pressure @ Pump Inlet									40.258			
PS to FLG	2 1		0.0 158.62	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0009	40.258 0.433 0.079		Vel = 1.60	
FLG									40.770		K Factor = 24.84	
FLG to UG1	1 -3		158.62 158.62	6 6.16	E	20.084	4.000 20.084 24.084	140 0.0008	40.770 1.732 0.020		Vel = 1.71	
UG1									42.522		K Factor = 24.32	
UG1 to UG2	-3 -3		158.62 158.62	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0008	42.522 0.0 0.098		Vel = 1.71	
UG2 to UG3									42.620 0.0			
UG2 to UG3	-3 -3		-33.50 125.12	8 8.27			179.000 179.000	140 0.0001	42.620 0.0 0.022		Vel = 0.75	
UG3									42.642		K Factor = 19.16	
UG2 to UG0	-3 -3		33.50 33.5	8 8.27	V	20.56	261.000 20.560 281.560	140 0	42.620 0.0 0.003		Vel = 0.20	
UG0 to UG3									42.623 0.0			
UG0 to UG3	-3 -3		0.0 33.5	8 8.27	10V T	205.602 55.354	1507.000 260.956 1767.956	140 0	42.623 0.0 0.019		Vel = 0.20	
UG3									42.642		K Factor = 5.13	
UG3 to BF1	-3 2		158.62 158.62	8 8.27	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140 0.0002	42.642 -2.166 0.122		Vel = 0.95	
BF1 to BF2									40.598 14.666		* * Fixed Loss = 12.5	
BF1 to BF2	2 -3		0.0 158.62	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0002	40.598 14.666 0.013		Vel = 0.95	
BF2 to UG4									55.277 0.0			
BF2 to UG4	-3 -3		0.0 158.62	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0002	55.277 0.0 0.029		Vel = 0.95	
UG4									55.306		K Factor = 21.33	
UG4 to UG5	-3 -3		158.62 158.62	8 8.27	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150 0.0002	55.306 0.0 0.746		Vel = 0.95	
UG5 to UG6									56.052 0.0			
UG5 to UG6	-3 -3		0.0 158.62	8 8.27	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150 0.0002	56.052 0.0 0.624		Vel = 0.95	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-9

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG6			0.0 158.62					56.676		K Factor = 21.07	
UG6 to UG7	-3 -3		158.62	12	T 106.533	47.000 106.533	150	56.676 0.0		Vel = 0.43	
UG7			0.0 158.62					56.679		K Factor = 21.07	
UG7 to UG8	-3 -3		158.62	6	E T 22.818 48.896	13.000 71.714	150	56.679 0.0		Vel = 1.71	
UG8			0.0 158.62					56.740		K Factor = 21.06	
UG8 to UG9	-3 -3		158.62	6	T 43.037	77.000 43.037	140	56.740 0.0		Vel = 1.71	
UG9 to TEST	-3 -3		0.0 158.62	12	2V T G E 15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140	56.837 0.0 0.064		Vel = 0.43	
TEST			100.00 258.62					56.901		Qa = 100.00 K Factor = 34.28	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-10  
Drawing : FP17  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-10  
Contract : 4070  
Data File : NWHES 10 SYS-2 ZONE3 616 LH STD.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP17  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-10  
**Remote area location** 4TH-5TH GRADE 614  
**Occupancy classification** LH  
**Density** 0.10 - Gpm/SqFt  
**Area of application** 978 - SqFt  
**Coverage/sprinkler** 225 SF MAX - SqFt  
**Type of sprinkler calculated** QR EC PENDENT 1/2" 155F 5.6K  
**# Sprinklers calculated** 6  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 231.274 - GPM @ 41.517 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO** ABL FIRE PROTECTION, LLC

**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**


REDUCE AREA FOR HYDRAULIC CALCULATION PER NFPA13 2013 SECTION 11.2.3.2.3

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-10

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 12.993 D2 - System Flow : 131.274 D2 - System Pressure : 69.456 Hose ( Demand ) : _____ D3 - System Demand : 131.274 Hose ( Adj City ) : 100 Safety Margin : 15.589
--	--	--





# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-10

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                 Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-10

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			85.045	131.27	69.456
TEST	58.0	50	756.0	57.106	231.27	57.106

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	27.0	5.6	12.25	19.6	0.1 196
2H	27.0	5.6	13.86	20.85	0.1 196
3H	27.0	5.6	19.72	24.87	0.1 196
4H	26.646	5.6	12.5	19.8	0.1 196
5H	26.646	5.6	14.14	21.05	0.1 196
6H	26.646	5.6	20.1	25.11	0.1 196
1	27.833		13.1		
2	27.833		14.86		
3	27.833		21.24		
4	27.479		13.4		
5	27.479		15.18		
6	27.479		21.69		
610	27.833		29.57		
611	27.479		30.17		
A17	26.917		36.7		
A16	26.917		39.34		
A15	26.917		48.61		
A14T	26.917		49.99		
A14B	23.0		51.77		
A13T	23.0		51.89		
A13B	12.917		56.36		
A12	11.167		57.4		
A11	11.167		57.87		
A10	11.167		58.14		
A9	7.0		63.29		
A8	11.75		61.38		
A7	13.625		60.89		
A6	12.292		61.7		
A5	17.417		59.8		
A4	16.75		60.32		
A3	12.833		62.76		
A2	16.833		61.49		
A1	10.5		64.49		
TOR2	10.5		64.63		
BOR2	2.0		69.35		
PD	2.0		69.46		
PS	2.0		41.05		
FLG	1.0		41.54		
UG1	-3.0		43.28		
UG2	-3.0		43.35		
UG0	-3.0		43.35		

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-10

Page 5  
Date 4/19/22

---

## NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
UG3	-3.0		43.37		
BF1	2.0		41.29		
BF2	-3.0		55.96		
UG4	-3.0		55.98		
UG5	-3.0		56.51		
UG6	-3.0		56.95		
UG7	-3.0		56.95		
UG8	-3.0		56.99		
UG9	-3.0		57.06		
TEST	-3.0		57.11	100.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-10

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	27 27.833	5.60	19.60 19.6	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1254	12.250 -0.361 1.212		Vel = 7.28	
1			0.0 19.60					13.101		K Factor = 5.42	
2H to 2	27 27.833	5.60	20.85 20.85	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1406	13.858 -0.361 1.359		Vel = 7.74	
2			0.0 20.85					14.856		K Factor = 5.41	
3H to 3	27 27.833	5.60	24.87 24.87	1 1.049	2E T 4.0 5.0	0.667 9.000 9.667	120 0.1948	19.719 -0.361 1.883		Vel = 9.23	
3			0.0 24.87					21.241		K Factor = 5.40	
4H to 4	26.646 27.479	5.60	19.80 19.8	1 1.049	2E T 4.0 5.0	0.833 9.000 9.833	120 0.1277	12.500 -0.361 1.256		Vel = 7.35	
4			0.0 19.80					13.395		K Factor = 5.41	
5H to 5	26.646 27.479	5.60	21.06 21.06	1 1.049	2E T 4.0 5.0	0.833 9.000 9.833	120 0.1432	14.136 -0.361 1.408		Vel = 7.82	
5			0.0 21.06					15.183		K Factor = 5.40	
6H to 6	26.646 27.479	5.60	25.11 25.11	1 1.049	2E T 4.0 5.0	0.833 9.000 9.833	120 0.1982	20.099 -0.361 1.949		Vel = 9.32	
6			0.0 25.11					21.687		K Factor = 5.39	
1 to 2	27.833 27.833		19.60 19.6	1 1.049		14.000 14.000	120 0.1254	13.101 0.0 1.755		Vel = 7.28	
2 to 3	27.833 27.833		20.85 40.45	1 1.049		13.333 13.333	120 0.4789	14.856 0.0 6.385		Vel = 15.02	
3 to 610	27.833 27.833		24.87 65.32	1 1.049	T 5.0	2.167 5.000 7.167	120 1.1621	21.241 0.0 8.329		Vel = 24.25	
610			0.0 65.32					29.570		K Factor = 12.01	
4 to 5	27.479 27.479		19.80 19.8	1 1.049		14.000 14.000	120 0.1277	13.395 0.0 1.788		Vel = 7.35	
5 to 6	27.479 27.479		21.05 40.85	1 1.049		13.333 13.333	120 0.4878	15.183 0.0 6.504		Vel = 15.16	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-10

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
6 to 611	27.479 27.479		25.11 65.96	1 1.049	T 5.0	2.167 5.000 7.167	120	21.687 0.0			
			0.0							Vel = 24.49	
611			65.96					30.169		K Factor = 12.01	
610 to 611	27.833 27.479		65.32 65.32	2 2.157		12.833 12.833	120	29.570 0.153 0.446		Vel = 5.74	
611 to A17	27.479 26.917		65.95 131.27	2 2.157	2E T 12.307 12.307	25.167 24.614 49.781	120	30.169 0.243 6.288		Vel = 11.53	
A17			0.0 131.27					36.700		K Factor = 21.67	
A17 to A16	26.917 26.917		131.27 131.27	2.5 2.635		55.417 55.417	120	36.700 0.0 2.640		Vel = 7.72	
A16 to A15	26.917 26.917		0.0 131.27	2.5 2.635	T 16.474	178.042 16.474 194.516	120	39.340 0.0 9.270		Vel = 7.72	
A15 to A14T	26.917 26.917		0.0 131.27	2.5 2.635	T 16.474	12.542 16.474 29.016	120	48.610 0.0 1.382		Vel = 7.72	
A14T			0.0 131.27					49.992		K Factor = 18.57	
A14T to A14B	26.917 23		131.27 131.27	4 4.26	E	13.167 4.000 13.167 17.167	120	49.992 1.696 0.080		Vel = 2.95	
A14B to A13T	23 23		0.0 131.27	4 4.26	E	13.167 13.750 13.167 26.917	120	51.768 0.0 0.123		Vel = 2.95	
A13T			0.0 131.27					51.891		K Factor = 18.22	
A13T to A13B	23 12.917		131.27 131.27	4 4.26	E	13.167 10.083 13.167 23.250	120	51.891 4.367 0.107		Vel = 2.95	
A13B			0.0 131.27					56.365		K Factor = 17.48	
A13B to A12	12.917 11.167		131.27 131.27	4 4.26	3E	39.501 20.708 39.501 60.209	120	56.365 0.758 0.277		Vel = 2.95	
A12			0.0 131.27					57.400		K Factor = 17.33	
A12 to A11	11.167 11.167		131.27 131.27	4 4.26	4E	52.668 49.375 52.668 102.043	120	57.400 0.0 0.468		Vel = 2.95	
A11 to A10	11.167 11.167		0.0 131.27	4 4.26	2E	26.334 33.750 26.334 60.084	120	57.868 0.0 0.276		Vel = 2.95	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-10

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A10 to A9	11.167 7		0.0 131.27	4 4.26	T B Fsp S	26.334 15.8 0.0 28.968	3.833 71.102 74.935	120 0.0046	58.144 4.805 0.344		** Fixed Loss = 3 Vel = 2.95	
A9 to A8	7 11.750		0.0 131.27	4 4.26	2E	26.334 26.334 32.542	6.208 26.334 32.542	120 0.0046	63.293 -2.057 0.149		Vel = 2.95	
A8 to A7	11.750 13.625		0.0 131.27	4 4.26	3E	39.501 39.501 69.793	30.292 39.501 69.793	120 0.0046	61.385 -0.812 0.321		Vel = 2.95	
A7 to A6	13.625 12.292		0.0 131.27	4 4.26	2E	26.334 26.334 50.501	24.167 26.334 50.501	120 0.0046	60.894 0.577 0.232		Vel = 2.95	
A6 to A5	12.292 17.417		0.0 131.27	4 4.26	2E	26.334 26.334 69.126	42.792 26.334 69.126	120 0.0046	61.703 -2.220 0.318		Vel = 2.95	
A5 to A4	17.417 16.750		0.0 131.27	4 4.26	2E	26.334 26.334 49.667	23.333 26.334 49.667	120 0.0046	59.801 0.289 0.228		Vel = 2.95	
A4			0.0 131.27						60.318		K Factor = 16.90	
A4 to A3	16.750 12.833		131.27 131.27	4 4.26	4E	52.668 52.668 163.126	110.458 52.668 163.126	120 0.0046	60.318 1.696 0.749		Vel = 2.95	
A3 to A2	12.833 16.833		0.0 131.27	4 4.26	2E	26.334 26.334 100.417	74.083 26.334 100.417	120 0.0046	62.763 -1.732 0.461		Vel = 2.95	
A2 to A1	16.833 10.500		0.0 131.27	4 4.26	2E	26.334 26.334 55.042	28.708 26.334 55.042	120 0.0046	61.492 2.743 0.253		Vel = 2.95	
A1 to TOR2	10.500 10.500		0.0 131.27	4 4.26	E	13.167 13.167 31.542	18.375 13.167 31.542	120 0.0046	64.488 0.0 0.145		Vel = 2.95	
TOR2			0.0 131.27						64.633		K Factor = 16.33	
TOR2 to BOR2	10.500 2		131.27 131.27	6 6.357	T B Fsp	37.72 12.573 0.0	9.042 50.293 59.335	120 0.0007	64.633 4.681 0.039		** Fixed Loss = 1 Vel = 1.33	
BOR2			0.0 131.27						69.353		K Factor = 15.76	
BOR2 to PD	2 2		131.27 131.27	6 6.357	E 2T B S	17.603 75.44 12.573 40.235	11.542 145.851 157.393	120 0.0007	69.353 0.0 0.103		Vel = 1.33	
PD			0.0 131.27						69.456		K Factor = 15.75	
System Demand Pressure									69.456			
Safety Margin									15.589			
Continuation Pressure									85.045			

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-10

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
Pressure @ Pump Outlet									85.045			
Pressure From Pump Curve									-43.997			
Pressure @ Pump Inlet									41.048			
PS to FLG	2 1		0.0 131.27	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0006	41.048 0.433 0.055		Vel = 1.33	
FLG			0.0 131.27						41.536		K Factor = 20.37	
FLG to UG1	1 -3		131.27 131.27	6 6.16	E	20.084	4.000 20.084 24.084	140 0.0006	41.536 1.732 0.014		Vel = 1.41	
UG1			0.0 131.27						43.282		K Factor = 19.95	
UG1 to UG2	-3 -3		131.27 131.27	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0006	43.282 0.0 0.069		Vel = 1.41	
UG2 to UG3	-3 -3		-27.72 103.55	8 8.27			179.000 179.000	140 0.0001	43.351 0.0 0.016		Vel = 0.62	
UG3			0.0 103.55						43.367		K Factor = 15.72	
UG2 to UG0	-3 -3		27.72 27.72	8 8.27	V	20.56	261.000 20.560 281.560	140 0	43.351 0.0 0.002		Vel = 0.17	
UG0 to UG3	-3 -3		0.0 27.72	8 8.27	10V T	205.602 55.354	1507.000 260.956 1767.956	140 0	43.353 0.0 0.014		Vel = 0.17	
UG3			0.0 27.72						43.367		K Factor = 4.21	
UG3 to BF1	-3 2		131.27 131.27	8 8.27	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140 0.0001	43.367 -2.166 0.086		Vel = 0.78	
BF1 to BF2	2 -3		0.0 131.27	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0001	41.287 14.666 0.009		* * Fixed Loss = 12.5 Vel = 0.78	
BF2 to UG4	-3 -3		0.0 131.27	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0001	55.962 0.0 0.021		Vel = 0.78	
UG4			0.0 131.27						55.983		K Factor = 17.54	
UG4 to UG5	-3 -3		131.27 131.27	8 8.27	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150 0.0001	55.983 0.0 0.525		Vel = 0.78	
UG5 to UG6	-3 -3		0.0 131.27	8 8.27	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150 0.0001	56.508 0.0 0.439		Vel = 0.78	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-10

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG6			0.0 131.27					56.947		K Factor = 17.40	
UG6 to UG7	-3 -3		131.27	12	T 106.533	47.000 106.533	150	56.947 0.0		Vel = 0.35	
UG7			0.0 131.27					56.950		K Factor = 17.39	
UG7 to UG8	-3 -3		131.27	6	E T 22.818 48.896	13.000 71.714	150	56.950 0.0		Vel = 1.41	
UG8			0.0 131.27					56.993		K Factor = 17.39	
UG8 to UG9	-3 -3		131.27	6	T 43.037	77.000 43.037	140	56.993 0.0		Vel = 1.41	
UG9 to TEST	-3 -3		0.0 131.27	12	2V T G E 15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140	57.061 0.0		Vel = 0.35	
TEST			100.00 231.27					57.106		Qa = 100.00 K Factor = 30.60	





## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-11  
Drawing : FP16  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-11  
Contract : 4070  
Data File : NWHES 11 SYS-2 ZONE3 M301 OH1.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP16  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-11  
**Remote area location** MECH M301  
**Occupancy classification** OH-1  
**Density** 0.15 - Gpm/SqFt  
**Area of application** WHOLE AREA - SqFt  
**Coverage/sprinkler** 130 SF MAX - SqFt  
**Type of sprinkler calculated** QR UPRIGHT 1/2" 155F 5.6K  
**# Sprinklers calculated** 10  
**In-rack demand** N/A - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 445.991 - GPM @ 42.26 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO**

ABL FIRE PROTECTION, LLC  
**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL


**NOTES:**

# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-11

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 42.302 A2 - Adj Resid : 18.917 @ 500 A3 - Adj Resid : 0 @ 719.14	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 719.14 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.71 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 19.904 D2 - System Flow : 195.991 D2 - System Pressure : 70.664 Hose ( Demand ) : _____ D3 - System Demand : 195.991 Hose ( Adj City ) : 250 Safety Margin : 10.727
--	--	--



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-11

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
PD	See Information on Pump Curve			81.391	195.99	70.664
TEST	58.0	50	756.0	54.986	445.99	54.986

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
1H	31.0	5.6	11.75	19.2	0.15 102.375
2H	31.0	5.6	12.75	20.0	0.15 119.438
3H	31.0	5.6	13.9	20.88	0.15 84
4H	32.917	5.6	16.7	22.88	0.15 84
5H	36.333	5.6	10.99	18.56	0.15 102.375
6H	36.333	5.6	11.93	19.34	0.15 119.438
7H	36.333	5.6	13.76	20.77	0.15 84
8H	42.958	5.6	9.42	17.19	0.15 102.375
9H	42.958	5.6	10.24	17.92	0.15 119.438
10H	42.958	5.6	11.82	19.25	0.15 84
1	30.208		13.14		
2	30.208		14.22		
3	30.208		15.46		
5	33.667		13.01		
6	33.667		14.02		
7	33.667		16.26		
8	42.542		10.42		
9	42.542		11.3		
10	42.542		13.01		
CC0	30.208		20.94		
4	31.5		20.39		
CC1	33.667		19.54		
CC2B	34.542		19.82		
CC2T	41.042		17.3		
CC3	42.542		16.87		
CC4	40.792		18.52		
CC5	39.042		20.38		
CC6	37.292		21.89		
CC7	35.583		23.09		
CC8	33.792		24.11		
CC9	32.042		24.92		
C0	30.208		26.66		
C1	33.667		25.2		
C2B	34.542		25.16		
C2T	41.042		22.5		
C4	40.792		22.72		
C5	39.042		23.76		
C6	37.292		24.95		
C7	35.583		26.29		
C8	33.792		27.9		
C9	32.042		29.74		

**NODE ANALYSIS (cont.)**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
C10T	31.583		31.99		
C10B	23.833		36.95		
C11T	23.833		41.26		
C11B	23.333		42.35		
C12B	23.333		43.98		
C12T	26.917		43.61		
C13	26.917		45.58		
A14T	26.917		46.07		
A14B	23.0		47.93		
A13T	23.0		48.19		
A13B	12.917		52.78		
A12	11.167		54.12		
A11	11.167		55.1		
A10	11.167		55.68		
A9	7.0		61.21		
A8	11.75		59.46		
A7	13.625		59.32		
A6	12.292		60.39		
A5	17.417		58.84		
A4	16.75		59.6		
A3	12.833		62.87		
A2	16.833		62.11		
A1	10.5		65.38		
TOR2	10.5		65.69		
BOR2	2.0		70.45		
PD	2.0		70.66		
PS	2.0		37.4		
FLG	1.0		37.95		
UG1	-3.0		39.71		
UG2	-3.0		39.85		
UG0	-3.0		39.86		
UG3	-3.0		39.89		
BF1	2.0		37.9		
BF2	-3.0		52.59		
UG4	-3.0		52.63		
UG5	-3.0		53.73		
UG6	-3.0		54.65		
UG7	-3.0		54.66		
UG8	-3.0		54.75		
UG9	-3.0		54.89		
TEST	-3.0		54.99	250.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	31 30.208	5.60	19.20 19.2	1 1.049	E T	2.0 5.0	1.667 7.000 8.667	120 0.1206	11.749 0.343 1.045		Vel = 7.13	
1			0.0 19.20						13.137		K Factor = 5.30	
2H to 2	31 30.208	5.60	20.00 20.0	1 1.049	E T	2.0 5.0	1.667 7.000 8.667	120 0.1301	12.752 0.343 1.128		Vel = 7.42	
2			0.0 20.00						14.223		K Factor = 5.30	
3H to 3	31 30.208	5.60	20.88 20.88	1 1.049	E T	2.0 5.0	1.667 7.000 8.667	120 0.1409	13.896 0.343 1.221		Vel = 7.75	
3			0.0 20.88						15.460		K Factor = 5.31	
4H to 4	32.917 31.500	5.60	22.88 22.88	1 1.049	2T	10.0	8.458 10.000 18.458	120 0.1670	16.698 0.614 3.082		Vel = 8.49	
4			0.0 22.88						20.394		K Factor = 5.07	
5H to 5	36.333 33.667	5.60	18.56 18.56	1 1.049	T	5.0	2.667 5.000 7.667	120 0.1132	10.988 1.155 0.868		Vel = 6.89	
5			0.0 18.56						13.011		K Factor = 5.15	
6H to 6	36.333 33.667	5.60	19.34 19.34	1 1.049	T	5.0	2.667 5.000 7.667	120 0.1222	11.930 1.155 0.937		Vel = 7.18	
6			0.0 19.34						14.022		K Factor = 5.16	
7H to 7	36.333 33.667	5.60	20.77 20.77	1 1.049	E T	2.0 5.0	2.667 7.000 9.667	120 0.1395	13.761 1.155 1.349		Vel = 7.71	
7			0.0 20.77						16.265		K Factor = 5.15	
8H to 8	42.958 42.542	5.60	17.19 17.19	1 1.049	E T	2.0 5.0	1.333 7.000 8.333	120 0.0984	9.423 0.180 0.820		Vel = 6.38	
8			0.0 17.19						10.423		K Factor = 5.32	
9H to 9	42.958 42.542	5.60	17.92 17.92	1 1.049	E T	2.0 5.0	1.333 7.000 8.333	120 0.1062	10.235 0.180 0.885		Vel = 6.65	
9			0.0 17.92						11.300		K Factor = 5.33	
10H to 10	42.958 42.542	5.60	19.25 19.25	1 1.049	E T	2.0 5.0	1.333 7.000 8.333	120 0.1213	11.821 0.180 1.011		Vel = 7.15	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 19.25						13.012		K Factor = 5.34	
1 to 2	30.208 30.208		19.20 19.2	1 1.049			9.000 9.000	120 0.1207	13.137 0.0 1.086		Vel = 7.13	
2 to 3	30.208 30.208		19.99 39.19	1.25 1.38			10.417 10.417	120 0.1187	14.223 0.0 1.237		Vel = 8.41	
3 to CC0	30.208 30.208		20.88 60.07	1.25 1.38	2E T	6.0 6.0	8.917 12.000 20.917	120 0.2618	15.460 0.0 5.476		Vel = 12.89	
CC0			0.0 60.07						20.936		K Factor = 13.13	
5 to 6	33.667 33.667		18.56 18.56	1 1.049			8.917 8.917	120 0.1134	13.011 0.0 1.011		Vel = 6.89	
6 to 7	33.667 33.667		19.34 37.9	1.25 1.38	2E	6.0	14.083 6.000 20.083	120 0.1117	14.022 0.0 2.243		Vel = 8.13	
7 to CC1	33.667 33.667		20.78 58.68	1.25 1.38	T	6.0	7.042 6.000 13.042	120 0.2507	16.265 0.0 3.270		Vel = 12.59	
CC1			0.0 58.68						19.535		K Factor = 13.28	
8 to 9	42.542 42.542		17.19 17.19	1 1.049			8.917 8.917	120 0.0984	10.423 0.0 0.877		Vel = 6.38	
9 to 10	42.542 42.542		17.92 35.11	1.25 1.38	2E	6.0	11.667 6.000 17.667	120 0.0969	11.300 0.0 1.712		Vel = 7.53	
10 to CC3	42.542 42.542		19.25 54.36	1.25 1.38	E T	3.0 6.0	8.708 9.000 17.708	120 0.2176	13.012 0.0 3.854		Vel = 11.66	
CC3			0.0 54.36						16.866		K Factor = 13.24	
CC0 to 4	30.208 31.500		31.02 31.02	2.5 2.635			5.250 5.250	120 0.0034	20.936 -0.560 0.018		Vel = 1.83	
4 to CC1	31.500 33.667		22.89 53.91	2.5 2.635			8.667 8.667	120 0.0092	20.394 -0.939 0.080		Vel = 3.17	
CC1 to CC2B	33.667 34.542		29.79 83.7	2.5 2.635	3E	24.711	7.083 24.711 31.794	120 0.0207	19.535 -0.379 0.659		Vel = 4.92	
CC2B to CC2T	34.542 41.042		0.0 83.7	2.5 2.635	E	8.237	6.500 8.237 14.737	120 0.0207	19.815 -2.815 0.305		Vel = 4.92	



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
CC2T to CC3	41.042 42.542		0.0 83.7	2.5 2.635	E	8.237	1.917 8.237 10.154	120 0.0208	17.305 -0.650 0.211		Vel = 4.92	
CC3 to CC4	42.542 40.792		54.36 138.06	2.5 2.635	T	16.474	0.583 16.474 17.057	120 0.0523	16.866 0.758 0.892		Vel = 8.12	
CC4 to CC5	40.792 39.042		-24.58 113.48	2.5 2.635	T	16.474	14.000 16.474 30.474	120 0.0364	18.516 0.758 1.109		Vel = 6.68	
CC5 to CC6	39.042 37.292		-21.83 91.65	2.5 2.635	T	16.474	14.000 16.474 30.474	120 0.0245	20.383 0.758 0.747		Vel = 5.39	
CC6 to CC7	37.292 35.583		-20.72 70.93	2.5 2.635	T	16.474	13.667 16.474 30.141	120 0.0153	21.888 0.740 0.460		Vel = 4.17	
CC7 to CC8	35.583 33.792		-21.21 49.72	2.5 2.635	T	16.474	14.333 16.474 30.807	120 0.0079	23.088 0.776 0.243		Vel = 2.93	
CC8 to CC9	33.792 32.042		-23.25 26.47	2.5 2.635	E	8.237	14.167 8.237 22.404	120 0.0025	24.107 0.758 0.055		Vel = 1.56	
CC9			0.0 26.47						24.920		K Factor = 5.30	
CC0 to C0	30.208 30.208		29.04 29.04	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0683	20.936 0.0 5.722		Vel = 6.23	
C0			0.0 29.04						26.658		K Factor = 5.62	
CC1 to C1	33.667 33.667		28.89 28.89	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0676	19.535 0.0 5.665		Vel = 6.20	
C1			0.0 28.89						25.200		K Factor = 5.76	
CC4 to C4	40.792 40.792		24.58 24.58	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0501	18.516 0.0 4.201		Vel = 5.27	
C4			0.0 24.58						22.717		K Factor = 5.16	
CC5 to C5	39.042 39.042		21.83 21.83	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0402	20.383 0.0 3.374		Vel = 4.68	
C5			0.0 21.83						23.757		K Factor = 4.48	
CC6 to C6	37.292 37.292		20.72 20.72	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0365	21.888 0.0 3.064		Vel = 4.44	
C6			0.0 20.72						24.952		K Factor = 4.15	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
CC7 to C7	35.583 35.583		21.21 21.21	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0382	23.088 0.0 3.199			Vel = 4.55
C7			0.0 21.21						26.287			K Factor = 4.14
CC8 to C8	33.792 33.792		23.25 23.25	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0452	24.107 0.0 3.790			Vel = 4.99
C8			0.0 23.25						27.897			K Factor = 4.40
CC9 to C9	32.042 32.042		26.47 26.47	1.25 1.38	T	6.0	77.833 6.000 83.833	120 0.0575	24.920 0.0 4.818			Vel = 5.68
C9			0.0 26.47						29.738			K Factor = 4.85
C0 to C1	30.208 33.667		29.04 29.04	2.5 2.635			13.917 13.917	120 0.0029	26.658 -1.498 0.040			Vel = 1.71
C1 to C2B	33.667 34.542		28.89 57.93	2.5 2.635	3E	24.711	7.083 24.711 31.794	120 0.0105	25.200 -0.379 0.334			Vel = 3.41
C2B to C2T	34.542 41.042		0.0 57.93	2.5 2.635	E	8.237	6.667 8.237 14.904	120 0.0105	25.155 -2.815 0.156			Vel = 3.41
C2T to C4	41.042 40.792		0.0 57.93	2.5 2.635	E	8.237	2.500 8.237 10.737	120 0.0105	22.496 0.108 0.113			Vel = 3.41
C4 to C5	40.792 39.042		24.58 82.51	2.5 2.635			14.000 14.000	120 0.0201	22.717 0.758 0.282			Vel = 4.85
C5 to C6	39.042 37.292		21.83 104.34	2.5 2.635			14.000 14.000	120 0.0312	23.757 0.758 0.437			Vel = 6.14
C6 to C7	37.292 35.583		20.72 125.06	2.5 2.635			13.667 13.667	120 0.0435	24.952 0.740 0.595			Vel = 7.36
C7 to C8	35.583 33.792		21.22 146.28	2.5 2.635			14.333 14.333	120 0.0582	26.287 0.776 0.834			Vel = 8.61
C8 to C9	33.792 32.042		23.24 169.52	2.5 2.635			14.167 14.167	120 0.0764	27.897 0.758 1.083			Vel = 9.97
C9			0.0 169.52						29.738			K Factor = 31.09
C9 to C10T	32.042 31.583		195.99 195.99	2.5 2.635	2E	16.474	4.083 16.474 20.557	120 0.1000	29.738 0.199 2.056			Vel = 11.53

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
C10T to C10B	31.583 23.833		0.0 195.99	2.5 2.635	E	8.237	7.750 8.237 15.987	120 0.1000	31.993 3.357 1.599		Vel = 11.53	
C10B to C11T	23.833 23.833		0.0 195.99	2.5 2.635	2E	16.474	26.583 16.474 43.057	120 0.1000	36.949 0.0 4.307		Vel = 11.53	
C11T			0.0 195.99						41.256		K Factor = 30.51	
C11T to C11B	23.833 23.333		195.99	2.5 2.635	E	8.237	0.500 8.237 8.737	120 0.0999	41.256 0.217 0.873		Vel = 11.53	
C11B to C12B	23.333 23.333		0.0 195.99	2.5 2.635	E	8.237	8.125 8.237 16.362	120 0.1000	42.346 0.0 1.636		Vel = 11.53	
C12B			0.0 195.99						43.982		K Factor = 29.55	
C12B to C12T	23.333 26.917		195.99	2.5 2.635	E	8.237	3.583 8.237 11.820	120 0.1000	43.982 -1.552 1.182		Vel = 11.53	
C12T to C13	26.917 26.917		0.0 195.99	2.5 2.635	T	16.474	3.208 16.474 19.682	120 0.1000	43.612 0.0 1.969		Vel = 11.53	
C13			0.0 195.99						45.581		K Factor = 29.03	
C13 to A14T	26.917 26.917		195.99	4 4.26	T	26.334	24.083 26.334 50.417	120 0.0096	45.581 0.0 0.486		Vel = 4.41	
A14T			0.0 195.99						46.067		K Factor = 28.88	
A14T to A14B	26.917 23		195.99	4 4.26	E	13.167	4.000 13.167 17.167	120 0.0097	46.067 1.696 0.166		Vel = 4.41	
A14B to A13T	23 23		0.0 195.99	4 4.26	E	13.167	13.750 13.167 26.917	120 0.0096	47.929 0.0 0.259		Vel = 4.41	
A13T			0.0 195.99						48.188		K Factor = 28.23	
A13T to A13B	23 12.917		195.99	4 4.26	E	13.167	10.083 13.167 23.250	120 0.0097	48.188 4.367 0.225		Vel = 4.41	
A13B			0.0 195.99						52.780		K Factor = 26.98	
A13B to A12	12.917 11.167		195.99	4 4.26	3E	39.501	20.708 39.501 60.209	120 0.0096	52.780 0.758 0.580		Vel = 4.41	
A12			0.0 195.99						54.118		K Factor = 26.64	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 11  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A12 to A11	11.167 11.167		195.99	4	4E	52.668	49.375 52.668	120	54.118 0.0			
			195.99	4.26			102.043	0.0096	0.984	Vel =	4.41	
A11 to A10	11.167 11.167		0.0	4	2E	26.334	33.750 26.334	120	55.102 0.0			
			195.99	4.26			60.084	0.0096	0.579	Vel =	4.41	
A10 to A9	11.167 7		0.0	4	T B Fsp S	26.334 15.8 0.0 28.968	3.833 71.102 74.935	120	55.681 4.805 0.722		** Fixed Loss = 3	Vel = 4.41
A9 to A8	7 11.750		0.0	4	2E	26.334	6.208 26.334	120	61.208 -2.057			
			195.99	4.26			32.542	0.0096	0.313	Vel =	4.41	
A8 to A7	11.750 13.625		0.0	4	3E	39.501	30.292 39.501	120	59.464 -0.812			
			195.99	4.26			69.793	0.0096	0.673	Vel =	4.41	
A7 to A6	13.625 12.292		0.0	4	2E	26.334	24.167 26.334	120	59.325 0.577			
			195.99	4.26			50.501	0.0096	0.487	Vel =	4.41	
A6 to A5	12.292 17.417		0.0	4	2E	26.334	42.792 26.334	120	60.389 -2.220			
			195.99	4.26			69.126	0.0096	0.667	Vel =	4.41	
A5 to A4	17.417 16.750		0.0	4	2E	26.334	23.333 26.334	120	58.836 0.289			
			195.99	4.26			49.667	0.0096	0.479	Vel =	4.41	
A4			0.0 195.99						59.604		K Factor =	25.39
A4 to A3	16.750 12.833		195.99	4	4E	52.668	110.458 52.668	120	59.604 1.696			
			195.99	4.26			163.126	0.0096	1.572	Vel =	4.41	
A3 to A2	12.833 16.833		0.0	4	2E	26.334	74.083 26.334	120	62.872 -1.732			
			195.99	4.26			100.417	0.0096	0.968	Vel =	4.41	
A2 to A1	16.833 10.500		0.0	4	2E	26.334	28.708 26.334	120	62.108 2.743			
			195.99	4.26			55.042	0.0096	0.531	Vel =	4.41	
A1 to TOR2	10.500 10.500		0.0	4	E	13.167	18.375 13.167	120	65.382 0.0			
			195.99	4.26			31.542	0.0096	0.304	Vel =	4.41	
TOR2			0.0 195.99						65.686		K Factor =	24.18
TOR2 to BOR2	10.500 2		195.99	6	T B Fsp	37.72 12.573 0.0	9.042 50.293 59.335	120	65.686 4.681 0.081		** Fixed Loss = 1	Vel = 1.98
			195.99	6.357				0.0014				
BOR2			0.0 195.99						70.448		K Factor =	23.35
BOR2 to PD	2 2		195.99	6	E 2T B	17.603 75.44 12.573	11.542 145.851 157.393	120	70.448 0.0 0.216			Vel = 1.98
			195.99	6.357				0.0014				

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 12  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
					S	40.235						
PD			0.0 195.99						70.664		K Factor = 23.31	
									70.664			
									10.727			
									81.391			
									81.391			
									-43.993			
									37.398			
PS to FLG	2 1		0.0 195.99	6 6.357	2T G	75.44 3.772	5.458 79.212	120	37.398 0.433			Vel = 1.98
			0.0 195.99						37.947		K Factor = 31.82	
FLG to UG1	1 -3		195.99 195.99	6 6.16	E	20.084	4.000 20.084	140	37.947 1.732			Vel = 2.11
			0.0 195.99						39.708		K Factor = 31.10	
UG1 to UG2	-3 -3		195.99 195.99	6 6.16	T	43.037	77.000 43.037	140	39.708 0.0			Vel = 2.11
UG2 to UG3	-3 -3		-41.39 154.6	8 8.27			179.000	140	39.853 0.0			Vel = 0.92
			0.0 154.60						39.886		K Factor = 24.48	
UG2 to UG0	-3 -3		41.39 41.39	8 8.27	V	20.56	261.000 20.560	140	39.853 0.0			Vel = 0.25
UG0 to UG3	-3 -3		0.0 41.39	8 8.27	10V T	205.602 55.354	1507.000 260.956	140	39.857 0.0			Vel = 0.25
			0.0 41.39						39.886		K Factor = 6.55	
UG3 to BF1	-3 2		195.99 195.99	8 8.27	G 2V 2E	6.326 41.12	521.000 104.382	140	39.886 -2.166			Vel = 1.17
BF1 to BF2	2 -3		0.0 195.99	8 8.27	2E	56.936	15.000 56.936	140	37.899 14.666		** Fixed Loss = 12.5	Vel = 1.17
BF2 to UG4	-3 -3		0.0 195.99	8 8.27	V T	20.56 55.354	75.000 75.914	140	52.586 0.0			Vel = 1.17
			0.0 195.99						52.629		K Factor = 27.02	
UG4 to UG5	-3 -3		195.99 195.99	8 8.27	4G 8V	28.75 186.874	4156.000 215.624	150	52.629 0.0			Vel = 1.17
									4371.624			Vel = 1.17

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-11

Page 13  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG5 to UG6	-3 -3		0.0 195.99	8 8.27	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150 0.0003	53.731 0.0 0.923		Vel = 1.17	
UG6			0.0 195.99						54.654		K Factor = 26.51	
UG6 to UG7	-3 -3		195.99 195.99	12 12.34	T	106.533	47.000 106.533 153.533	150 0	54.654 0.0 0.005		Vel = 0.53	
UG7			0.0 195.99						54.659		K Factor = 26.51	
UG7 to UG8	-3 -3		195.99 195.99	6 6.16	E T	22.818 48.896	13.000 71.714 84.714	150 0.0011	54.659 0.0 0.090		Vel = 2.11	
UG8			0.0 195.99						54.749		K Factor = 26.49	
UG8 to UG9	-3 -3		195.99 195.99	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0012	54.749 0.0 0.144		Vel = 2.11	
UG9 to TEST	-3 -3		0.0 195.99	12 12.34	2V T G E	15.94 93.767 9.377 42.195	2136.000 161.279 2297.279	140 0	54.893 0.0 0.094		Vel = 0.53	
TEST			250.00 445.99						54.987		Qa = 250.00 K Factor = 60.14	



## Hydraulic Calculations by HydraCALC

ABL FIRE PROTECTION  
300 HOKE STREET  
RALEIGH, NC 27612  
(919)835-2225

Job Name : NWHES AREA-12  
Drawing : FP16  
Location : 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
Remote Area : AREA-12  
Contract : 4070  
Data File : NWHES 12 SYS-2 ZONE3 GYM301 LH.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** NORTHWEST HARNETT ELEMENTARY SCHOOL  
**Location** 736 ROLLINS ROAD, FUQUAY VARINA, NC 27526  
**Drawing #** FP16  
**Contract #** 4070  
**Date** 4/19/22

**DESIGN**

**Remote area #** AREA-12  
**Remote area location** GYM 301  
**Occupancy classification** LH  
**Density** 0.10 - Gpm/SqFt  
**Area of application** 1604 - SqFt  
**Coverage/sprinkler** 225 SF MAX - SqFt  
**Type of sprinkler calculated** QR UPRIGHT 1/2" 155F 5.6K  
**# Sprinklers calculated** 10  
**In-rack demand** N/A - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 307.095 - GPM @ 43.130 - Psi  
**Type of system** WET SYSTEM  
**Volume of system (dry or pre-action)** N/A - Gal

**WATER SUPPLY INFORMATION**

**Test date** 10/7/2020  
**Location** BETTS RD & NC 42  
**Source of info** LKC ENGINEERING, PLLC JACKSON MAPLES

**CONTRACTOR INFO**

ABL FIRE PROTECTION, LLC  
**Address** 300 HOKE ST., RALEIGH, NC 27601  
**Phone #** 919 835-2225 X107  
**Name of designer** CHRISTY LAMSON  
**Authority having jurisdiction** HARNETT COUNTY FIRE MARSHALL

**NOTES:**




# Water Supply Curve

ABL FIRE PROTECTION  
NWHES AREA-12

Page 2  
Date 4/19/22

<b>City Water Supply:</b> C1 - Static Pressure : 58 C2 - Residual Pressure: 50 C2 - Residual Flow : 756  <b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b> A1 - Adjusted Static: 43.145 A2 - Adj Resid : 21.583 @ 500 A3 - Adj Resid : 0 @ 741.15	<b>Pump Data:</b> P1 - Pump Churn Pressure : 44 P2 - Pump Rated Pressure : 40 P2 - Pump Rated Flow : 500 P3 - Pump Pressure @ Max Flow : 26 P3 - Pump Max Flow : 741.15 City Residual Flow @ 0 = 2205.82 City Residual Flow @ 20 = 1755.10 City Water @ 150% of Pump = 50.29 Pump flow terminated at adjusted curve 0 psi	<b>Demand:</b> D1 - Elevation : 20.013 D2 - System Flow : 207.095 D2 - System Pressure : 69.220 Hose ( Demand ) : _____ D3 - System Demand : 207.095 Hose ( Adj City ) : 100 Safety Margin : 13.359
--	--	--



# Fittings Used Summary

ABL FIRE PROTECTION  
NWHES AREA-12

Page 3  
Date 4/19/22

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL FIRE PROTECTION  
NWHES AREA-12

Page 4  
Date 4/19/22

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PD	See Information on Pump Curve			82.579	207.1	69.22
TEST	58.0	50	756.0	56.489	307.1	56.489

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1H	31.708	5.6	14.71	21.48	0.1 194.833
2H	31.708	5.6	14.39	21.24	0.1 194.833
3H	31.708	5.6	14.41	21.26	0.1 194.833
4H	31.708	5.6	15.14	21.79	0.1 194.833
5H	36.833	5.6	13.77	20.78	0.1 194.833
6H	36.833	5.6	13.69	20.72	0.1 194.833
7H	36.833	5.6	13.86	20.85	0.1 194.833
8H	43.208	5.6	12.31	19.65	0.1 196
9H	43.208	5.6	12.25	19.6	0.1 196
10H	43.208	5.6	12.42	19.73	0.1 196
1	30.208		16.33		
2	30.208		15.98		
3	30.208		16.01		
4	30.208		16.78		
5	33.667		16.05		
6	33.667		15.97		
7	33.667		16.15		
8	40.792		14.27		
9	40.792		14.21		
10	40.792		14.39		
CC5	39.042		17.14		
CC6	37.292		18.45		
CC7	35.583		19.55		
CC8	33.792		20.52		
CC9	32.042		21.35		
CC0	30.208		19.12		
CC1	33.667		17.69		
CC2B	34.542		17.75		
CC2T	41.042		15.14		
CC3	42.542		14.62		
CC4	40.792		15.61		
C0	30.208		21.08		
C1	33.667		19.69		
C2B	34.542		19.93		
C2T	41.042		17.41		
C4	40.792		17.73		
C5	39.042		19.0		
C6	37.292		20.41		
C7	35.583		21.93		
C8	33.792		23.72		
C9	32.042		25.73		

**NODE ANALYSIS (cont.)**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
C10T	31.583		28.2		
C10B	23.833		33.33		
C11T	23.833		38.1		
C11B	23.333		39.28		
C12B	23.333		41.1		
C12T	26.917		40.85		
C13	26.917		43.03		
A14T	26.917		43.57		
A14B	23.0		45.45		
A13T	23.0		45.74		
A13B	12.917		50.35		
A12	11.167		51.75		
A11	11.167		52.84		
A10	11.167		53.48		
A9	7.0		59.09		
A8	11.75		57.38		
A7	13.625		57.31		
A6	12.292		58.43		
A5	17.417		56.95		
A4	16.75		57.76		
A3	12.833		61.2		
A2	16.833		60.54		
A1	10.5		63.87		
TOR2	10.5		64.21		
BOR2	2.0		68.98		
PD	2.0		69.22		
PS	2.0		38.59		
FLG	1.0		39.15		
UG1	-3.0		40.91		
UG2	-3.0		41.07		
UG0	-3.0		41.08		
UG3	-3.0		41.11		
BF1	2.0		39.14		
BF2	-3.0		53.83		
UG4	-3.0		53.88		
UG5	-3.0		55.1		
UG6	-3.0		56.12		
UG7	-3.0		56.13		
UG8	-3.0		56.23		
UG9	-3.0		56.39		
TEST	-3.0		56.49	100.0	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 6  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1H to 1	31.708 30.208	5.60	21.48 21.48	1 1.049	T 5.0	1.500 5.000 6.500	120 0.1485	14.711 0.650 0.965			Vel = 7.97
1			0.0 21.48					16.326			K Factor = 5.32
2H to 2	31.708 30.208	5.60	21.24 21.24	1 1.049	T 5.0	1.500 5.000 6.500	120 0.1455	14.388 0.650 0.946			Vel = 7.88
2			0.0 21.24					15.984			K Factor = 5.31
3H to 3	31.708 30.208	5.60	21.26 21.26	1 1.049	T 5.0	1.500 5.000 6.500	120 0.1457	14.413 0.650 0.947			Vel = 7.89
3			0.0 21.26					16.010			K Factor = 5.31
4H to 4	31.708 30.208	5.60	21.79 21.79	1 1.049	T 5.0	1.500 5.000 6.500	120 0.1523	15.138 0.650 0.990			Vel = 8.09
4			0.0 21.79					16.778			K Factor = 5.32
5H to 5	36.833 33.667	5.60	20.78 20.78	1 1.049	T 5.0	1.542 5.000 6.542	120 0.1397	13.768 1.371 0.914			Vel = 7.71
5			0.0 20.78					16.053			K Factor = 5.19
6H to 6	36.833 33.667	5.60	20.72 20.72	1 1.049	T 5.0	1.542 5.000 6.542	120 0.1389	13.689 1.371 0.909			Vel = 7.69
6			0.0 20.72					15.969			K Factor = 5.19
7H to 7	36.833 33.667	5.60	20.85 20.85	1 1.049	T 5.0	1.542 5.000 6.542	120 0.1405	13.858 1.371 0.919			Vel = 7.74
7			0.0 20.85					16.148			K Factor = 5.19
8H to 8	43.208 40.792	5.60	19.65 19.65	1 1.049	T 5.0	2.292 5.000 7.292	120 0.1260	12.308 1.046 0.919			Vel = 7.29
8			0.0 19.65					14.273			K Factor = 5.20
9H to 9	43.208 40.792	5.60	19.60 19.6	1 1.049	T 5.0	2.292 5.000 7.292	120 0.1253	12.250 1.046 0.914			Vel = 7.28
9			0.0 19.60					14.210			K Factor = 5.20
10H to 10	43.208 40.792	5.60	19.74 19.74	1 1.049	T 5.0	2.292 5.000 7.292	120 0.1270	12.419 1.046 0.926			Vel = 7.33

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 7  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 19.74					14.391		K Factor = 5.20	
1 to CC0	30.208 30.208		38.16 38.16	1.25 1.38	T 6.0	18.750 6.000 24.750	120	16.326 0.0 2.799		Vel = 8.19	
			0.0 38.16					19.125		K Factor = 8.73	
1 to 2	30.208 30.208		-16.68 -16.68	1.25 1.38		14.000 14.000	120	16.326 0.0 -0.342		Vel = 3.58	
2 to 3	30.208 30.208		21.24 4.56	1.25 1.38		11.750 11.750	120	15.984 0.0 0.026		Vel = 0.98	
3 to 4	30.208 30.208		21.26 25.82	1.25 1.38		14.000 14.000	120	16.010 0.0 0.768		Vel = 5.54	
4 to C0	30.208 30.208		21.79 47.61	1.25 1.38	T 6.0	19.292 6.000 25.292	120	16.778 0.0 4.307		Vel = 10.21	
			0.0 47.61					21.085		K Factor = 10.37	
5 to CC1	33.667 33.667		28.60 28.6	1.25 1.38	T 6.0	18.750 6.000 24.750	120	16.053 0.0 1.641		Vel = 6.13	
			0.0 28.60					17.694		K Factor = 6.80	
5 to 6	33.667 33.667		-7.82 -7.82	1.25 1.38		14.000 14.000	120	16.053 0.0 -0.084		Vel = 1.68	
6 to 7	33.667 33.667		20.72 12.9	1.25 1.38		11.750 11.750	120	15.969 0.0 0.179		Vel = 2.77	
7 to C1	33.667 33.667		20.85 33.75	1.25 1.38	T 6.0	33.292 6.000 39.292	120	16.148 0.0 3.540		Vel = 7.24	
			0.0 33.75					19.688		K Factor = 7.61	
8 to CC4	40.792 40.792		26.27 26.27	1.25 1.38	T 6.0	17.667 6.000 23.667	120	14.273 0.0 1.341		Vel = 5.63	
			0.0 26.27					15.614		K Factor = 6.65	
8 to 9	40.792 40.792		-6.63 -6.63	1.25 1.38		14.000 14.000	120	14.273 0.0 -0.063		Vel = 1.42	
9 to 10	40.792 40.792		19.60 12.97	1.25 1.38		11.750 11.750	120	14.210 0.0 0.181		Vel = 2.78	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 8  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10 to C4	40.792 40.792		19.74 32.71	1.25 1.38	T	6.0	33.292 6.000 39.292	120 0.0850	14.391 0.0 3.341		Vel = 7.02	
C4			0.0 32.71						17.732		K Factor = 7.77	
CC5 to C5	39.042 39.042		15.26 15.26	1.25 1.38	2T	12.0	77.833 12.000 89.833	120 0.0207	17.140 0.0 1.864		Vel = 3.27	
C5			0.0 15.26						19.004		K Factor = 3.50	
CC6 to C6	37.292 37.292		15.69 15.69	1.25 1.38	2T	12.0	77.833 12.000 89.833	120 0.0218	18.450 0.0 1.961		Vel = 3.37	
C6			0.0 15.69						20.411		K Factor = 3.47	
CC7 to C7	35.583 35.583		17.43 17.43	1.25 1.38	2T	12.0	77.833 12.000 89.833	120 0.0265	19.549 0.0 2.385		Vel = 3.74	
C7			0.0 17.43						21.934		K Factor = 3.72	
CC8 to C8	33.792 33.792		20.43 20.43	1.25 1.38	2T	12.0	77.833 12.000 89.833	120 0.0356	20.524 0.0 3.199		Vel = 4.38	
C8			0.0 20.43						23.723		K Factor = 4.19	
CC9 to C9	32.042 32.042		24.22 24.22	1.25 1.38	2T	12.0	77.833 12.000 89.833	120 0.0488	21.346 0.0 4.381		Vel = 5.20	
C9			0.0 24.22						25.727		K Factor = 4.78	
CC0 to CC1	30.208 33.667		38.16 38.16	2.5 2.635			13.917 13.917	120 0.0048	19.125 -1.498 0.067		Vel = 2.25	
CC1 to CC2B	33.667 34.542		28.60 66.76	2.5 2.635	3E	24.711	7.083 24.711 31.794	120 0.0137	17.694 -0.379 0.434		Vel = 3.93	
CC2B to CC2T	34.542 41.042		0.0 66.76	2.5 2.635	E	8.237	6.500 8.237 14.737	120 0.0136	17.749 -2.815 0.201		Vel = 3.93	
CC2T to CC3	41.042 42.542		0.0 66.76	2.5 2.635	E	8.237	1.917 8.237 10.154	120 0.0137	15.135 -0.650 0.139		Vel = 3.93	
CC3 to CC4	42.542 40.792		0.0 66.76	2.5 2.635	T	16.474	0.583 16.474 17.057	120 0.0136	14.624 0.758 0.232		Vel = 3.93	
CC4 to CC5	40.792 39.042		26.27 93.03	2.5 2.635	T	16.474	14.000 16.474 30.474	120 0.0252	15.614 0.758 0.768		Vel = 5.47	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 9  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
CC5 to CC6	39.042 37.292		-15.26 77.77	2.5 2.635	T	16.474	14.000 16.474 30.474	120 0.0181	17.140 0.758 0.552			Vel = 4.58
CC6 to CC7	37.292 35.583		-15.69 62.08	2.5 2.635	T	16.474	13.667 16.474 30.141	120 0.0119	18.450 0.740 0.359			Vel = 3.65
CC7 to CC8	35.583 33.792		-17.43 44.65	2.5 2.635	T	16.474	14.333 16.474 30.807	120 0.0065	19.549 0.776 0.199			Vel = 2.63
CC8 to CC9	33.792 32.042		-20.43 24.22	2.5 2.635	T	16.474	14.167 16.474 30.641	120 0.0021	20.524 0.758 0.064			Vel = 1.42
CC9			0.0 24.22						21.346			K Factor = 5.24
C0 to C1	30.208 33.667		47.61 47.61	2.5 2.635			13.917 13.917	120 0.0073	21.085 -1.498 0.101			Vel = 2.80
C1 to C2B	33.667 34.542		33.75 81.36	2.5 2.635	3E	24.711	7.083 24.711 31.794	120 0.0197	19.688 -0.379 0.625			Vel = 4.79
C2B to C2T	34.542 41.042		0.0 81.36	2.5 2.635	E	8.237	6.667 8.237 14.904	120 0.0197	19.934 -2.815 0.293			Vel = 4.79
C2T to C4	41.042 40.792		0.0 81.36	2.5 2.635	E	8.237	2.500 8.237 10.737	120 0.0197	17.412 0.108 0.212			Vel = 4.79
C4 to C5	40.792 39.042		32.70 114.06	2.5 2.635			14.000 14.000	120 0.0367	17.732 0.758 0.514			Vel = 6.71
C5 to C6	39.042 37.292		15.26 129.32	2.5 2.635			14.000 14.000	120 0.0464	19.004 0.758 0.649			Vel = 7.61
C6 to C7	37.292 35.583		15.69 145.01	2.5 2.635			13.667 13.667	120 0.0573	20.411 0.740 0.783			Vel = 8.53
C7 to C8	35.583 33.792		17.43 162.44	2.5 2.635			14.333 14.333	120 0.0707	21.934 0.776 1.013			Vel = 9.56
C8 to C9	33.792 32.042		20.44 182.88	2.5 2.635			14.167 14.167	120 0.0880	23.723 0.758 1.246			Vel = 10.76
C9			0.0 182.88						25.727			K Factor = 36.06
C9 to C10T	32.042 31.583		207.10 207.1	2.5 2.635	2E	16.474	4.083 16.474 20.557	120 0.1108	25.727 0.199 2.277			Vel = 12.18
C10T to C10B	31.583 23.833		0.0 207.1	2.5 2.635	E	8.237	7.750 8.237 15.987	120 0.1107	28.203 3.357 1.770			Vel = 12.18



# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 10  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
C10B to C11T	23.833 23.833		0.0 207.1	2.5 2.635	2E	16.474	26.583 16.474 43.057	120 0.1108	33.330 0.0 4.769		Vel = 12.18	
C11T to C11B	23.833 23.333		0.0 207.1	2.5 2.635	E	8.237	0.500 8.237 8.737	120 0.1107	38.099 0.217 0.967		Vel = 12.18	
C11B to C12B	23.333 23.333		0.0 207.1	2.5 2.635	E	8.237	8.125 8.237 16.362	120 0.1107	39.283 0.0 1.812		Vel = 12.18	
C12B			0.0 207.10						41.095		K Factor = 32.31	
C12B to C12T	23.333 26.917		207.10 207.1	2.5 2.635	E	8.237	3.583 8.237 11.820	120 0.1107	41.095 -1.552 1.309		Vel = 12.18	
C12T to C13	26.917 26.917		0.0 207.1	2.5 2.635	T	16.474	3.208 16.474 19.682	120 0.1108	40.852 0.0 2.180		Vel = 12.18	
C13			0.0 207.10						43.032		K Factor = 31.57	
C13 to A14T	26.917 26.917		207.10 207.1	4 4.26	T	26.334	24.083 26.334 50.417	120 0.0107	43.032 0.0 0.538		Vel = 4.66	
A14T			0.0 207.10						43.570		K Factor = 31.38	
A14T to A14B	26.917 23		207.10 207.1	4 4.26	E	13.167	4.000 13.167 17.167	120 0.0107	43.570 1.696 0.184		Vel = 4.66	
A14B to A13T	23 23		0.0 207.1	4 4.26	E	13.167	13.750 13.167 26.917	120 0.0107	45.450 0.0 0.287		Vel = 4.66	
A13T			0.0 207.10						45.737		K Factor = 30.62	
A13T to A13B	23 12.917		207.10 207.1	4 4.26	E	13.167	10.083 13.167 23.250	120 0.0107	45.737 4.367 0.248		Vel = 4.66	
A13B			0.0 207.10						50.352		K Factor = 29.19	
A13B to A12	12.917 11.167		207.10 207.1	4 4.26	3E	39.501	20.708 39.501 60.209	120 0.0107	50.352 0.758 0.643		Vel = 4.66	
A12			0.0 207.10						51.753		K Factor = 28.79	
A12 to A11	11.167 11.167		207.10 207.1	4 4.26	4E	52.668	49.375 52.668 102.043	120 0.0107	51.753 0.0 1.089		Vel = 4.66	
A11 to A10	11.167 11.167		0.0 207.1	4 4.26	2E	26.334	33.750 26.334 60.084	120 0.0107	52.842 0.0 0.641		Vel = 4.66	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 11  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A10 to A9	11.167 7		0.0 207.1	4 4.26	T B Fsp S 26.334 15.8 0.0 28.968	3.833 71.102 74.935	120 0.0107	53.483 4.805 0.800		** Fixed Loss = 3 Vel = 4.66	
A9 to A8	7 11.750		0.0 207.1	4 4.26	2E 26.334	6.208 26.334 32.542	120 0.0107	59.088 -2.057 0.347		Vel = 4.66	
A8 to A7	11.750 13.625		0.0 207.1	4 4.26	3E 39.501	30.292 39.501 69.793	120 0.0107	57.378 -0.812 0.745		Vel = 4.66	
A7 to A6	13.625 12.292		0.0 207.1	4 4.26	2E 26.334	24.167 26.334 50.501	120 0.0107	57.311 0.577 0.540		Vel = 4.66	
A6 to A5	12.292 17.417		0.0 207.1	4 4.26	2E 26.334	42.792 26.334 69.126	120 0.0107	58.428 -2.220 0.738		Vel = 4.66	
A5 to A4	17.417 16.750		0.0 207.1	4 4.26	2E 26.334	23.333 26.334 49.667	120 0.0107	56.946 0.289 0.530		Vel = 4.66	
A4			0.0 207.10					57.765		K Factor = 27.25	
A4 to A3	16.750 12.833		207.10 207.1	4 4.26	4E 52.668	110.458 52.668 163.126	120 0.0107	57.765 1.696 1.741		Vel = 4.66	
A3 to A2	12.833 16.833		0.0 207.1	4 4.26	2E 26.334	74.083 26.334 100.417	120 0.0107	61.202 -1.732 1.072		Vel = 4.66	
A2 to A1	16.833 10.500		0.0 207.1	4 4.26	2E 26.334	28.708 26.334 55.042	120 0.0107	60.542 2.743 0.587		Vel = 4.66	
A1 to TOR2	10.500 10.500		0.0 207.1	4 4.26	E 13.167	18.375 13.167 31.542	120 0.0107	63.872 0.0 0.337		Vel = 4.66	
TOR2			0.0 207.10					64.209		K Factor = 25.85	
TOR2 to BOR2	10.500 2		207.10 207.1	6 6.357	T B Fsp 0.0	37.72 12.573 50.293 59.335	120 0.0015	64.209 4.681 0.090		** Fixed Loss = 1 Vel = 2.09	
BOR2			0.0 207.10					68.980		K Factor = 24.94	
BOR2 to PD	2 2		207.10 207.1	6 6.357	E 2T B S 17.603 75.44 12.573 40.235	11.542 145.851 157.393	120 0.0015	68.980 0.0 0.240		Vel = 2.09	
PD			0.0 207.10					69.220		K Factor = 24.89	
System Demand Pressure								69.220			
Safety Margin								13.359			
Continuation Pressure								82.579			

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 12  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
Pressure @ Pump Outlet									82.579			
Pressure From Pump Curve									-43.993			
Pressure @ Pump Inlet									38.586			
PS to FLG	2 1		0.0 207.1	6 6.357	2T G	75.44 3.772	5.458 79.212 84.670	120 0.0015	38.586 0.433 0.128		Vel = 2.09	
FLG			0.0 207.10						39.147		K Factor = 33.10	
FLG to UG1	1 -3		207.10 207.1	6 6.16	E	20.084	4.000 20.084 24.084	140 0.0014	39.147 1.732 0.033		Vel = 2.23	
UG1			0.0 207.10						40.912		K Factor = 32.38	
UG1 to UG2	-3 -3		207.10 207.1	6 6.16	T	43.037	77.000 43.037 120.037	140 0.0013	40.912 0.0 0.160		Vel = 2.23	
UG2 to UG3	-3 -3		-43.74 163.36	8 8.27			179.000 179.000	140 0.0002	41.072 0.0 0.037		Vel = 0.98	
UG3			0.0 163.36						41.109		K Factor = 25.48	
UG2 to UG0	-3 -3		43.73 43.73	8 8.27	V	20.56	261.000 20.560 281.560	140 0	41.072 0.0 0.005		Vel = 0.26	
UG0 to UG3	-3 -3		0.0 43.73	8 8.27	10V T	205.602 55.354	1507.000 260.956 1767.956	140 0	41.077 0.0 0.032		Vel = 0.26	
UG3			0.0 43.73						41.109		K Factor = 6.82	
UG3 to BF1	-3 2		207.10 207.1	8 8.27	G 2V 2E	6.326 41.12 56.936	521.000 104.382 625.382	140 0.0003	41.109 -2.166 0.198		Vel = 1.24	
BF1 to BF2	2 -3		0.0 207.1	8 8.27	2E	56.936	15.000 56.936 71.936	140 0.0003	39.141 14.666 0.023		** Fixed Loss = 12.5 Vel = 1.24	
BF2 to UG4	-3 -3		0.0 207.1	8 8.27	V T	20.56 55.354	75.000 75.914 150.914	140 0.0003	53.830 0.0 0.048		Vel = 1.24	
UG4			0.0 207.10						53.878		K Factor = 28.21	
UG4 to UG5	-3 -3		207.10 207.1	8 8.27	4G 8V	28.75 186.874	4156.000 215.624 4371.624	150 0.0003	53.878 0.0 1.221		Vel = 1.24	
UG5 to UG6	-3 -3		0.0 207.1	8 8.27	8V E T 2G	186.874 32.344 62.89 14.375	3360.000 296.483 3656.483	150 0.0003	55.099 0.0 1.021		Vel = 1.24	

# Final Calculations : Hazen-Williams

ABL FIRE PROTECTION  
NWHES AREA-12

Page 13  
Date 4/19/22

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG6			0.0 207.10					56.120		K Factor = 27.65	
UG6 to UG7	-3 -3		207.10 207.1	12 12.34	T	106.533 106.533 153.533	47.000 150 0	56.120 0.0 0.006		Vel = 0.56	
UG7			0.0 207.10					56.126		K Factor = 27.64	
UG7 to UG8	-3 -3		207.10 207.1	6 6.16	E T	22.818 48.896 84.714	13.000 150 0.0012	56.126 0.0 0.099		Vel = 2.23	
UG8			0.0 207.10					56.225		K Factor = 27.62	
UG8 to UG9	-3 -3		207.10 207.1	6 6.16	T	43.037 43.037 120.037	77.000 140 0.0013	56.225 0.0 0.160		Vel = 2.23	
UG9 to TEST	-3 -3		0.0 207.1	12 12.34	2V T G E	15.94 93.767 9.377 42.195	2136.000 140 2297.279 0	56.385 0.0 0.104		Vel = 0.56	
TEST			100.00 307.10					56.489		Qa = 100.00 K Factor = 40.86	



LKC Engineering, PLLC  
 140 Aqua Shed Court  
 Aberdeen, NC 28315  
 PH: (910) 420-1437  
 FAX: (910) 637-0096  
 License #P-1095

**FIRE FLOW TEST RESULTS:**

Test Number 2  
 Test Date & Time 10/7/20 1:00 PM  
 Client \_\_\_\_\_  
 Location NW Harnett Co, NC  
 Performed by J Maples Logan Willams

Static Pressure	68	psi	Location: <u>Betts Rd &amp; NC 42</u>
Residual Pressure	60	psi	Location: _____
Nozzle inside Diameter		inches	(measure nozzle used)
Pitot Tube Pressure	25	psi	Location: <u>Betts Rd &amp; Christian Light Rd</u>
Discharge rate (measured)	840	gpm	Flow Measuring Device: <u>PollardWater Pitot Gauge</u>
Required Residual Pressure	30	psi	(varies - 20psi minimum)

Formula:  $Q_R = Q_F \times \left(\frac{H_R}{H_F}\right)^{0.54}$

Q<sub>(R)</sub> = Rated Capacity (in gpm) at 20 psi residual  
 Q<sub>(F)</sub> = Total test flow (gpm) from at pitot pressure  
 H<sub>(R)</sub> = Static Pressure - Required Pressure (psi)  
 H<sub>(F)</sub> = Static Pressure - Residual Pressure

Q<sub>(R)</sub> = 

840	38	8
Q <sub>(F)</sub>	H <sub>(R)</sub>	H <sub>(F)</sub>

Available Fire Flow Q<sub>(R)</sub> = **1,948** gpm at 30 psi residual (calculated)

Performed By: Jackson Maples 10/7/2020  
 Date

Certified By: \_\_\_\_\_  
 Date

Notes: