

Harnett County

Inspections
420 McKinney Pkwy
Lillington , NC 27546

Phone: 910-893-7525
Fax: 910-893-2793

Inspection Report

Permit: BCOM2110-0007

APPLICANT: Crete Solutions LLC

Site Address: 2544 US 401 N LILLINGTON, NC 27546

Harnett County Inspections Department

Inspection Type: ROUGH IN

Inspection Date: 03/23/2022

Result: DISAPPROVED

Remarks:

Notes: Need truss documents for inspection. Need ladder to access attic. Ceiling covered before framing inspection.
Fire block/caulk lowered ceiling at bathrooms where missing for plumbing. Could not locate plumbing DWV test.

All violations are subject to reinspection fees at the inspectors discretion.

Brad Sutton
Inspector