

SUBMITTAL DATA  
PREPARED FOR:

OVERHILLS ELEMENTARY CLASSROOM  
ADDITION

2626 RAY ROAD  
SPRING LAKE, NC 28390

PREPARED BY:  
J & D SPRINKLER CO, INC.  
315 W. MAIN STREET  
CLAYTON, NC 27520

PH: (919)-553-2356

FAX: (919)-359-0622

# TABLE OF CONTENTS

1. SPRINKLER HEADS
2. PIPE
3. HANGERS
4. FITTINGS
5. VALVES
6. HYDRAULIC CALCULATIONS
7. WATER TEST

# **SPRINKLER HEADS**



## TECHNICAL DATA

### MIRAGE® QUICK RESPONSE EXTENDED COVERAGE CONCEALED PENDENT SPRINKLERS (VK632 AND VK634)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page [www.vikinggroupinc.com](http://www.vikinggroupinc.com)

#### 1. DESCRIPTION

Viking Mirage® Quick Response Extended Coverage Concealed Pendent Sprinkler VK632 and VK634 are thermosensitive glass-bulb spray sprinkler designed for installation on concealed pipe systems where the appearance of a smooth ceiling is desired. The glass bulb operating element and special deflector characteristics meet the challenges of quick response extended coverage standards.

The sprinkler is pre-assembled with a threaded adapter for installation with a low-profile cover assembly that provides up to ½" (12.7 mm) of vertical adjustment. The two-piece design allows installation and testing of the sprinkler prior to installation of the cover plate. The "push-on", "thread-off" design of the concealed cover plate assembly allows easy installation of the cover plate after the system has been tested and the ceiling finish has been applied. The cover assembly can be removed and reinstalled, allowing temporary removal of ceiling panels without taking the sprinkler system out of service or removing the sprinkler.

The Electroless Nickel PTFE (ENT) coating has been investigated for installation in corrosive environments and is listed and approved as indicated in the Approval Charts. The ENT finish is only available for the sprinkler assembly, the cover plate is not plated.

#### 2. LISTINGS AND APPROVALS

 **cULus Listed:** Category VNIV

Refer to the Approval Chart and Design Criteria for cULus Listing requirements that must be followed.

#### 3. TECHNICAL DATA

##### Specifications:

Available since 2007.

Minimum Operating Pressure: 7 psi (0.5 bar)

Maximum Working Pressure: 175 psi (12 Bar).

Factory tested hydrostatically to 500 psi (34.5 bar)

Thread sizes: VK632: 1/2" (15 mm) NPT; VK634: 3/4" (20 mm) NPT

Nominal K-Factors: VK632: 5.6 U.S. (80.6 metric\*); VK634: 8.0 U.S. (115.2 metric\*)

\* Metric K-factor measurement shown is in Bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.

Glass-bulb fluid temperature rated to -65 °F (-55 °C)

Patents Pending

##### Material Standards:

Sprinkler Body: Brass UNS-C84400

Deflector: Copper UNS-C19500

Deflector Pins: Stainless Steel Alloy

Bulb: Glass, nominal 3 mm diameter

Pip Cap: Leaded Bronze UNS-C31400 or UNS-C31600, or Pip Cap and Insert Assembly: Copper UNS-C11000 and Stainless Steel UNS-S30400

Button: Brass UNS-C36000

Screws: 18-8 Stainless Steel

Belleville Spring Sealing Assembly: Nickel Alloy, coated on both sides with PTFE Tape

Yoke: Phosphor Bronze UNS-C51000

Cover Adapter: Cold Rolled Steel UNS-G10080, Finish: Clear Chromate over Zinc Plating

##### Cover Assembly Materials:

Cover: Copper UNS-C11000

Base: Brass UNS-C26000 or UNS-C26800


Springs: Nickel Alloy

Solder: Eutectic

**Ordering Information:** The sprinkler and cover plate must be ordered separately. Refer to Tables 1 and 2.

#### 4. INSTALLATION

Refer to appropriate NFPA Installation Standards.



**For Light Hazard Occupancies Only**



**WARNING:** Cancer and Reproductive Harm-  
[www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)



## TECHNICAL DATA

### MIRAGE® QUICK RESPONSE EXTENDED COVERAGE CONCEALED PENDENT SPRINKLERS (VK632 AND VK634)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page [www.vikinggroupinc.com](http://www.vikinggroupinc.com)

#### 5. OPERATION

During fire conditions, when the temperature around the sprinkler approaches its operating temperature, the cover plate detaches. Continued heating of the exposed sprinkler causes the heat-sensitive liquid in the glass bulb to expand and the bulb to shatter, releasing the yoke, pip-cap and sealing spring assembly. Water flowing through the sprinkler orifice strikes the sprinkler deflector, forming a uniform spray pattern to extinguish or control the fire.

#### 6. INSPECTIONS, TESTS AND MAINTENANCE

Refer to NFPA 25 for Inspection, Testing and Maintenance requirements.

#### 7. AVAILABILITY

Viking Sprinklers VK632 and VK634 are available through a network of domestic and international distributors. See The Viking Corporation web site for the closest distributor or contact The Viking Corporation.

#### 8. GUARANTEE

For details of warranty, refer to Viking's current list price schedule or contact Viking directly.

**TABLE 1: SPRINKLER ORDERING INFORMATION**

Instructions: Using the sprinkler base part number,  
(1) add the suffix for the desired Finish  
(2) add the suffix for the desired Temperature Rating.  
(3) Select a cover plate (See Table 2)

SIN	Sprinkler Base Part Number	Size		1: Finishes		2: Temperature Ratings			
		NPT Inch	BSPT mm	Description	Suffix	Sprinkler Temperature Classification	Nominal Rating	Max. Ambient Ceiling Temperature <sup>1</sup>	Suffix
VK632	14613	1/2	--	Brass	A	Ordinary	135 °F (57 °C)	100 °F (38 °C)	A
VK634	14535 <sup>7</sup>	3/4	--	ENT <sup>2,3,6</sup>	JN	Ordinary	155 °F (68 °C)	100 °F (38 °C)	B
						Intermediate	175 °F (79 °C)	150 °F (65 °C)	D
						Intermediate	200 °F (93 °C)	150 °F (65 °C)	E
						<b>Corrosion Resistant Sprinkler Finish: ENT<sup>2,3,6</sup></b>			
						<b>Example: 14613JNE = VK632 1/2" NPT, 200 °F (93 °C) Temperature Rated Sprinkler with an Electroless Nickel PTFE (ENT<sup>2,3,6</sup>) finish.</b>			

#### Accessories

##### Sprinkler Wrenches and tools:

- A. Heavy Duty Part Number: 14047W/B<sup>4</sup>
- B. Head Cabinet Wrench Part Number: 14031<sup>5</sup>
- C. Optional Small Concealed Cover Plate Installer Tool Part No. 14412
- D. Optional Large Concealed Cover Plate Installer Tool Part No. 14867

##### Sprinkler Cabinet:

Holds up to 6 sprinklers: Part number 01731A.

#### Footnotes

1. Based on NFPA 13, NFPA 13R, and NFPA 13D. Other limits may apply, depending on fire loading, sprinkler location, and other requirements of the Authority Having Jurisdiction. Refer to specific installation standards.
2. cULus Listed as corrosion resistant.
3. The corrosion resistant and corrosion proofing coatings have passed the standard corrosion test required by the approving agencies indicated in the Approval Chart. These tests cannot and do not represent all possible corrosive environments. Prior to installation, verify through the end-user that the coatings are compatible with or suitable for the proposed environment. For automatic sprinklers, the ENT coating is applied to all exposed exterior surfaces, including the waterway.
4. Requires a 1/2" ratchet (not available from Viking).
5. Also optional for removal of the protective cap. Ideal for sprinkler cabinets.
6. The ENT finish is NOT available and NOT cULus Listed for 135 °F (57 °C) temperature-rated sprinklers.
7. Part number 14535 (VK634) is not available with ENT finish.



**TECHNICAL DATA**

**MIRAGE® QUICK RESPONSE  
EXTENDED COVERAGE  
CONCEALED PENDENT  
SPRINKLERS (VK632 AND VK634)**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058  
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com  
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com


**TABLE 2: COVER PLATE ORDERING INFORMATION**

Instructions: Using the cover plate base part number,  
 (1) add the suffix for the desired Finish  
 (2) add the suffix for the required Cover Plate Nominal Rating.

Cover Plate Base Part Number <sup>4</sup>	Size Inch (mm)	Style	1: Finishes		Temperature Rating Matrix <sup>1,2</sup>			
			Description	Suffix <sup>5</sup>	Cover Plate Nominal Rating (Required)	Sprinkler Nominal Rating / Temperature Classification	Sprinkler Max. Ambient Ceiling Temperature <sup>2,3</sup>	Suffix
23190	2-3/4 (70)	Round	Polished Chrome	F	135 °F (57 °C)	135 °F (57 °C) / ORD	100 °F (38 °C)	A
23174	3-5/16 (84)	Round	Brushed Chrome	F-/B		155 °F (68 °C) / ORD	100 °F (38 °C)	
23179	3-5/16 (84)	Square	Bright Brass	B	165 °F (74 °C)	175 °F (79 °C) / INT	150 °F (65 °C)	C
			Antique Brass	B-/A		200 °F (93 °C) / INT	150 °F (65 °C)	
			Brushed Brass	B-/B	<b>Example: 23190MC/W =                      165 °F (74 °C) Temperature Rated 2-3/4" (70 mm) Diameter                      Round Cover Plate with a Painted White finish.</b>			
			Brushed Copper	E-/B				
			Painted White	M-/W				
			Painted Ivory	M-/I				
			Painted Black	M-/B				

**Footnotes**

1. The sprinkler temperature rating is stamped on the deflector.
2. Based on NFPA-13, NFPA 13R, and NFPA 13D. Other limits may apply, depending on fire loading, sprinkler location, and other requirements of the Authority Having Jurisdiction. Refer to specific installation standards.
3. Maximum ambient temperature for cover assembly is 150 °F (65 °C).
4. Part number shown is the base part number. For complete part number, refer to current Viking price list schedule.
5. Where a dash (-) is shown in the Finish suffix designation, insert the desired Temperature Rating suffix. See example above.
6. Square cover plate 23179 cULus Listing is for the 135 °F (57 °C) temperature rated cover plate only. Refer to the Approval Chart.



All custom color painted cover plates will have an identifying label affixed to the inside of the cover that indicates the custom color and will have a representative sample (a paint dot) of the paint on the label.

**Figure 1: Identification of Custom Paint for Concealed Covers**



**Figure 2: Square Cover Assembly 23179**



## TECHNICAL DATA

### MIRAGE® QUICK RESPONSE EXTENDED COVERAGE CONCEALED PENDENT SPRINKLERS (VK632 AND VK634)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058  
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com  
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

<b>Approval Chart</b> Mirage® QR Extended Coverage Concealed Pendent Sprinklers For Light Hazard Occupancies Only. Maximum 175 PSI (12 Bar) WWP										
Sprinkler Base Part Number <sup>1</sup>	SIN	Thread Size		Nominal K-Factor		Maximum Areas of Coverage <sup>4</sup>	Minimum Water Supply Requirements <sup>4</sup> Flow/Pressure	Listings and Approvals <sup>3</sup> (Refer also to Design Criteria)		
		NPT Inches	BSPT mm	U.S.	metric <sup>2</sup>			cULus <sup>5</sup>	FM	NYC
<b>Standard Orifice</b>										
14613	VK632	1/2	15	5.6	80.6	16' x 16' (4.9 m x 4.9 m)	26 gpm @ 21.6 psi (98.4 L/min @ 1.49 Bar)	AW1, BX1	--	See Footnote 6.
14613	VK632	1/2	15	5.6	80.6	18' x 18' (5.5 m x 5.5 m)	33 gpm @ 34.7 psi (124.9 L/min @ 2.39 Bar)	AW1, BX1	--	See Footnote 6.
14613	VK632	1/2	15	5.6	80.6	20' x 20' (6.1 m x 6.1 m)	40 gpm @ 51.0 psi (151.4 L/min @ 3.52 Bar)	CW1, DX1	--	See Footnote 6.
<b>Large Orifice</b>										
14535 <sup>10</sup>	VK634	3/4	20	8.0	115.2	16' x 16' (4.9 m x 4.9 m)	26 gpm @ 10.6 psi (98.4 L/min @ 0.73 Bar)	AW1, BX1	--	See Footnote 6.
14535 <sup>10</sup>	VK634	3/4	20	8.0	115.2	18' x 18' (5.5 m x 5.5 m)	33 gpm @ 17.0 psi (124.9 L/min @ 1.17 Bar)	AW1, BX1	--	See Footnote 6.
14535 <sup>10</sup>	VK634	3/4	20	8.0	115.2	20' x 20' (6.1 m x 6.1 m)	40 gpm @ 25.0 psi (151.4 L/min @ 1.72 Bar)	CW1, DX1	--	See Footnote 6.
<b>Sprinkler Temperature Ratings</b> A - 135 °F (57 °C) <sup>9</sup> and 155 °F (68 °C) B - 175 °F (79 °C) and 200 °F (93 °C) C - 135 °F (57 °C) <sup>9</sup> D - 175 °F (79 °C)				<b>Cover Plate Temperature Ratings<sup>7</sup></b> W - 135°F (57°C) cover 23190 <sup>1</sup> , or 23174 <sup>1</sup> (large diameter) X - 165°F (74°C) cover 23190 <sup>1</sup> , or 23174 <sup>1</sup> (large diameter)				<b>Cover Plate Finishes<sup>8</sup></b> 1 - Polished Chrome, Brushed Chrome, Bright Brass, Antique Brass, Brushed Brass, Brushed Copper, Painted White, Painted Ivory, and Painted Black		
<b>Footnotes</b>										
<ol style="list-style-type: none"> <li>Part number shown is the base part number. For complete part number, refer to current Viking price list schedule.</li> <li>Metric K-factor measurement shown is when pressure is measured in Bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.</li> <li>This chart shows the listings and approvals available at the time of printing. Other approvals may be in process. Check with the manufacturer for any additional approvals.</li> <li>For areas of coverage smaller than shown, use the "Minimum Water Supply Requirement" for the next larger area listed. Flows and pressures listed are per sprinkler.</li> <li>Listed by Underwriter's Laboratories, Inc. for use in the U.S. and Canada for Light Hazard occupancies with smooth, flat, horizontal ceilings only.</li> <li>Meets New York City requirements, effective July 1, 2008.</li> <li>The 135 °F (57 °C) cover has an orange label. The 165 °F (74 °C) cover has a white label.</li> <li>Painted finish consists of Polyester Baked Enamel. Other paint colors are available on request with the same listings as the standard paint colors. Listings and approvals apply for any paint manufacturer. Contact Viking for additional information.</li> <li>The ENT finish is NOT available and NOT cULus Listed for 135 °F (57 °C) temperature-rated sprinklers.</li> <li>Part number 14535 (VK634) is not available with ENT finish.</li> </ol> <p><b>NOTE: Custom colors are indicated on a label inside the cover assembly. Refer to Figure 1.</b></p>										



**TECHNICAL DATA**

**MIRAGE® QUICK RESPONSE  
EXTENDED COVERAGE  
CONCEALED PENDENT  
SPRINKLERS (VK632 AND VK634)**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058  
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com  
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

**DESIGN CRITERIA**

(Also refer to the Approval Chart)

**cULus Listing Requirements:** Mirage® Quick Response Extended Coverage Concealed Pendent Sprinklers VK632 and VK634 are cULus Listed for installation in accordance with the latest edition of NFPA 13 for extended coverage pendent spray sprinklers:


- Limited to Light Hazard occupancies, with smooth, flat, horizontal ceilings only.
- Minimum spacing allowed is 8 ft. (2.4 m) unless baffles are installed in accordance with NFPA 13.
- Minimum distance from walls is 4 in. (102 mm).
- Maximum distance from walls shall be no more than one-half of the allowable distance between sprinklers. The distance shall be measured perpendicular to the wall.
- The sprinkler installation and obstruction rules contained in NFPA 13 for extended coverage pendent spray sprinklers must be followed.

**NOTE: Concealed sprinklers must be installed in neutral or negative pressure plenums only.**


**IMPORTANT: Always refer to Bulletin Form No. F\_091699 - Care and Handling of Sprinklers. Also refer Bulletin Form No. F\_080614 for general care, installation, and maintenance information. Viking sprinklers are to be installed in accordance with the latest edition of Viking technical data, the appropriate standards of NFPA, FM Global, LPCB, APSAD, VdS or other similar organizations, and also with the provisions of governmental codes, ordinances, and standards, whenever applicable.**

**Sprinkler and Adapter Assembly**

- Protective cap removed
- Use wrench 14031\*\*




**Step 1:**  
Carefully slide the wrench sideways around the deflector and pins



**Step 2:**  
Carefully press the wrench upward and turn slightly to ensure engagement with the sprinkler wrench flats.

**NEVER** install the sprinkler by applying the installation wrench across the frame arms. **DO NOT** overtighten. Use only the designated sprinkler wrenches, Part Numbers 14047WB\*\* or 14031\*\*. A leak-tight seal should be achieved by turning the sprinkler clockwise 1 to 1-1/2 turns beyond finger tight.



**Figure 3: Sprinkler Installation and Proper Wrench Usage**  
 \*\* A 1/2" ratchet is required (Not available from us.)







TECHNICAL DATA

MIRAGE® QUICK RESPONSE  
EXTENDED COVERAGE  
CONCEALED PENDENT  
SPRINKLERS (VK632 AND VK634)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058  
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com  
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com



# Reliable®

## Model F3QR56 Dry K5.6 (80 metric) Quick-Response, Standard Spray Sprinklers

### Features

- Available in the following configurations:
  - Pendent with standard escutcheon
  - Pendent with Model HB extended escutcheon
  - Pendent with Model FP recessed escutcheon
  - Pendent with Model F1 recessed escutcheon
  - Concealed Pendent with Model CCP cover plate
  - Horizontal Sidewall with Standard escutcheon
  - Horizontal Sidewall with Model HB extended escutcheon
  - Horizontal Sidewall with Model FP recessed escutcheon (FM Standard Response)
  - Horizontal Sidewall with Model F1 recessed escutcheon (FM Standard Response)
  - Upright
- Available with 1" NPT, ISO7-1R1, 3/4" NPT, or ISO7-1R3/4 inlet fitting.
- 3/4" NPT inlet fittings permit replacement of older 3/4" inlet dry sprinklers without changing to a larger sprinkler fitting.
- Sprinklers, escutcheons, and cover plates are available in a wide variety of standard and special application finishes.
- White polyester, black polyester, and Electroless Nickel PTFE (ENT) finish sprinklers are cULus Listed as Corrosion Resistant.
- Available with cULus Listed 250 psi (17.2 bar) pressure rating for Dry Pendent and select HSW configurations. FM Approved for 175 psi (12 bar).

### Product Description

Model F3QR56 Dry sprinklers are quick-response, standard coverage sprinklers with a nominal K-Factor of 5.6 (80 metric). Available in Dry Pendent, Dry Horizontal Sidewall, and Dry Upright configurations, Model F3QR56 Dry sprinklers all use a 3 mm glass bulb operating element. See the Temperature Ratings table in this Bulletin for available temperature ratings. Model F3QR56 Dry sprinklers are intended for installation on wet-pipe, dry-pipe, or preaction sprinkler systems in accordance with NFPA 13, FM Property Loss Prevention Data Sheets, and other applicable installation standards.

Model F3QR56 Dry Pendent and Sidewall sprinklers are available with a variety of escutcheon options as illustrated in Figs. 1 through 3 and Figs. 5 through 9. In addition, Model F3QR56 Dry Pendent sprinklers are also available with the Model CCP conical concealed cover plate as illustrated in Fig. 4. Available sprinkler, escutcheon, and cover plate finishes are identified in the Finishes table in this Bulletin. The Model F1 escutcheon, Model FP escutcheon, and Model CCP cover plate are the only recessed escutcheons and cover plate listed for use with Model F3QR56 Dry sprinklers; the use of any other recessed escutcheon or cover plate with Model F3QR56 Dry sprinklers will void all guarantees, warranties, listings and approvals.



Pendent  
(See Fig. 1)



Pendent / HB  
(See Fig. 2)



Recessed FP Pendent  
(See Fig. 3)



Concealed  
(See Fig. 4)




Recessed F1 Pendent  
(See Fig. 5)



Horizontal Sidewall  
(See Fig. 6)



Horizontal Sidewall / HB  
(See Fig. 7)



Recessed FP  
Horizontal Sidewall  
(See Fig. 8)



Recessed F1  
Horizontal Sidewall  
(See Fig. 9)



Upright  
(See Fig. 10)

Inlet fittings are available with 1" NPT, ISO 7-1R1, 3/4" NPT, or ISO7-1R3/4 threads. Sprinklers with 3/4" NPT and ISO7-1R3/4 inlet fittings are intended primarily for replacement of existing 3/4" or ISO7-1R3/4 inlet dry sprinklers, but may also be used in new installations.

See the Available Configurations, Listings, and Approvals table in this Bulletin for further information on Model F3QR56 Dry sprinklers.

### Available Configurations, Listings, and Approvals

Sprinkler Model	Escutcheon or Cover Plate	Available Length (See Figs. 1-9)	Listings and Approvals <sup>(1)</sup>	Inlet Threads	Sprinkler Identification Number (SIN)
F3QR56 Dry Pendent	Standard Escutcheon	2" to 36" (50 to 900 mm)	cULus, NYC	3/4" NPT or ISO7-1R3/4	R5714
	HB Extended Escutcheon	3-1/2" to 36" (90 to 900 mm)			
	F1 Recessed Escutcheon				
	FP Recessed Escutcheon				
	CCP Cover Plate				
	Standard Escutcheon	2" to 48" (50 to 1200 mm)	cULus, FM, NYC	1" NPT or ISO7-1R1	
	HB Extended Escutcheon	3-1/2" to 48" (90 to 1200 mm)			
	F1 Recessed Escutcheon				
	FP Recessed Escutcheon				
	CCP Cover Plate				
F3QR56 Dry Horizontal Sidewall	Standard Escutcheon	2" to 48" (50 to 1200 mm)	cULus <sup>(2)</sup> , NYC <sup>(2)</sup>	3/4" NPT or ISO7-1R3/4	R5734
	HB Extended Escutcheon	3-1/2" to 48" (90 to 1200 mm)			
	F1 Recessed Escutcheon				
	FP Recessed Escutcheon				
	Standard Escutcheon	2" to 48" (50 to 1200 mm)	cULus <sup>(2)</sup> , FM <sup>(3)</sup> , NYC <sup>(2)</sup>	1" NPT or ISO7-1R1	
	HB Extended Escutcheon	3-1/2" to 48" (90 to 1200 mm)			
	F1 Recessed Escutcheon	3-1/2" to 48" (90 to 1200 mm)	cULus <sup>(2)</sup> , FM <sup>(3)(4)</sup> , NYC <sup>(2)</sup>		
	FP Recessed Escutcheon				
F3QR56 Dry Upright	N/A	5" to 48" (127 to 1200 mm)	cULus <sup>(2)</sup>	1" NPT or ISO7-1R1	R5724

<sup>(1)</sup> For available temperature ratings and finishes see the Temperature Ratings and Finishes tables, respectively, in this Bulletin.

<sup>(2)</sup> cULus Listing and NYC for Light Hazard and Ordinary Hazard only.

<sup>(3)</sup> FM Approved for Light Hazard only.

<sup>(4)</sup> Model F3QR56 Dry Horizontal Sidewall with Model F1 or Model FP recessed escutcheon are FM Approved as Standard Response.

## Listing and Approval Agencies

See the Available Configurations, Listings, and Approvals table in this Bulletin for listings and approvals applicable to each available configuration.

1. Listed by Underwriters Laboratories, Inc. and UL Certified for Canada (cULus)
2. Certified by FM Approvals (FM)
3. Permitted in New York City based on UL Listing per Local Law 33/2007 (NYC)

## Technical Data

Nominal K-Factor: 5.6 gpm/psi<sup>1/2</sup> (80 L/min/bar<sup>1/2</sup>)

Sprinkler	Listing or Approval	Deflector to Ceiling Distance	Maximum Working Pressure
F3QR56 Dry Pendent	cULus, NYC	See note below	250 psi (17.2 bar)
	FM	See note below	175 psi (12 bar)
F3QR56 Dry Horizontal Sidewall	cULus, NYC	4" to 6"	250 psi (17.2 bar)
		4" to 12"	175 psi (12 bar)
	FM	See note below	175 psi (12 bar)
F3QR56 Dry Upright	cULus	See note below	175 psi (12 bar)

**Note:** Deflector distance to be in accordance with applicable NFPA, FM, or other agency requirements. Information is provided only when additional clarification is necessary.

Temperature Classification	Glass Bulb Color	Sprinkler Temperature Rating	Cover Plate Temperature Rating	Maximum Ceiling Temperature	Listings and Approvals <sup>(1)</sup>
Ordinary	Orange	135°F (57°C)	135°F (57°C)	100°F (38°C)	cULus, FM, NYC
	Red	155°F (68°C)			
Intermediate	Yellow	175°F (79°C)	165°F (74°C)	150°F (66°C)	cULus, NYC
Intermediate	Green	200°F (93°C)	165°F (74°C)	150°F (66°C)	cULus, FM, NYC
High	Blue	286°F (141°C)	None	225°F (107°C)	cULus, FM <sup>(2)</sup> , NYC
			165°F (74°C)	150°F (66°C)	cULus, NYC

<sup>(1)</sup> For listed and approved sprinkler, escutcheon, and inlet configurations see the Available Configurations, Listings, and Approvals table in this Bulletin.

<sup>(2)</sup> High temperature classification is FM Approved with Standard and Model HB escutcheons only.

## Finish Notes

1. Finishes vary with type of trim selected. See table provided with each sprinkler detail for finish combinations.
2. Paint or any other coating applied over the factory finish will void all approvals and warranties.
3. Other finishes and colors may be available on special order. Consult your Reliable sales representative for details.
4. For Standard, Model HB, and Model F1 trims, both components of escutcheon are finished.
5. For Model FP and CCP trims, only the trim ring and cover plate are finished. The threaded sprinkler cup is unfinished.

# Model F3QR56 Dry Pendent Sprinkler with Standard Escutcheon (SIN R5714)

"A" Dim.	2" to 48" (51mm to 1219mm) in 1/4" (6mm) increments for 1" connections or
	2" to 36" (51mm to 914mm) in 1/4" (6mm) increments for 3/4" connections




Fig. 1

**Note:** The sprinkler can protrudes 1/2" (12mm) when escutcheon is in nominal position. Escutcheon adjustment provides -1/2" (12mm) to +1" (25mm) "A" dimension adjustment range.

Finish Combinations: Standard Escutcheon	
Sprinkler	Escutcheon <sup>(2)(3)</sup>
Bronze	Polished Stainless
Bronze	Laquered Brass
Chrome	Polished Stainless
White Polyester <sup>(1)</sup>	White Polyester
Black Polyester <sup>(1)</sup>	Black Polyester
Custom Color Polyester <sup>(1)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(4)</sup>	Polished Stainless

- Notes:**
1. UL Listed as Corrosion Resistant.
  2. Escutcheons do not carry corrosion resistant listings.
  3. Base material is 316 stainless steel unless noted.
  4. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Pendent Sprinkler with Model HB Extended Escutcheon (SIN R5714)

<b>"A" Dim.</b>	3½" to 48" (89mm to 1219mm) in ¼" (6mm) increments for 1" connections or 3½" to 36" (89mm to 914mm) in ¼" (6mm) increments for ¾" connections
-----------------	---




Fig. 2

**Note:** The sprinkler can protrudes 1¼" when escutcheon is in nominal position. Escutcheon adjustment provides -½" (-12.7mm) to +½" (+12.7mm) "A" dimension adjustment range.

Finish Combinations: HB Escutcheon	
Sprinkler	Escutcheon <sup>(2)(3)</sup>
Bronze	Chrome
Chrome	Chrome
White Polyester <sup>(1)</sup>	White Polyester
Black Polyester <sup>(1)</sup>	Black Polyester
Custom Color Polyester <sup>(1)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(1)(4)</sup>	Stainless Steel

**Notes:**

1. UL Listed as Corrosion Resistant.
2. Escutcheons do not carry corrosion resistant listings.
3. Base material is cold rolled steel unless noted.
4. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Pendent Sprinkler with Model FP Recessed Escutcheon (SIN R5714)

"A" Dim.	3 1/2" to 48" (89mm to 1219mm) in 1/4" (6mm) increments for 1" connections or
	3 1/2" to 36" (89mm to 914mm) in 1/4" (6mm) increments for 3/4" connections




Fig. 3

**Note:** Do not install the Model F3QR56 Dry Pendent sprinkler with the Model FP escutcheon in ceilings which have positive pressure in the space above.

Finish Combinations: FP Recessed Escutcheon	
Sprinkler <sup>(1)</sup>	Escutcheon <sup>(3)(4)</sup>
Bronze	Chrome
Bronze	Brass
Chrome	Chrome
White Polyester <sup>(2)</sup>	White Polyester
Black Polyester <sup>(2)</sup>	Black Polyester
Custom Color Polyester <sup>(2)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(2)(5)</sup>	Stainless Steel

- Notes:**
1. Cup for FP Recessed is unfinished galvanized steel except electroless nickel PTFE sprinkler uses a stainless steel cup.
  2. UL Listed as Corrosion Resistant.
  3. Escutcheons do not carry corrosion resistant listings.
  4. Base material is cold rolled steel unless noted.
  5. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Pendent Sprinkler with Model CCP Cover Plate (SIN R5714)

"A" Dim.	3 1/2" to 48" (89mm to 1219mm) in 1/4" (6mm) increments for 1" connections or
	3 1/2" to 36" (89mm to 914mm) in 1/4" (6mm) increments for 3/4" connections




Fig. 4

**Note:** Do not install the Model F3QR56 Dry Pendent sprinkler with the Model CCP cover plate in ceilings which have positive pressure in the space above.

Finish Combinations: CCP Conical Cover Plate	
Sprinkler	Cover Plate <sup>(2)</sup>
Bronze	White Polyester
	Chrome Bright
	Chrome Dull
	Bright Brass
	Unfinished Bronze
	Custom Color

**Notes:**

1. Cup for CCP Concealed in unfinished galvanized steel.
2. Cover plates do not carry corrosion resistant listings.



# Model F3QR56 Dry Pendent Sprinkler with Model F1 Recessed Escutcheon (SIN R5714)

<b>"A" Dim.</b>	3 1/2" to 48" (89mm to 1219mm) in 1/4" (6mm) increments for 1" connections or 3 1/2" to 36" (89mm to 914mm) in 1/4" (6mm) increments for 3/4" connections.
-----------------	--




Fig. 5

Finish Combinations: F1 Recessed Escutcheon	
Sprinkler	Escutcheon <sup>(2)(3)</sup>
Bronze	Chrome
Bronze	Brass
Chrome	Chrome
White Polyester <sup>(1)</sup>	White Polyester
Black Polyester <sup>(1)</sup>	Black Polyester
Custom Color Polyester <sup>(1)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(1)(4)</sup>	Stainless Steel

**Notes:**

1. UL Listed as Corrosion Resistant.
2. Escutcheons do not carry corrosion resistant listings.
3. Base material is cold rolled steel unless noted.
4. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Horizontal Sidewall Sprinkler with Standard Escutcheon (SIN R5734)

<b>"A" Dim.</b>	2" to 48" (51mm to 1219mm) in 1/4" (6mm) increments for 1" connections or 2" to 36" (51mm to 914mm) in 1/4" (6mm) increments for 3/4" connections
-----------------	---




Fig. 6

**Note:** The sprinkler can protrudes 1/2" when escutcheon is in nominal position. Escutcheon adjustment provides -1/2" (-12mm) to +1" (25mm) "A" dimension adjustment range.

Finish Combinations: Standard Escutcheon	
Sprinkler	Escutcheon <sup>(2)(3)</sup>
Bronze	Polished Stainless
Bronze	Laquered Brass
Chrome	Polished Stainless
White Polyester <sup>(1)</sup>	White Polyester
Black Polyester <sup>(1)</sup>	Black Polyester
Custom Color Polyester <sup>(1)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(1)(4)</sup>	Polished Stainless

**Notes:**

1. UL Listed as Corrosion Resistant.
2. Escutcheons do not carry corrosion resistant listings.
3. Base material is 316 stainless steel unless noted.
4. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Horizontal Sidewall Sprinkler with Model HB Escutcheon (SIN R5734)

"A" Dim.	3 1/2" to 48" (89mm to 1219mm) in 1/4" (6mm) increments for 1" connections or
	3 1/2" to 36" (89mm to 914mm) in 1/4" (6mm) increments for 3/4" connections




Fig. 7

**Note:** The sprinkler can protrudes 1 1/4" when escutcheon is in nominal position. Escutcheon adjustment provides -1/2" (-12.7mm) to +1/2" (+12.7mm) "A" dimension adjustment range.

Finish Combinations: HB Escutcheon	
Sprinkler	Escutcheon <sup>(2)(3)</sup>
Bronze	Chrome
Chrome	Chrome
White Polyester <sup>(1)</sup>	White Polyester
Black Polyester <sup>(1)</sup>	Black Polyester
Custom Color Polyester <sup>(1)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(1)(4)</sup>	Stainless Steel

**Notes:**

1. UL Listed as Corrosion Resistant.
2. Escutcheons do not carry corrosion resistant listings.
3. Base material is cold rolled steel unless noted.
4. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Horizontal Sidewall Sprinkler with Model FP Recessed Escutcheon (SIN R5734)

"A" Dim.	3 1/2" to 48" (89mm to 1219mm) in 1/4" (6mm) increments for 1" connections or
	3 1/2" to 36" (89mm to 914mm) in 1/4" (6mm) increments for 3/4" connections




Fig. 8

**Note:** Do not install the Model F3QR56 Dry Horizontal Sidewall sprinkler with the Model FP escutcheon in walls which are positively pressurized with respect to the protected space.

Finish Combinations: FP Recessed Escutcheon	
Sprinkler <sup>(1)</sup>	Escutcheon <sup>(3)(4)</sup>
Bronze	Chrome
Bronze	Brass
Chrome	Chrome
White Polyester <sup>(2)</sup>	White Polyester
Black Polyester <sup>(2)</sup>	Black Polyester
Custom Color Polyester <sup>(2)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(2)(5)</sup>	Stainless Steel

**Notes:**

1. Cup for FP Recessed is unfinished galvanized steel except electroless nickel PTFE sprinkler uses a stainless steel cup.
2. UL Listed as Corrosion Resistant.
3. Escutcheons do not carry corrosion resistant listings.
4. Base material is cold rolled steel unless noted.
5. FM Approved as Corrosion Resistant.

# Model F3QR56 Dry Horizontal Sidewall Sprinkler with Model F1 Recessed Escutcheon (SIN R5734)

**"A" Dim.** 3 1/2" to 48" (89mm to 1219mm) in 1/4" (6mm) increments for 1" connections or 3 1/2" to 36" (89mm to 914mm) in 1/4" (6mm) increments for 3/4" connections




Fig. 9

Finish Combinations: F1 Recessed Escutcheon	
Sprinkler	Escutcheon <sup>(2)(3)</sup>
Bronze	Chrome
Bronze	Brass
Chrome	Chrome
White Polyester <sup>(1)</sup>	White Polyester
Black Polyester <sup>(1)</sup>	Black Polyester
Custom Color Polyester <sup>(1)</sup>	Custom Color Polyester
Electroless Nickel PTFE <sup>(1)(4)</sup>	Stainless Steel

**Notes:**

1. UL Listed as Corrosion Resistant.
2. Escutcheons do not carry corrosion resistant listings.
3. Base material is cold rolled steel unless noted.
4. FM Approved as Corrosion Resistant.

**Model F3QR56 Dry Upright (SIN 5724)**

Order Dimensions 5" to 48" (127 mm to 1219 mm)




Fig. 10

Finish Combinations: Upright	
Sprinkler	Escutcheon
Bronze	NA
Electroless Nickel PTFE <sup>(1)</sup>	NA

**Notes:**

1. UL Listed as Corrosion Resistant.
2. Escutcheons do not carry corrosion resistant listings.
3. Base material is cold rolled steel unless noted.

MINIMUM EXPOSED BARREL LENGTH WHEN CONNECTED TO WET PIPE SPRINKLER SYSTEM


NOTE: STANDARD DRY PENDENT IS SHOWN, HOWEVER, MINIMUM EXPOSED BARREL LENGTH APPLIES TO ALL STYLES OF DRY SPRINKLERS CONNECTED TO A WET PIPE SYSTEM.

AMBIENT TEMPERATURE EXPOSED TO DISCHARGE END OF SPRINKLER*	EXPOSED BARREL AMBIENT TEMPERATURE		
	40°F/4°C	50°F/10°C	60°F/16°C
	EXPOSED MINIMUM BARREL LENGTH** (FACE OF FITTING TO TOP OF CEILING)***		
	IN. (MM)	IN. (MM)	IN. (MM)
40°F (4°C)	0	0	0
30°F (-1°C)	0	0	0
20°F (-7°C)	4 (100)	0	0
10°F (-12°C)	8 (200)	1 (25)	0
0°F (-18°C)	12 (300)	3 (75)	0
-10°F (-23°C)	14 (350)	4 (100)	1 (25)
-20°F (-29°C)	14 (350)	6 (150)	3 (75)
-30°F (-34°C)	16 (400)	8 (200)	4 (100)
-40°F (-40°C)	18 (450)	8 (200)	4 (100)
-50°F (-46°C)	20 (500)	10 (250)	6 (150)
-60°F (-51°C)	20 (500)	10 (250)	6 (150)


\* FOR AMBIENT TEMPERATURES EXPOSED TO THE DISCHARGE END OF THE SPRINKLER THAT OCCUR BETWEEN THE VALUES LISTED, USE THE NEXT COOLER TEMPERATURE.

\*\* THE MINIMUM EXPOSED BARREL LENGTH IS NOT THE SAME AS THE "A" DIMENSION. THE MINIMUM EXPOSED BARREL LENGTH IS BASED ON A PROPERLY SEALED PENETRATION WITH A MAXIMUM WIND VELOCITY ON THE EXPOSED SPRINKLER OF 30 MPH (48 KM/H). LONGER EXPOSED BARREL LENGTHS WILL HELP AVOID FREEZING OF THE WET PIPING WHERE HIGHER WIND VELOCITY IS EXPECTED.

\*\*\* THE MINIMUM EXPOSED BARREL LENGTH IS MEASURED FROM THE FACE OF THE FITTING TO THE INSIDE FACE OF THE INSULATION, WALL, OR CEILING LEADING TO THE COLD SPACE, WHICHEVER IS CLOSEST TO THE FITTING.



RECOMMENDED DRY SPRINKLER SEAL ARRANGEMENTS (DRY SPRINKLER WITH STANDARD ESCUTCHEON SHOWN)



COMDRYDET11

Fig. 11


## **\*CAUTION\***

RELIABLE DRY SPRINKLERS MAY BE INSTALLED IN A LISTED CPVC SPRINKLER FITTING, ONLY UPON VERIFICATION THAT THE FITTING DOES NOT INTERFERE WITH THE SPRINKLER'S INLET.

Do not install dry sprinklers with standard inlets into CPVC fittings that have an internal obstruction; this will damage the sprinkler, the fitting, or both.

Short inlet ("PL") versions of Reliable dry sprinklers are available that may or may not be compatible with fittings having internal obstructions in existing installations. Sprinklers with the short inlet ("PL") should only be installed in CPVC fittings of wet-pipe systems.

In all cases, verify sprinkler and fitting dimensions prior to installation to avoid interference.



**BE SURE TO ORDER THE CORRECT SPRINKLERS FOR YOUR APPLICATION**

COMDRYDET2

Fig. 12






Fig. 13 - Model F3R Wrench





Fig. 14 - Model XLO2 Wrench

## MATERIAL SPECIFICATIONS



ITEM #	DESCRIPTION	MATERIAL SPECIFICATION
1	FRAME	BRASS PER UNS C83600
2	DEFLECTOR	BRONZE PER UNS C51000
3	LOAD SCREW	BRASS PER UNS C22000
4	SEAT ADAPTOR	BRASS ALLOY PER UNS C36000
5	BULB INSERT	COPPER ALLOY PER UNS C31400
6	GLASS BULB	GLASS W/GLYCERIN SOLUTION
7	ORIFICE ADAPTOR	BRASS ALLOY PER UNS C36000
8	OUTER TUBE	GALVANIZED STEEL
9	INNER TUBE	BRASS ALLOY PER UNS C23000
10	YOKE	BRASS ALLOY PER UNS C38000
11	INLET	BRASS ALLOY PER UNS C35330
12	CAP	BRASS ALLOY PER UNS C54400
13	SPRING WASHER/SEAL	PTFE COATED BERYLLIUM NICKEL
14	FLIP DISK	BRASS ALLOY PER UNS C54400
15	CAN/ESCUTCHEON	PAINTED OR PLATED MILD STEEL, EXCEPT FOR TYPE 316 STAINLESS STEEL FOR SPRINKLERS WITH ENT FINISH

(PIPE WRENCH MAY ONLY BE USED ON OUTER STEEL PIPE OF SPRINKLER)

COMDRYDET13

APPEARANCE OF DEFLECTOR MAY VARY DEPENDING ON MODEL

Fig. 15

## Installation Instructions

When used on wet pipe systems, Reliable Model F3QR56 dry sprinklers may be installed in ductile or malleable cast iron threaded tees, or CPVC tees and adapters upon verification that the sprinkler inlet fitting does not interfere with the interior of the fitting (see Figure 12).

When used on dry pipe systems, Reliable Model F3QR56 dry pendent sprinklers MUST ONLY BE installed in the outlets of ductile or malleable cast iron threaded tees on horizontal pipe such that the inlet of the sprinkler protrudes above the bottom level of the pipe.

When used on dry pipe systems, Reliable Model F3QR56 dry sidewall and dry upright sprinklers may be installed in ductile or malleable cast iron threaded tees, or CPVC tees and adapters upon verification that the sprinkler inlet fitting does not interfere with the interior of the fitting (see Figure 12).

DO NOT install Reliable dry sprinklers into elbows or couplings, welded outlets, mechanical tees, or gasket sealed CPVC fittings.

Dry sprinklers connected to wet pipe systems must be installed as indicated in Figure 11 and as required by NFPA 13 with the Exposed Minimum Barrel Length located in a heated area.

An orange protective clip is factory installed on the sprinkler to protect the glass bulb thermal element from damage. The clip should remain in place during installation of the sprinkler and be removed when the sprinkler system is placed in service. Sprinklers with 3/4" NPT and ISO7-1R3/4 inlets are supplied with a protective cap on the inlet that must be removed before installation.

### Use the following steps for installation:

1. Cut a hole in the wall or ceiling directly in-line with the outlet of the fitting. See the Installation Data table for the recommended hole diameter based on the escutcheon or cover plate option selected.
2. Apply pipe joint compound or PTFE tape to the male threads of the sprinkler's inlet fitting.
3. Install the sprinkler in the fitting using the installation wrench specified in the Installation Data table. The Model F3R wrench is designed to be inserted into the grooves in the sprinkler's wrench boss as shown in Fig. 13. The Model XLO2 wrench is designed to fit into the cup and engage the wrench boss as shown in Fig. 14. Do NOT wrench any part of the sprinkler assembly other than the wrench boss. When inserting or removing the wrench from the sprinkler, care should be taken to prevent damage to the sprinkler. The sprinkler is then tightened into the pipe fitting to achieve a leak free connection. The recommended minimum to maximum installation torque is 22 - 30 lb-ft (30 – 40 N-m) for 1" NPT and ISO7-1R1 sprinklers, and 14 - 20 lb-ft (19 – 27 N-m) for 3/4" NPT and ISO7-1R3/4 sprinklers.

- 3a. Alternatively, where access to the outer tube of the sprinkler is available, the Model F3QR56 Dry sprinkler may be installed using a pipe wrench. The pipe wrench shall only be permitted to interface with the galvanized steel outer tube portion of the sprinkler (Item #8 in Fig. 15). Do NOT wrench any other portion of the sprinkler assembly. A pipe wrench can install the sprinkler into the fitting with a large amount of torque; consideration should be given to the need for future removal of the sprinkler because the installation torque will have to be matched or exceeded to remove the sprinkler. The recommended minimum to maximum installation torque is 22 - 30 lb-ft (30 – 40 N-m) for 1" NPT and ISO7-1R1 sprinklers, and 14 - 20 lb-ft (19 – 27 N-m) for 3/4" NPT and ISO7-1R3/4 sprinklers.
4. Standard and Model HB escutcheons can be installed by slipping the escutcheon over the can until the escutcheon is seated against the ceiling or wall. Model F1 escutcheons are installed by pressing the escutcheon onto the collar until the escutcheon is seated against the ceiling or wall. The Model FP escutcheon is installed by pressing or threading the escutcheon into the cup by hand; the escutcheon can be tightened against the ceiling or wall by turning the escutcheon in a clockwise direction and removed by turning the escutcheon in a counter-clockwise direction. To install the Model CCP cover plate, first remove the protective clip. Install the Model CCP cover plate on the sprinkler by pressing or threading the cover plate into the cup by hand; the cover plate can be tightened against the ceiling by turning the cover plate in a clockwise direction and removed by turning the cover plate in a counter-clockwise direction.
5. Remove the orange protective clip when placing the sprinkler system in service.

## Installation Data

Sprinkler Model	Escutcheon or Cover Plate	Suggested Hole Diameter in Wall or Ceiling	Installation Wrench	Required Centerline of Sprinkler Tube/Inlet to Finished Ceiling Vertical Dimension*
<b>F3QR56 Dry Pendent</b>	Standard Escutcheon	2-1/8" (54 mm)	F3R	Not Applicable
	HB Extended Escutcheon	2-1/2" (64 mm)	F3R	
	F1 Recessed Escutcheon	2-1/4" (57 mm)	XLO2	
	FP Recessed Escutcheon	2-1/2" (64 mm)	XLO2	
	CCP Cover Plate		XLO2	
<b>F3QR56 Dry Horizontal Sidewall</b>	Standard Escutcheon	2-1/8" (54 mm)	F3R	4-5/8" to 12-5/8" (118 mm to 321 mm)
	HB Extended Escutcheon	2-1/2" (64 mm)	F3R	cULus, NYC 4-5/8" to 6-5/8" (118 mm to 168 mm)
	F1 Recessed Escutcheon	2-1/4" (57 mm)	XLO2	
	FP Recessed Escutcheon	2-1/2" (64 mm)	XLO2	FM 4-5/8" to 12-5/8" (118 mm to 321 mm)
	F1 Recessed Escutcheon	2-1/4" (57 mm)	XLO2	
	FP Recessed Escutcheon	2-1/2" (64 mm)	XLO2	
<b>F3QR56 Dry Upright</b>	N/A	1-1/2" (38mm)	F3R	Not Applicable

\*Note: Based on 5/8" (16 mm) centerline of sprinkler tube/inlet to deflector vertical distance.

## Maintenance

The Model F3QR56 Dry Sprinklers should be inspected and the sprinkler system maintained in accordance with NFPA 25. Do not remove the factory applied thermally sensitive wax fillet between the bulb supporting cup and the wrenching boss. Do not replace this wax with a substitute substance.

An Alternate substance may interfere with proper operation of the sprinkler. Do not clean sprinklers with soap and water, ammonia or any other cleaning fluids. Remove dust by using a soft brush or gently vacuuming. Replace any sprinkler which has been painted (other than factory applied) or damaged in any way. A stock of spare sprinklers should be maintained to allow quick replacement of damaged or operated sprinklers. Prior to installation, sprinklers should be maintained in the original cartons and packaging until used to minimize the potential for damage to sprinklers that would cause improper operation or non-operation.

## Ordering Information

Specify:

- Sprinkler: [Model F3QR56 Dry Pendent SIN R5714]  
[Model F3QR56 Dry Horizontal Sidewall SIN R5734]  
[Model F2QR Dry Upright SIN R5724]
- Escutcheon/Cover Plate: [None][Standard escutcheon]  
[Model HB extended escutcheon][Model F1 recessed escutcheon][Model FP recessed escutcheon][Model CCP cover plate – pendent only]
- Inlet Threads: [1" NPT][ISO7-1R1][3/4" NPT][ISO7-1R3/4]

- Inlet Fitting: [Long – Standard Inlet Fitting][Short "PL" – Wet Pipe Systems only]
- Sprinkler Temperature Rating: See Temperature Ratings Table
- Sprinkler Finish: See Finish Combinations Table
- Escutcheon/Cover Plate Finish: See Finish Combinations Table
- Length:

\*For dry pendants and dry sidewalls: "A" Dimension is from face of tee to face of finished ceiling or wall in 1/4" (6mm) increments. See Fig. 1 through Fig. 9.

\*For dry uprights: Order dimension is from face of tee to top of deflector in 1/4" (6mm) increments. See Fig. 10.

## Notes:

- For Dry Upright, customer is responsible for determining the correct deflector distance from structure above.
- Length is based on normally gauged pipe thread "make-up" of .600" (15mm) per ANSI B2.1 (approximately 7-1/2 threads).

## Installation Wrench

Model F3R Sprinkler Wrench (Standard and HB escutcheons)  
Model XLO2 Sprinkler Wrench (FP Recessed and CCP Concealed)

The equipment presented in this bulletin is to be installed in accordance with the latest published Standards of the National Fire Protection Association, Factory Mutual Research Corporation, or other similar organizations and also with the provisions of governmental codes or ordinances whenever applicable.

Products manufactured and distributed by Reliable have been protecting life and property for almost 100 years.

Manufactured by

# Reliable®

**Reliable Automatic Sprinkler Co., Inc.**

(800) 431-1588  
(800) 848-6051  
(914) 829-2042  
www.reliablesprinkler.com

Sales Offices  
Sales Fax  
Corporate Offices  
Internet Address



Recycled Paper

Revision lines indicate updated or new data.

EG. Printed in U.S.A. 11/22 P/N 9999970175



## F1FR56 Series Quick Response Sprinklers

K-factor 5.6 (80)

### Features

- Standard coverage quick-response sprinklers
- Upright, pendent, horizontal sidewall, and vertical sidewall deflectors
- Low profile, compact design
- Available in a wide variety of finishes

### Product Description

Reliable Model F1FR56 series sprinklers are quick-response standard spray automatic fire sprinklers utilizing a sensitive 3.0 mm glass bulb thermal element.

Pendent and horizontal sidewall sprinklers may be installed exposed or surface mounted using escutcheons such as the Reliable Models B, C, or HB (reference Technical Bulletin 204). When installed recessed or concealed, the Model F1FR56 series sprinklers are specifically listed with and may only be installed with listed Reliable escutcheons and cover plates. Refer to the technical information on the following pages for specific listings for recessed and concealed installations and refer to Figures 5 and 6 for dimensional information.

When fitted with an approved water shield, these sprinklers may be considered intermediate sprinklers for use in racks, below grated walkways, and other areas where intermediate level sprinklers are required.

Table A provides a summary of the approvals and availability of specific Model F1FR series sprinkler configurations. Additional technical information for each sprinkler model is provided on the following pages.




Model F1FR56 Pendent



Model F1FR56 Upright



Model F1FR56 Vertical Sidewall



Model F1FR56 Horizontal Sidewall

**Note:** Not all versions of the product are shown.

**Note:** This bulletin may contain information on New and Legacy sprinklers that reflects a dimensional change only. Sprinkler Identification Number (SIN), application, performance, and listings/approval are not otherwise affected. Sprinklers with New frames will include the suffix "N" in the order.

### F1FR Series Sprinklers Summary

Table A

Sprinkler Model	K-Factor gpm/psi <sup>1/2</sup> (lpm/bar <sup>1/2</sup> )	Orientation	Listings & Approvals	Max. Working Pressure psi (bar)	Sprinkler Identification Number (SIN)
F1FR56	5.6 (80)	Upright Intermediate Upright	cULus, FM, LPCB, VdS, EC, WM, UKCA	175 (12) 250 (17) (cULus only)	RA1425
		Pendent	cULus, FM, LPCB, VdS, EC, WM, UKCA	175 (12) 250 (17) (cULus only)	RA1414
		Concealed Pendent	cULus, VdS, EC, WM, UKCA	175 (12) 250 (17) (cULus only)	RA1414
		Horizontal Sidewall	cULus, FM	175 (12) 250 (17) (cULus only)	RA1435
		Vertical Sidewall	cULus, FM, LPCB, UKCA	175 (12)	RA1485

**Model F1FR56 Upright Sprinkler**

**SIN RA1425**

**Technical Specifications**

**Style:** Upright, Intermediate Upright

**Threads:** 1/2" NPT or ISO 7-R1/2

**Nominal K-Factor:** 5.6 (80 metric)

**Max. Working Pressure:**

175 psi (12 bar)

250 psi (17 bar) (cULus only)

**Material Specifications**

**Thermal Sensor:** 3 mm Glass Bulb

**Sprinkler Frame:** Brass Alloy

**Cap:** Bronze Alloy

**Sealing Washer:** Nickel with PTFE

**Load Screw:** Copper Alloy

**Deflector:** Brass Alloy

**Sprinkler Finishes**

(See Table B)

**Sensitivity**

Quick response

**Temperature Ratings**

135°F (57°C)

155°F (68°C)

175°F (79°C)

200°F (93°C)

286°F (141°C)

**Guards & Shields (New Frames)**

Factory Water Shield (cULus, FM)

F-1 Guard (cULus, FM)

F-3 Guard with Shield (cULus, FM)

**Guards and Shields (Legacy Frames)**

Factory Water Shield

C-1 Guard (FM)

C-3 Guard with Shield (cULus, FM)

D-1 Guard (cULus)

D-3 Guard with Shield (cULus)

**Sprinkler Wrench**

Model W2

Model J (New frame with guard installed)

Model JD (Legacy frame with guard installed)

**Listings and Approvals**

cULus Listed

FM Approved

LPCB

VdS

EC


WM

UKCA: 0832-UKCA-CPR-S5045



**Model F1FR56 Upright Sprinkler Components and Dimensions**

**Figure 1**



**Technical Specifications**

**Style:**  
 Pendent  
 Recessed Pendent  
 Concealed Pendent  
**Threads:** 1/2" NPT or ISO 7-R1/2  
**Nominal K-Factor:** 5.6 (80 metric)  
**Max. Working Pressure:**  
 175 psi (12 bar)  
 250 psi (17 bar) (cULus only)

**Material Specifications**  
**Thermal Sensor:** 3 mm Glass Bulb  
**Sprinkler Frame:** Brass Alloy  
**Cap:** Bronze Alloy  
**Sealing Washer:** Nickel with PTFE  
**Load Screw:** Copper Alloy  
**Deflector:** Brass Alloy

**Sprinkler Finishes**  
 (See Table B)

**Sensitivity**  
 Quick response

**Temperature Ratings<sup>(1)</sup>**  
 135°F (57°C)  
 155°F (68°C)  
 175°F (79°C)  
 200°F (93°C)  
 286°F (141°C)

**Recessed Escutcheons**

Model F1 (cULus, LPCB, VdS, CE, WM)  
 Model F2 (cULus, FM, LPCB, VdS, CE, WM)  
 Model FP (cULus, VdS, CE, WM)

**Cover Plate**

Model CCP (cULus, VdS<sup>(2)</sup>, CE<sup>(2)</sup>)

**Guards & Shields (New Frames)<sup>(3)</sup>**

F-1 Guard (FM)  
 F-5 Guard/Shield Kit (FM)  
 F-7 Guard (cULus)  
 F-8 Guard/Shield Kit (cULus)  
 S-1 Shield (cULus, FM)

**Guards & Shields (Legacy Frames)<sup>(3)</sup>**

C-1 Guard (FM)  
 C-5 Guard/Shield Kit (FM)  
 D-1 Guard (cULus, FM)  
 D-4 Guard/Shield Kit (FM)  
 D-5 Guard/Shield Kit (cULus, FM)  
 S-1 Shield (cULus, FM)

**Sprinkler Wrenches**

Model W2 (pendent)  
 Model W4 (recessed or concealed)  
 Model J (New frame with guard installed)  
 Model JD (Legacy frame with guard installed)

**Listings and Approvals<sup>(4)</sup>**

cULus Listed  
 FM Approved  
 LPCB  
 VdS  
 EC  
 WM  
 UKCA: 0832-UKCA-CPR-S5045,  
 0831-UKCA-CPR-5072 (CCP)




**Notes:**

1. 286°F (141°C) temperature rated sprinkler not listed for recessed or concealed use.
2. VdS and CE approval for CCP concealed use is for 155°C (68°C) sprinkler ONLY.
3. Not suitable for recessed or concealed installations.
4. When used surface mounted or exposed. See Recessed Escutcheon and Cover Plate section for specific approvals when installed recessed or concealed.

**Model F1FR56 Pendent Sprinkler Components and Dimensions**

**Figure 2**



**Note:** Please refer to Figure 8 for recessed and concealed installation.

**Technical Specifications**

**Style:**

Horizontal Sidewall  
Recessed Horizontal Sidewall

**Threads:** 1/2" NPT or ISO 7-R1/2

**Nominal K-Factor:** 5.6 (80 metric)

**Max. Working Pressure:**

175 psi (12 bar)  
250 psi (17 bar) (cULus only)

**Material Specifications**

**Thermal Sensor:** 3 mm Glass Bulb

**Sprinkler Frame:** Brass Alloy

**Cap:** Bronze Alloy

**Sealing Washer:** Nickel with PTFE

**Load Screw:** Copper Alloy

**Deflector:** Brass Alloy

**Sprinkler Finishes**

(See Table B)

**Sensitivity**

Quick response

**Temperature Ratings <sup>(1)</sup>**

135°F (57°C)  
155°F (68°C)  
175°F (79°C)  
200°F (93°C)  
286°F (141°C)

**Recessed Escutcheons<sup>(2)</sup>**

Model F1 (cULus)  
Model F2 (cULus, FM)  
Model FP (cULus)

**Guards & Shields (New Frames)<sup>(3)</sup>**

F-4 Guard (FM)  
F-7 Guard (cULus)

**Guards & Shields (Legacy Frames)<sup>(3)</sup>**


C1 Guard (FM)  
D1 Guard (cULus)

**Sprinkler Wrenches**

Model W2 (non-recessed)  
Model W4 (recessed)  
Model J (New frame with guard installed)  
Model JD (Legacy frame with guard installed)

**Listings and Approvals**

cULus Listed<sup>(4)</sup>  
FM Approved<sup>(5)</sup>




**Notes:**

1. 286°F (141°C) temperature rated sprinkler not listed for recessed use.
2. FM approved recessed installation when used with Model F2 escutcheon ONLY.
3. Not suitable for recessed horizontal sidewall installations.
4. cULus Listed for Light and Ordinary Hazard when installed exposed or surface mounted. Listed for Light Hazard ONLY when installed recessed.
5. FM Approved for Light Hazard ONLY.

**Model F1FR56 Horizontal Sidewall Sprinkler Components and Dimensions**

**Figure 3**



**Note:** Please refer to Figure 9 for recessed installation.



**Technical Specifications**

**Style:**

Upright Vertical Sidewall  
Pendent Vertical Sidewall

**Threads:** 1/2" NPT or ISO 7-R1/2

**Nominal K-Factor:** 5.6 (80 metric)

**Max. Working Pressure:** 175 psi (12 bar)

**Material Specifications**

**Thermal Sensor:** 3 mm Glass Bulb

**Sprinkler Frame:** Brass Alloy

**Cap:** Bronze Alloy

**Sealing Washer:** Nickel with PTFE

**Load Screw:** Copper Alloy

**Deflector:** Brass Alloy

**Sprinkler Finishes**

(See Table B)

**Sensitivity**

Quick response

**Temperature Ratings**

135°F (57°C)

155°F (68°C)

175°F (79°C)

200°F (93°C)

286°F (141°C)

**Guards & Shields (New Frames)**

F-2 Guard (FM)

**Guards & Shields (Legacy Frames)**

C1 Guard (FM)

**Sprinkler Wrenches**

Model W2

Model J (New frame with guard installed)

Model JD (Legacy frame with guard installed)

**Listings and Approvals<sup>(1)</sup>**

cULus Listed

FM Approved

LPCB<sup>(2)</sup>

UKCA: 0832-UKCA-CPR-S5045






**Notes:**

1. Listed and approved for Light Hazard ONLY.
2. LPCB approved for use in pendent position ONLY.



**Model F1FR56 Vertical Sprinkler Components and Dimensions**

**Figure 4**






F1\_REC\_PEND\_CCP




Note: Model FP recessed assemblies may not be used where the pressure in the space above the ceiling is positive with respect to the protected area. Ensure that the openings in the Model FP cup are unobstructed following installation.

Note: Model CCP concealed assemblies may not be used where the pressure in the space above the ceiling is positive with respect to the protected area. Ensure that the openings in the Model CCP cup are unobstructed following installation.






Model F1FR Horizontal Sidewall Sprinkler  
with Model F1 Recessed Escutcheon  
3/4" (19mm) Nominal Adjustment F1FR\_REC\_HSW



Model F1FR Horizontal Sidewall Sprinkler  
with Model F2 Recessed Escutcheon  
1/2" (13mm) Nominal Adjustment



Model F1FR Horizontal Sidewall Sprinkler  
with Model FP Recessed Escutcheon  
1/2" (13mm) Nominal Adjustment

Note: Model FP recessed assemblies may not be used where the pressure in the space behind the sprinkler is positive with respect to the space in the protected area. Ensure that the openings in the Model FP cup are unobstructed following installation.

## Wrenches



Model W2 (upright, pendent)



Model J (New frame with guard installed)  
Model JD (Legacy frame with guard installed, similar but with zinc finish)



Model W4  
(recessed, concealed pendent)

## Finishes<sup>(1)</sup>

Table B

Standard Finishes			Special Application Finishes		
Sprinkler	F1, F2 and FP <sup>(2)</sup> Escutcheons	CCP Cover Plate <sup>(2)</sup>	Sprinkler	F1, F2 and FP <sup>(2)</sup> Escutcheons	CCP Cover Plate <sup>(2)</sup>
Bronze	Brass	Chrome	Electroless Nickel PTFE <sup>(3)(4)</sup>	Bright Brass	Bright Brass
Chrome	Chrome	White Paint	Bright Brass <sup>(5)</sup>	Satin Chrome	Satin Chrome
White Polyester <sup>(3)</sup>	White Polyester		Satin Chrome	Custom Color Polyester	Custom Color Paint
			Custom Color Polyester <sup>(3)</sup>		

### Notes:

1. Paint or any other coating applied over the factory finish will void all approvals and warranties.
2. Model FP escutcheons and Model CCP sprinklers utilize a galvanized steel cup with a finished trim ring or cover plate.
3. cULus Listed as corrosion resistant.
4. FM Approved as corrosion resistant.
5. For 200°F (93°C) maximum temperature rated sprinklers only.

## Installation

Model F1FR Series sprinklers must be installed in accordance with NFPA13 and the requirements of all applicable authorities having jurisdiction. Model F1FR Series sprinklers must be installed with the Reliable sprinkler installation wrench identified in this Bulletin. Any other wrench may damage the sprinkler. The Models W2 and W4 wrenches have two sets of jaws. Use the smallest set of jaws that fit on the wrench flats of the sprinkler. A leak tight sprinkler joint can be obtained with a torque of 8 to 18 lb-ft (11 to 24 N-m). Do not tighten sprinklers over the maximum recommended installation torque. Exceeding the maximum recommended installation torque may cause leakage or impairment of the sprinkler.

Glass bulb sprinklers have orange bulb protectors or protective caps to minimize bulb damage during shipping, handling and installation. Reliable sprinkler installation wrenches are designed to install sprinklers with bulb protectors in place. Remove the bulb protector at the time when the sprinkler system is placed in service for fire protection. Removal of the bulb protector before this time may leave the bulb vulnerable to damage. Remove bulb protectors by undoing the clasp by hand. Do not use tools to remove bulb protectors.

## Maintenance

Reliable Model F1FR series sprinklers should be inspected and the sprinkler system maintained in accordance with NFPA 25, as well as the requirements of any Authorities Having Jurisdiction.

Prior to installation, sprinklers should remain in the original cartons and packaging until used. This will minimize the potential for damage to sprinklers that could cause improper operation or non-operation.

Do not clean sprinklers with soap and water, ammonia liquid or any other cleaning fluids. Remove dust by gentle vacuuming without touching the sprinkler.

Replace any sprinkler which has been painted (other than factory applied). A stock of spare sprinklers should be maintained to allow quick replacement of damaged or operated sprinklers. Failure to properly maintain sprinklers may result in inadvertent operation or non-operation during a fire event.

## Guarantee

For the guarantee, terms, and conditions, visit [www.reliablesprinkler.com](http://www.reliablesprinkler.com).

## Ordering Information

**Specify the following when ordering:**

### Model

- F1FR56

### Deflector/Orientation

- Upright
- Intermediate Upright
- Pendent
- CCP Concealed Pendent
- Horizontal Sidewall
- Vertical Sidewall

### Temperature Rating

- See sprinkler technical specifications

### Sprinkler Finish

- See Table B

### Recessed Escutcheon<sup>(1)(2)</sup>

- F1
- F2
- FP

### Escutcheon Finish

- See Table B

### CCP Cover Plate Temperature Rating

- 135°F (57°C) [For use with 135°F (57°C) and 155°F (68°C) sprinklers.]
- 165°F (74°C) [For use with 175°F (79°C) and 200°F (93°C) sprinklers.]

### CCP Cover Plate Finish

- See Table B

### Sprinkler Wrench

- Model W2
- Model W4 (recessed, concealed)
- Model J (New frame with guard installed)
- Model JD (Legacy frame with guard installed)

### Notes:

1. 286°F (141°C) sprinklers are not listed to be used recessed or concealed.
2. For FM, recessed sprinklers must use the Model F2 escutcheon.

**PIPE**

# SCHEDULE 10 & 40



**Always ready to protect your most valuable assets.**

As the leading supplier of steel sprinkler pipe, we understand that there are no second chances in fire suppression. You need products of enduring quality and exceptional strength—plus reliable service. You need Bull Moose.

## Bull Moose Fire Sprinkler Pipe Product Information

Nominal Pipe Size (Inches)		1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"	6"	8"	NPS (In.)		1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"	
<b>SCHEDULE 10</b>	O.D. (in)	1.315	1.660	1.900	2.375	2.875	3.500	4.500	6.625	8.625	<b>SCHEDULE 40</b>	1.315	1.660	1.900	2.375	2.875	3.500	4.500		
	I.D. (in)	1.097	1.442	1.682	2.157	2.635	3.260	4.260	6.357	8.249		1.049	1.380	1.610	2.067	2.469	3.068	4.026		
	Empty Weight (lb/ft)	1.410	1.810	2.090	2.640	3.530	4.340	5.620	9.290	16.940		1.680	2.270	2.720	3.660	5.800	7.580	10.800		
	Water Filled Weight (lb/ft)	1.820	2.518	3.053	4.223	5.893	7.957	11.796	23.038	40.086		2.055	2.918	3.602	5.114	7.875	10.783	16.316		
	C.R.R.	15.27	9.91	7.76	6.27	4.92	3.54	2.50	1.158	1.805		1.00	1.00	1.00	1.00	1.00	1.00	1.00		
	Pieces per Lift	91	61	61	37	30	19	19	10	7		70	51	44	30	30	19	19		
	Lift Weight (lbs) 21' lengths	2,695	2,319	2,677	2,051	2,224	1,732	2,242	1,951	2,490		2,470	2,431	2,513	2,306	3,654	3,024	4,309		
	Lift Weight (lbs) 24' lengths	3,079	2,650	3,060	2,344	2,542	1,979	2,563	2,230	2,848		2,822	2,778	2,872	2,635	4,176	3,456	4,925		
	Lift Weight (lbs) 25' lengths	3,208	2,760	3,187	2,442	2,648	2,062	2,670				2,940	2,894	2,992	2,745	4,350	3,601	5,130		

### SCHEDULE 10 & 40 ADVANTAGES:

- UL listed (US & Canada) and FM approved
- ASTM A135 and A795 Type E, Grade A Certified
- Complies with NFPA-13, 13R and 14
- Industry-leading hydraulic characteristics
- CRR of 1.0 and greater
- All pipe NDT weld tested

### OTHER BENEFITS/SERVICES:

- We have the most stocking locations in the industry, for best delivery and availability
- Plain end or roll groove
- Eddy Guard II™ bacterial-resistant internal coating
- Custom length options
- Hot dipped galvanization
- Reddi-Pipe® red or black pipe eliminates field painting
- Compatible for use in wet, dry, preaction and deluge sprinkler systems
- The only maker with EPDs (to help earn LEED points).

**Exclusive maker of Reddi-Pipe®**  
RED OR BLACK PAINTED PIPE.



cULUS LISTED



**BULL MOOSE**  
TUBE

800.325.4467  
sales@BullMooseIndustries.com  
BullMooseTube.com

# **HANGER MATERIAL**



## Threaded Rods

### Low Carbon Steel Threaded Rod

The most economical and most common form of Threaded Rod. Typically used by the plumbing and contracting trades. Used in maintenance departments in various applications including hanging, mounting, bracing, supporting, and fastening applications.

- Low carbon steel according to ASTM A307, Grade A requirements
- Conforms to ASME B18.31.3
- Class 1A rolled threads
- Zinc Plated according to Fe/Zn 3AT Per ASTM F1941
- Hot Dip Galvanized according to ASTM A153 or F2329
- 60,000 psi Min. Tensile Strength



FASTENERS

		1 ft				2 ft				3 ft				6 ft				10 ft				12 ft								
		Plain		Zinc		Plain		Zinc		Plain		Zinc		Hot Dip Galvanized		Plain		Zinc		Plain		Zinc		Hot Dip Galvanized		Plain		Zinc		Hot Dip Galvanized
Diameter	Thread Size	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.
#6	32	-	-	-	-	47002	47052	-	-	47102	47152	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
#8	32	-	-	-	-	47003	47053	-	-	47103	47153	-	-	47136	47186	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
#10	24	-	-	-	-	47004	47054	-	-	47104	47154	-	-	47137	47187	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
#12	24	-	-	-	-	47006	47056	-	-	-	47156	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1/4"	20	0156376	0156317	0156377	0156318	47007	47057	-	-	47107	47157	-	-	47140	47190	-	-	47207	47257	-	-	-	-	-	-	-	-	-	-	
5/16"	18	0156378	0156319	0156379	0156320	47009	47059	-	-	47109	47159	-	-	47141	47191	-	-	47209	47259	-	-	-	-	-	-	-	-	-	-	
3/8"	16	0156380	0156321	0156381	0156322	47011	47061	47602	47111	47161	47618	47142	47192	47634	47211	47261	47650	-	-	-	-	-	-	-	-	-	-	-	-	
7/16"	14	0156382	0156323	0156383	0156324	47013	47063	0156404	47113	47163	-	47143	47193	-	47213	47263	-	-	-	-	-	-	-	-	-	-	-	-	-	
1/2"	13	0156384	0156325	0156385	0156326	47015	47065	47604	47115	47165	47620	47144	47194	47636	47215	47265	47652	-	-	-	-	-	-	-	-	-	-	-	-	
9/16"	12	0156386	0156327	0156387	0156328	47017	47067	-	47117	47167	-	47145	47195	-	47217	47267	-	-	-	-	-	-	-	-	-	-	-	-	-	
5/8"	11	0156388	0156329	0156389	0156330	47019	47069	47606	47119	47169	47622	47146	47196	47638	47219	47269	47654	-	-	-	-	-	-	-	-	-	-	-	-	
3/4"	10	0156390	0156331	0156391	0156332	47021	47071	47607	47121	47171	47623	47147	47197	47639	47221	47271	47655	-	-	-	-	-	-	-	-	-	-	-	-	
7/8"	9	0156392	0156333	0156393	0156334	47023	47073	0156408	47123	47173	47624	47148	47198	47640	47223	47273	47656	-	-	-	-	-	-	-	-	-	-	-	-	
1"	8	0156394	0156335	0156395	0156336	47025	47075	47609	47125	47175	47625	47149	47199	47641	47225	47275	47657	-	-	-	-	-	-	-	-	-	-	-	-	
1-1/8"	7	-	-	-	-	47027	47077	-	47127	47177	47626	47150	47200	47642	47227	47277	47658	-	-	-	-	-	-	-	-	-	-	-	-	
1-1/4"	7	-	-	-	-	47028	47078	47611	47128	47178	47627	47151	47201	47643	47228	47278	47659	-	-	-	-	-	-	-	-	-	-	-	-	
1-3/8"	6	-	-	-	-	47029	47079	-	47129	47179	-	47233	47237	47644	47229	47279	47660	-	-	-	-	-	-	-	-	-	-	-	-	
1-1/2"	6	-	-	-	-	47030	47080	-	47130	47180	47629	47234	47238	47645	47230	47280	47661	-	-	-	-	-	-	-	-	-	-	-	-	
1-3/4"	5	-	-	-	-	47031	47081	-	47131	47181	47630	47235	47239	47646	47231	47281	47662	-	-	-	-	-	-	-	-	-	-	-	-	
2"	4.5	-	-	-	-	47032	47082	-	47132	47182	-	47236	47240	47647	47232	47282	47663	-	-	-	-	-	-	-	-	-	-	-	-	

		3 ft		6 ft		12 ft	
		Plain	Zinc	Plain	Zinc	Plain	Zinc
Diameter	Thread Size	Part No.	Part No.	Part No.	Part No.	Part No.	Part No.
#10	32	47005	47055	47105	47155	-	-
1/4"	28	47008	47058	47108	47158	47208	47258
5/16"	24	47010	47060	47110	47160	47210	47260
3/8"	24	47012	47062	47112	47162	47212	47262
7/16"	20	47014	47064	47114	47164	47214	47264
1/2"	20	47016	47066	47116	47166	47216	47266
9/16"	18	47018	47068	47118	47168	-	47268
5/8"	18	47020	47070	47120	47170	47220	47270
3/4"	16	47022	47072	47122	47172	47222	47272
7/8"	14	47024	47074	47124	47174	47224	47274
1"	14	47026	47076	47126	47176	47226	47276
1-1/8"	12	47033	47083	47133	47183	47094	-
1-1/4"	12	47034	47084	47134	47184	47095	47098
1-1/2"	12	47035	47085	47135	47185	47096	-

### Left Hand Low Carbon Steel Threaded Rod



The most economical and most common form of Threaded Rod. Typically used by the plumbing and contracting trades. Used in maintenance departments in various applications; left hand threading. Plain Finish, or bare metal finish which may contain a light coating of oil.

- 6 foot lengths

Thread - Left Hand - Coarse		
Diameter	Thread Size	Plain Part No.
1/4"	20	47302
5/16"	18	47303
3/8"	16	47304
1/2"	13	47306
5/8"	11	47308
3/4"	10	47309
7/8"	9	47310
1"	8	47311
1-1/8"	7	47312
1-1/4"	7	47313
1-1/2"	6	47315
2"	4.5	47318

### Metric Threaded Rod

- Made from heat treated Class 8.8 steel.



		Class 4.6		Class 8.8	
		Plain	Zinc	Plain	Zinc
Diameter	Thread Size	Part No.	Part No.	Part No.	Part No.
M2	0.4	-	0162065	-	-
M3	0.5	-	0162068	-	-
M4	0.7	47556	0162070	-	-
M5	0.8	47570	0162071	-	-
M6	1.0	47571	0162072	47870	-
M8	1.25	47572	0162073	47872	-
M10	1.5	47573	0162075	47873	-
M12	1.75	47574	0162078	47874	-
M14	2.0	47575	0162081	47875	-
M16	2.0	47576	0162083	47876	-
M18	2.5	47577	0162085	47877	-
M20	2.5	47578	0162086	47878	-
M22	2.5	47579	-	47879	-
M24	3.0	47580	0162088	47880	-

		Class 4.6		Class 8.8	
		Plain	Zinc	Plain	Zinc
Diameter	Thread Size	Part No.	Part No.	Part No.	Part No.
M27	3.0	47581	0162089	47881	-
M30	3.5	47582	0162090	47882	-
M33	3.5	47733	-	47883	-
M36	4.0	47583	-	47884	-
M39	4.0	47734	-	47885	-
M42	4.5	47735	-	47886	-
M48	5.0	47737	-	-	-

		Class 4.6	
		Plain	Zinc
Diameter	Thread Size	Part No.	Part No.
M8	1.0	0162074	-
M10	1.0	0162077	-
M10	1.25	0162076	-
M12	1.25	0162080	-
M12	1.5	0162079	-
M14	1.5	0162082	-
M16	1.5	0162084	-

HOW DO YOU PREFER TO BUY?

Local Store | Personal Service | Inventory Solutions | [fastenal.com](http://fastenal.com)

## Fig. 69 (Formerly Afcon Fig. 300) Adjustable Swivel Ring, Tapped Per NFPA Standards

**Size Range:** 1/2" through 8"

**Material:** Carbon steel

**Finish:** Strap is Pre-Galvanized Zinc Material. Nut is Zinc Plated.

**Service:** Recommended for suspension of non-insulated **stationary** pipe line.

**Maximum Temperature:** 450° F

**Approvals:** Complies with Federal Specification A-A-1192A (Type 10), WW-H-171-E (Type 10), and ANSI/MSS SP-58 (Type 10). UL Listed and FM Approved (Sizes 3/4" - 8").

**Features:**



- 1/2" - 2" sizes designed for use with steel and CPVC piping and manufactured with FBC System Compatible oil.
- Threads are countersunk so that they cannot become burred or damaged.
- Knurled swivel nut provides vertical adjustment after piping is in place.
- Captured swivel nut in the 1/2" through 6" sizes. The capture is permanent in the bottom portion of the band, allowing the hanger to be opened during installation if desired, but not allowing the nut to fall completely out.

**Ordering:** Specify size, figure number and name.


**Non-captured nut also available upon request.**




1/2" through 2" Size  
Rounded Edge Design



1/2" through 1" pipe



1 1/4" through 2" pipe



2 1/2" through 8" pipe



2 1/2" through 8" Size

**FIG. 69: DIMENSIONS (IN) • LOADS (LBS) • WEIGHT (LBS)**

Pipe Size	Max Load	Weight	Rod Size A	B	C	F	G Width
1/2	300	0.10	3/8	2 7/8	2	1 9/16	5/8
3/4		0.10		2 3/4	1 7/8	1 5/16	
1		0.10		2 9/16	1 11/16	1	
1 1/4		0.10		2 5/8	1 3/4	7/8	
1 1/2		0.10		2 3/4	1 7/8	1 1/8	
2	525	0.11	1/2	3 1/4	2 3/8	1 1/8	3/4
2 1/2		0.20		4	2 3/4	1 5/16	
3		0.20		3 13/16	2 15/16	1 3/16	
4	650	0.30	1/2	4 11/16	3 13/16	1 9/16	3/4
5		0.54		5 5/16	4 3/8		
6	1,000	0.65	1/2	6 11/16	5 9/16	2 1/4	3/4
8		1.00		8 9/16	7 9/16	3 1/4	

**PROJECT INFORMATION**



**APPROVAL STAMP**

<b>Project:</b>	<input type="checkbox"/> Approved
<b>Address:</b>	<input type="checkbox"/> Approved as noted
<b>Contractor:</b>	<input type="checkbox"/> Not approved
<b>Engineer:</b>	<b>Remarks:</b>
<b>Submittal Date:</b>	
<b>Notes 1:</b>	
<b>Notes 2:</b>	

# 300 Universal Beam Clamp



- Conforms with Federal Specification WW-H-171 (Type 23), Manufacturers Standardization Society ANSI®/MSS-SP-58 (Type 19 and 23)



Material: Steel

Part Number	Rod Size RS	Flange Thickness FT	A	Torque TQ	Static Load 1 F1	Static Load 2 F2	Certifications	Standard Packaging Quantity
Finish: Plain								
3000037PL	3/8"	13/16" Max	1 1/8"	5 ft lb	500 lb	250 lb	cULus, FM	100 pc
3000050PL	1/2"	13/16" Max	1 1/8"	8 ft lb	950 lb	760 lb	cULus, FM	50 pc
3000062PL	5/8"	13/16" Max	1 1/8"	5 ft lb	950 lb	760 lb	cULus	50 pc
3000075PL	3/4"	13/16" Max	1 1/8"	5 ft lb	950 lb	760 lb	cULus	50 pc
3000087PL	7/8"	13/16" Max	1 1/8"	5 ft lb	950 lb	760 lb	cULus	50 pc
Finish: Electrogalvanized								
3000037EG	3/8"	13/16" Max	1 1/8"	5 ft lb	500 lb	250 lb	cULus, FM	100 pc
3000050EG	1/2"	13/16" Max	1 1/8"	8 ft lb	950 lb	760 lb	cULus, FM	50 pc
3000062EG	5/8"	13/16" Max	1 1/8"	5 ft lb	950 lb	760 lb	cULus	50 pc
3000075EG	3/4"	13/16" Max	1 1/8"	5 ft lb	950 lb	760 lb	cULus	50 pc
3000087EG	7/8"	13/16" Max	1 1/8"	5 ft lb	950 lb	760 lb	cULus	50 pc

Setscrew must be tightened and torqued onto the sloped side of the I-beam.

Recognizing that torque wrenches are generally not used or available on many job sites, the setscrew should be tightened so it contacts the I-beam and then an additional 1/4 to 1/2 turn added.

ANSI is a registered trademark of American National Standards Institute. FM is a registered certification mark of FM Approvals LLC, LTD. UL, UR, cUL, cUR, cULus and cURus are registered certification marks of UL LLC.

#### WARNING

Pentair products shall be installed and used only as indicated in Pentair's product instruction sheets and training materials. Instruction sheets are available at [erico.pentair.com](http://erico.pentair.com) and from your Pentair customer service representative. Improper installation, misuse, misapplication or other failure to completely follow Pentair's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.

© 2017 Pentair All rights reserved

Pentair, CADDY, CADWELD, CRITEC, ERICO, ERIFLEX, ERITECH and LENTON are owned by Pentair or its global affiliates.

All other trademarks are the property of their respective owners. Pentair reserves the right to change specifications without prior notice.



# **FITTINGS**



# C.I. THREADED FITTINGS




LISTED

LISTED

APPROVED



For fire protection services request submittal GRS 1.3

CAST IRON THREADED FITTINGS ARE UL, ULC LISTED AND FACTORY MUTUAL APPROVED FOR 300 PSI SERVICE. GRAY IRON PER ASTM A126 CLASS B. DIMENSIONS CONFORM TO ANSI B16.4 CLASS 125 EXCEPT PLUGS CONFORM TO ASME B16.14. THREADS ARE NPT PER ANSI/ASME B1.20.1.




CAST IRON 90 DEGREE ELBOW					
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSIONS		WEIGHT EACH PIECE
			A	B	
1	CB90033	300	1.50	1.50	0.95
1 1/4	CB90044	300	1.75	1.75	1.34
1 1/2	CB90055	300	1.94	1.94	1.80
2	CB90066	300	2.25	2.25	2.90
2 1/2	CB90077	300	2.70	2.70	4.75

CAST IRON STRAIGHT TEE					
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSIONS		WEIGHT EACH PIECE
			A	B	
1	CT333	300	1.50	1.50	1.21
1 1/4	CT444	300	1.75	1.75	1.87
1 1/2	CT555	300	1.94	1.94	2.51
2	CT666	300	2.25	2.25	3.96
2 1/2	CT777	300	2.70	2.70	6.45



CAST IRON RED. COUPLING				
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSION	WEIGHT EACH PIECE
			A	
1X1/2	CRC031	300	1.70	0.62
1X3/4	CRC032	300	1.70	0.80

CAST IRON 45 DEGREE ELBOW					
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSIONS		WEIGHT EACH PIECE
			A	B	
1	CB45033	300	1.12	1.12	0.84
1 1/4	CB45044	300	1.29	1.29	1.40
1 1/2	CB45055	300	1.43	1.43	1.80
2	CB45066	300	1.68	1.68	2.79



CAST IRON RED. 90 DEG. ELBOW					
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSIONS		WEIGHT EACH PIECE
			A	B	
1X1/2	CB90031	300	1.26	1.36	0.64
1X3/4	CB90032	300	1.37	1.45	0.87
1 1/4X1/2	CB90041	300	1.34	1.53	0.96
1 1/4X3/4	CB90042	300	1.45	1.62	1.13
1 1/4X1	CB90043	300	1.58	1.67	1.16
1 1/2x1 1/2	CB90051	300	1.41	1.66	1.17
1 1/2x3/4	CB90052	300	1.52	1.75	1.28
1 1/2X1	CB90053	300	1.65	1.80	1.51
1 1/2X1 1/4	CB90054	300	1.82	1.88	1.62
2X1/2	CB90061	300	1.49	1.88	2.00
2X3/4	CB90062	300	1.60	1.97	2.05
2X1	CB90063	300	1.73	2.02	2.10
2X1 1/4	CB90064	300	1.90	2.10	2.30
2X1 1/2	CB90065	300	2.02	2.16	2.60



CAST IRON PLUGS				
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSION	WEIGHT EACH PIECE
			A	
1/2	CPL001	300	0.94	0.10
3/4	CPL002	300	1.07	0.17
1	CPL003	300	1.25	0.28
1 1/4	CPL004	300	1.36	0.44
1 1/2	CPL005	300	1.45	0.62
2	CPL006	300	1.56	0.91



# C.I. THREADED FITTINGS



LISTED




LISTED




APPROVED

For fire protection services request submittal GRS 1.3



CAST IRON CROSS					
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSIONS		WEIGHT EACH PIECE
			A	B	
1	CX033	300	1.50	1.50	1.54
1 1/4	CX044	300	1.75	1.75	2.40
1 1/2	CX055	300	1.94	1.94	3.10
2	CX066	300	2.25	2.25	4.00
1 1/4X1	CX043	300	1.58	1.67	2.05
1 1/2X1	CX053	300	1.65	1.80	2.40
2X1	CX063	300	1.73	2.02	2.75



CAST IRON REDUCING TEE						
NOMINAL SIZE (INCH)	ITEM CODE #	MAX. WORKING P.S.I.	DIMENSIONS			WEIGHT EACH PIECE
			A	B	C	
1X1X1/2	CT331	300	1.26	1.26	1.36	0.95
1X1X3/4	CT332	300	1.37	1.37	1.45	1.10
1X1/2X1	CT313	300	1.50	1.36	1.50	1.08
1X3/4X1	CT323	300	1.50	1.45	1.50	1.18
1X1X1 1/4	CT334	300	1.67	1.67	1.58	1.52
1X1X1 1/2	CT335	300	1.80	1.80	1.65	1.73
1 1/4X1X1/2	CT431	300	1.34	1.26	1.53	1.17
1 1/4X1X3/4	CT432	300	1.45	1.37	1.62	1.38
1 1/4X1X1	CT433	300	1.58	1.50	1.57	1.47
1 1/4X1X1 1/4	CT434	300	1.75	1.67	1.75	1.80
1 1/4X1X1 1/2	CT435	300	1.88	1.80	1.82	2.05
1 1/4X1 1/4X1/2	CT441	300	1.34	1.34	1.53	1.37
1 1/4X1 1/4X3/4	CT442	300	1.45	1.45	1.62	1.54
1 1/4X1 1/4X1	CT443	300	1.58	1.58	1.67	1.65
1 1/4X1 1/4X1 1/2	CT445	300	1.88	1.88	1.82	2.21
1 1/4X1 1/4X2	CT446	300	2.10	2.10	1.90	2.55
1 1/2X1X1/2	CT531	300	1.41	1.34	1.66	1.41
1 1/2X1X3/4	CT532	300	1.52	1.37	1.75	1.65
1 1/2X1X1	CT533	300	1.65	1.50	1.80	1.65
1 1/2X1X1 1/4	CT534	300	1.82	1.67	1.88	2.00
1 1/2X1X1 1/2	CT535	300	1.94	1.80	1.94	2.30
1 1/2X1 1/4X1/2	CT541	300	1.41	1.34	1.66	1.58
1 1/2X1 1/4X3/4	CT542	300	1.52	1.45	1.75	1.72
1 1/2X1 1/4X1	CT543	300	1.65	1.58	1.80	1.85
1 1/2x1 1/4x1 1/4	CT544	300	1.82	1.75	1.88	2.22
1 1/2x1 1/4x1 1/2	CT545	300	1.94	1.88	1.94	2.45
1 1/2X1 1/4X2	CT546	300	2.16	2.10	2.02	2.80
1 1/2X1 1/2X1/2	CT551	300	1.41	1.41	1.66	1.76
1 1/2X1 1/2X3/4	CT552	300	1.52	1.52	1.75	1.87
1 1/2X1 1/2X1	CT553	300	1.65	1.65	1.80	1.94
1 1/2X1 1/2X1 1/4	CT554	300	1.82	1.82	1.88	2.29
1 1/2X1 1/2X2	CT556	300	2.16	2.16	2.02	3.28
2X1X2	CT636	300	2.25	2.02	2.25	3.40
2X1 1/4X2	CT646	300	2.25	2.10	2.25	2.80
2X1 1/2X1/2	CT651	300	1.49	1.41	1.88	2.09
2X1 1/2X3/4	CT652	300	1.60	1.52	1.97	2.40
2X1 1/2X1	CT653	300	1.73	1.65	2.02	2.54
2X1 1/2X1 1/4	CT654	300	1.90	1.82	2.10	2.85
2X1 1/2X1 1/2	CT655	300	1.49	1.41	1.88	2.24
2X1 1/2X2	CT656	300	2.25	2.16	2.25	3.75
2X2X1/2	CT661	300	1.49	1.49	1.88	2.60
2X2X3/4	CT662	300	1.60	1.60	1.97	2.71
2X2X1	CT663	300	1.73	1.73	2.02	2.97
2X2X1 1/4	CT664	300	1.90	1.90	2.10	3.32
2X2X1 1/2	CT665	300	2.02	2.02	2.16	3.72
2x2x2 1/2	CT667	300	2.60	2.60	2.39	5.10

## Grinnell Grooved Fire Protection Products Grooved Fittings

### General Description



See Fire Protection  
Submittal Sheet for  
Pressure Rating and  
Listing/Approval  
Information

The grooved fittings provide an economical and efficient method of changing direction, adding an outlet, reducing, or capping grooved piping systems. Grooved fittings are available in durable ductile iron or fabricated steel as indicated.

**Note:** Figure 510S and 519S fittings are special short radius fittings with smaller center to end dimensions than standard grooved fittings. Depending on the size and coupling used, there may be interferences at the bolt pads that require repositioning of the coupling orientation. The use of flange adapters is not recommended with Figures 510S and 519S fittings. Contact Tyco Fire Products for details.

#### WARNING

*The Fittings described herein must be installed and maintained in compliance with this document, as well as with the applicable standards of the National Fire Protection Association, in addition to the standards of any other authorities having jurisdiction. Failure to do so may impair the performance of this device.*

*The owner is responsible for maintaining their fire protection system and devices in proper operating condition. The installing contractor or sprinkler manufacturer should be contacted with any questions.*

### Technical Data

#### Approvals:

UL, FM, ULC, VdS, and LPCB;

**Note:** See Fire Protection Submittal Sheet for exact Listing / Approval information.

#### Material:

Cast: Figures: 201, 210, 219, 250, 260, 501, 510, 519, 510DE, 501S, 510S and 519S -  
Ductile iron conforming to ASTM A-536,  
Grade 65-45-12

Fabricated Steel: Figures 391, 392, 393, 312, 313, 321, 327, 341 and 350 - Carbon Steel,  
(Sizes 1 1/4" - 6" are Schedule 40);  
(Sizes 8" - 12" are Schedule 30),  
conforming to ASTM A-53 Grade B

#### Protective Coatings:

- Non-lead orange paint
- Fire brigade red (optional) non-lead paint
- Hot dipped galvanized conforming to ASTM A-153

### Ordering Procedure

When placing an order, indicate the full product name. Please specify the quantity, figure number, wall thickness, and size.

Grinnell Grooved Piping Products, valves, accessories and other products are available throughout the U.S., Canada, and internationally, through a network of distribution centers. You may write directly or call 215-362-0700 for the distributor nearest you.

### Care and Maintenance

The owner is responsible for the inspection, testing, and maintenance of their fire protection system and devices in accordance with the applicable standards of the National Fire Protection Association (e.g., NFPA 25), in addition to the standards of any authority having jurisdiction. The installing contractor or product manufacturer should be contacted relative to any questions. Any impairment must be immediately corrected. It is recommended that automatic sprinkler systems be inspected, tested, and maintained by a qualified Inspection Service.

### Limited Warranty

Products manufactured by Tyco Fire Products are warranted solely to the original Buyer for ten (10) years against defects in material and workmanship when paid for and properly installed and maintained under normal use and service. This warranty will expire ten (10) years from date of shipment by Tyco Fire Products. No warranty is given for products or components manufactured by companies not affiliated by ownership with Tyco Fire Products or for products and components which have been subject to misuse, improper installation, corrosion, or which have not been installed, maintained, modified or repaired in accordance with applicable Standards of the National Fire Protection Association (NFPA), and/or the standards of any other Authorities Having Jurisdiction. Materials found by Tyco Fire Products to be defective shall be either repaired or replaced, at Tyco Fire Products' sole option. Tyco Fire Products neither assumes, nor authorizes any person to assume for it, any other obligation in connection with the sale of products or parts of products. Tyco Fire Products shall not be responsible for sprinkler system design errors or inaccurate or incomplete information supplied by Buyer or Buyer's representatives.

IN NO EVENT SHALL TYCO FIRE PRODUCTS BE LIABLE, IN CONTRACT, TORT, STRICT LIABILITY OR UNDER ANY OTHER LEGAL THEORY, FOR INCIDENTAL, INDIRECT, SPECIAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LABOR CHARGES, REGARDLESS OF WHETHER TYCO FIRE PRODUCTS WAS INFORMED ABOUT THE POSSIBILITY OF SUCH DAMAGES, AND IN NO EVENT SHALL TYCO FIRE PRODUCTS' LIABILITY EXCEED AN AMOUNT EQUAL TO THE SALES PRICE.

**THE FOREGOING WARRANTY IS MADE IN LIEU OF ANY AND ALL OTHER WARRANTIES EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.**

# Figures 201, 210, 219, and 260




Figure 201




Figure 210




Figure 219




Figure 260

Nominal Size	Figure 201 45° Elbow		Figure 210 90° Elbow		Figure 219 Tee		Figure 260‡ End Cap	
	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.	E to E Inches mm	Appx. Wt. Lbs. Kg.
1 1/4"	1.75 44.5	0.9 0.4	2.75 69.9	1.0 0.5	2.75 69.9	1.4 0.6	0.88 22.4	0.4 0.2
1 1/2"	1.75 44.5	1.1 0.5	2.75 69.9	1.2 0.5	2.75 69.9	1.8 0.8	0.88 22.4	0.6 0.3
2"	2.00 50.8	1.8 0.8	3.25 82.6	2.0 0.9	3.25 82.6	2.7 1.2	0.88 22.4	0.9 0.4
2 1/2"	2.25 57.2	2.2 1.0	3.75 95.3	3.0 1.4	3.75 95.3	5.8 2.6	0.88 22.4	0.9 0.4
76.1mm	2.25 57.2	2.2 1.0	3.75 95.3	3.0 1.4	3.75 95.3	5.8 2.6	0.94 23.9	1.1 0.5
3"	2.50 63.5	3.5 1.6	4.25 108.0	4.5 2.0	4.25 108.0	7.0 3.2	0.88 22.4	1.1 0.5
108.0mm	2.88 73.0	5.5 2.5	4.75 120.7	8.5 3.9	4.75 120.7	11.5 5.2	-	-
4"	3.00 76.2	5.2 2.4	5.00 127.0	8.5 3.9	5.00 127.0	11.8 5.4	1.00 25.4	2.6 1.2
133.0mm	3.25 82.6	7.7 3.5	5.25 133.4	11.3 5.1	5.25 133.4	10.6 4.8	-	-
139.7mm	3.25 82.6	7.7 3.5	5.50 139.7	11.3 5.1	5.50 139.7	15.3 6.9	0.92 23.4	4.7 2.1
5"	3.25 82.6	8.5 3.9	5.50 139.7	13.5 6.1	5.50 139.7	17.0 7.7	1.00 25.4	5.0 2.3
159.0mm	3.50 88.9	12.0 5.4	6.00 152.4	14.6 6.6	6.00 152.4	13.9 6.3	-	-
165.1mm	3.50 88.9	12.0 5.4	6.50 165.1	18.5 8.4	6.50 165.1	26.0 11.8	1.00 25.4	7.5 3.4
6"	3.50 88.9	12.0 5.4	6.50 165.1	18.5 8.4	6.50 165.1	26.0 11.8	1.00 25.4	7.5 3.4
216.3mm	4.25 108.0	23.0 10.4	7.75 196.9	36.5 16.6	7.75 196.9	45.0 20.4	-	-
8"	4.25 108.0	23.0 10.4	7.75 196.9	36.5 16.6	7.75 196.9	45.0 20.4	1.19 30.2	12.8 5.8
10"	4.75 120.7	31.0 14.1	9.00 228.6	60.0 27.2	9.00 228.6	72.1 32.7	1.25 31.8	20.0 9.1
12"	5.25 133.4	40.0 18.1	10.00 254.0	67.0 30.4	10.00 254.0	92.5 42.0	1.25 31.8	36.0 16.3

‡ - Available with tapped plugs, contact Tyco Fire & Building Products.

Friction Resistance* (Expressed as Equivalent Straight Pipe)				
Size Inches mm	Elbow		Tee	
	90° Feet Meters	45° Feet Meters	Branch Feet Meters	Run Feet Meters
1 1/4 42.4	1.9 0.6	1.0 0.3	4.8 1.5	1.9 0.6
1 1/2 48.3	2.3 0.7	1.2 0.4	5.8 1.8	2.3 0.7
2 60.3	3.2 1.0	1.6 0.5	8.0 2.5	3.2 1.0
2 1/2 73.0	3.9 1.2	2.0 0.6	9.8 3.0	3.9 1.2
76.1mm	4.1 1.2	2.1 0.6	10.3 3.1	4.1 1.2
3 88.9	4.9 1.5	2.4 0.7	12.2 3.7	4.9 1.5
108.0mm	6.5 2.0	3.3 1.0	16.3 5.0	6.5 2.0
4 114.3	6.5 2.0	3.3 1.0	16.3 5.0	6.5 2.0
133.0mm	8.0 2.4	4.0 1.2	20.0 6.1	8.0 2.4
139.7mm	8.0 2.4	4.1 1.3	20.0 6.1	8.0 2.4
5 141.3	8.2 2.5	4.1 1.3	20.5 6.3	8.2 2.5
159.0mm	9.5 2.9	4.8 1.4	23.8 7.2	9.5 2.9
165.1mm	9.5 2.9	4.8 1.4	23.8 7.2	9.5 2.9
6 168.3	9.9 3.0	5.0 1.5	24.8 7.6	9.9 3.0
216.3mm	13.1 4.0	6.6 2.0	32.8 10.0	13.1 4.0
8 219.1	13.1 4.0	6.6 2.0	32.8 10.0	13.1 4.0
10 273.0	16.5 5.0	8.3 2.5	41.3 12.6	16.5 5.0
12 323.4	19.9 6.1	9.9 3.0	49.7 15.1	19.9 6.1

For reducing tees and branches, use the value that is corresponding to the branch size. Example: for 8" x 8" x 2" tee, the branch value 2" is 8.0 feet.

\* Friction resistance for all elbows and tees except Figures 510S and 519S.



# Figures 501, 510, 519 and 510DE




Figure 501




Figure 510




Figure 519




Figure 510DE

Nominal Size	Figure 501 45° Elbow		Figure 510 90° Elbow		Figure 519 Tee		Figure 510DE 90° Drain Elbow			
	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	A Inches mm	B Inches mm	Appx. Wt. Lbs. Kg.
1 1/4"	1.75 44.5	0.9 0.4	2.75 69.9	1.0 0.5	2.75 69.9	1.4 0.6	-	-	-	-
1 1/2"	1.75 44.5	1.1 0.5	2.75 69.9	1.2 0.5	2.75 69.9	1.8 0.8	-	-	-	-
2"	2.00 50.8	1.8 0.8	3.25 82.6	2.0 0.9	3.25 82.6	2.7 1.2	-	-	-	-
2 1/2"	2.25 57.2	2.2 1.0	3.75 95.3	3.0 1.4	3.75 95.3	5.8 2.6	3.75 95.3	2.00 50.8	2.75 69.9	2.7 1.2
3"	2.50 63.5	3.5 1.6	4.25 108.0	4.5 2.0	4.25 108.0	7.0 3.2	4.25 108.0	2.34 59.4	2.75 69.9	3.7 1.7
4"	3.00 76.2	5.2 2.4	5.00 127.0	8.5 3.9	5.00 127.0	11.8 5.4	5.00 127.0	2.85 72.4	2.75 69.9	7.0 3.2
5"	3.25 82.6	8.5 3.9	5.50 139.7	13.5 6.1	5.50 139.7	17.0 7.7	5.50 139.7	3.38 85.9	2.75 69.9	13.0 5.9
6"	3.50 88.9	12.0 5.4	6.50 165.1	18.5 8.4	6.50 165.1	26.0 11.8	6.50 165.1	3.92 99.6	2.75 69.9	13.4 6.1
8"	4.25 108.0	23.0 10.4	7.75 196.9	36.5 16.6	7.75 196.9	45.0 20.4	7.75 196.9	4.95 125.7	2.75 69.9	26.3 11.9

# Figures 501S, 510S and 519S




Figure 501S




Figure 510S\*




Figure 519S\*

Friction Resistance 501S, 510S & 519S (Expressed as Equivalent Straight Pipe)				
Size Inches mm	Elbow		Tee	
	90° Feet Meters	45° Feet Meters	Branch Feet Meters	Run Feet Meters
2 60.3	3.2 1.0	1.6 0.5	8.0 2.5	3.2 1.0
2 1/2 73.0	3.9 1.2	2.0 0.6	9.8 3.0	3.9 1.2
76.1mm	4.1 1.2	2.1 0.6	10.3 3.1	4.1 1.2
3 88.9	4.9 1.5	2.4 0.7	12.2 3.7	4.9 1.5
4 114.3	6.5 2.0	3.3 1.0	16.3 5.0	6.5 2.0
139.7mm	8.0 2.4	4.1 1.3	20.0 6.1	8.0 2.4
5 141.3	8.2 2.5	4.1 1.3	20.5 6.3	8.2 2.5
165.1mm	9.5 2.9	4.8 1.4	23.8 7.2	9.5 2.9
6 168.3	9.9 3.0	5.0 1.5	24.8 7.6	9.9 3.0
8 219.1	13.1 4.0	6.6 2.0	32.8 10.0	13.1 4.0

Nominal Size	Figure 501S 45° Elbow		Figure 510S 90° Elbow		Figure 519S Tee	
	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.
2"	2.00 50.8	1.8 0.8	2.75 69.9	1.5 0.7	2.75 69.9	2.1 1.0
2 1/2"	2.25 57.2	2.2 1.0	3.00 76.2	2.2 1.0	3.00 76.2	3.0 1.4
76.1mm	2.25 57.2	2.2 1.0	3.00 76.2	2.3 1.0	3.00 76.2	3.1 1.4
3"	2.50 63.5	3.5 1.6	3.38 85.9	3.0 1.3	3.38 85.9	4.1 1.9
4"	3.00 76.2	5.2 2.4	4.00 101.6	5.6 2.6	4.00 101.6	7.7 3.5
139.7mm	3.25 82.6	7.7 3.5	4.88 124.0	8.6 3.9	4.88 124.0	12.0 5.4
5"	3.25 82.6	8.5 3.9	4.88 124.0	8.8 3.9	4.88 124.0	12.0 5.4
165.1mm	3.50 88.9	12.0 5.4	5.50 139.7	11.00 5.0	5.50 139.7	15.0 6.8
6"	3.50 88.9	12.0 5.4	5.50 139.7	11.2 5.1	5.50 139.7	15.2 6.9
8"	4.25 108.0	23.0 10.4	6.88 174.8	23.4 10.6	6.88 174.8	31.2 14.2

\*Note: Figure 510S and 519S fittings are special short radius fittings with smaller center to end dimensions than standard grooved fittings. Depending on the size and coupling used, there may be interferences at the bolt pads which requires repositioning of the coupling orientation. The use of flange adapters is not recommended with Figures 510S and 519S fittings. Contact Tyco Fire Products for details.

# Figures 250 and 350




Figure 250  
Cast




Figure 350  
Fabricated  
Sizes 3" to 6"





Figure 350  
Fabricated  
Sizes 8" to 12"

Figures 250 and 350 Concentric Reducer - Groove x Groove								
Nominal Size Inches	E to E Inches	Appx. Wt. Lbs.	Nominal Size Inches	E to E Inches	Appx. Wt. Lbs.	Nominal Size Inches	E to E Inches	Appx. Wt. Lbs.
	mm	Kg.		mm	Kg.		mm	Kg.
*2 x 1¼	2.50 63.5	1.0 0.5	*139.7mm x 3	3.50 88.9	4.2 1.9	*6 x 5	4.00 101.6	5.8 2.6
*2 x 1½	2.50 63.5	1.3 0.6	*139.7mm x 4	3.50 88.9	4.4 2.0	8 x 2	5.00 127.0	12.2 5.5
*2½ x 2	2.50 63.5	1.2 0.5	5 x 1½	3.50 88.9	4.6 2.1	8 x 2½	5.00 127.0	12.1 5.5
*76.1mm x 1½	2.50 63.5	1.5 0.7	5 x 2	3.50 88.9	4.6 2.1	8 x 3	5.00 127.0	12.0 5.5
*76.1mm x 2	2.50 63.5	1.6 0.8	5 x 2½	3.50 88.9	4.5 2.0	8 x 4	5.00 127.0	11.9 5.4
3 x 1¼	2.50 63.5	1.3 0.6	5 x 3	3.50 88.9	4.4 2.0	8 x 5	5.00 127.0	11.3 5.1
3 x 1½	2.50 63.5	1.3 0.6	*5 x 4	3.50 88.9	4.5 2.0	8 x 6	5.00 127.0	10.8 4.9
*3 x 2	2.50 63.5	1.3 0.6	*165.1mm x 3	4.00 101.6	5.5 2.5	10 x 4	6.00 152.4	21.9 10.0
*3 x 2½	3.00 76.2	1.5 0.7	*165.1mm x 4	4.00 101.6	6.0 2.7	10 x 5	6.00 152.4	21.6 9.8
*3 x 76.1mm	3.00 76.2	2.0 0.9	*165.1mm x 139.7mm	4.00 101.6	5.6 2.5	10 x 6	6.00 152.4	21.1 9.6
4 x 1¼	3.00 76.2	2.2 1.0	*6 x 2	4.00 101.6	6.0 2.7	10 x 8	6.00 152.4	19.5 8.9
4 x 1½	3.00 76.2	2.3 1.0	6 x 2½	4.00 101.6	6.0 2.7	12 x 4	7.00 177.8	28.0 12.7
*4 x 2	3.00 76.2	2.3 1.0	*6 x 76.1mm	4.00 101.6	6.0 2.7	12 x 6	7.00 177.8	30.0 13.6
*4 x 2½	3.00 76.2	2.3 1.0	6 x 3	4.00 101.6	6.0 2.7	12 x 8	7.00 177.8	28.0 12.7
*4 x 76.1mm	3.00 76.2	3.2 1.5	*6 x 4	4.00 101.6	5.9 2.7	12 x 10	7.00 177.8	33.0 15.0
4 x 3	3.00 76.2	2.6 1.2	*6 x 139.7mm	4.00 101.6	6.3 2.9			

Note: Sizes marked with an asterisk (\*) are only available in Figure 250 Cast.  
 Sizes without an asterisk are only available in Figure 350 Fabricated.

## ADA CAP® Patented



Pipe Size Inches	Outlet NPT* Inches	Nominal Dimensions				Net Wt. Lbs. Kg.
		O.D. A Inches mm	Takeout B Inches mm	Center to End C Inches mm		
1½	½	1.900 48.3	1.25 31.8	1.75 44.5	1.89 48.0	0.77 0.3
	¾		1.25 31.8	1.75 44.5	1.89 48.0	0.77 0.3
	1		1.37 34.8	2.00 50.8	2.02 51.3	0.88 0.4
2	½	2.375 60.3	1.25 31.8	1.75 44.5	1.89 48.0	0.92 0.4
	¾		1.25 31.8	1.75 44.5	1.89 48.0	0.92 0.4
	1		1.37 34.8	2.00 50.8	2.02 51.3	1.06 0.5
2½	½	2.875 73.0	1.47 37.3	1.97 50.0	1.89 48.0	1.28 0.6
	¾		1.47 37.3	1.97 50.0	1.89 48.0	1.28 0.6
	1		1.37 34.8	2.00 50.8	2.02 51.3	1.50 0.7

\* ISO-7 threaded outlets are available upon request.

# Figures 391, 392, 393, 312 and 313




Figure 391




Figure 392




Figure 393




Figure 312




Figure 313

Nominal Size	Figures 391, 392 and 393 Adapter Nipples		Figure 312 22 1/2° Elbow		Figure 313 11 1/4° Elbow	
	E to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.	C to E Inches mm	Appx. Wt. Lbs. Kg.
1 1/4"	4.00 101.6	0.8 0.4	1.75 44.5	0.4 0.2	1.38 35.1	0.4 0.2
1 1/2"	4.00 101.6	0.9 0.4	1.75 44.5	0.5 0.2	1.38 35.1	0.5 0.2
2"	4.00 101.6	1.2 0.5	1.88 47.8	0.6 0.3	1.38 35.1	0.6 0.3
2 1/2"	4.00 101.6	1.9 0.9	2.00 50.8	0.7 0.3	1.50 38.1	1.1 0.5
3"	4.00 101.6	2.5 1.1	2.25 57.2	1.4 0.6	1.50 38.1	1.2 0.5
4"	6.00 152.4	5.5 2.5	2.63 66.8	2.4 1.1	1.75 44.5	2.2 1.0
5"	6.00 152.4	7.4 3.4	2.88 73.2	4.1 1.9	2.00 50.8	3.3 1.5
6"	6.00 152.4	9.5 4.3	3.13 79.5	5.6 2.5	2.00 50.8	4.6 2.1
8"	6.00 152.4	14.2 6.4	3.88 98.6	11.1 5.0	2.00 50.8	8.7 3.9
10"	8.00 203.2	27.0 12.2	4.38 11.3	14.0 6.4	2.13 54.1	9.1 4.1
12"	8.00 203.2	33.0 15.0	4.88 124.0	22.0 10.0	2.25 57.2	16.7 7.6

# Figures 327 and 341




Figure 327




Figure 341

Nominal Size	Figure 327 Cross		Figure 341 150 lbs. Flange Adapter	
	C to E Inches mm	Appx. Wt. Lbs. kg.	E to E Inches mm	Appx. Wt. Lbs. kg.
1 1/4"	2.75 69.6	2.0 0.9	4.00 101.6	2.8 1.3
1 1/2"	2.75 69.9	2.2 2.0	4.00 101.6	3.2 1.5
2"	3.25 82.6	2.7 1.2	4.0 101.6	5.2 2.4
2 1/2"	3.75 95.3	5.0 2.3	4.00 101.6	8.0 3.6
3"	4.25 108.0	7.1 3.2	4.00 101.6	10.2 4.6
4"	5.00 127.0	11.9 5.4	6.00 152.4	17.2 7.8
5"	5.50 139.7	17.1 7.8	6.00 152.4	21.4 9.7
6"	6.50 165.1	27.5 12.5	6.00 152.4	26.0 11.8
8"	7.75 196.9	47.0 21.3	6.00 152.4	38.4 17.4
10"	9.00 228.6	68.0 30.8	8.00 203.2	65.0 29.5
12"	10.00 254.0	107.0 48.5	8.00 203.2	91.0 41.3

# Figure 321




Figure 321

Figure 321 Reducing Tee					
Nominal Size Inches	C to E Inches <i>mm</i>	Appx. Wt. Lbs. <i>Kg.</i>	Nominal Size Inches	C to E Inches <i>mm</i>	Appx. Wt. Lbs. <i>Kg.</i>
1½ x 1½ x 1¼	3.25 82.6	2.0 0.9	6 x 6 x 4	6.50 165.1	26.6 12.1
2 x 2 x 1½	3.25 82.6	2.7 1.2	6 x 6 x 5	6.50 165.1	27.0 12.2
2½ x 2½ x 1¼	3.75 95.3	4.2 1.9	8 x 8 x 2	7.75 196.9	36.2 16.4
2½ x 2½ x 1½	3.75 95.3	4.2 1.9	8 x 8 x 3	7.75 196.9	36.5 16.6
2½ x 2½ x 2	3.75 95.3	4.3 2.0	8 x 8 x 4	7.75 196.9	36.6 16.6
3 x 3 x 1½	4.25 108.0	5.3 2.4	8 x 8 x 5	7.75 196.9	36.8 16.7
3 x 3 x 2	4.25 108.0	5.5 2.5	8 x 8 x 6	7.75 196.9	37.0 16.8
3 x 3 x 2½	4.25 108.0	5.8 2.6	10 x 10 x 2	9.00 228.6	57.1 25.9
4 x 4 x 1¼	5.00 127.0	9.8 4.4	10 x 10 x 3	9.00 228.6	57.4 26.0
4 x 4 x 1½	5.00 127.0	9.9 4.5	10 x 10 x 4	9.00 228.6	57.6 26.1
4 x 4 x 2	5.00 127.0	10.1 4.6	10 x 10 x 5	9.00 228.6	57.8 26.2
4 x 4 x 2½	5.00 127.0	10.3 4.7	10 x 10 x 6	9.00 228.6	58.0 26.3
4 x 4 x 3	5.00 127.0	10.5 4.8	10 x 10 x 8	9.00 228.6	58.4 26.5
5 x 5 x 2	5.50 139.7	14.5 6.6	12 x 12 x 3	10.00 254.0	80.2 36.4
5 x 5 x 2½	5.50 139.7	14.8 6.7	12 x 12 x 4	10.00 254.0	80.5 36.5
5 x 5 x 3	5.50 139.7	15.2 6.9	12 x 12 x 5	10.00 254.0	80.7 36.6
5 x 5 x 4	5.50 139.7	15.8 7.2	12 x 12 x 6	10.00 254.0	80.9 36.7
6 x 6 x 2	6.50 165.1	26.5 11.9	12 x 12 x 8	10.00 254.0	91.4 41.5
6 x 6 x 2½	6.50 165.1	26.5 12.0	12 x 12 x 10	10.00 254.0	91.8 41.6
6 x 6 x 3	6.50 165.1	26.5 12.0			

General Notes: It is the Designer's responsibility to select products suitable for the intended service and to ensure that pressure ratings and performance data is not exceeded. Always read and understand the installation instructions (IH-1000). Never remove any piping component or correct or modify any piping deficiencies without first depressurizing and draining the system. Material and gasket selection should be verified to be compatible for the specific application.



Certified Company

# VALVES

## Engineering Specification

Job Name \_\_\_\_\_

Contractor \_\_\_\_\_

Job Location \_\_\_\_\_

Approval \_\_\_\_\_

Engineer \_\_\_\_\_

Contractor's P.O. No. \_\_\_\_\_

Approval \_\_\_\_\_

Representative \_\_\_\_\_

# Colt™ Series C500 (Colt 500), C500N (Colt 500N), C500Z (Colt 500Z) Reduced Pressure Detector Assemblies

Sizes: 2½" – 10"

The Colt C500, C500N, C500Z Reduced Pressure Detector Assemblies are designed to protect drinking water supplies from dangerous cross-connections in accordance with national plumbing codes and water authority requirements for health-hazard non-potable service applications such as irrigation, fire line, or industrial processing. The Colt C500, C500N, C500Z are used to monitor unauthorized use of water from the fire protection system.

### Features

- Extremely Compact Design
- 70% Lighter than Traditional Designs
- 304 (Schedule 40) Stainless Steel Housing & Sleeve
- Groove Fittings Allow Integral Pipeline Adjustment
- Patented Link Check Provides Lowest Pressure Loss
- Unmatched Ease of Serviceability
- Replaceable Check Disc Rubber
- Available with Grooved Butterfly Valve Shutoffs
- Bottom Mounted Cast Stainless Steel Relief Valve
- Metered Bypass to Detect Leakage or Theft of Water from the Fire Sprinkler System


### Specifications

The Colt C500, C500N, C500Z Reduced Pressure Detector Assemblies shall consist of two independent Link Check modules, a differential pressure relief valve located between and below the two modules, two drip tight shutoff valves, and required test cocks. Link Check modules and relief valve shall be contained within a sleeve accessible single housing constructed from 304 (Schedule 40) stainless steel pipe with groove end connections. Link Checks shall have reversible elastomer discs and in operation produce drip tight closure against the reverse flow of liquid caused by backpressure or backsiphonage. The bypass assembly consists of a meter registering either gallon or cubic measurements, a reduced pressure zone assembly and required test cocks. Assembly shall be Colt C500, C500N, C500Z as manufactured by the Ames Fire & Waterworks.

C500N OSY  
(Colt 500N GV)



C500 OSY  
(Colt 500 GV)



### ⚠ WARNING

It is illegal to use this product in any plumbing system providing water for human consumption, such as drinking or dishwashing, in the United States. Before installing standard material product, consult your local water authority, building and plumbing codes.

### NOTICE

The information contained herein is not intended to replace the full product installation and safety information available or the experience of a trained product installer. You are required to thoroughly read all installation instructions and product safety information before beginning the installation of this product.

Ames Fire & Waterworks product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Ames Fire & Waterworks Technical Service. Ames Fire & Waterworks reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Ames Fire & Waterworks products previously or subsequently sold.



**AMES**  
FIRE & WATERWORKS  
A WATTS Brand

## Configurations

- Horizontal
- “Z” pattern horizontal
- “N” pattern horizontal

## Materials

- Housing & Sleeve: 304 (Schedule 40) Stainless Steel
- Elastomers: EPDM, Silicone and Buna ‘N’
- Link Checks: Noryl®, Stainless Steel
- Check Discs: Reversible Silicone or EPDM
- Test Cocks: Lead Free\* Bronze Body
- Pins & Fasteners: 300 Series Stainless Steel
- Springs: Stainless Steel

\*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

## Pressure – Temperature

Temperature Range: 33°F – 140°F (0.5°C – 60°C)

Maximum Working Pressure: 175 psi (12.1 bar)

## Available Models

Suffix:

OSY — UL/FM outside stem and yoke resilient seated gate valves

BFG — UL/FM grooved gear operated butterfly valves w/ tamper switch

\*OSY FxG — Flanged inlet gate connection and grooved outlet gate connection

\*OSY GxG — Grooved inlet gate connection and flanged outlet gate connection


\*OSY GxG — Grooved inlet gate connection and grooved outlet gate connection

Available with grooved NRS gate valves — consult factory\*

Post indicator plate and operating nut available — consult factory\*


\*Consult factory for dimensions

## Dimensions – Weights



### C500, C500N, C500Z

SIZE	DIMENSIONS												WEIGHT									
	A		C (OSY)		D		G		H		I		J		M		P		C500		C500N	
in.	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kgs.	lbs.	kgs.
2½	30¾	781	16⅞	416	6½	165	29¼	738	21½	546	15½	393	8⅜	223	21¼	540	13⅜	335	118	54	126	57
3	31¾	806	18⅞	479	6⅞	170	30¼	768	22¼	565	17⅞	435	9⅞	233	23	584	14½	368	134	61	147	67
4	33¾	857	22¼	578	7	178	35⅝	905	23½	597	18½	470	9⅞	252	26¼	667	15⅜	386	164	74	187	85
6	43½	1105	30⅞	765	8½	216	44¾	1137	33¼	845	23⅞	589	13⅞	332	34¼	870	19	483	276	125	317	144
8	49¾	1264	37¼	959	9⅞	246	54⅞	1375	40⅞	1019	27⅞	697	15⅞	399	36⅞	937	21⅞	538	441	200	516	234
10	57¾	1467	45¾	1162	11⅞	285	66	1676	49½	1257	32½	826	17⅞	440	44½	1124	24	610	723	328	893	405



### C500NBFG/C500ZBFG

SIZE	DIMENSIONS												WEIGHT			
	G		H		I		J		M		P		C500BFG			
in.	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kgs.		
2½	32½	826	23	584	15½	394	9½	241	19¾	502	15⅜	402	81	37		
3	34	864	24	610	16⅞	414	10⅞	256	21¼	540	16⅞	410	84	38		
4	35⅞	905	25½	648	17⅞	437	10⅞	279	23½	597	16⅞	422	101	46		
6	46½	1181	35¼	895	20½	521	13½	343	27¼	692	19	483	174	79		

Noryl® is a registered trademark of SABIC Innovative Plastics™.

## Approvals

- Approved by the Foundation for Cross-Connection Control and Hydraulic Research at The University of Southern California (FCCCHR-USC) (Excluding 10" 'N' and 'Z' configurations)
- AWWA C511-97



For additional approval information please contact the factory or visit our website at [www.amesfirewater.com](http://www.amesfirewater.com)

## Capacity







UL/FM Certified Flow Characteristics

N&Z Flow characteristics collected using butterfly shutoff valves.

## Flow capacity chart identifies valve performance based upon rated water velocity up to 25fps

- Service Flow is typically determined by a rated velocity of 7.5fps based upon schedule 40 pipe.
- Rated Flow identifies maximum continuous duty performance determined by AWWA.
- UL Flow Rate is 150% of Rated Flow and is not recommended for continuous duty.
- AWWA Manual M22 [Appendix C] recommends that the maximum water velocity in services be not more than 10fps.

— Horizontal — N - Pattern - - - - Z - Pattern



### NOTICE

Inquire with governing authorities for local installation requirements





**A WATTS Brand**

---

**USA: Backflow** Tel: (978) 689-6066 • Fax: (978) 975-8350 • [AmesFireWater.com](http://AmesFireWater.com)  
**USA: Control Valves** Tel: (713) 943-0688 • Fax: (713) 944-9445 • [AmesFireWater.com](http://AmesFireWater.com)  
**Canada:** Tel: (888) 208-8927 • Fax: (905) 481-2316 • [AmesFireWater.ca](http://AmesFireWater.ca)  
**Latin America:** Tel: (52) 55-4122-0138 • [AmesFireWater.com](http://AmesFireWater.com)



## TECHNICAL DATA

### EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page: [www.vikinggroupinc.com](http://www.vikinggroupinc.com)

## 1. DESCRIPTION

The Viking Easy Riser® Swing Check Valve is a general purpose rubber-faced check valve approved for use in fire service systems. The valve is for use in wet system risers, preaction system risers and wherever a check valve with a drain connection and gauge connections can be utilized. When used with a flow switch on wet pipe systems not requiring a mechanical alarm, the Easy Riser® Swing Check Valve may replace an alarm check valve.

### 1-A Features

1. Ductile iron body for less weight and extra strength.
2. Rated to 300 psi (20.7 bar) water working pressure.
3. Rubber-faced clapper hinged to access cover for quick removal and easy servicing. All moving parts can be serviced without removing the valve from the installed position.
4. With the cover/clapper assembly removed, clapper rubber replacement requires removal of only one screw.
5. Valve housing tapped for inlet and outlet pressure gauges, and system main drain.

### 1-B Accessories

300 PSI (20.7 bar) Trim Package including:

- A. All necessary nipples and fittings
- B. Main Drain Ball Valve
- C. Necessary gauges



**WARNING:** Cancer and Reproductive Harm-  
[www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

## 2. LISTINGS AND APPROVALS:

**cULus Listed:** HMER

**FM Approved:** Single Check Valves

**NYC Department of Buildings:** MEA 89-92-E, Vol. XI

**VNIPO** (250 psi (17.2 bar) MWP)

**CE:** Pressure Equipment Directive 97/23/EC (250 psi (17.2 bar) MWP)

## 3. TECHNICAL DATA

### Specifications:

**Standard Flanged Connections:** ANSI B16.42 Class 150 (mates with ANSI Class 125 and Class 150 flanges).

**Standard Grooved Connections:** ANSI/AWWA C606

**Drain outlet:** 2-1/2" and 3" valves - one 1-1/4" (32 mm) NPT; 4", 6" & 8" valves - 2" (50 mm) NPT

**Gauge Outlets:** two 1/4" (8 mm) NPT

**Other Outlets:** two 1/2" (15 mm) NPT

Systems with water working pressures above 175 psi (12 bar) may require extra-heavy pattern fittings. Viking Easy Riser® Swing Check Valve flanges are Ductile Iron ANSI B16.42, Class 150, with a maximum water working pressure of 300 psi (20.7 bar). ANSI B16.42, Class 150 flanges are NOT compatible with ANSI Class 250 or Class 300 flanges. To mate the Easy Riser® Swing Check Valve with ANSI Class 250 or Class 300 flanges, use the grooved-inlet/grooved-outlet style installed with listed grooved/flanged adapters of the appropriate pressure rating. For piping with grooved connections, the grooved-inlet and/or grooved-outlet style Easy Riser® Swing Check Valve may be installed with listed grooved couplings of the appropriate pressure rating.

### Material Standards:

Refer to Figure 1.

### Ordering Information:

See Table 1 for part numbers and shipping weights.



## TECHNICAL DATA

### EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com  
Visit the Viking website for the latest edition of this technical data page: www.vikinggroupinc.com

#### 4. INSTALLATION

The Easy Riser® Swing Check Valve must be installed in an area not subject to freezing temperatures or physical damage. When corrosive atmospheres and/or contaminated water supplies are present, it is the owner's responsibility to verify compatibility with the Easy Riser® Swing Check Valve, trim, and associated equipment.

Prior to installing the valve, thoroughly flush the water supply piping to verify that no foreign matter is present.

The Easy Riser® Swing Check Valve may be installed in the vertical position with direction of flow up, or in the horizontal position with the access cover up.

1. Remove all plastic thread protectors from the openings of the Easy Riser® Swing Check Valve.
2. Apply a small amount of pipe-joint compound or tape to the external threads of all pipe connections required. Take care not to allow any compound, tape, or other foreign matter inside any of the nipples or openings of the valve or trim components.
3. Easy Riser® Swing Check Valve Trim Charts are provided with Trim Packages and on the Viking website.
4. Verify that all system components are rated for the water working pressure of the system.

#### Hydrostatic Test:

The Easy Riser® Swing Check Valve is manufactured and listed for use at a maximum water working pressure of 300 psi (20.7 bar). The valve is factory tested at 600 psi (41.4 bar). Easy Riser® Swing Check Valves may be hydrostatically tested at 350 psi (24.1 bar) and/or 50 psi (3.5 bar) above the normal water working pressure for limited periods of time (two hours) for the purpose of acceptance by the Authority Having Jurisdiction. If air testing is required, DO NOT exceed 40 psi (2.8 bar) air pressure.

#### 5. OPERATION (Refer to Figure 1.)

Water flowing through the Viking Easy Riser® Swing Check Valve lifts the rubber-gasketed clapper (8 and 9) off the seat (12) and flows into the sprinkler piping. When flow through the valve stops, the clapper (8) closes quickly. The rubber gasket (9) forms a tight seal against the brass water seat (12), trapping pressurized water above the clapper and preventing reverse flow from the sprinkler piping.

#### 6. INSPECTIONS, TESTS, AND MAINTENANCE

##### NOTICE

**The owner is responsible for maintaining the fire protection system and devices in proper operating condition.**

The Viking Easy Riser® Swing Check Valve and trim must be kept free of foreign matter, freezing conditions, corrosive atmospheres, contaminated water supplies, and any condition that could impair its operation or damage the device.

It is imperative that the system be inspected and tested on a regular basis. The frequency of the inspections may vary due to contaminated water supplies, corrosive water supplies, and corrosive atmospheres. For minimum maintenance and inspection requirements, refer to NFPA 25. In addition, the Authority Having Jurisdiction may have additional maintenance, testing, and inspection requirements that must be followed.

##### ⚠ WARNING

**Any system maintenance that involves placing a control valve or detection system out of service may eliminate the fire protection capabilities of that system. Prior to proceeding, notify all Authorities Having Jurisdiction. Consideration should be given to employment of a fire patrol in the affected areas.**

#### 6-A. Five-Year Internal Inspection

Internal inspection of check valves is recommended every five years unless inspections and tests indicate more frequent inspections are required. (Refer to Figure 1.)

1. Notify the Authority Having Jurisdiction, remote station alarm monitors, and those in the area affected that the system will be taken out of service. Consideration should be given to employment of a fire patrol in the affected areas.
2. Close the water supply main control valve, placing the system out of service.
3. Open the main drain. If necessary, open the system test valve to vent and completely drain the system.
4. Use the appropriate wrench to loosen and remove cover screws (14), and remove cover and clapper assembly (2-11).
5. Inspect water seat (12). Wipe away all contaminants, dirt, and mineral deposits. DO NOT use solvents or abrasives.
6. Inspect cover and clapper assembly (2-11) and cover gasket (13). Test the hinged clapper (8) for freedom of movement. Renew or replace damaged or worn parts as required.



## TECHNICAL DATA

### EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page: [www.vikinggroupinc.com](http://www.vikinggroupinc.com)

#### CAUTION

**NEVER apply any lubricant to seats, gaskets, or any internal operating parts of the valve. Petroleum-based grease or oil will damage rubber components and may prevent proper operation.**

7. When internal inspection of the Easy Riser® Swing Check Valve is complete, perform step 5 of paragraph 6-B. MAINTENANCE to re-install cover and clapper assembly (2-11).

#### **6-B. Maintenance** (Refer to Figure 1.)

1. Perform steps 1 through 5 of paragraph 6-A, FIVE-YEAR INTERNAL INSPECTION.
2. To replace clapper assembly (3, 6-11):
  - a. Remove the cover screws (14) from the cover (2) using a Socket Wrench with a 9/16" socket.
  - b. Remove the cover and clapper assembly (2-11) from the valve.
  - c. Remove the cover gasket (13) by sliding it over the clapper assembly.
  - d. Remove the existing clapper assembly (3, 6-11) from the cover assembly (2):
    - i. Remove one of the retaining rings (5) from the clapper hinge pin (4) using a flat head screwdriver.
    - ii. Remove the clapper hinge pin (4) from the cover and clapper assembly. This will allow the clapper assembly (3, 6-11) to be removed from the cover assembly (2).
  - e. Install the new clapper assembly (3, 6-11) onto the cover assembly (2):
    - i. Make sure the clapper rubber (9) is facing opposite the direction of the flow arrow on the inside of the cover (2).
    - ii. Line up the holes of the cover assembly (2) and the clapper assembly (3, 6-11) and insert the hinge pin (4).
    - iii. Install the retaining ring (5) onto the hinge pin (4).
    - iv. Install the cover gasket (13) onto the new cover and clapper assembly (2-11) by sliding the cover gasket (13) over the clapper assembly (3, 6-11) and lining up the holes with the cover (2).
    - v. To install the new cover and clapper assembly (2-11) into the valve, slide the clapper assembly into the valve with the clapper rubber (9) lined up with the water seat (12). Ensure the rubber retainer (10) fits inside the seat of the valve (pull back slightly and there should be some resistance).
    - vi. Line up the holes of the cover (2) and cover gasket (13) with the valve body (1) and replace the cover screws (14) using a Socket Wrench with a 9/16" socket.
3. To replace the clapper rubber (9):
  - i. Remove the cover screws (14) from the cover (2) using a Socket Wrench with a 9/16" socket.
  - ii. Remove the cover and clapper assembly (2-11) from the valve.
  - iii. Remove the cover gasket (13) by sliding it over the clapper assembly (3, 6-11).
  - iv. Use a 7/32" Allen wrench to hold the button head socket screw (11) in place and remove the jam nut (6) from the clapper rubber (9) using a Socket Wrench with a 9/16" socket.
  - v. Remove the button head socket screw (11) and sealing washer (7) from the clapper assembly (3, 6-11).
  - vi. Remove the clapper rubber retainer (10) from the clapper (8) to free the clapper rubber (9).
  - vii. To install the new clapper rubber (9), position the clapper rubber (9) on the clapper assembly so the grooved edge is facing down. This will allow the clapper rubber retainer (10) to fit up into the grooved edge of the clapper rubber (9).
  - viii. Install the button head socket screw (11) and sealing washer assembly (7) and the jam nut (6) using a 7/32" Allen wrench and a Socket Wrench with a 9/16" socket.
  - ix. Install the cover gasket (13) onto the cover (2) by sliding it over the clapper assembly (3, 6-11).
  - x. Re-install the cover and clapper assembly (2-11) back into the valve, with the clapper rubber (9) lined up with the water seat (12). Ensure the clapper rubber retainer (10) fits inside the seat of the valve (pull back slightly and there should be some resistance).
  - xi. Line up the holes of the cover (2) and cover gasket (13) with the valve body (1) and replace the cover screws (14) using a Socket Wrench with a 9/16" socket.
4. To replace the cover gasket (13):
  - i. Remove the cover screws (14) from the cover (2) using a Socket Wrench with a 9/16" socket.
  - ii. Remove the cover and clapper assembly (2-11) from the valve.
  - iii. Remove the cover gasket (13) by sliding it over the clapper assembly (3, 6-11).
  - iv. Install the new cover gasket (13) by sliding it over the clapper assembly (3, 6-11), onto the cover (2).
5. Reinstall the cover and clapper assembly (2-11) into the valve:
  - i. Line up the clapper rubber (9) with the water seat (12). Ensure the clapper rubber retainer (10) fits inside the seat of the valve (pull back slightly and there should be some resistance).
  - ii. Line up the holes of the cover (2) and cover gasket (13) with the valve body (1) and replace the cover screws (14) using a Socket Wrench with a 9/16" socket.



# TECHNICAL DATA

## EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page: www.vikinggroupinc.com

### 7. AVAILABILITY

The Viking Easy Riser® Swing Check Valve is available through a network of domestic and international distributors. See the Viking Corp. Web site for closest distributor or contact The Viking Corporation.

### 8. GUARANTEES

For details of warranty, refer to Viking's current list price schedule or contact Viking directly.

**Table 1 - Valve Part Numbers and Specifications**

Description	Nominal Size	Part Number	Friction Loss*	Shipping Weight
<b>Flange/Flange</b>				
<b>Flange Drilling</b>	<b>Model F-1</b>			
ANSI	3"	08505	10 ft. (3.1m)	35 lbs. (16 kg)
ANSI	4"	08508	13 ft. (4.0 m)	44 lbs. (20 kg)
ANSI	6"	08511	20 ft. (6.0 m)	75 lbs. (34 kg)
ANSI/Japan	DN100	09039	13 ft. (4.0 m)	44 lbs. (20 kg)
ANSI/Japan	DN150	09385	20 ft. (6.0 m)	75 lbs. (34 kg)
ANSI/Japan	DN200	14023	23 ft. (7.0 m)	119 lbs. (54 kg)
PN10/16	DN80	08796	10 ft. (3.1m)	35 lbs. (16 kg)
PN10/16	DN100	08797	13 ft. (4.0 m)	44 lbs. (20 kg)
PN10/16	DN150	08835	20 ft. (6.0 m)	75 lbs. (34 kg)
PN10	DN200	08836	23 ft. (7.0 m)	119 lbs. (54 kg)
PN16	DN200	12355	23 ft. (7.0 m)	119 lbs. (54 kg)
<b>Flange/Groove</b>				
<b>Flange Drilling / Pipe O.D.</b>	<b>Model F-1</b>			
ANSI / 89mm	3"	08506	10 ft. (3.1m)	27 lbs. (12 kg)
ANSI / 114mm	4"	08509	13 ft. (4.0 m)	37 lbs. (17 kg)
ANSI / 168mm	6"	08512	20 ft. (6.0 m)	64 lbs. (29 kg)
ANSI / 219mm	8"	08515	23 ft. (7.0 m)	119 lbs. (54 kg)
PN10/16 / 89mm	DN80	12648	10 ft. (3.1m)	27 lbs. (12 kg)
PN10/16 / 114mm	DN100	12649	13 ft. (4.0 m)	37 lbs. (17 kg)
PN10/16 / 165mm	DN150	12652	20 ft. (6.0 m)	64 lbs. (29 kg)
PN10/16 / 168mm	DN150	08512	20 ft. (6.0 m)	64 lbs. (29 kg)
PN10 / 219mm	DN200	12651	23 ft. (7.0 m)	119 lbs. (54 kg)
PN16 / 219mm	DN200	12650	23 ft. (7.0 m)	119 lbs. (54 kg)
<b>Groove/Groove</b>				
<b>Pipe O.D.</b>	<b>Model E-1</b>			
73mm	2½" / DN65	07929	6 ft. (1.8m)	16 lbs. (7 kg)
76 mm	2½" / DN65	13516	6 ft. (1.8m)	16 lbs. (7 kg)
	<b>Model F-1</b>			
89mm	3" / DN80	08507	10 ft. (3.1m)	20 lbs. (9 kg)
114mm	4" / DN100	08510	13 ft. (4.0 m)	27 lbs. (12 kg)
165mm	DN150	12356	20 ft. (6.0 m)	51 lbs. (23 kg)
168mm	6" / DN150	08513	20 ft. (6.0 m)	51 lbs. (23 kg)
219mm	8" / DN200	08516	23 ft. (7.0 m)	106 lbs. (48 kg)

\*Expressed in equivalent length of Schedule 40 pipe based on Hazen & Williams formula: C = 120.

**Table 2 - Torque Values for Easy Riser Swing Check Valve Cover Screws**

Valve Size	Screw Size	Torque Value
2-1/2" (DN65)	3/8"-16 H.H.C.	19 ft-lb (2.63 kg-m)
3" (DN80)	3/8"-16 H.H.C.	19 ft-lb (2.63 kg-m)
4" (DN100)	3/8"-16 H.H.C.	19 ft-lb (2.63 kg-m)
6" (DN150)	½"-13 H.H.C.	45 ft-lb (6.23 kg-m)
8" (DN200)	5/8"-11 H.H.C.	93 ft-lb (12.9 kg-m)

**Table 3 - Trim Package Part Numbers**

Valve Size	Part Number
<b>Wet System Trim Packages</b>	
2-1/2", 3" (DN65), (DN80)	07236
4", 6", 8", (DN100), (DN150), (DN200)	07237
<b>Preaction System Trim Packages</b>	
2-1/2", 3" (DN65)	13776
4", 6", 8", (DN80), (DN100), (DN150), (DN200)	13777




# TECHNICAL DATA

## EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page: www.vikinggroupinc.com



SIZE	A	B	C	D	E	F	G**
2-1/2" (65mm)	9" (228,6)	4-1/2" (114,3)	2-5/8" (66,7)	2" (50,8)	2" (50,8)	Fig-Flg Not Available	
3" (80mm)	10-1/8" (257)	4-13/16" (122,2)	2-11/16" (68,3)	2-9/32" (58,1)	2-9/32" (58,1)	7-7/8" (200)	25/32" (20)
4" (100mm)	10-5/8" (269,9)	5-3/16" (131,8)	3-1/8" (79,4)	2-1/4" (57,2)	2-1/4" (57,2)	9" (228,6)	15/16" (23,81)
6" (150mm)	13-3/8" (340)	6-13/16" (173,3)	4-1/16" (103,2)	2-1/4" (57,2)	2-1/4" (57,2)	11" (279,4)	1" (25,4)
8" (200mm)	17" (431,8)	8-13/16" (223,4)	5" (127)	2-1/2" (63,4)	2-7/8" (73,0)	13-1/2" (342,9)	1-1/8" (28,58)

Dimensions shown in parentheses are millimeter.

\* For availability of Flg X Flg, Flg X Grv, or Grv X Grv options refer to Table 1.

\*\* 4", 6", and 8" valves are manufactured with sculptured flanges. Dimension indicates thickness of flange at bolt holes.

**Figure 1 - Replacement Parts**

ITEM NO.	PART NUMBER					DESCRIPTION	MATERIAL	NO. REQ'D				
	E-1	F-1	F-1	F-1	F-1							
	2-1/2" (DN65)	3" (DN80)	4" (DN100)	6" (DN150)	8" (DN200)			2-1/2"	3"	4"	6"	8"
1	--	--	--	--	--	Body	Ductile Iron, ASTM A536 (65-45-12)	1	1	1	1	1
2	--	--	--	--	--	Cover Assembly	E-Coated HSLA Steel, A715 and Stainless Steel, UNS-S30400	1	1	1	1	1
3	07576	07576	07576	07576	None	Bushing	Lubricomp 189 Ryton	2	2	2	2	0
4	05355A	05355A	04900A	04991A	05334A	Clapper Hinge Pin	Stainless Steel, UNS-S30400	1	1	1	1	1
5	05445A	05445A	05445A	05445A	05369A	Hinge Pin Retaining Ring	Stainless Steel, UNS-S15700	2	2	2	2	2
6	01755A					Clapper Hex Jam Nut #10-24 UNC	Stainless Steel, UNS-S30400	1	0	0	0	0
		08159	08159			Clapper Hex Jam Nut 3/8"-24 UNF	Stainless Steel, UNS-S30400	0	1	1	0	0
				08144	08144	Clapper Hex Jam Nut 1/2"-20 UNF	Stainless Steel, UNS-S30400	0	0	0	1	1
7	--	08158	08158	08143	08143	Sealing Washer	EPDM and Stainless Steel	1	1	1	1	1
8	*	*	*	*	*	Clapper	PTFE Coated HR Steel UNS-G10180	1	1	1	1	1
9	*	*	*	*	*	Clapper Rubber	EPDM, ASTM D2000	1	1	1	1	1
10	*	*	*	*	*	Clapper Rubber Retainer	Stainless Steel, UNS-S30400	1	1	1	1	1
11	06595A					H.H.C. Screw, #10-24 UNC x 1/2" (12.7 mm) lg.	Stainless Steel, UNS-S30400	1	0	0	0	0
		10194	10194			Screw, Button Head, Socket, 3/8" - 24 UNF x 1/2 (12.7 mm) lg.	Stainless Steel, UNS-S30400	0	1	1	0	0
				10308		Screw, Button Head, Socket, 1/2" - 20 UNF x 3/4 (19.1 mm) lg.	Stainless Steel, UNS-S30400	0	0	0	1	0
					10686	Screw, Button Head, Socket, 1/2" - 20 UNF x 7/8 (22.2 mm) lg.	Stainless Steel, UNS-S30400	0	0	0	0	1
12	--	--	--	--	--	Seat	Brass, UNS-C84400	1	1	1	1	1
13	05354B	05354B	04649B	04992B	05339C	Cover Gasket	EPDM, ASTM D2000	1	1	1	1	1
14	01517A	01517A	01517A			Screw, Hex Head Cap, 3/8" - 16 UNC x 3/4 (19.1 mm) lg.	Steel, Zinc Plated	4	4	6	0	0
				04993A		Screw, Hex Head Cap, 1/2" - 13 x 7/8 (22.2 mm) lg.	Steel, Zinc Plated	0	0	0	6	0
					01922A	Screw, Hex Head Cap, 5/8" - 11 UNC x 1-1/4" (31.8 mm) lg.	Steel, Zinc Plated	0	0	0	0	6
15	--	--	--	--	--	1/2" (15 mm) NPT Pipe Plug	Steel	2	2	2	2	2

-- Indicates replacement part is not available

\* Indicates replacement part only available in a Sub-Assembly listed below.

### Sub-Assemblies

3, 6-11	05499B	08518	08519	08520	08521	Clapper Assembly
6, 7, 9, 11, 13	06343A	08522	08523	08524	08525	Replacement Rubber Kit




# TECHNICAL DATA

## EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page: www.vikinggroupinc.com



**Figure 2**

**Note 1:** 300 psi (20.7 bar) water pressure gauges are provided with trim. 600 psi (41.4 bar) water pressure gauges are available. Order separately when needed\*. Refer to Viking's current price schedule.

\* NFPA 13 requires gauges to have a minimum limit not less than twice the normal water working pressure at the point where the gauges are installed. When normal water working pressure exceeds 150 psi (10.3 bar), order 600 psi (41.4 bar) water pressure gauges separately.

**Note 2:** System Drain Ball Valve is UL Listed and FM Approved for 300 psi (20.7 bar) water working pressure.





# TECHNICAL DATA

## EASY RISER® SWING CHECK VALVE MODELS E-1 & F-1

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page: www.vikinggroupinc.com





## Tyco Fire Products Model BFV-1 Butterfly Valve

### General Description



The Model BFV-1 Butterfly Valve is specifically designed to provide for efficient control of fire protection water supplies. The Model BFV-1 is designed to meet the increasing pressure requirements of the Fire Protection Industry with a maximum operating pressure of 300 psi. Flow may be from either direction, and the valves may be positioned in any orientation. The valve is furnished with grooved ends for use with grooved couplings and can be easily adapted to flanged components utilizing Grinnell Figure 71 Class 150 flange adapters. The body and disc construction provides for increased strength and durability. The Model BFV-1 Butterfly Valve is provided with 2 sets of SPDT Supervisory Switches for use in outdoor and indoor applications. A high strength stainless steel upper stem is provided for dependability. The surfaces at the upper stem and lower trunnion areas incorporate a reduced dynamic torque and anti-compression set design to ensure low operating torque and increased seal longevity.

This unique Tyco design feature prevents elastomeric failure of the disc encapsulation that is commonly experienced

with other manufacturers. This is accomplished by providing uniform compression throughout the opening and closing operation of the disc.

The Model BFV-1 Butterfly Valves are a redesignation for the Central Figure 570, Central Figure 580 and Grinnell Figure 580.

#### WARNING

*The Model BFV-1 Butterfly Valve described herein must be installed and maintained in compliance with this document, as well as with the applicable standards of the National Fire Protection Association, in addition to the standards of any other authorities having jurisdiction. Failure to do so may impair the integrity of this device.*

*The owner is responsible for maintaining his fire protection system and devices in proper operating condition. The installing contractor or sprinkler manufacturer should be contacted relative to any questions.*

### Technical Data

**Model:** BFV-1

**Sizes:** 2-1/2", 3", 4", 5", 6", 8" & 10"

**Maximum Working Pressure:** 300 psi (2068 kPa)

**Factory Hydro Test:** 100% at 600 psi (4137 kPa) in accordance with test requirements of MSS SP-67, UL, FM and ULC

**Approvals:** UL, FM and ULC for both indoor and outdoor use. Note: 8" - 10" are FM approved only. See Fire Protection Submittal Sheet for exact Listing / Approval information.

**Materials of Construction:**

**Body:** Ductile iron conforming to ASTM A-536, Grade 65-45-12

**Body Coating:** Epoxy

**Disc:** Ductile iron conforming to ASTM A-536, Grade 65-45-12

**Disc Seal:** Grade EPDM "E" encapsulated rubber conforming to ASTM D-2000

**Upper Stem:** Type 440 Stainless Steel

(2-1/2"-8") Type 17-4 Stainless Steel (10")

**Lower Plug and Stem:**

Type 17-4 Stainless Steel

**Operator:** Gear operator with iron housing coated with Epoxy

**Bracket:** Steel - Black Zinc Plated

### Ordering Information

When placing an order, indicate the full product name. Please specify the quantity, valve model number, size, type of seal; EPDM "E", and part number from the following list.

Valve Size	Valve Part Number
2-1/2"	59-300-F-025
3"	59-300-F-030
4"	59-300-F-040
5"	59-300-F-050
6"	59-300-F-060
8"	59-300-F-080
10"	59-300-F-100

Tyco Fire Products, valves, accessories and other products are available throughout the U.S., Canada, and internationally, through a network of distribution centers. You may write directly or call 215-362-0700 for the distributor nearest you.

### Care and Maintenance

The owner is responsible for the inspection, testing, and maintenance of their fire protection system and devices in accordance with the applicable standards of the National Fire Protection Association (e.g., NFPA 25), in addition to the standards of any authority having jurisdiction. The installing contractor or product manufacturer should be contacted relative to any questions. Any impairment must be immediately corrected.

It is recommended that automatic sprinkler systems be inspected, tested, and maintained by a qualified Inspection Service.

# Limited Warranty

Products manufactured by Tyco Fire Products are warranted solely to the original Buyer for ten (10) years against defects in material and workmanship when paid for and properly installed and maintained under normal use and service. This warranty will expire ten (10) years from date of shipment by Tyco Fire Products. No warranty is given for products or components manufactured by companies not affiliated by ownership with Tyco Fire Products or for products and components which have been subject to misuse, improper installation, corrosion, or which have not been installed,



maintained, modified or repaired in accordance with applicable Standards of the National Fire Protection Association, and/or the standards of any other Authorities Having Jurisdiction. Materials found by Tyco Fire Products to be defective shall be either repaired or replaced, at Tyco Fire Products' sole option. Tyco Fire Products neither assumes, nor authorizes any person to assume for it, any other obligation in connection with the sale of products or parts of products. Tyco Fire Products shall not be responsible for sprinkler system design errors or inaccurate or incomplete information supplied by Buyer or Buyer's representatives.

IN NO EVENT SHALL TYCO FIRE PRODUCTS BE LIABLE, IN CONTRACT, TORT, STRICT LIABILITY OR

UNDER ANY OTHER LEGAL THEORY, FOR INCIDENTAL, INDIRECT, SPECIAL OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO LABOR CHARGES, REGARDLESS OF WHETHER TYCO FIRE PRODUCTS WAS INFORMED ABOUT THE POSSIBILITY OF SUCH DAMAGES, AND IN NO EVENT SHALL TYCO FIRE PRODUCTS' LIABILITY EXCEED AN AMOUNT EQUAL TO THE SALES PRICE.

**THE FOREGOING WARRANTY IS MADE IN LIEU OF ANY AND ALL OTHER WARRANTIES EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.**

## Model BFV-1 Butterfly Valve



Nominal Dimensions								Approx. Weight
Size	A	B	C	D	E	F	G	
Inches	Inches	Inches	Inches	Inches	Inches	Inches	Inches	lbs.
mm	mm	mm	mm	mm	mm	mm	mm	Kg.
2 1/2"	5.08	10.41	6.97	2.88	3.81	5.72	N/A*	12.0
73.0	129.0	264.4	177.0	73.0	96.8	145.3		5.4
3"	5.41	11.38	7.29	3.50	3.81	5.72	N/A*	14.0
88.9	137.4	289.1	185.2	88.9	96.8	145.3		6.4
4"	6.37	12.70	8.25	4.75	4.56	5.72	N/A*	22.0
114.3	161.8	322.6	209.6	120.7	115.8	145.3		10.0
5"	7.33	14.56	10.41	6.25	5.81	6.18	N/A*	31.0
141.3	186.2	369.8	264.4	158.8	147.6	157.0		14.1
6"	7.62	15.23	10.70	6.75	5.81	6.18	N/A*	36.0
168.3	193.5	386.8	271.8	171.5	147.6	157.0		16.3
8"	9.24	17.50	13.37	10.00	5.25	6.43	1.22	52.0
219.1	234.7	444.5	339.6	254.0	133.4	163.3	31.0	23.6
10"	11.81	21.78	16.93	12.00	6.25	7.96	1.75	75.0
273.0	299.9	553.2	430.0	304.3	158.8	202.2	44.5	34.1

\* End of disc does not extend beyond valve body.

Friction Resistance	
Size	Equiv. Length in Feet
2 1/2"	6'
3"	7'
4"	6'
5"	10'
6"	13'
8"	14'
10"	16'

Note: Friction Resistance is specified in equivalent length of Std. weight (C-120) steel pipe.

General Notes: It is the Designer's responsibility to select products suitable for the intended service and to ensure that pressure ratings and performance data is not exceeded. Always read and understand the installation instructions (IH-1000). Never remove any piping component or correct or modify any piping deficiencies without first depressurizing and draining the system. Material and gasket selection should be verified to be compatible for the specific application.





# UNITED BRASS WORKS, INC

714 S. Main St.. Randleman, N.C. 27317

Phone: 800/334-3

035 Fax: 800/498-4696



## Model 125SUL Globe Valve Soft Disc



UL Listed for Fire Sprinkler Service at 250 WOG

200 WOG @ 180 ° Max

100% Pressure Tested

Threaded Ends


Rising Stem • Integral Seat

Swivel Disc Holder

**\*Contains Lead. Not Intended for Use in Potable Water Systems\***

### MATERIAL LIST

NO.	DESCRIPTION	MATERIAL
1	Hex Nut	Steel
2	Hand Wheel	Zinc
3	Packing Nut	Brass
4	Packing	Graphite Non-Asb.
5	Bonnet (1/4" - 1") Bonnet (1 1/4" - 2")	Brass Bronze
6	Stem & Disc Holder	Brass
7	Disc	Buna N
8	Body	Bronze



Size	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
A	2.22	2.47	2.97	3.56	4.06	4.69
B	2.03	2.38	2.75	3.00	3.72	3.72
C (closed)	3.38	3.50	4.25	4.75	5.50	5.50
Ship Wt. (lbs.)	0.69	0.94	1.76	2.50	3.26	5.32
Qty. Unit Pack	12	6	6	4	2	2
Qty. Per Case	72	60	36	24	12	12

# **HYDRAULIC CALCULATIONS**



# Hydraulic Calculations

for

Project Name: OVERHILLS ELEMENTARY  
Location: 2626 RAY ROAD, SPRING LAKE, NC 28390,  
Drawing Name: PIPING

Calculation Date: 4/19/2023

## Design

Remote Area Number: A  
Remote Area Location: CLEARSTORY  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density 0.10 gpm/ft<sup>2</sup>  
Area of Application: 1500 ft<sup>2</sup> (Actual 1576 ft<sup>2</sup>)  
Coverage per Sprinkler: 288 ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 6  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 305.79 @ 109.634 (Safety Margin = 20.152)  
from Pump at Node: 1: 205.79 @ 109.634 (Safety Margin = 20.152)  
Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherA N/A

Name of Contractor:  
Address:  
Phone Number:  
Name of designer: BKB  
Authority Having Jurisdiction: HARNETT CO

## Notes:

Automatic peaking results Left: N/A Right: N/A

---

---


---

# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: A

N 1.85

Date: 4/19/2023




# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: A

N<sup>1.85</sup>

Date: 4/19/2023



**Pump Rating: 750.00 @ 80.000**

**Supply: Static: 138.000**  
**Residual: 92.000**  
**Flowing: 776.00**





# Summary Of Outflowing Devices

Job Number: B22243

Report Description: Light Hazard (A)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	2341	33.75	32.98	8	17.799			
Sprinkler	2342	33.26	32.98	8	17.284			
⇒ Sprinkler	<b>2343</b>	<b>32.98</b>	<b>32.98</b>	<b>8</b>	<b>17.000</b>			
Sprinkler	2354	35.71	32.98	8	19.921			
Sprinkler	2355	35.19	32.98	8	19.344			
Sprinkler	2356	34.90	32.98	8	19.032			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	138.000	92.000	776.00	129.786	305.79	109.634
Pump Analysis							
Node	Churn (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)	
1	96.000	80.000	750.00	129.786	205.79	109.634	
Node Analysis							
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes		
1	1'-2½	Supply	109.634	205.79	P2		
2341	28'-0	Sprinkler	17.799	33.75			
2342	28'-0	Sprinkler	17.284	33.26			
2343	28'-0	Sprinkler	17.000	32.98			
2354	28'-0	Sprinkler	19.921	35.71			
2355	28'-0	Sprinkler	19.344	35.19			
2356	28'-0	Sprinkler	19.032	34.90			
22	1'-2½		109.275				
24	12'-5½		92.234				
29	12'-5½		92.171				
30	12'-5½		92.167				
31	12'-5½		92.136				
38	12'-5½		92.131				
41	12'-5½		92.144				
42	12'-5½		92.147				
43	12'-5½		92.205				

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
224	28'-9½		25.837		
227	28'-9½		25.154		
229	28'-9½		24.690		
233	28'-9½		35.346		
234	28'-9½		36.430		
235	28'-9½		34.407		
236	28'-9½		33.804		
340	20'-0		88.134		
349	20'-0		88.118		
462	12'-5½		93.093		
463	12'-5½		93.127		
464	12'-5½		92.203		
465	12'-5½		92.165		
469	12'-5½		91.257		
480	12'-5½		91.137		
482	12'-5½		89.418		
490	20'-0		88.004		
491	12'-5½		92.101		
492	12'-5½		92.142		
493	12'-5½		93.038		
494	12'-5½		93.006		
497	20'-0		87.891		
563	12'-5½		95.429		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
564	12'-5½		95.389		
565	12'-5½		95.451		
568	12'-5½		95.546		
571	12'-5½		95.555		
575	12'-5½		95.553		
576	12'-5½		95.557		
577	12'-5½		95.503		
583	12'-5½		95.463		
585	12'-5½		95.189		
587	12'-5½		95.414		
620	12'-5½		96.089		
623	12'-5½		96.113		
658	12'-5½		98.057		
659	12'-5½		98.200		
738	11'-1½		99.555		
774	11'-1½		99.575		
785	11'-1½		99.606		
787	11'-1½		99.668		
788	11'-1½		99.585		
789	11'-1½		99.619		
796	11'-1½		99.564		
805	11'-1½		99.571		
810	11'-1½		100.122		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
812	11'-1½		100.130		
813	11'-1½		99.780		
815	11'-1½		99.706		
825	11'-1½		99.571		
884	11'-1½		99.571		
899	11'-1½		99.571		
938	11'-1½		99.571		
949	11'-1½		99.571		
957	11'-1½		99.571		
971	11'-1½		99.571		
980	11'-1½		99.571		
983	11'-1½		99.571		
1037	11'-1½		99.571		
1069	3'-7½	Gauge	107.902		
1071	4'-2½		107.500		
1097	11'-1½		99.571		
1184	11'-1½		99.571		
1215	11'-1½		99.571		
1275	11'-1½		99.571		
1278	11'-1½		99.571		
1287	11'-1½		99.571		
1295	11'-1½		99.571		
1349	11'-1½		99.571		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1359	11'-1½		99.571		
1457	11'-1½		99.571		
1470	11'-1½		99.571		
1550	11'-1½		99.571		
1561	11'-1½		99.571		

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
					Total (Foot)			Friction(Pf)	
2343	28'-0	8	32.98	1	(See Notes)	18'-5½	120	17.000	••••• Route 1 ••••• Sprinkler, 3E(2'-0)
229	28'-9½		32.98	1.0490		6'-0	0.328366	-0.335	
						24'-5½		8.025	
229	28'-9½		34.90	1	(See Notes)	2'-3½	120	24.690	Flow (q) from Route 4 PO(5'-0)
236	28'-9½		67.89	1.0490		5'-0	1.248153		
						7'-3½		9.114	
236	28'-9½			2		16'-2	120	33.804	
235	28'-9½		67.89	2.1570		16'-2	0.037290	0.603	
235	28'-9½		68.44	2	(See Notes)	2'-7½	120	34.407	Flow (q) from Route 2 T(12'-3½)
234	28'-9½		136.33	2.1570		12'-3½	0.135456		
						14'-11		2.022	
234	28'-9½		69.46	2	(See Notes)	90'-6½	120	36.430	Flow (q) from Route 3 9E(6'-2), PO(12'-3½)
482	12'-5½		205.79	2.1570		67'-8	0.290156	7.081	
						158'-2½		45.907	
482	12'-5½			2½	(See Notes)	31'-3½	120	89.418	2T(16'-5½)
469	12'-5½		99.67	2.6350		32'-11½	0.028630		
						64'-3		1.840	
469	12'-5½			2½	(See Notes)	14'-5	120	91.257	3E(8'-3)
465	12'-5½		88.95	2.6350		24'-8½	0.023193		
						39'-1½		0.907	
465	12'-5½			2½		1'-8½	120	92.165	
464	12'-5½		88.40	2.6350		1'-8½	0.022928	0.039	
464	12'-5½		2.22	2½	(See Notes)	5'-6½	120	92.203	Flow (q) from Route 7 2T(16'-5½)
463	12'-5½		90.62	2.6350		32'-11½	0.024007		
						38'-6		0.924	
463	12'-5½		13.66	2½	(See Notes)	23'-3	120	93.127	Flow (q) from Route 45 2T(16'-5½), C(16'-5½)
564	12'-5½		104.28	2.6350		49'-5	0.031125		
						72'-8		2.262	
564	12'-5½			2½		3'-7	120	95.389	
565	12'-5½		76.09	2.6350		3'-7	0.017374	0.062	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
					Total (Foot)			Friction(Pf)	
565	12'-5½			1½	(See Notes)	130'-4½	120	95.451	PO(9'-11) E(4'-11½), PO(9'-11)
813	11'-1½		27.91	1.6820		24'-9	0.024178	0.578	
						155'-1½		3.751	
813	11'-1½		149.69	4	(See Notes)	17'-2	120	99.780	Flow (q) from Route 11 T(26'-4)
812	11'-1½		177.60	4.2600		26'-4	0.008033		
						43'-6		0.349	
812	11'-1½		28.19	4	(See Notes)	264'-7	120	100.130	Flow (q) from Route 25 6E(13'-2), T(26'-4), f, sCV(28'-11½), BV(15'-9½)
1071	4'-2½		205.79	4.2600		150'-1½	0.010550	2.996	
						414'-8½		4.375	
1071	4'-2½			4	(See Notes)	0'-0	120	107.500	E(10'-0), BOR
1069	3'-7½		205.79	4.0260		10'-0	0.013891	0.263	
						10'-0		0.139	
1069	3'-7½			4	(See Notes)	3'-11	120	107.902	T(20'-0)
22	1'-2½		205.79	4.0260		20'-0	0.013891	1.040	
						23'-11		0.332	
22	1'-2½			6	(See Notes)	211'-5½	140	109.275	3E(22'-1), 2EE(11'-0½)
1	1'-2½		205.79	6.2800		88'-3	0.001198	0.000	
						299'-8½		0.359	
			100.00					109.634	Hose Allowance At Source
1			305.79						Total(Pt) Route 1
2342	28'-0	8	33.26	1	(See Notes)	18'-7½	120	17.284	***** Route 2 ***** Sprinkler, 3E(2'-0)
227	28'-9½		33.26	1.0490		6'-0	0.333438	-0.335	
						24'-7½		8.205	
227	28'-9½		35.19	1	(See Notes)	2'-3½	120	25.154	Flow (q) from Route 5 PO(5'-0)
235	28'-9½		68.44	1.0490		5'-0	1.267224		
						7'-3½		9.254	
								34.407	Total(Pt) Route 2
2341	28'-0	8	33.75	1	(See Notes)	18'-5½	120	17.799	***** Route 3 ***** Sprinkler, 3E(2'-0)
224	28'-9½		33.75	1.0490		6'-0	0.342619	-0.335	
						24'-5½		8.374	



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
224	28'-9½		35.71	1	(See Notes)	2'-3½	120	25.837	Flow (q) from Route 6 PO(5'-0)
233	28'-9½		69.46	1.0490		5'-0	1.302153		
						7'-3½		9.509	
233	28'-9½			2	(See Notes)	15'-6½	120	35.346	T(12'-3½)
234	28'-9½		69.46	2.1570		12'-3½	0.038903		
						27'-10		1.083	
								36.430	Total(Pt) Route 3
2356	28'-0	8	34.90	1	(See Notes)	2'-5½	120	19.032	***** Route 4 ***** Sprinkler, 2E(2'-0), 2T(5'-0)
229	28'-9½		34.90	1.0490		14'-0	0.364524	-0.335	
						16'-5½		5.993	
								24.690	Total(Pt) Route 4
2355	28'-0	8	35.19	1	(See Notes)	2'-7½	120	19.344	***** Route 5 ***** Sprinkler, 2E(2'-0), 2T(5'-0)
227	28'-9½		35.19	1.0490		14'-0	0.370036	-0.335	
						16'-7½		6.145	
								25.154	Total(Pt) Route 5
2354	28'-0	8	35.71	1	(See Notes)	2'-5½	120	19.921	***** Route 6 ***** Sprinkler, 2E(2'-0), 2T(5'-0)
224	28'-9½		35.71	1.0490		14'-0	0.380246	-0.335	
						16'-5½		6.251	
								25.837	Total(Pt) Route 6
38	12'-5½		12.58	2		47'-6½	120	92.131	***** Route 7 ***** Flow (q) from Route 8
31	12'-5½		2.86	2.1570		47'-6½	0.000107	0.005	
31	12'-5½		12.47	2		13'-3	120	92.136	Flow (q) from Route 9
30	12'-5½		15.33	2.1570		13'-3	0.002377	0.031	
30	12'-5½		0.55	2		1'-8½	120	92.167	Flow (q) from Route 48
29	12'-5½		15.88	2.1570		1'-8½	0.002537	0.004	
29	12'-5½			1½	(See Notes)	123'-3	120	92.171	PO(9'-11) PO(9'-11)
464	12'-5½		2.22	1.6820		19'-9½	0.000224		
						143'-1		0.032	
								92.203	Total(Pt) Route 7

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
480	12'-5½			2½	(See Notes)	7'-6½	120	91.137	..... Route 8 .....
497	20'-0		14.32	2.6350		16'-5½	0.000791	-3.265	
						24'-0		0.019	
497	20'-0			1½	(See Notes)	28'-0	120	87.891	E(4'-11½)
349	20'-0		14.32	1.6820		4'-11½	0.007040	-0.005	
						32'-11½		0.232	
349	20'-0			1½	(See Notes)	109'-5½	120	88.118	3E(4'-11½), PO(9'-11)
38	12'-5½		12.58	1.6820		24'-9	0.005538	3.270	
						134'-2½		0.743	
								92.131	Total(Pt) Route 8
469	12'-5½		88.95	2½	(See Notes)	7'-6½	120	91.257	..... Route 9 .....
490	20'-0		10.72	2.6350		16'-5½	0.000463	-3.265	
						24'-0		0.011	
490	20'-0			1½	(See Notes)	27'-11	120	88.004	E(4'-11½)
340	20'-0		10.72	1.6820		4'-11½	0.004122	-0.005	
						32'-10½		0.136	
340	20'-0		1.74	1½	(See Notes)	109'-7	120	88.134	Flow (q) from Route 10 3E(4'-11½), PO(9'-11)
31	12'-5½		12.47	1.6820		24'-9	0.005446	3.270	
						134'-4		0.732	
								92.136	Total(Pt) Route 9
349	20'-0			1½	(See Notes)	56'-4	120	88.118	..... Route 10 .....
340	20'-0		1.74	1.6820		59'-5	0.000143		
						115'-9		0.017	
								88.134	Total(Pt) Route 10
971	11'-1½		0.06 + 0.08	1½	(See Notes)	52'-2	120	99.571	..... Route 11 .....
983	11'-1½		0.14	1.6820		19'-9½	0.000001		
						71'-11½		0.000	
983	11'-1½			1½	(See Notes)	32'-8	120	99.571	PO(9'-11)
980	11'-1½		0.08	1.6820		9'-11	0.000000		
						42'-7		0.000	
980	11'-1½		0.48	4		10'-2	120	99.571	Flow (q) from Route 12
949	11'-1½		0.56	4.2600		10'-2	0.000000	0.000	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	

949	11'-1½		0.12	4		16'-8	120	99.571	Flow (q) from Route 29
899	11'-1½		0.68	4.2600		16'-8	0.000000	0.000	
899	11'-1½		0.14	4	(See Notes)	13'-2½	120	99.571	Flow (q) from Route 31 T(26'-4)
825	11'-1½		0.82	4.2600		26'-4	0.000000	0.000	
						39'-6½			
825	11'-1½		27.67	4		12'-11	120	99.571	Flow (q) from Route 33
774	11'-1½		28.49	4.2600		12'-11	0.000272	0.004	
774	11'-1½		27.02	4		10'-9	120	99.575	Flow (q) from Route 24
788	11'-1½		55.52	4.2600		10'-9	0.000935	0.010	
788	11'-1½		17.00	4		13'-11	120	99.585	Flow (q) from Route 14
785	11'-1½		72.51	4.2600		13'-11	0.001532	0.021	
785	11'-1½		17.29	4		5'-8	120	99.606	Flow (q) from Route 16
789	11'-1½		89.81	4.2600		5'-8	0.002275	0.013	
789	11'-1½		15.13	4		16'-2	120	99.619	Flow (q) from Route 38
787	11'-1½		104.93	4.2600		16'-2	0.003035	0.049	
787	11'-1½		17.54	4		9'-4	120	99.668	Flow (q) from Route 15
815	11'-1½		122.47	4.2600		9'-4	0.004039	0.038	
815	11'-1½		27.22	4		12'-8	120	99.706	Flow (q) from Route 21
813	11'-1½		149.69	4.2600		12'-8	0.005855	0.074	
								99.780	Total(Pt) Route 11

1457	11'-1½		0.19	1½	(See Notes)	168'-10	120	99.571	***** Route 12 ***** PO(9'-11), Flow (q) from Route 27 PO(9'-11)
1470	11'-1½		0.10	1.6820		188'-7½	0.000001	0.000	
1470	11'-1½		0.09	4		16'-8	120	99.571	Flow (q) from Route 13
1359	11'-1½		0.19	4.2600		16'-8	0.000000	0.000	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
1359	11'-1½		0.10	4		10'-2	120	99.571	Flow (q) from Route 26
1275	11'-1½		0.29	4.2600		10'-2	0.000000	0.000	
1275	11'-1½		0.07	4		8'-6	120	99.571	Flow (q) from Route 18
1215	11'-1½		0.36	4.2600		8'-6	0.000000	0.000	
1215	11'-1½		0.06	4		18'-6	120	99.571	Flow (q) from Route 19
1037	11'-1½		0.42	4.2600		18'-6	0.000000	0.000	
1037	11'-1½		0.06	4		8'-6	120	99.571	Flow (q) from Route 37
980	11'-1½		0.48	4.2600		8'-6	0.000000	0.000	
								99.571	Total(Pt) Route 12
1457	11'-1½		0.19	2½		14'-0	120	99.571	••••• Route 13 ••••• Flow (q) from Route 27
1550	11'-1½		0.09	2.6350		14'-0	0.000000	0.000	
1550	11'-1½			1½	(See Notes)	168'-10	120	99.571	PO(9'-11)
1561	11'-1½		0.09	1.6820		188'-7½	0.000001	0.000	
1561	11'-1½			4		14'-0	120	99.571	PO(9'-11)
1470	11'-1½		0.09	4.2600		14'-0	0.000000	0.000	
								99.571	Total(Pt) Route 13
658	12'-5½		34.29	1½	(See Notes)	63'-8½	120	98.057	••••• Route 14 ••••• T(9'-11), Flow (q) from Route 17 3E(4'-11½), PO(9'-11)
788	11'-1½		17.00	1.6820		34'-8	0.009660	0.578	
					98'-4½		0.950		
								99.585	Total(Pt) Route 14
585	12'-5½		101.51	2½		16'-11½	120	95.189	••••• Route 15 ••••• Flow (q) from Route 42
583	12'-5½		73.02	2.6350		16'-11½	0.016099	0.273	
583	12'-5½			2½		5'-11	120	95.463	
577	12'-5½		45.99	2.6350		5'-11	0.006846	0.041	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
577	12'-5½			2½		19'-0	120	95.503	
575	12'-5½		27.37	2.6350		19'-0	0.002622	0.050	
575	12'-5½			2½		6'-7	120	95.553	
576	12'-5½		11.70	2.6350		6'-7	0.000544	0.004	
576	12'-5½		3.64	1½	(See Notes)	51'-9	120	95.557	PO(9'-11), Flow (q) from Route 22 E(4'-11½)
620	12'-5½		15.34	1.6820		14'-10	0.007993		
						66'-7		0.532	
620	12'-5½		17.33	1½	(See Notes)	45'-5½	120	96.089	Flow (q) from Route 23 2E(4'-11½), T(9'-11)
659	12'-5½		32.67	1.6820		19'-9½	0.032357		
						65'-3		2.112	
659	12'-5½			1½	(See Notes)	62'-1½	120	98.200	3E(4'-11½), PO(9'-11)
787	11'-1½		17.54	1.6820		24'-9	0.010240	0.578	
						86'-10½		0.890	
								99.668	Total(Pt) Route 15
658	12'-5½		34.29	1½	(See Notes)	77'-7	120	98.057	••••• Route 16 ••••• Flow (q) from Route 17 2E(4'-11½), PO(9'-11)
785	11'-1½		17.29	1.6820		19'-9½	0.009977	0.578	
						97'-4½		0.972	
								99.606	Total(Pt) Route 16
577	12'-5½			1½	(See Notes)	33'-6	120	95.503	••••• Route 17 ••••• PO(9'-11) T(9'-11)
623	12'-5½		18.62	1.6820		19'-9½	0.011438		
						53'-3½		0.609	
623	12'-5½		15.67	1½	(See Notes)	45'-0½	120	96.113	Flow (q) from Route 34 2E(4'-11½)
658	12'-5½		34.29	1.6820		9'-11	0.035395		
						54'-11		1.944	
								98.057	Total(Pt) Route 17
1278	11'-1½		0.13	1½	(See Notes)	32'-8½	120	99.571	••••• Route 18 ••••• Flow (q) from Route 20 PO(9'-11)
1275	11'-1½		0.07	1.6820		9'-11	0.000000		
						42'-7½		0.000	
								99.571	Total(Pt) Route 18

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
Total		Friction(Pf)							
1278	11'-1½		0.13	1½	(See Notes)	41'-2½	120	99.571	
1215	11'-1½		0.06	1.6820		24'-9	0.000000	0.000	
						65'-11½		99.571	
								Total(Pt)	Route 19
1287	11'-1½		0.06 + 0.07	1½	(See Notes)	51'-4½	120	99.571	***** Route 20 ***** Flow (q) from Route 28 and 2E(4'-11½), T(9'-11)
1278	11'-1½		0.13	1.6820		19'-9½	0.000001	0.000	
						71'-2		99.571	
								Total(Pt)	Route 20
568	12'-5½		48.18	1½	(See Notes)	130'-4½	120	95.546	***** Route 21 ***** PO(9'-11), Flow (q) from Route 41 E(4'-11½), PO(9'-11)
815	11'-1½		27.22	1.6820		24'-9	0.023091	0.578	
						155'-1½		3.582	
								Total(Pt)	Route 21
568	12'-5½		48.18	2½		6'-1	120	95.546	***** Route 22 ***** Flow (q) from Route 41
571	12'-5½		20.96	2.6350		6'-1	0.001600	0.010	
571	12'-5½			2½		18'-3	120	95.555	
576	12'-5½		3.64	2.6350		18'-3	0.000063	0.001	
								Total(Pt)	Route 22
571	12'-5½			1½	(See Notes)	33'-6	120	95.555	***** Route 23 ***** PO(9'-11) T(9'-11)
620	12'-5½		17.33	1.6820		19'-9½	0.010010	0.533	
						53'-3½		96.089	
								Total(Pt)	Route 23
583	12'-5½			1½	(See Notes)	130'-4½	120	95.463	***** Route 24 ***** PO(9'-11) E(4'-11½), PO(9'-11)
774	11'-1½		27.02	1.6820		24'-9	0.022782	0.578	
						155'-1½		3.534	
								Total(Pt)	Route 24
564	12'-5½		76.09	2½		14'-5	120	95.389	***** Route 25 ***** Flow (q) from Route 1
563	12'-5½		28.19	2.6350		14'-5	0.002768	0.040	
563	12'-5½			1½	(See Notes)	132'-4½	120	95.429	
810	11'-1½		28.19	1.6820		34'-8	0.024634	0.578	PO(9'-11) 3E(4'-11½), PO(9'-11)
						167'-0½		4.115	

Pipe Information									
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)		Friction(Pf)	
810	11'-1½			4	(See Notes)	2'-10	120	100.122	T(26'-4)
812	11'-1½		28.19	4.2600		26'-4	0.000267		
						29'-2		0.008	
								100.130	Total(Pt) Route 25
1295	11'-1½			2½	(See Notes)	6'-1	120	99.571	***** Route 26 *****
1349	11'-1½		0.29	2.6350		6'-1	0.000001	0.000	
1349	11'-1½			1½		168'-10		120	
1359	11'-1½		0.10	1.6820		19'-9½	0.000001		PO(9'-11)
						188'-7½		0.000	PO(9'-11)
								99.571	Total(Pt) Route 26
1349	11'-1½		0.10	2½	(See Notes)	16'-8	120	99.571	***** Route 27 ***** Flow (q) from Route 26
1457	11'-1½		0.19	2.6350		16'-8	0.000000	0.000	
								99.571	Total(Pt) Route 27
1097	11'-1½			2½	(See Notes)	8'-8	120	99.571	***** Route 28 *****
1184	11'-1½		0.42	2.6350		8'-8	0.000001	0.000	
1184	11'-1½			2½		16'-9		120	
1295	11'-1½		0.35	2.6350		16'-9	0.000001	0.000	
1295	11'-1½			1½	99'-6	120		99.571	PO(9'-11)
1287	11'-1½		0.06	1.6820		34'-8	0.000000		E(4'-11½), 2T(9'-11)
						134'-2		0.000	
								99.571	Total(Pt) Route 28
938	11'-1½		0.68	1½	(See Notes)	168'-10	120	99.571	***** Route 29 ***** PO(9'-11), Flow (q) from Route 32 PO(9'-11)
949	11'-1½		0.12	1.6820		19'-9½	0.000001		
						188'-7½		0.000	
								99.571	Total(Pt) Route 29
938	11'-1½		0.68	2½	(See Notes)	6'-4	120	99.571	***** Route 30 ***** Flow (q) from Route 32
957	11'-1½		0.56	2.6350		6'-4	0.000002	0.000	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
957	11'-1½			2½		18'-0	120	99.571	
1097	11'-1½		0.47	2.6350		18'-0	0.000001	0.000	
1097	11'-1½			1½	(See Notes)	121'-3½	120	99.571	
971	11'-1½		0.06	1.6820		44'-6½	0.000000		PO(9'-11)
						165'-10		0.000	7E(4'-11½)
								99.571	Total(Pt) Route 30
805	11'-1½		0.82	2½		14'-1	120	99.571	..... Route 31 ..... Flow (q) from Route 40
884	11'-1½		0.82	2.6350		14'-1	0.000004	0.000	
884	11'-1½			1½	(See Notes)	168'-10	120	99.571	PO(9'-11)
899	11'-1½		0.14	1.6820		19'-9½	0.000001		PO(9'-11)
						188'-7½		0.000	
								99.571	Total(Pt) Route 31
884	11'-1½		0.14	2½		16'-8	120	99.571	..... Route 32 ..... Flow (q) from Route 31
938	11'-1½		0.68	2.6350		16'-8	0.000003	0.000	
								99.571	Total(Pt) Route 32
587	12'-5½		28.49	1½	(See Notes)	126'-11½	120	95.414	..... Route 33 ..... Flow (q) from Route 36
738	11'-1½		28.49	1.6820		14'-10	0.025127	0.578	
738	11'-1½			4	(See Notes)	141'-9½		3.563	
738	11'-1½			4	(See Notes)	19'-11	120	99.555	E(4'-11½), PO(9'-11)
796	11'-1½		28.49	4.2600		13'-2	0.000272		
796	11'-1½			4	(See Notes)	33'-1		0.009	
796	11'-1½			4	(See Notes)	0'-10½	120	99.564	E(13'-2)
825	11'-1½		27.67	4.2600		26'-4	0.000258		
825	11'-1½			4	(See Notes)	27'-2½		0.007	
								99.571	Total(Pt) Route 33
575	12'-5½			1½	(See Notes)	52'-5½	120	95.553	..... Route 34 ..... PO(9'-11)
623	12'-5½		15.67	1.6820		14'-10	0.008313		
623	12'-5½			1.6820		67'-4		0.560	
								96.113	Total(Pt) Route 34



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
1184	11'-1½			1½	(See Notes)	112'-11	120	99.571	***** Route 35 ***** PO(9'-11)
1287	11'-1½		0.07	1.6820		24'-9	0.000000		
						137'-8		0.000	
								99.571	Total(Pt) Route 35
585	12'-5½		101.51	2½	(See Notes)	13'-8½	120	95.189	***** Route 36 ***** 2T(16'-5½), C(16'-5½), Flow (q) from Route 42 PO(16'-5½)
587	12'-5½		28.49	2.6350		65'-11	0.002823		
						79'-7		0.225	
								95.414	Total(Pt) Route 36
983	11'-1½			1½	(See Notes)	41'-2	120	99.571	***** Route 37 ***** T(9'-11)
1037	11'-1½		0.06	1.6820		24'-9	0.000000		
						65'-11		0.000	
								99.571	Total(Pt) Route 37
659	12'-5½			1½	(See Notes)	78'-3	120	98.200	***** Route 38 ***** T(9'-11)
789	11'-1½		15.13	1.6820		29'-8½	0.007788	0.578	
						107'-11½		0.841	
								99.619	Total(Pt) Route 38
957	11'-1½			1½	(See Notes)	100'-0	120	99.571	***** Route 39 ***** PO(9'-11)
971	11'-1½		0.08	1.6820		29'-8½	0.000001		
						129'-8½		0.000	
								99.571	Total(Pt) Route 39
796	11'-1½			1½	(See Notes)	168'-10	120	99.564	***** Route 40 ***** PO(9'-11)
805	11'-1½		0.82	1.6820		19'-9½	0.000035		
						188'-7½		0.007	
								99.571	Total(Pt) Route 40
565	12'-5½		27.91	2½		12'-8	120	95.451	***** Route 41 ***** Flow (q) from Route 1
568	12'-5½		48.18	2.6350		12'-8	0.007461		
								0.095	
								95.546	Total(Pt) Route 41
491	12'-5½		91.79	2½		1'-9	120	92.101	***** Route 42 ***** Flow (q) from Route 46
492	12'-5½		89.19	2.6350		1'-9	0.023309		
								0.041	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
							Friction(Pf)		
492	12'-5½			2½	(See Notes)	6'-2	120	92.142	2T(16'-5½)
493	12'-5½		88.36	2.6350		32'-11½	0.022909		
						39'-1½		0.896	
493	12'-5½		13.15	2½	(See Notes)	23'-3	120	93.038	Flow (q) from Route 43 2T(16'-5½), C(16'-5½)
585	12'-5½		101.51	2.6350		49'-5	0.029614		
						72'-8		2.152	
								95.189	Total(Pt) Route 42
491	12'-5½		91.79	1½	(See Notes)	123'-3	120	92.101	***** Route 43 ***** PO(9'-11), Flow (q) from Route 46 PO(9'-11)
41	12'-5½		2.60	1.6820		19'-9½	0.000300		
						143'-1		0.043	
41	12'-5½		9.72	2		1'-9	120	92.144	Flow (q) from Route 44
42	12'-5½		12.32	2.1570		1'-9	0.001587	0.003	
42	12'-5½		0.83	2	(See Notes)	20'-3½	120	92.147	Flow (q) from Route 47 PO(12'-3½)
43	12'-5½		13.15	2.1570		12'-3½	0.001791		
						32'-7		0.058	
43	12'-5½			1½	(See Notes)	123'-3	120	92.205	PO(9'-11)
494	12'-5½		13.15	1.6820		9'-11	0.006013		
						133'-2		0.801	
494	12'-5½			2½	(See Notes)	14'-1½	120	93.006	2T(16'-5½)
493	12'-5½		13.15	2.6350		32'-11½	0.000676		
						47'-0½		0.032	
								93.038	Total(Pt) Route 43
38	12'-5½		12.58	2		13'-1½	120	92.131	***** Route 44 ***** Flow (q) from Route 8
41	12'-5½		9.72	2.1570			0.001023		
						13'-1½		0.013	
								92.144	Total(Pt) Route 44
29	12'-5½		2.22	2	(See Notes)	20'-6	120	92.171	***** Route 45 ***** Flow (q) from Route 7 PO(12'-3½)
24	12'-5½		13.66	2.1570		12'-3½	0.001919		
						32'-9½		0.063	
24	12'-5½			1½	(See Notes)	123'-3	120	92.234	PO(9'-11)
462	12'-5½		13.66	1.6820		9'-11	0.006445		
						133'-2		0.858	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
462	12'-5½			2½	(See Notes)	14'-11½	120	93.093	2T(16'-5½)
463	12'-5½		13.66	2.6350		32'-11½	0.000724		
						47'-11		0.035	
								93.127	Total(Pt) Route 45
482	12'-5½		99.67	2½	(See Notes)	20'-6	120	89.418	***** Route 46 ***** Flow (q) from Route 1 2T(16'-5½)
480	12'-5½		106.11	2.6350		32'-11½	0.032147		
						53'-5½		1.719	
480	12'-5½		14.32	2½	(See Notes)	14'-6½	120	91.137	Flow (q) from Route 8 3E(8'-3)
491	12'-5½		91.79	2.6350		24'-8½	0.024583		
						39'-3		0.964	
								92.101	Total(Pt) Route 46
492	12'-5½			1½	(See Notes)	123'-3	120	92.142	***** Route 47 ***** PO(9'-11) PO(9'-11)
42	12'-5½		0.83	1.6820		19'-9½	0.000036		
						143'-1		0.005	
								92.147	Total(Pt) Route 47
465	12'-5½			1½	(See Notes)	123'-3	120	92.165	***** Route 48 ***** PO(9'-11) PO(9'-11)
30	12'-5½		0.55	1.6820		19'-9½	0.000017		
						143'-1		0.002	
								92.167	Total(Pt) Route 48

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51


**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BalV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connectic	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# Hydraulic Overview

Job Number: B22243  
Report Description: Light Hazard (B)

Job	
Job Number <b>B22243</b>	Designer <b>BKB</b>
Job Name: <b>OVERHILLS ELEMENTARY</b>	Phone <b>919.243.2464</b>
Address 1 <b>2626 RAY ROAD</b>	State Certification/License Number <b>16269FS</b>
Address 2 <b>SPRING LAKE, NC 28390</b>	AHJ <b>HARNETT CO</b>
Address 3	Job Site/Building <b>HARNETT CO SCHOOLS</b>


FAX  


System	
Density <b>0.10 gpm/ft<sup>2</sup></b>	Area of Application <b>1500 ft<sup>2</sup> (Actual 1589 ft<sup>2</sup>)</b>
Most Demanding Sprinkler Data <b>8 K-Factor 32.98 at 17.000</b>	Hose Streams <b>100.00</b>
Coverage Per Sprinkler <b>324 ft<sup>2</sup></b>	Number Of Sprinklers Calculated <b>8</b>
System Pressure Demand <b>56.241</b>	System Flow Demand <b>274.59</b>
Total Demand <b>374.59 @ 56.241</b>	Pressure Result <b>+69.803 (55.4%)</b>

Supplies						Check Point Gauges			
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	776.00	100.00	138.000	92.000	BOR (1069)	54.023	37.36	274.59
1	Pump	750.00		96.000	80.000				

Pumps: Static = Churn (Pressure @ Zero Flow)

**PIPING** Water Supply at Node 1 (776.00, 0.00, 138.000, 92.000)



# Hydraulic Calculations

for

Project Name: OVERHILLS ELEMENTARY  
Location: 2626 RAY ROAD, SPRING LAKE, NC 28390,  
Drawing Name: PIPING

Calculation Date: 4/19/2023

## Design

Remote Area Number: B  
Remote Area Location: CLASSROOMS  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density 0.10 gpm/ft<sup>2</sup>  
Area of Application: 1500 ft<sup>2</sup> (Actual 1589 ft<sup>2</sup>)  
Coverage per Sprinkler: 324 ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 8  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 374.59 @ 56.241 (Safety Margin = 69.803)  
from Pump at Node: 1: 274.59 @ 56.241 (Safety Margin = 69.803)  
Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherA N/A

Name of Contractor:  
Address:  
Phone Number:  
Name of designer: BKB  
Authority Having Jurisdiction: HARNETT CO

## Notes:

Automatic peaking results Left: 55.261 Right: N/A

---

---


---

# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: B

N<sup>1.85</sup>

Date: 4/19/2023




# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: B

N<sup>1.85</sup>

Date: 4/19/2023



**Pump Rating: 750.00 @ 80.000**

**Supply: Static: 138.000**  
**Residual: 92.000**  
**Flowing: 776.00**





# Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	2325	34.66	32.98	8	18.766			
Sprinkler	2326	34.51	32.98	8	18.612			
Sprinkler	2334	33.89	32.98	8	17.947			
Sprinkler	2337	34.60	32.98	8	18.702			
Sprinkler	2338	34.47	32.98	8	18.565			
⇒ Sprinkler	<b>2344</b>	<b>32.98</b>	<b>32.98</b>	<b>8</b>	<b>17.000</b>			
Sprinkler	2350	34.78	32.98	8	18.906			
Sprinkler	2351	34.69	32.98	8	18.804			

⇒ Most Demanding Sprinkler Data

<b>Supply Analysis</b>							
Node	Name	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	138.000	92.000	776.00	126.044	374.59	56.241

<b>Pump Analysis</b>						
Node	Churn (psi)	Residual @ (psi)	Flow (gpm)	Available @ (psi)	Total Demand (gpm)	Required Pressure (psi)
1	96.000	80.000	750.00	126.044	274.59	56.241

<b>Node Analysis</b>					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	1'-2½	Supply	56.241	274.59	P2
2325	9'-4	Sprinkler	18.766	34.66	
2326	9'-4	Sprinkler	18.612	34.51	
2334	8'-8½	Sprinkler	17.947	33.89	
2337	9'-4	Sprinkler	18.702	34.60	
2338	9'-4	Sprinkler	18.565	34.47	
2344	8'-8½	Sprinkler	17.000	32.98	
2350	9'-4	Sprinkler	18.906	34.78	
2351	9'-4	Sprinkler	18.804	34.69	
22	1'-2½		55.629		
24	12'-5½		29.148		
29	12'-5½		28.940		
30	12'-5½		28.909		
31	12'-5½		28.425		
38	12'-5½		25.843		
41	12'-5½		24.602		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
42	12'-5½		24.489		
43	12'-5½		24.140		
128	12'-5½		22.476		
132	12'-5½		22.301		
156	12'-5½		24.058		
170	12'-5½		22.394		
174	12'-5½		22.243		
179	12'-5½		24.119		
207	12'-5½		22.649		
211	12'-5½		22.541		
340	20'-0		26.325		
349	20'-0		26.044		
462	12'-5½		31.977		
463	12'-5½		32.091		
464	12'-5½		30.907		
465	12'-5½		30.872		
469	12'-5½		30.400		
480	12'-5½		29.984		
490	20'-0		27.120		
491	12'-5½		29.901		
492	12'-5½		29.906		
493	12'-5½		30.758		
494	12'-5½		30.248		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
497	20'-0		26.655		
563	12'-5½		35.543		
564	12'-5½		35.476		
565	12'-5½		35.565		
568	12'-5½		35.686		
571	12'-5½		35.695		
575	12'-5½		35.679		
576	12'-5½		35.693		
577	12'-5½		35.554		
583	12'-5½		35.465		
585	12'-5½		34.916		
587	12'-5½		35.307		
620	12'-5½		36.599		
623	12'-5½		36.614		
658	12'-5½		39.935		
659	12'-5½		40.188		
738	11'-1½		42.084		
774	11'-1½		42.118		
785	11'-1½		42.172		
787	11'-1½		42.279		
788	11'-1½		42.136		
789	11'-1½		42.195		
796	11'-1½		42.100		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
805	11'-1½		42.112		
810	11'-1½		43.054		
812	11'-1½		43.067		
813	11'-1½		42.471		
815	11'-1½		42.343		
825	11'-1½		42.112		
884	11'-1½		42.112		
899	11'-1½		42.112		
938	11'-1½		42.112		
949	11'-1½		42.112		
957	11'-1½		42.112		
971	11'-1½		42.112		
980	11'-1½		42.112		
983	11'-1½		42.112		
1037	11'-1½		42.112		
1069	3'-7½	Gauge	54.023		
1071	4'-2½		53.523		
1097	11'-1½		42.112		
1184	11'-1½		42.112		
1215	11'-1½		42.112		
1275	11'-1½		42.112		
1278	11'-1½		42.112		
1287	11'-1½		42.112		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1295	11'-1½		42.112		
1349	11'-1½		42.112		
1359	11'-1½		42.112		
1457	11'-1½		42.112		
1470	11'-1½		42.112		
1550	11'-1½		42.112		
1561	11'-1½		42.112		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
2344	8'-8½	8	32.98	1	(See Notes)	11'-7½	120	17.000	••••• Route 1 ••••• Sprinkler, 5E(2'-0), PO(5'-0)
179	12'-5½		32.98	1.0490		15'-0	0.328366	-1.618	
						26'-7½		8.737	
179	12'-5½		13.45	1½	(See Notes)	83'-4	120	24.119	Flow (q) from Route 45 PO(9'-11)
491	12'-5½		46.43	1.6820		9'-11	0.062019		
						93'-2½		5.782	
491	12'-5½			2½	(See Notes)	14'-6½	120	29.901	3E(8'-3), 2T(16'-5½)
480	12'-5½		17.52	2.6350		57'-8	0.001148		
						72'-2		0.083	
480	12'-5½		20.89	2½	(See Notes)	51'-10	120	29.984	Flow (q) from Route 9 2T(16'-5½)
469	12'-5½		38.41	2.6350		32'-11½	0.004905		
						84'-9		0.416	
469	12'-5½		24.12	2½	(See Notes)	14'-5	120	30.400	Flow (q) from Route 10 3E(8'-3)
465	12'-5½		62.53	2.6350		24'-8½	0.012083		
						39'-1½		0.473	
465	12'-5½		20.55	2½		1'-8½	120	30.872	Flow (q) from Route 2
464	12'-5½		83.08	2.6350			0.020440		
						1'-8½		0.035	
464	12'-5½		20.57	2½	(See Notes)	5'-6½	120	30.907	Flow (q) from Route 42 2T(16'-5½)
463	12'-5½		103.64	2.6350		32'-11½	0.030775		
						38'-6		1.184	
463	12'-5½		26.02	2½	(See Notes)	23'-3	120	32.091	Flow (q) from Route 43 2T(16'-5½), C(16'-5½)
564	12'-5½		129.66	2.6350		49'-5	0.046577		
						72'-8		3.384	
564	12'-5½			2½		3'-7	120	35.476	
565	12'-5½		92.29	2.6350			0.024831		
						3'-7		0.089	
565	12'-5½			1½	(See Notes)	130'-4½	120	35.565	PO(9'-11) E(4'-11½), PO(9'-11)
813	11'-1½		37.02	1.6820		24'-9	0.040789	0.578	
						155'-1½		6.328	
813	11'-1½		200.19	4	(See Notes)	17'-2	120	42.471	Flow (q) from Route 7 T(26'-4)
812	11'-1½		237.21	4.2600		26'-4	0.013723		
						43'-6		0.597	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot) Total (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe) Friction(Pf)	Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
812	11'-1½		37.37	4	(See Notes)	264'-7	120	43.067	Flow (q) from Route 23 6E(13'-2), T(26'-4), f, sCV(28'-1½), BV(15'-9½)
1071	4'-2½		274.59	4.2600		150'-1½	0.017988	2.996	
						414'-8½		7.460	
1071	4'-2½			4	(See Notes)	0'-0	120	53.523	E(10'-0), BOR
1069	3'-7½		274.59	4.0260		10'-0	0.023685	0.263	
						10'-0		0.237	
1069	3'-7½			4	(See Notes)	3'-11	120	54.023	T(20'-0)
22	1'-2½		274.59	4.0260		20'-0	0.023685	1.040	
						23'-11		0.566	
22	1'-2½			6	(See Notes)	211'-5½	140	55.629	3E(22'-1), 2EE(11'-0½)
1	1'-2½		274.59	6.2800		88'-3	0.002043	0.000	
						299'-8½		0.612	
			100.00					56.241	Hose Allowance At Source
1			374.59						Total(Pt) Route 1
2334	8'-8½	8	33.89	1	(See Notes)	9'-4½	120	17.947	••••• Route 2 ••••• Sprinkler, 4E(2'-0), PO(5'-0)
156	12'-5½		33.89	1.0490		13'-0	0.345243	-1.618	
						22'-4½		7.729	
156	12'-5½			1½	(See Notes)	30'-2	120	24.058	PO(9'-11)
41	12'-5½		20.44	1.6820		9'-11	0.013594	0.545	
						40'-0½			
41	12'-5½		91.70	2		13'-1½	120	24.602	Flow (q) from Route 3
38	12'-5½		112.14	2.1570		13'-1½	0.094382	1.240	
38	12'-5½			2		47'-6½	120	25.843	
31	12'-5½		83.20	2.1570		47'-6½	0.054332	2.582	
31	12'-5½			2		13'-3	120	28.425	
30	12'-5½		67.14	2.1570		13'-3	0.036532	0.484	
30	12'-5½			1½	(See Notes)	123'-3	120	28.909	PO(9'-11)
465	12'-5½		20.55	1.6820		19'-9½	0.013725		PO(9'-11)
						143'-1		1.964	



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes  Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
								Friction(Pf)	
								30.872	Total(Pt) Route 2
2338	9'-4	8	34.47	1	(See Notes)	5'-1½	120	18.565	***** Route 3 ***** Sprinkler, 2E(2'-0), PO(5'-0)
174	12'-5½		34.47	1.0490		9'-0	0.356232	-1.347	
						14'-1½		5.025	
174	12'-5½			1½	(See Notes)	15'-4½	120	22.243	Flow (q) from Route 4 PO(9'-11)
132	12'-5½		10.21	1.6820		15'-4½	0.003766	0.058	
132	12'-5½		34.51	1½	(See Notes)	21'-10½	120	22.301	Flow (q) from Route 5 PO(9'-11)
43	12'-5½		44.73	1.6820		9'-11	0.057869	1.839	
						31'-9½			
43	12'-5½			2	(See Notes)	20'-3½	120	24.140	Flow (q) from Route 5
42	12'-5½		44.73	2.1570		20'-3½	0.017233	0.349	
42	12'-5½		46.97	2	(See Notes)	1'-9	120	24.489	Flow (q) from Route 5
41	12'-5½		91.70	2.1570		1'-9	0.065044	0.113	
								24.602	Total(Pt) Route 3
2326	9'-4	8	34.51	1	(See Notes)	5'-1	120	18.612	***** Route 4 ***** Sprinkler, 2E(2'-0), PO(5'-0)
132	12'-5½		34.51	1.0490		9'-0	0.357075	-1.347	
						14'-1		5.035	
								22.301	Total(Pt) Route 4
2337	9'-4	8	34.60	1	(See Notes)	5'-0½	120	18.702	***** Route 5 ***** Sprinkler, 2E(2'-0), PO(5'-0)
170	12'-5½		34.60	1.0490		9'-0	0.358663	-1.347	
						14'-0½		5.039	
170	12'-5½			1½	(See Notes)	15'-4½	120	22.394	Flow (q) from Route 6 PO(9'-11)
128	12'-5½		12.32	1.6820		15'-4½	0.005327	0.082	
128	12'-5½		34.66	1½	(See Notes)	21'-10½	120	22.476	Flow (q) from Route 6 PO(9'-11)
42	12'-5½		46.97	1.6820		9'-11	0.063363	2.014	
						31'-9½			
								24.489	Total(Pt) Route 5

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
2325	9'-4	8	34.66	1	(See Notes)	5'-0½	120	18.766	***** Route 6 ***** Sprinkler, 2E(2'-0), PO(5'-0)
						9'-0	0.359803	-1.347	
128	12'-5½		34.66	1.0490		14'-0½		5.056	
								22.476	Total(Pt) Route 6
2351	9'-4	8	34.69	1	(See Notes)	5'-1½	120	18.804	***** Route 7 ***** Sprinkler, 2E(2'-0), PO(5'-0)
						9'-0	0.360467	-1.347	
211	12'-5½		34.69	1.0490		14'-1½		5.085	
211	12'-5½		24.26	1½	(See Notes)	70'-0	120	22.541	Flow (q) from Route 46 PO(9'-11)
						9'-11	0.096432		
494	12'-5½		58.95	1.6820		79'-11		7.707	
494	12'-5½			2½	(See Notes)	14'-1½	120	30.248	2T(16'-5½)
						32'-11½	0.010834		
493	12'-5½		58.95	2.6350		47'-0½		0.510	
493	12'-5½		85.98	2½	(See Notes)	23'-3	120	30.758	Flow (q) from Route 8 2T(16'-5½), C(16'-5½)
						49'-5	0.057220		
585	12'-5½		144.92	2.6350		72'-8		4.158	
585	12'-5½			2½	(See Notes)	16'-11½	120	34.916	
							0.032355		
583	12'-5½		106.49	2.6350		16'-11½		0.549	
583	12'-5½			2½	(See Notes)	5'-11	120	35.465	
							0.014995		
577	12'-5½		70.27	2.6350		5'-11		0.089	
577	12'-5½			2½	(See Notes)	19'-0	120	35.554	
							0.006615		
575	12'-5½		45.15	2.6350		19'-0		0.126	
575	12'-5½			2½	(See Notes)	6'-7	120	35.679	
							0.002130		
576	12'-5½		24.47	2.6350		6'-7		0.014	
576	12'-5½			2½	(See Notes)	18'-3	120	35.693	
							0.000075		
571	12'-5½		4.01	2.6350		18'-3		0.001	
571	12'-5½		19.04	1½	(See Notes)	33'-6	120	35.695	PO(9'-11), Flow (q) from Route 40 T(9'-11)
						19'-9½	0.016983		
620	12'-5½		23.06	1.6820		53'-3½		0.905	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
620	12'-5½		20.46	1½	(See Notes)	45'-5½	120	36.599	Flow (q) from Route 21 2E(4'-11½), T(9'-11)
659	12'-5½		43.51	1.6820		19'-9½	0.054991		
						65'-3		3.589	
659	12'-5½			1½	(See Notes)	62'-1½	120	40.188	3E(4'-11½), PO(9'-11)
787	11'-1½		23.37	1.6820		24'-9	0.017408	0.578	
						86'-10½		1.513	
787	11'-1½		140.60	4		9'-4	120	42.279	Flow (q) from Route 12
815	11'-1½		163.96	4.2600		9'-4	0.006930	0.065	
815	11'-1½		36.23	4		12'-8	120	42.343	Flow (q) from Route 39
813	11'-1½		200.19	4.2600		12'-8	0.010025	0.127	
								42.471	Total(Pt) Route 7
2350	9'-4	8	34.78	1	(See Notes)	5'-0½	120	18.906	••••• Route 8 ••••• Sprinkler, 2E(2'-0), PO(5'-0)
207	12'-5½		34.78	1.0490		9'-0	0.362283	-1.347	
						14'-0½		5.090	
207	12'-5½		22.28	1½	(See Notes)	70'-0	120	22.649	Flow (q) from Route 44 PO(9'-11)
492	12'-5½		57.06	1.6820		9'-11	0.090808	7.257	
						79'-11			
492	12'-5½		28.91	2½	(See Notes)	6'-2	120	29.906	Flow (q) from Route 41 2T(16'-5½)
493	12'-5½		85.98	2.6350		32'-11½	0.021779		
						39'-1½		0.852	
								30.758	Total(Pt) Route 8
38	12'-5½			1½	(See Notes)	109'-5½	120	25.843	••••• Route 9 ••••• PO(9'-11) 3E(4'-11½)
349	20'-0		28.94	1.6820		24'-9	0.025864	-3.270	
						134'-2½		3.471	
349	20'-0			1½	(See Notes)	28'-0	120	26.044	E(4'-11½), PO(9'-11)
497	20'-0		20.89	1.6820		14'-10	0.014148	0.005	
						42'-10		0.606	
497	20'-0			2½	(See Notes)	7'-6½	120	26.655	2T(16'-5½)
480	12'-5½		20.89	2.6350		32'-11½	0.001589	3.265	
						40'-5½		0.064	
								29.984	Total(Pt) Route 9

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value	
										Node 2
31	12'-5½			1½	(See Notes)	109'-7	120	28.425		
340	20'-0		16.07	1.6820		24'-9	0.008706	-3.270		
						134'-4		1.170		
340	20'-0		8.05	1½	(See Notes)	27'-11	120	26.325	Flow (q) from Route 11 E(4'-11½), PO(9'-11)	
490	20'-0		24.12	1.6820		14'-10	0.018462	0.005		
						42'-9½		0.790		
490	20'-0			2½		7'-6½	120	27.120		
469	12'-5½		24.12	2.6350			0.002074	3.265		
						7'-6½		0.016		
								30.400	Total(Pt) Route 10	
349	20'-0			1½	(See Notes)	56'-4	120	26.044	..... Route 11 ..... 2T(9'-11), C(9'-11) 2T(9'-11), C(9'-11)	
340	20'-0		8.05	1.6820		59'-5	0.002427			
						115'-9		0.281		
								26.325	Total(Pt) Route 11	
971	11'-1½		0.08 + 0.11	1½	(See Notes)	52'-2	120	42.112	..... Route 12 ..... Flow (q) from Route 28 and 37 2E(4'-11½), T(9'-11)	
983	11'-1½		0.19	1.6820		19'-9½	0.000002			
						71'-11½		0.000		
983	11'-1½			1½	(See Notes)	32'-8	120	42.112	PO(9'-11)	
980	11'-1½		0.11	1.6820		9'-11	0.000001			
						42'-7		0.000		
980	11'-1½		0.64	4		10'-2	120	42.112	Flow (q) from Route 13	
949	11'-1½		0.75	4.2600			0.000000			
						10'-2		0.000		
949	11'-1½		0.17	4		16'-8	120	42.112	Flow (q) from Route 27	
899	11'-1½		0.92	4.2600			0.000000			
						16'-8		0.000		
899	11'-1½		0.19	4	(See Notes)	13'-2½	120	42.112	Flow (q) from Route 29 T(26'-4)	
825	11'-1½		1.11	4.2600		26'-4	0.000001			
						39'-6½		0.000		
825	11'-1½		37.33	4		12'-11	120	42.112	Flow (q) from Route 31	
774	11'-1½		38.44	4.2600			0.000473			
						12'-11		0.006		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot) Total (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe) Friction(Pf)	Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
774	11'-1½		36.22	4		10'-9	120	42.118	Flow (q) from Route 22
788	11'-1½		74.65	4.2600		10'-9	0.001616	0.017	
788	11'-1½		22.70	4		13'-11	120	42.136	Flow (q) from Route 15
785	11'-1½		97.35	4.2600		13'-11	0.002642	0.037	
785	11'-1½		23.10	4		5'-8	120	42.172	Flow (q) from Route 16
789	11'-1½		120.45	4.2600		5'-8	0.003917	0.022	
789	11'-1½		20.15	4		16'-2	120	42.195	Flow (q) from Route 36
787	11'-1½		140.60	4.2600		16'-2	0.005214	0.084	
								42.279	Total(Pt) Route 12
1457	11'-1½		0.26	1½	(See Notes)	168'-10	120	42.112	••••• Route 13 ••••• PO(9'-11), Flow (q) from Route 25 PO(9'-11)
1470	11'-1½		0.13	1.6820		19'-9½	0.000001	0.000	
1470	11'-1½		0.13	4		188'-7½			
1470	11'-1½		0.13	4		16'-8	120	42.112	Flow (q) from Route 14
1359	11'-1½		0.26	4.2600		16'-8	0.000000	0.000	
1359	11'-1½		0.13	4		10'-2	120	42.112	Flow (q) from Route 24
1275	11'-1½		0.39	4.2600		10'-2	0.000000	0.000	
1275	11'-1½		0.10	4		8'-6	120	42.112	Flow (q) from Route 18
1215	11'-1½		0.48	4.2600		8'-6	0.000000	0.000	
1215	11'-1½		0.08	4		18'-6	120	42.112	Flow (q) from Route 19
1037	11'-1½		0.56	4.2600		18'-6	0.000000	0.000	
1037	11'-1½		0.08	4		8'-6	120	42.112	Flow (q) from Route 35
980	11'-1½		0.64	4.2600		8'-6	0.000000	0.000	
								42.112	Total(Pt) Route 13

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
1457	11'-1½		0.26	2½		14'-0	120	42.112	***** Route 14 ***** Flow (q) from Route 25
1550	11'-1½		0.13	2.6350		14'-0	0.000000	0.000	
1550	11'-1½			1½	(See Notes)	168'-10	120	42.112	PO(9'-11)
1561	11'-1½		0.13	1.6820		19'-9½	0.000001		PO(9'-11)
						188'-7½		0.000	
1561	11'-1½			4		14'-0	120	42.112	
1470	11'-1½		0.13	4.2600		14'-0	0.000000	0.000	
								42.112	Total(Pt) Route 14
658	12'-5½		45.80	1½	(See Notes)	63'-8½	120	39.935	***** Route 15 ***** T(9'-11), Flow (q) from Route 17 3E(4'-11½), PO(9'-11)
788	11'-1½		22.70	1.6820		34'-8	0.016499	0.578	
						98'-4½		1.623	
								42.136	Total(Pt) Route 15
658	12'-5½		45.80	1½	(See Notes)	77'-7	120	39.935	***** Route 16 ***** Flow (q) from Route 17 2E(4'-11½), PO(9'-11)
785	11'-1½		23.10	1.6820		19'-9½	0.017044	0.578	
						97'-4½		1.660	
								42.172	Total(Pt) Route 16
577	12'-5½			1½	(See Notes)	33'-6	120	35.554	***** Route 17 ***** PO(9'-11)
623	12'-5½		25.12	1.6820		19'-9½	0.019902	1.060	
623	12'-5½		20.68	1½	(See Notes)	53'-3½		120	36.614
658	12'-5½		45.80	1.6820		45'-0½	0.060457	3.320	
					9'-11				
					54'-11				
								39.935	Total(Pt) Route 17
1278	11'-1½		0.17	1½	(See Notes)	32'-8½	120	42.112	***** Route 18 ***** Flow (q) from Route 20 PO(9'-11)
1275	11'-1½		0.10	1.6820		9'-11	0.000001	0.000	
						42'-7½			
								42.112	Total(Pt) Route 18
1278	11'-1½		0.17	1½	(See Notes)	41'-2½	120	42.112	***** Route 19 ***** T(9'-11), Flow (q) from Route 20 E(4'-11½), PO(9'-11)
1215	11'-1½		0.08	1.6820		24'-9	0.000000	0.000	
						65'-11½			
								42.112	Total(Pt) Route 19

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)			Friction(Pf)				
1287	11'-1½		0.08 + 0.09	1½	(See Notes)	51'-4½	120	42.112	
1278	11'-1½		0.17	1.6820		19'-9½	0.000002		
						71'-2		0.000	
								42.112	Total(Pt) Route 20
576	12'-5½			1½	(See Notes)	51'-9	120	35.693	***** Route 21 ***** PO(9'-11) E(4'-11½)
620	12'-5½		20.46	1.6820		14'-10	0.013611		
						66'-7		0.906	
								36.599	
583	12'-5½			1½	(See Notes)	130'-4½	120	35.465	***** Route 22 ***** PO(9'-11) E(4'-11½), PO(9'-11)
774	11'-1½		36.22	1.6820		24'-9	0.039163	0.578	
						155'-1½		6.076	
								42.118	
564	12'-5½		92.29	2½		14'-5	120	35.476	***** Route 23 ***** Flow (q) from Route 1
563	12'-5½		37.37	2.6350		14'-5	0.004663	0.067	
563	12'-5½			1½		(See Notes)		132'-4½	
810	11'-1½		37.37	1.6820	34'-8		0.041506	0.578	
					167'-0½			6.933	
810	11'-1½			4	(See Notes)	2'-10	120	43.054	T(26'-4)
812	11'-1½		37.37	4.2600		26'-4	0.000449		
						29'-2		0.013	
								43.067	
1295	11'-1½			2½		6'-1	120	42.112	***** Route 24 *****
1349	11'-1½		0.39	2.6350		6'-1	0.000001	0.000	
1349	11'-1½			1½		(See Notes)		168'-10	
1359	11'-1½		0.13	1.6820	19'-9½		0.000001		
					188'-7½			0.000	
								42.112	Total(Pt) Route 24
1349	11'-1½		0.13	2½		16'-8	120	42.112	***** Route 25 ***** Flow (q) from Route 24
1457	11'-1½		0.26	2.6350		16'-8	0.000000	0.000	
								42.112	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
	Node 2		Elev 2 (Foot)	Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	
Total (Foot)		Friction(Pf)							
1097	11'-1½			2½		8'-8	120	42.112	
1184	11'-1½		0.56	2.6350		8'-8	0.000002	0.000	
1184	11'-1½			2½		16'-9	120	42.112	
1295	11'-1½		0.47	2.6350		16'-9	0.000001	0.000	
1295	11'-1½			1½	(See Notes)	99'-6	120	42.112	PO(9'-11)
1287	11'-1½		0.08	1.6820		34'-8	0.000000		E(4'-11½), 2T(9'-11)
						134'-2		0.000	
								42.112	Total(Pt) Route 26
938	11'-1½		0.92	1½	(See Notes)	168'-10	120	42.112	***** Route 27 ***** PO(9'-11), Flow (q) from Route 30 PO(9'-11)
949	11'-1½		0.17	1.6820		19'-9½	0.000002		
						188'-7½		0.000	
								42.112	Total(Pt) Route 27
938	11'-1½		0.92	2½		6'-4	120	42.112	***** Route 28 ***** Flow (q) from Route 30
957	11'-1½		0.75	2.6350		6'-4	0.000003	0.000	
957	11'-1½			2½		18'-0	120	42.112	
1097	11'-1½		0.64	2.6350		18'-0	0.000003	0.000	
1097	11'-1½			1½	(See Notes)	121'-3½	120	42.112	PO(9'-11)
971	11'-1½		0.08	1.6820		44'-6½	0.000000		7E(4'-11½)
						165'-10		0.000	
								42.112	Total(Pt) Route 28
805	11'-1½		1.11	2½		14'-1	120	42.112	***** Route 29 ***** Flow (q) from Route 38
884	11'-1½		1.11	2.6350		14'-1	0.000007	0.000	
884	11'-1½			1½	(See Notes)	168'-10	120	42.112	
899	11'-1½		0.19	1.6820		19'-9½	0.000002		PO(9'-11)
						188'-7½		0.000	
								42.112	Total(Pt) Route 29



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
884	11'-1½		0.19	2½		16'-8	120	42.112	••••• Route 30 ••••• Flow (q) from Route 29
938	11'-1½		0.92	2.6350		16'-8	0.000005	0.000	
								42.112	
587	12'-5½		38.44	1½	(See Notes)	126'-11½	120	35.307	••••• Route 31 ••••• Flow (q) from Route 34 E(4'-11½), PO(9'-11)
738	11'-1½		38.44	1.6820		14'-10	0.043718	0.578	
738	11'-1½			4		141'-9½		6.199	
796	11'-1½		38.44	4.2600	(See Notes)	19'-11	120	42.084	E(13'-2)
796	11'-1½			4		13'-2	0.000473		
825	11'-1½		37.33	4.2600		33'-1		0.016	
796	11'-1½			4	(See Notes)	0'-10½	120	42.100	T(26'-4)
825	11'-1½					26'-4	0.000448		
						27'-2½		0.012	
								42.112	Total(Pt) Route 31
575	12'-5½			1½	(See Notes)	52'-5½	120	35.679	••••• Route 32 ••••• PO(9'-11) E(4'-11½)
623	12'-5½		20.68	1.6820		14'-10	0.013886		
						67'-4		0.935	
								36.614	Total(Pt) Route 32
1184	11'-1½			1½	(See Notes)	112'-11	120	42.112	••••• Route 33 ••••• PO(9'-11) 3E(4'-11½)
1287	11'-1½		0.09	1.6820		24'-9	0.000001		
						137'-8		0.000	
								42.112	Total(Pt) Route 33
585	12'-5½			2½	(See Notes)	13'-8½	120	34.916	••••• Route 34 ••••• 2T(16'-5½), C(16'-5½) PO(16'-5½)
587	12'-5½		38.44	2.6350		65'-11	0.004912		
						79'-7		0.391	
								35.307	Total(Pt) Route 34
983	11'-1½			1½	(See Notes)	41'-2	120	42.112	••••• Route 35 ••••• T(9'-11) E(4'-11½), PO(9'-11)
1037	11'-1½		0.08	1.6820		24'-9	0.000001		
						65'-11		0.000	
								42.112	Total(Pt) Route 35
659	12'-5½			1½	(See Notes)	78'-3	120	40.188	••••• Route 36 ••••• T(9'-11) 2E(4'-11½), PO(9'-11)
789	11'-1½		20.15	1.6820		29'-8½	0.013232	0.578	
						107'-11½		1.428	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
								42.195	Total(Pt) Route 36
957	11'-1½			1½	(See Notes)	100'-0	120	42.112	••••• Route 37 ••••• PO(9'-11)  2E(4'-11½), T(9'-11)
971	11'-1½		0.11	1.6820		29'-8½	0.000001		
						129'-8½		0.000	
								42.112	Total(Pt) Route 37
796	11'-1½			1½	(See Notes)	168'-10	120	42.100	••••• Route 38 ••••• PO(9'-11)  PO(9'-11)
805	11'-1½		1.11	1.6820		19'-9½	0.000062		
						188'-7½		0.012	
								42.112	Total(Pt) Route 38
565	12'-5½		37.02	2½	(See Notes)	12'-8	120	35.565	••••• Route 39 ••••• Flow (q) from Route 1
568	12'-5½		55.27	2.6350		12'-8	0.009617	0.122	
568	12'-5½			1½		130'-4½		120	
815	11'-1½		36.23	1.6820	(See Notes)	24'-9	0.039185	0.578	PO(9'-11) E(4'-11½), PO(9'-11)
						155'-1½		6.079	
								42.343	Total(Pt) Route 39
568	12'-5½		36.23	2½	(See Notes)	6'-1	120	35.686	••••• Route 40 ••••• Flow (q) from Route 39
571	12'-5½		19.04	2.6350		6'-1	0.001339	0.008	
								35.695	Total(Pt) Route 40
491	12'-5½		17.52	2½	(See Notes)	1'-9	120	29.901	••••• Route 41 ••••• Flow (q) from Route 1
492	12'-5½		28.91	2.6350		1'-9	0.002901	0.005	
								29.906	Total(Pt) Route 41
30	12'-5½		20.55	2	(See Notes)	1'-8½	120	28.909	••••• Route 42 ••••• Flow (q) from Route 2
29	12'-5½		46.59	2.1570		1'-8½	0.018583	0.031	
29	12'-5½			1½		123'-3		120	
464	12'-5½		20.57	1.6820	(See Notes)	19'-9½	0.013747	1.967	PO(9'-11) PO(9'-11)
						143'-1			
								30.907	Total(Pt) Route 42

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
29	12'-5½		20.57	2	(See Notes)	20'-6	120	28.940	••••• Route 43 ••••• Flow (q) from Route 42  PO(12'-3½)
24	12'-5½		26.02	2.1570		12'-3½	0.006327		
						32'-9½		0.208	
24	12'-5½			1½	(See Notes)	123'-3	120	29.148	PO(9'-11)
462	12'-5½		26.02	1.6820		9'-11	0.021245		
						133'-2		2.829	
462	12'-5½			2½	(See Notes)	14'-11½	120	31.977	2T(16'-5½)
463	12'-5½		26.02	2.6350		32'-11½	0.002387		
						47'-11		0.114	
								32.091	Total(Pt) Route 43
170	12'-5½		12.32	1½		16'-0	120	22.394	••••• Route 44 ••••• Flow (q) from Route 5
207	12'-5½		22.28	1.6820		16'-0	0.015938	0.255	
								22.649	
156	12'-5½		20.44	1½		9'-9½	120	24.058	••••• Route 45 ••••• Flow (q) from Route 2
179	12'-5½		13.45	1.6820		9'-9½	0.006266	0.061	
								24.119	
174	12'-5½		10.21	1½		16'-0	120	22.243	••••• Route 46 ••••• Flow (q) from Route 3
211	12'-5½		24.26	1.6820		16'-0	0.018655	0.298	
								22.541	

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**


ALV Alarm Valve	AngV Angle Valve	b Bushing
BalV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connectic	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
fg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		



# Hydraulic Overview

Job Number: B22243  
 Report Description: Light Hazard (C)

<b>Job</b>	
Job Number B22243	Designer BKB
Job Name: OVERHILLS ELEMENTARY	Phone 919.243.2464
Address 1 2626 RAY ROAD	State Certification/License Number 16269FS
Address 2 SPRING LAKE, NC 28390	AHJ HARNETT CO
Address 3	Job Site/Building HARNETT CO SCHOOLS




<b>System</b>	
Density 0.10 gpm/ft <sup>2</sup>	Area of Application 1500 ft <sup>2</sup> (Actual 903 ft <sup>2</sup> )
Most Demanding Sprinkler Data 8 K-Factor 32.98 at 17.000	Hose Streams 100.00
Coverage Per Sprinkler 324 ft <sup>2</sup>	Number Of Sprinklers Calculated 6 0
System Pressure Demand 58.323	System Flow Demand 201.42
Total Demand 301.42 @ 58.323	Pressure Result +71.679 (55.1%)

<b>Supplies</b>						<b>Check Point Gauges</b>			
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	776.00	100.00	138.000	92.000	BOR (1069)	56.618	26.77	201.42
1	Pump	750.00		96.000	80.000				

Pumps: Static = Churn (Pressure @ Zero Flow)

**PIPING** Water Supply at Node 1 (776.00, 0.00, 138.000, 92.000)



# Hydraulic Calculations

for

Project Name: OVERHILLS ELEMENTARY  
Location: 2626 RAY ROAD, SPRING LAKE, NC 28390,  
Drawing Name: PIPING

Calculation Date: 4/19/2023

## Design

Remote Area Number: C  
Remote Area Location: CLASSROOM  
Occupancy Classification: Light Hazard  
Commodity Classification: N/A

Density 0.10 gpm/ft<sup>2</sup>  
Area of Application: 1500 ft<sup>2</sup> (Actual 903 ft<sup>2</sup>)  
Coverage per Sprinkler: 324 ft<sup>2</sup>  
Type of sprinklers calculated: Pendent  
No. of sprinklers calculated: 6  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 100.00 at Node: 1 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):  
From Water Supply at Node 1: 301.42 @ 58.323 (Safety Margin = 71.679)  
from Pump at Node: 1: 201.42 @ 58.323 (Safety Margin = 71.679)  
Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherA N/A

Name of Contractor:  
Address:  
Phone Number:  
Name of designer: BKB  
Authority Having Jurisdiction: HARNETT CO

## Notes:

Automatic peaking results Left: 54.867 Right: 58.440

---

---


---

# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: C

N<sup>1.85</sup>

Date: 4/19/2023




Water Supply  
Summary Sheet  
Node: 1

# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: C

N 1.85

Date: 4/19/2023



**Pump Rating: 750.00 @ 80.000**

**Supply: Static: 138.000**  
**Residual: 92.000**  
**Flowing: 776.00**





# Summary Of Outflowing Devices

Job Number: B22243  
Report Description: Light Hazard (C)

Device	Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
⇒ Sprinkler 2361	32.98	32.98	8	17.000			
Sprinkler 2362	33.01	32.98	8	17.024			
Sprinkler 2371	33.29	32.98	8	17.320			
Sprinkler 2372	33.32	32.98	8	17.345			
Sprinkler 2385	34.39	32.98	8	18.482			
Sprinkler 2386	34.42	32.98	8	18.513			

⇒ Most Demanding Sprinkler Data

## Supply Analysis

Node	Name	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	138.000	92.000	776.00	130.002	301.42	58.323

## Pump Analysis

Node	Churn (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)
1	96.000	80.000	750.00	130.002	201.42	58.323

## Node Analysis

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	1'-2½	Supply	58.323	201.42	P2
2361	10'-0	Sprinkler	17.000	32.98	
2362	10'-0	Sprinkler	17.024	33.01	
2371	10'-0	Sprinkler	17.320	33.29	
2372	10'-0	Sprinkler	17.345	33.32	
2385	10'-0	Sprinkler	18.482	34.39	
2386	10'-0	Sprinkler	18.513	34.42	
22	1'-2½		57.978		
24	12'-5½		41.388		
29	12'-5½		41.329		
30	12'-5½		41.326		
31	12'-5½		41.313		
38	12'-5½		41.319		
41	12'-5½		41.349		
42	12'-5½		41.353		
43	12'-5½		41.410		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
259	12'-5		20.319		
262	12'-5½		20.260		
288	12'-5		20.714		
291	12'-5½		20.656		
324	12'-5		22.152		
327	12'-5½		22.095		
340	20'-0		37.314		
349	20'-0		37.369		
462	12'-5½		42.195		
463	12'-5½		42.228		
464	12'-5½		41.321		
465	12'-5½		41.280		
469	12'-5½		40.285		
478	12'-5½		38.946		
480	12'-5½		40.539		
481	12'-5½		38.942		
490	20'-0		37.043		
491	12'-5½		41.348		
492	12'-5½		41.384		
493	12'-5½		42.226		
494	12'-5½		42.195		
497	20'-0		37.282		
563	12'-5½		44.475		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
564	12'-5½		44.437		
565	12'-5½		44.498		
568	12'-5½		44.591		
571	12'-5½		44.602		
575	12'-5½		44.600		
576	12'-5½		44.603		
577	12'-5½		44.555		
583	12'-5½		44.517		
585	12'-5½		44.260		
587	12'-5½		44.476		
620	12'-5½		45.115		
623	12'-5½		45.139		
658	12'-5½		47.007		
659	12'-5½		47.145		
738	11'-1½		48.470		
774	11'-1½		48.488		
785	11'-1½		48.519		
787	11'-1½		48.578		
788	11'-1½		48.498		
789	11'-1½		48.531		
796	11'-1½		48.478		
805	11'-1½		48.485		
810	11'-1½		49.014		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
812	11'-1½		49.021		
813	11'-1½		48.686		
815	11'-1½		48.614		
825	11'-1½		48.485		
884	11'-1½		48.485		
899	11'-1½		48.485		
938	11'-1½		48.485		
949	11'-1½		48.485		
957	11'-1½		48.485		
971	11'-1½		48.485		
980	11'-1½		48.485		
983	11'-1½		48.485		
1037	11'-1½		48.485		
1069	3'-7½	Gauge	56.618		
1071	4'-2½		56.222		
1097	11'-1½		48.485		
1184	11'-1½		48.485		
1215	11'-1½		48.485		
1275	11'-1½		48.485		
1278	11'-1½		48.485		
1287	11'-1½		48.485		
1295	11'-1½		48.485		
1349	11'-1½		48.485		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1359	11'-1½		48.485		
1457	11'-1½		48.485		
1470	11'-1½		48.485		
1550	11'-1½		48.485		
1561	11'-1½		48.485		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	
Friction(Pf)									
2361	10'-0	8	32.98	1	(See Notes)	4'-3½	120	17.000	••••• Route 1 ••••• Sprinkler, 2E(2'-0), PO(5'-0)
259	12'-5		32.98	1.0490		9'-0	0.328366	-1.040	
						13'-3½		4.359	
259	12'-5			1½		12'-0	120	20.319	
288	12'-5		32.98	1.6820		12'-0	0.032943	0.395	
288	12'-5		33.29	1½		12'-0	120	20.714	
324	12'-5		66.28	1.6820	12'-0	0.119789	1.437		
324	12'-5		34.39	1½	(See Notes)	35'-1	120	22.152	Flow (q) from Route 5 4E(4'-11½), PO(9'-11)
478	12'-5½		100.67	1.6820		29'-8½	0.259570	-0.018	
						64'-9		16.813	
478	12'-5½		8.57	2½	(See Notes)	6'-6	120	38.946	Flow (q) from Route 2 2T(16'-5½)
469	12'-5½		109.25	2.6350		32'-11½	0.033924		
						39'-5½		1.339	
469	12'-5½			2½	(See Notes)	14'-5	120	40.285	3E(8'-3)
465	12'-5½		93.49	2.6350		24'-8½	0.025430		
						39'-1½		0.995	
465	12'-5½			2½		1'-8½	120	41.280	
464	12'-5½		90.78	2.6350		1'-8½	0.024086	0.041	
464	12'-5½			2½		(See Notes)	5'-6½	120	
463	12'-5½		89.74	2.6350	32'-11½	0.023574			
					38'-6		0.907		
463	12'-5½		13.21	2½	(See Notes)	23'-3	120	42.228	Flow (q) from Route 8 2T(16'-5½), C(16'-5½)
564	12'-5½		102.95	2.6350		49'-5	0.030394		
						72'-8		2.209	
564	12'-5½			2½		3'-7	120	44.437	
565	12'-5½		75.33	2.6350		3'-7	0.017056	0.061	
565	12'-5½			1½		(See Notes)	130'-4½	120	
813	11'-1½		27.33	1.6820	24'-9	0.023269	0.578		
					155'-1½		3.610		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot) Total (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe) Friction(Pf)	Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
813	11'-1½		146.47	4	(See Notes)	17'-2	120	48.686	Flow (q) from Route 7 T(26'-4)
812	11'-1½		173.81	4.2600		26'-4	0.007719		
						43'-6		0.336	
812	11'-1½		27.61	4	(See Notes)	264'-7	120	49.021	Flow (q) from Route 25 6E(13'-2), T(26'-4), f, sCV(28'-11½), BV(15'-9½)
1071	4'-2½		201.42	4.2600		150'-1½	0.010139	2.996	
						414'-8½		4.205	
1071	4'-2½			4	(See Notes)	0'-0	120	56.222	E(10'-0), BOR
1069	3'-7½		201.42	4.0260		10'-0	0.013351	0.263	
						10'-0		0.134	
1069	3'-7½			4	(See Notes)	3'-11	120	56.618	T(20'-0)
22	1'-2½		201.42	4.0260		20'-0	0.013351	1.040	
						23'-11		0.319	
22	1'-2½			6	(See Notes)	211'-5½	140	57.978	3E(22'-1), 2EE(11'-0½)
1	1'-2½		201.42	6.2800		88'-3	0.001152	0.000	
						299'-8½		0.345	
			100.00					58.323	Hose Allowance At Source
1			301.42						Total(Pt) Route 1
2362	10'-0	8	33.01	1	(See Notes)	4'-0½	120	17.024	••••• Route 2 ••••• Sprinkler, 2E(2'-0), PO(5'-0)
262	12'-5½		33.01	1.0490		9'-0	0.328795	-1.058	
						13'-0½		4.294	
262	12'-5½			1½		12'-0	120	20.260	Flow (q) from Route 4
291	12'-5½		33.01	1.6820			0.032986		
						12'-0		0.396	
291	12'-5½		33.32	1½		12'-0	120	20.656	Flow (q) from Route 4
327	12'-5½		66.33	1.6820			0.119949		
						12'-0		1.439	
327	12'-5½		34.42	1½	(See Notes)	35'-1½	120	22.095	Flow (q) from Route 6 4E(4'-11½), PO(9'-11)
481	12'-5½		100.75	1.6820		29'-8½	0.259934		
						64'-9½		16.847	
481	12'-5½			2½		13'-9½	120	38.942	Flow (q) from Route 6
478	12'-5½		8.57	2.6350			0.000306		
						13'-9½		0.004	



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
Node 2	Elev 2 (Foot)	K-Factor	Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
								Friction(Pf)	
								38.946	Total(Pt) Route 2
2371	10'-0	8	33.29	1	(See Notes)	4'-3½	120	17.320	***** Route 3 ***** Sprinkler, 2E(2'-0), PO(5'-0)
288	12'-5	K-Factor	33.29	1.0490		9'-0	0.334072	-1.040	
						13'-3½		4.435	
								20.714	Total(Pt) Route 3
2372	10'-0	8	33.32	1	(See Notes)	4'-0½	120	17.345	***** Route 4 ***** Sprinkler, 2E(2'-0), PO(5'-0)
291	12'-5½	K-Factor	33.32	1.0490		9'-0	0.334526	-1.058	
						13'-0½		4.369	
								20.656	Total(Pt) Route 4
2385	10'-0	8	34.39	1	(See Notes)	4'-3½	120	18.482	***** Route 5 ***** Sprinkler, 2E(2'-0), PO(5'-0)
324	12'-5	K-Factor	34.39	1.0490		9'-0	0.354767	-1.040	
						13'-3½		4.709	
								22.152	Total(Pt) Route 5
2386	10'-0	8	34.42	1	(See Notes)	4'-0½	120	18.513	***** Route 6 ***** Sprinkler, 2E(2'-0), PO(5'-0)
327	12'-5½	K-Factor	34.42	1.0490		9'-0	0.355311	-1.058	
						13'-0½		4.640	
								22.095	Total(Pt) Route 6
38	12'-5½	K-Factor	12.00 + 2.99	2		13'-1½	120	41.319	***** Route 7 ***** Flow (q) from Route 9 and 44
41	12'-5½	K-Factor	14.98	2.1570		13'-1½	0.002278	0.030	
41	12'-5½	K-Factor	0.22	2		1'-9	120	41.349	Flow (q) from Route 50
42	12'-5½	K-Factor	15.20	2.1570		1'-9	0.002341	0.004	
42	12'-5½	K-Factor		2	(See Notes)	20'-3½	120	41.353	PO(12'-3½)
43	12'-5½	K-Factor	13.01	2.1570		12'-3½	0.001756	0.057	
						32'-7			
43	12'-5½	K-Factor		1½	(See Notes)	123'-3	120	41.410	PO(9'-11)
494	12'-5½	K-Factor	13.01	1.6820		9'-11	0.005896	0.785	
						133'-2			
494	12'-5½	K-Factor		2½	(See Notes)	14'-1½	120	42.195	2T(16'-5½)
493	12'-5½	K-Factor	13.01	2.6350		32'-11½	0.000662	0.031	
						47'-0½			

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)		Elev(Pe)
			Total (Foot)		Friction(Pf)					
493	12'-5½		85.46	2½	(See Notes)	23'-3	120	42.226		Flow (q) from Route 42
585	12'-5½		98.47	2.6350		49'-5	0.027995		2T(16'-5½), C(16'-5½)	
						72'-8				
585	12'-5½			2½		16'-11½	120	44.260		
583	12'-5½		70.62	2.6350		16'-11½	0.015135	0.257		
583	12'-5½			2½		5'-11	120	44.517		
577	12'-5½		44.19	2.6350		5'-11	0.006357	0.038		
577	12'-5½			2½		19'-0	120	44.555		
575	12'-5½		25.99	2.6350		19'-0	0.002381	0.045		
575	12'-5½			2½		6'-7	120	44.600		
576	12'-5½		10.63	2.6350		6'-7	0.000456	0.003		
576	12'-5½		4.38	1½	(See Notes)	51'-9	120	44.603	PO(9'-11), Flow (q) from Route 22 E(4'-11½)	
620	12'-5½		15.01	1.6820		14'-10	0.007681			
					66'-7			0.511		
620	12'-5½		16.96	1½	(See Notes)	45'-5½	120	45.115	Flow (q) from Route 23	
659	12'-5½		31.98	1.6820		19'-9½	0.031108			2E(4'-11½), T(9'-11)
					65'-3			2.030		
659	12'-5½			1½	(See Notes)	62'-1½	120	47.145	3E(4'-11½), PO(9'-11)	
						24'-9	0.009844	0.578		
787	11'-1½		17.17	1.6820		86'-10½				0.855
787	11'-1½		102.65	4		9'-4	120	48.578	Flow (q) from Route 12	
815	11'-1½		119.82	4.2600		9'-4	0.003879	0.036		
815	11'-1½		26.65	4		12'-8	120	48.614	Flow (q) from Route 21	
813	11'-1½		146.47	4.2600		12'-8	0.005624	0.071		
								48.686	Total(Pt) Route 7	
31	12'-5½		12.45	2		13'-3	120	41.313	••••• Route 8 ••••• Flow (q) from Route 10	
30	12'-5½		9.46	2.1570		13'-3	0.000973	0.013		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
30	12'-5½		2.71	2		1'-8½	120	41.326	Flow (q) from Route 49
29	12'-5½		12.16	2.1570		1'-8½	0.001550	0.003	
29	12'-5½		1.05	2	(See Notes)	20'-6	120	41.329	Flow (q) from Route 47 PO(12'-3½)
24	12'-5½		13.21	2.1570		12'-3½	0.001805	0.059	
24	12'-5½			1½	(See Notes)	123'-3	120	41.388	PO(9'-11)
462	12'-5½		13.21	1.6820		9'-11	0.006063	0.807	
					133'-2				
462	12'-5½			2½	(See Notes)	14'-11½	120	42.195	2T(16'-5½)
463	12'-5½		13.21	2.6350		32'-11½	0.000681	0.033	
					47'-11				
								42.228	Total(Pt) Route 8
480	12'-5½		92.17	2½	(See Notes)	7'-6½	120	40.539	***** Route 9 ***** Flow (q) from Route 46 PO(16'-5½)
497	20'-0		8.68	2.6350		16'-5½	0.000313	-3.265	
					24'-0		0.008		
497	20'-0			1½	(See Notes)	28'-0	120	37.282	E(4'-11½)
349	20'-0		8.68	1.6820		4'-11½	0.002789	-0.005	
					32'-11½		0.092		
349	20'-0		3.31	1½	(See Notes)	109'-5½	120	37.369	Flow (q) from Route 11 3E(4'-11½), PO(9'-11)
38	12'-5½		12.00	1.6820		24'-9	0.005071	3.270	
					134'-2½		0.680		
								41.319	Total(Pt) Route 9
469	12'-5½		93.49	2½	(See Notes)	7'-6½	120	40.285	***** Route 10 ***** Flow (q) from Route 1 PO(16'-5½)
490	20'-0		15.76	2.6350		16'-5½	0.000944	-3.265	
					24'-0		0.023		
490	20'-0			1½	(See Notes)	27'-11	120	37.043	E(4'-11½)
340	20'-0		15.76	1.6820		4'-11½	0.008399	-0.005	
					32'-10½		0.276		
340	20'-0			1½	(See Notes)	109'-7	120	37.314	3E(4'-11½), PO(9'-11)
31	12'-5½		12.45	1.6820		24'-9	0.005428	3.270	
					134'-4		0.729		
								41.313	Total(Pt) Route 10

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Fitting (Foot)	Pf Friction Loss Per Unit (psi)		Elev(Pe)
					Total (Foot)		Friction(Pf)			
340	20'-0			1½	(See Notes)	56'-4	120	37.314	••••• Route 11 ••••• 2T(9'-11), C(9'-11)	
349	20'-0		3.31	1.6820		59'-5	0.000469			2T(9'-11), C(9'-11)
						115'-9				
								37.369	Total(Pt) Route 11	
971	11'-1½		0.06 + 0.08	1½	(See Notes)	52'-2	120	48.485	••••• Route 12 ••••• Flow (q) from Route 30 and 39 2E(4'-11½), T(9'-11)	
983	11'-1½		0.14	1.6820		19'-9½	0.000001			0.000
						71'-11½				
983	11'-1½			1½	(See Notes)	32'-8	120	48.485	PO(9'-11)	
980	11'-1½		0.08	1.6820		9'-11	0.000000			0.000
						42'-7				
980	11'-1½		0.47	4		10'-2	120	48.485	Flow (q) from Route 13	
949	11'-1½		0.54	4.2600		10'-2	0.000000			0.000
949	11'-1½		0.12	4		16'-8	120	48.485	Flow (q) from Route 29	
899	11'-1½		0.67	4.2600		16'-8	0.000000			0.000
899	11'-1½		0.14	4	(See Notes)	13'-2½	120	48.485	Flow (q) from Route 31 T(26'-4)	
825	11'-1½		0.80	4.2600		26'-4	0.000000			0.000
						39'-6½				
825	11'-1½		27.05	4		12'-11	120	48.485	Flow (q) from Route 33	
774	11'-1½		27.85	4.2600		12'-11	0.000261			0.003
774	11'-1½		26.43	4		10'-9	120	48.488	Flow (q) from Route 24	
788	11'-1½		54.28	4.2600		10'-9	0.000897			0.010
788	11'-1½		16.63	4		13'-11	120	48.498	Flow (q) from Route 15	
785	11'-1½		70.92	4.2600		13'-11	0.001470			0.020
785	11'-1½		16.92	4		5'-8	120	48.519	Flow (q) from Route 16	
789	11'-1½		87.84	4.2600		5'-8	0.002184			0.012
789	11'-1½		14.81	4		16'-2	120	48.531	Flow (q) from Route 38	
787	11'-1½		102.65	4.2600		16'-2	0.002914			0.047

Pipe Information										
Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.	
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)			Friction(Pf)		
								48.578	Total(Pt) Route 12	
1457	11'-1½		0.19	1½	(See Notes)	168'-10	120	48.485	***** Route 13 ***** PO(9'-11), Flow (q) from Route 27 PO(9'-11)	
1470	11'-1½		0.09	1.6820		19'-9½	0.000001			
						188'-7½		0.000		
1470	11'-1½		0.09	4		16'-8	120	48.485	Flow (q) from Route 14	
1359	11'-1½		0.19	4.2600		16'-8	0.000000			0.000
1359	11'-1½		0.10	4		10'-2	120	48.485	Flow (q) from Route 26	
1275	11'-1½		0.28	4.2600		10'-2	0.000000			0.000
1275	11'-1½		0.07	4		8'-6	120	48.485	Flow (q) from Route 18	
1215	11'-1½		0.35	4.2600		8'-6	0.000000			0.000
1215	11'-1½		0.06	4		18'-6	120	48.485	Flow (q) from Route 19	
1037	11'-1½		0.41	4.2600		18'-6	0.000000			0.000
1037	11'-1½		0.06	4		8'-6	120	48.485	Flow (q) from Route 37	
980	11'-1½		0.47	4.2600		8'-6	0.000000			0.000
								48.485	Total(Pt) Route 13	
1457	11'-1½		0.19	2½		14'-0	120	48.485	***** Route 14 ***** Flow (q) from Route 27	
1550	11'-1½		0.09	2.6350		14'-0	0.000000			0.000
1550	11'-1½			1½	(See Notes)	168'-10	120	48.485	PO(9'-11) PO(9'-11)	
1561	11'-1½		0.09	1.6820		19'-9½	0.000001			
						188'-7½		0.000		
1561	11'-1½			4		14'-0	120	48.485		
1470	11'-1½		0.09	4.2600		14'-0	0.000000			0.000
								48.485	Total(Pt) Route 14	
658	12'-5½		33.56	1½	(See Notes)	63'-8½	120	47.007	***** Route 15 ***** T(9'-11), Flow (q) from Route 17 3E(4'-11½), PO(9'-11)	
788	11'-1½		16.63	1.6820		34'-8	0.009282			0.578
						98'-4½		0.913		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot) Total (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe) Friction(Pf)	Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
								48.498	Total(Pt) Route 15
658	12'-5½		33.56	1½	(See Notes)	77'-7	120	47.007	••••• Route 16 ••••• Flow (q) from Route 17  2E(4'-11½), PO(9'-11)
785	11'-1½		16.92	1.6820		19'-9½	0.009586	0.578	
						97'-4½		0.934	
								48.519	Total(Pt) Route 16
577	12'-5½			1½	(See Notes)	33'-6	120	44.555	••••• Route 17 ••••• PO(9'-11)  T(9'-11)
623	12'-5½		18.20	1.6820		19'-9½	0.010966		
						53'-3½		0.584	
623	12'-5½		15.36	1½	(See Notes)	45'-0½	120	45.139	Flow (q) from Route 34  2E(4'-11½)
658	12'-5½		33.56	1.6820		9'-11	0.034008		
						54'-11		1.868	
								47.007	Total(Pt) Route 17
1278	11'-1½		0.13	1½	(See Notes)	32'-8½	120	48.485	••••• Route 18 ••••• Flow (q) from Route 20  PO(9'-11)
1275	11'-1½		0.07	1.6820		9'-11	0.000000		
						42'-7½		0.000	
								48.485	Total(Pt) Route 18
1278	11'-1½		0.13	1½	(See Notes)	41'-2½	120	48.485	••••• Route 19 ••••• T(9'-11), Flow (q) from Route 20 E(4'-11½), PO(9'-11)
1215	11'-1½		0.06	1.6820		24'-9	0.000000		
						65'-11½		0.000	
								48.485	Total(Pt) Route 19
1287	11'-1½		0.06 + 0.07	1½	(See Notes)	51'-4½	120	48.485	••••• Route 20 ••••• Flow (q) from Route 28 and 35 2E(4'-11½), T(9'-11)
1278	11'-1½		0.13	1.6820		19'-9½	0.000001		
						71'-2		0.000	
								48.485	Total(Pt) Route 20
568	12'-5½		48.00	1½	(See Notes)	130'-4½	120	44.591	••••• Route 21 ••••• PO(9'-11), Flow (q) from Route 41 E(4'-11½), PO(9'-11)
815	11'-1½		26.65	1.6820		24'-9	0.022205	0.578	
						155'-1½		3.445	
								48.614	Total(Pt) Route 21
568	12'-5½		48.00	2½		6'-1	120	44.591	••••• Route 22 ••••• Flow (q) from Route 41
571	12'-5½		21.35	2.6350		6'-1	0.001655	0.010	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
571	12'-5½			2½		18'-3	120	44.602	
576	12'-5½		4.38	2.6350		18'-3	0.000089	0.002	
								44.603	
571	12'-5½			1½	(See Notes)	33'-6	120	44.602	..... Route 23 ..... PO(9'-11) T(9'-11)
620	12'-5½		16.96	1.6820		19'-9½	0.009628		
								0.513	
								45.115	Total(Pt) Route 23
583	12'-5½			1½	(See Notes)	130'-4½	120	44.517	..... Route 24 ..... PO(9'-11) E(4'-11½), PO(9'-11)
774	11'-1½		26.43	1.6820		24'-9	0.021873	0.578	
								3.393	
								48.488	Total(Pt) Route 24
564	12'-5½		75.33	2½		14'-5	120	44.437	..... Route 25 ..... Flow (q) from Route 1
563	12'-5½		27.61	2.6350		14'-5	0.002664	0.038	
563	12'-5½			1½	(See Notes)	132'-4½	120	44.475	PO(9'-11) 3E(4'-11½), PO(9'-11)
810	11'-1½		27.61	1.6820		34'-8	0.023711	0.578	
								3.961	
810	11'-1½			4	(See Notes)	2'-10	120	49.014	T(26'-4)
812	11'-1½		27.61	4.2600		26'-4	0.000257		
								0.007	
								49.021	Total(Pt) Route 25
1295	11'-1½			2½		6'-1	120	48.485	..... Route 26 ..... PO(9'-11) PO(9'-11)
1349	11'-1½		0.28	2.6350		6'-1	0.000001	0.000	
1349	11'-1½			1½	(See Notes)	168'-10	120	48.485	PO(9'-11) PO(9'-11)
1359	11'-1½		0.10	1.6820		19'-9½	0.000001		
								0.000	
								48.485	Total(Pt) Route 26
1349	11'-1½		0.10	2½		16'-8	120	48.485	..... Route 27 ..... Flow (q) from Route 26
1457	11'-1½		0.19	2.6350		16'-8	0.000000	0.000	
								48.485	Total(Pt) Route 27

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
1097	11'-1½			2½		8'-8	120	48.485	••••• Route 28 •••••
1184	11'-1½		0.41	2.6350		8'-8	0.000001	0.000	
1184	11'-1½			2½		16'-9	120	48.485	
1295	11'-1½		0.34	2.6350		16'-9	0.000001	0.000	
1295	11'-1½			1½	(See Notes)	99'-6	120	48.485	
1287	11'-1½		0.06	1.6820		34'-8	0.000000	0.000	
						134'-2		0.000	PO(9'-11) E(4'-11½), 2T(9'-11)
								48.485	Total(Pt) Route 28
938	11'-1½		0.67	1½	(See Notes)	168'-10	120	48.485	••••• Route 29 ••••• PO(9'-11), Flow (q) from Route 32
949	11'-1½		0.12	1.6820		19'-9½	0.000001	0.000	
						188'-7½		0.000	
								48.485	Total(Pt) Route 29
938	11'-1½		0.67	2½		6'-4	120	48.485	••••• Route 30 ••••• Flow (q) from Route 32
957	11'-1½		0.54	2.6350		6'-4	0.000002	0.000	
957	11'-1½			2½		18'-0	120	48.485	
1097	11'-1½		0.46	2.6350		18'-0	0.000001	0.000	
1097	11'-1½			1½	(See Notes)	121'-3½	120	48.485	PO(9'-11) 7E(4'-11½)
971	11'-1½		0.06	1.6820		44'-6½	0.000000	0.000	
						165'-10		0.000	
								48.485	Total(Pt) Route 30
805	11'-1½		0.80	2½		14'-1	120	48.485	••••• Route 31 ••••• Flow (q) from Route 40
884	11'-1½		0.80	2.6350		14'-1	0.000004	0.000	
884	11'-1½			1½	(See Notes)	168'-10	120	48.485	
899	11'-1½		0.14	1.6820		19'-9½	0.000001	0.000	PO(9'-11)
						188'-7½		0.000	PO(9'-11)
								48.485	Total(Pt) Route 31



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
884	11'-1½		0.14	2½		16'-8	120	48.485	••••• Route 32 ••••• Flow (q) from Route 31
938	11'-1½		0.67	2.6350		16'-8	0.000003	0.000	
								48.485	
587	12'-5½		27.85	1½	(See Notes)	126'-11½	120	44.476	••••• Route 33 ••••• Flow (q) from Route 36 E(4'-11½), PO(9'-11)
738	11'-1½		27.85	1.6820		14'-10	0.024088	0.578	
738	11'-1½			4	(See Notes)	141'-9½		3.416	
796	11'-1½		27.85	4.2600			19'-11	120	48.470
796	11'-1½			4	(See Notes)	13'-2	0.000261	0.009	
825	11'-1½		27.05	4.2600				33'-1	0.007
								48.485	Total(Pt) Route 33
575	12'-5½			1½	(See Notes)	52'-5½	120	44.600	••••• Route 34 ••••• PO(9'-11) E(4'-11½)
623	12'-5½		15.36	1.6820		14'-10	0.008008	0.539	
								45.139	
1184	11'-1½			1½	(See Notes)	112'-11	120	48.485	••••• Route 35 ••••• PO(9'-11) 3E(4'-11½)
1287	11'-1½		0.07	1.6820		24'-9	0.000000	0.000	
								48.485	
585	12'-5½			2½	(See Notes)	13'-8½	120	44.260	••••• Route 36 ••••• 2T(16'-5½), C(16'-5½) PO(16'-5½)
587	12'-5½		27.85	2.6350		65'-11	0.002706	0.215	
								44.476	
983	11'-1½			1½	(See Notes)	41'-2	120	48.485	••••• Route 37 ••••• T(9'-11) E(4'-11½), PO(9'-11)
1037	11'-1½		0.06	1.6820		24'-9	0.000000	0.000	
								48.485	
659	12'-5½			1½	(See Notes)	78'-3	120	47.145	••••• Route 38 ••••• T(9'-11) 2E(4'-11½), PO(9'-11)
789	11'-1½		14.81	1.6820		29'-8½	0.007488	0.578	
								0.808	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	Friction(Pf)	
								48.531	Total(Pt) Route 38
957	11'-1½			1½	(See Notes)	100'-0	120	48.485	***** Route 39 ***** PO(9'-11)  2E(4'-11½), T(9'-11)
971	11'-1½		0.08	1.6820		29'-8½	0.000001		
						129'-8½		0.000	
								48.485	Total(Pt) Route 39
796	11'-1½			1½	(See Notes)	168'-10	120	48.478	***** Route 40 ***** PO(9'-11)  PO(9'-11)
805	11'-1½		0.80	1.6820		19'-9½	0.000034		
						188'-7½		0.006	
								48.485	Total(Pt) Route 40
565	12'-5½		27.33	2½		12'-8	120	44.498	***** Route 41 ***** Flow (q) from Route 1
568	12'-5½		48.00	2.6350		12'-8	0.007409		
								0.094	
								44.591	Total(Pt) Route 41
492	12'-5½		83.27 + 2.19	2½	(See Notes)	6'-2	120	41.384	***** Route 42 ***** Flow (q) from Route 43 and 48 2T(16'-5½)
493	12'-5½		85.46	2.6350		32'-11½	0.021537		
						39'-1½		0.842	
								42.226	Total(Pt) Route 42
491	12'-5½		83.49	2½		1'-9	120	41.348	***** Route 43 ***** Flow (q) from Route 45
492	12'-5½		83.27	2.6350		1'-9	0.020528		
								0.036	
								41.384	Total(Pt) Route 43
31	12'-5½		12.45	2		47'-6½	120	41.313	***** Route 44 ***** Flow (q) from Route 10
38	12'-5½		2.99	2.1570		47'-6½	0.000115		
								0.005	
								41.319	Total(Pt) Route 44
480	12'-5½		92.17	2½	(See Notes)	14'-6½	120	40.539	***** Route 45 ***** Flow (q) from Route 46  3E(8'-3)
491	12'-5½		83.49	2.6350		24'-8½	0.020629		
						39'-3		0.809	
								41.348	Total(Pt) Route 45
481	12'-5½		8.57	2½	(See Notes)	31'-6	120	38.942	***** Route 46 ***** Flow (q) from Route 2  2T(16'-5½)
480	12'-5½		92.17	2.6350		32'-11½	0.024772		
						64'-5½		1.597	
								40.539	Total(Pt) Route 46

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
464	12'-5½			1½	(See Notes)	123'-3	120	41.321	***** Route 47 ***** PO(9'-11)  PO(9'-11)
29	12'-5½		1.05	1.6820		19'-9½	0.000056		
						143'-1		0.008	
								41.329	Total(Pt) Route 47
42	12'-5½			1½	(See Notes)	123'-3	120	41.353	***** Route 48 ***** PO(9'-11)  PO(9'-11)
492	12'-5½		2.19	1.6820		19'-9½	0.000218		
						143'-1		0.031	
								41.384	Total(Pt) Route 48
465	12'-5½			1½	(See Notes)	123'-3	120	41.280	***** Route 49 ***** PO(9'-11)  PO(9'-11)
30	12'-5½		2.71	1.6820		19'-9½	0.000322		
						143'-1		0.046	
								41.326	Total(Pt) Route 49
491	12'-5½		83.49	1½	(See Notes)	123'-3	120	41.348	***** Route 50 ***** PO(9'-11), Flow (q) from Route 45 PO(9'-11)
41	12'-5½		0.22	1.6820		19'-9½	0.000003		
						143'-1		0.000	
								41.349	Total(Pt) Route 50

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BalV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connectic	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		



# Hydraulic Overview

Job Number: B22243  
Report Description: Ordinary Group I (D)


Job	
Job Number <b>B22243</b>	Designer <b>BKB</b>
Job Name: <b>OVERHILLS ELEMENTARY</b>	Phone <b>919.243.2464</b>
Address 1 <b>2626 RAY ROAD</b>	State Certification/License Number <b>16269FS</b>
Address 2 <b>SPRING LAKE, NC 28390</b>	AHJ <b>HARNETT CO</b>
Address 3	Job Site/Building <b>HARNETT CO SCHOOLS</b>

System	
Density <b>0.15 gpm/ft<sup>2</sup></b>	Area of Application <b>1500 ft<sup>2</sup> (Actual 412 ft<sup>2</sup>)</b>
Most Demanding Sprinkler Data <b>5.6 K-Factor 19.50 at 12.125</b>	Hose Streams <b>250.00</b>
Coverage Per Sprinkler <b>130 ft<sup>2</sup></b>	Number Of Sprinklers Calculated <b>5</b>
System Pressure Demand <b>28.459</b>	System Flow Demand <b>98.13</b>
Total Demand <b>348.13 @ 28.459</b>	Pressure Result <b>+99.100 (77.7%)</b>

Supplies						Check Point Gauges			
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	776.00	250.00	138.000	92.000	BOR (1069)	27.243	18.8	98.13
1	Pump	750.00		96.000	80.000				

Pumps: Static = Churn (Pressure @ Zero Flow)

## PIPING Water Supply at Node 1 (776.00, 0.00, 138.000, 92.000)



# Hydraulic Calculations

for

Project Name: OVERHILLS ELEMENTARY  
Location: 2626 RAY ROAD, SPRING LAKE, NC 28390,  
Drawing Name: PIPING

Calculation Date: 4/19/2023

## Design

Remote Area Number: D  
Remote Area Location: MEZZANINE  
Occupancy Classification: Ordinary Group I  
Commodity Classification: N/A

Density: 0.15 gpm/ft<sup>2</sup>  
Area of Application: 1500 ft<sup>2</sup> (Actual 412 ft<sup>2</sup>)  
Coverage per Sprinkler: 130 ft<sup>2</sup>  
Type of sprinklers calculated: Upright  
No. of sprinklers calculated: 5  
No. of nozzles calculated: 0

In-rack Demand: N/A gpm at Node: N/A  
Hose Streams: 250.00 at Node: 1 Type: Allowance at Source

### Total Water Required (including Hose Streams where applicable):

From Water Supply at Node 1: 348.13 @ 28.459 (Safety Margin = 99.100)  
from Pump at Node: 1: 98.13 @ 28.459 (Safety Margin = 99.100)

Type of System: WET  
Volume of Dry/PreAction/Antifreeze/OtherA N/A

Name of Contractor:  
Address:  
Phone Number:  
Name of designer: BKB  
Authority Having Jurisdiction HARNETT CO

## Notes:

Automatic peaking results Left: 28.010 Right: 28.755

---

---


---

# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: D

N<sup>1.85</sup>

Date: 4/19/2023




Water Supply  
Summary Sheet  
Node: 1

# Hydraulic Graph

Job Name: OVERHILLS ELEMENTARY  
Remote Area Number: D

N<sup>1.85</sup>

Date: 4/19/2023



**Pump Rating: 750.00 @ 80.000**

**Supply: Static: 138.000**  
**Residual: 92.000**  
**Flowing: 776.00**





# Summary Of Outflowing Devices

Job Number: B22243  
Report Description: Ordinary Group I (D)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	2345	19.59	19.50	5.6	12.241			
⇒ Sprinkler	<b>2349</b>	<b>19.50</b>	<b>19.50</b>	<b>5.6</b>	<b>12.125</b>			
Sprinkler	2363	19.50	19.50	5.6	12.125			
Sprinkler	2377	19.60	19.50	5.6	12.247			
Sprinkler	2381	19.94	19.50	5.6	12.681			

⇒ Most Demanding Sprinkler Data

Supply Analysis							
Node	Name	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)
1	Water Supply	138.000	92.000	776.00	127.559	348.13	28.459

Pump Analysis						
Node	Churn (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required Pressure (psi)
1	96.000	80.000	750.00	127.559	98.13	28.459

Node Analysis					
Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
1	1'-2½	Supply	28.459	98.13	P2
2345	20'-7½	Sprinkler	12.241	19.59	
2349	20'-7½	Sprinkler	12.125	19.50	
2363	20'-7½	Sprinkler	12.125	19.50	
2377	20'-7½	Sprinkler	12.247	19.60	
2381	20'-7½	Sprinkler	12.681	19.94	
22	1'-2½		28.368		
24	12'-5½		20.252		
29	12'-5½		20.224		
30	12'-5½		20.220		
31	12'-5½		20.161		
38	12'-5½		20.041		
41	12'-5½		20.108		
42	12'-5½		20.112		
43	12'-5½		20.143		
340	20'-0		16.724		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
349	20'-0		15.089		
462	12'-5½		20.634		
463	12'-5½		20.650		
464	12'-5½		20.446		
465	12'-5½		20.440		
469	12'-5½		20.338		
480	12'-5½		20.269		
490	20'-0		17.066		
491	12'-5½		20.365		
492	12'-5½		20.371		
493	12'-5½		20.579		
494	12'-5½		20.562		
497	20'-0		16.968		
563	12'-5½		21.215		
564	12'-5½		21.205		
565	12'-5½		21.220		
568	12'-5½		21.242		
571	12'-5½		21.244		
575	12'-5½		21.243		
576	12'-5½		21.244		
577	12'-5½		21.229		
583	12'-5½		21.218		
585	12'-5½		21.145		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
587	12'-5½		21.203		
620	12'-5½		21.380		
623	12'-5½		21.385		
658	12'-5½		21.879		
659	12'-5½		21.916		
738	11'-1½		22.691		
774	11'-1½		22.696		
785	11'-1½		22.704		
787	11'-1½		22.720		
788	11'-1½		22.699		
789	11'-1½		22.707		
796	11'-1½		22.693		
805	11'-1½		22.695		
810	11'-1½		22.835		
812	11'-1½		22.837		
813	11'-1½		22.748		
815	11'-1½		22.729		
825	11'-1½		22.695		
884	11'-1½		22.695		
899	11'-1½		22.695		
938	11'-1½		22.695		
949	11'-1½		22.695		
957	11'-1½		22.695		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
971	11'-1½		22.695		
980	11'-1½		22.695		
983	11'-1½		22.695		
1037	11'-1½		22.695		
1069	3'-7½	Gauge	27.243		
1071	4'-2½		26.945		
1097	11'-1½		22.695		
1184	11'-1½		22.695		
1215	11'-1½		22.695		
1275	11'-1½		22.695		
1278	11'-1½		22.695		
1287	11'-1½		22.695		
1295	11'-1½		22.695		
1349	11'-1½		22.695		
1359	11'-1½		22.695		
1457	11'-1½		22.695		
1470	11'-1½		22.695		
1550	11'-1½		22.695		
1561	11'-1½		22.695		
2340	20'-0		13.220		
2347	20'-0		13.098		
2358	20'-0		13.098		
2370	20'-0		13.226		

Node Number	Elevation (Foot)	Node Type	Pressure at Node (psi)	Discharge at Node (gpm)	Notes
2376	20'-0		13.683		

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)	Friction(Pf)						
2349	20'-7½	5.6	19.50	1	(See Notes)	0'-7½	120	12.125	
2347	20'-0		19.50	1.0490		5'-0	0.124177	0.274	
						5'-7½		0.699	
2347	20'-0			1½		10'-0	120	13.098	
2340	20'-0		19.23	1.6820		10'-0	0.012139	0.121	
2340	20'-0		19.59	1½	(See Notes)	55'-0½	120	13.220	Flow (q) from Route 3 3E(4'-11½), PO(9'-11)
38	12'-5½		38.82	1.6820		24'-9	0.044530	3.270	
						79'-9½		3.552	
38	12'-5½			2		47'-6½	120	20.041	
31	12'-5½		15.82	2.1570		47'-6½	0.002520	0.120	
31	12'-5½		5.63	2		13'-3	120	20.161	Flow (q) from Route 7
30	12'-5½		21.45	2.1570		13'-3	0.004425	0.059	
30	12'-5½			1½	(See Notes)	123'-3	120	20.220	PO(9'-11) PO(9'-11)
465	12'-5½		6.29	1.6820		19'-9½	0.001538		
						143'-1		0.220	
465	12'-5½		27.35	2½		1'-8½	120	20.440	Flow (q) from Route 2
464	12'-5½		33.64	2.6350		1'-8½	0.003839	0.006	
464	12'-5½		6.33	2½	(See Notes)	5'-6½	120	20.446	Flow (q) from Route 45 2T(16'-5½)
463	12'-5½		39.98	2.6350		32'-11½	0.005282		
						38'-6		0.203	
463	12'-5½		8.82	2½	(See Notes)	23'-3	120	20.650	Flow (q) from Route 46 2T(16'-5½), C(16'-5½)
564	12'-5½		48.80	2.6350		49'-5	0.007639		
						72'-8		0.555	
564	12'-5½			2½		3'-7	120	21.205	
565	12'-5½		35.38	2.6350		3'-7	0.004214	0.015	
565	12'-5½			1½	(See Notes)	130'-4½	120	21.220	PO(9'-11) E(4'-11½), PO(9'-11)
813	11'-1½		13.29	1.6820		24'-9	0.006126	0.578	
						155'-1½		0.950	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
813	11'-1½		71.43	4	(See Notes)	17'-2	120	22.748	Flow (q) from Route 10 T(26'-4)
812	11'-1½		84.71	4.2600		26'-4	0.002042		
						43'-6		0.089	
812	11'-1½		13.42	4	(See Notes)	264'-7	120	22.837	Flow (q) from Route 24 6E(13'-2), T(26'-4), f, sCV(28'-11½), BV(15'-9½)
1071	4'-2½		98.13	4.2600		150'-1½	0.002681	2.996	
						414'-8½		1.112	
1071	4'-2½			4	(See Notes)	0'-0	120	26.945	E(10'-0), BOR
1069	3'-7½		98.13	4.0260		10'-0	0.003530	0.263	
						10'-0		0.035	
1069	3'-7½			4	(See Notes)	3'-11	120	27.243	T(20'-0)
22	1'-2½		98.13	4.0260		20'-0	0.003530	1.040	
						23'-11		0.084	
22	1'-2½			6	(See Notes)	211'-5½	140	28.368	3E(22'-1), 2EE(11'-0½)
1	1'-2½		98.13	6.2800		88'-3	0.000304	0.000	
						299'-8½		0.091	
			250.00					28.459	Hose Allowance At Source
1			348.13						Total(Pt) Route 1
2363	20'-7½	5.6	19.50	1	(See Notes)	0'-7½	120	12.125	••••• Route 2 ••••• Sprinkler, PO(5'-0)
2358	20'-0		19.50	1.0490		5'-0	0.124177	0.274	
						5'-7½		0.699	
2358	20'-0		0.27	1½		10'-0	120	13.098	Flow (q) from Route 8
2370	20'-0		19.77	1.6820		10'-0	0.012781	0.128	
2370	20'-0		19.60	1½		10'-0	120	13.226	Flow (q) from Route 4
2376	20'-0		39.37	1.6820		10'-0	0.045700	0.457	
2376	20'-0		19.94	1½		14'-5	120	13.683	Flow (q) from Route 5
349	20'-0		59.31	1.6820		14'-5	0.097538	1.406	
349	20'-0			1½	(See Notes)	28'-0	120	15.089	E(4'-11½), PO(9'-11)
497	20'-0		38.44	1.6820		14'-10	0.043732	0.005	
						42'-10		1.873	



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
497	20'-0			2½		7'-6½	120	16.968	
480	12'-5½		38.44	2.6350		7'-6½	0.004913	3.265	
								0.037	
480	12'-5½			2½	(See Notes)	51'-10	120	20.269	2T(16'-5½)
469	12'-5½		12.11	2.6350		65'-11	0.000580		2T(16'-5½)
						117'-8½		0.068	
469	12'-5½		15.24	2½	(See Notes)	14'-5	120	20.338	Flow (q) from Route 6 3E(8'-3)
465	12'-5½		27.35	2.6350		24'-8½	0.002617		
						39'-1½		0.102	
								20.440	Total(Pt) Route 2
2345	20'-7½	5.6	19.59	1	(See Notes)	0'-7½	120	12.241	***** Route 3 ***** Sprinkler, PO(5'-0)
2340	20'-0		19.59	1.0490		5'-0	0.125268	0.274	
						5'-7½		0.705	
								13.220	Total(Pt) Route 3
2377	20'-7½	5.6	19.60	1	(See Notes)	0'-7½	120	12.247	***** Route 4 ***** Sprinkler, PO(5'-0)
2370	20'-0		19.60	1.0490		5'-0	0.125326	0.274	
						5'-7½		0.706	
								13.226	Total(Pt) Route 4
2381	20'-7½	5.6	19.94	1	(See Notes)	0'-7½	120	12.681	***** Route 5 ***** Sprinkler, PO(5'-0)
2376	20'-0		19.94	1.0490		5'-0	0.129428	0.274	
						5'-7½		0.729	
								13.683	Total(Pt) Route 5
490	20'-0		15.24	2½		7'-6½	120	17.066	***** Route 6 ***** Flow (q) from Route 9
469	12'-5½		15.24	2.6350		7'-6½	0.000887	3.265	
								0.007	
								20.338	Total(Pt) Route 6
349	20'-0			1½	(See Notes)	56'-4	120	15.089	***** Route 7 ***** 2T(9'-11), C(9'-11) 2T(9'-11), C(9'-11)
340	20'-0		20.87	1.6820		59'-5	0.014121		
						115'-9		1.634	
340	20'-0			1½	(See Notes)	109'-7	120	16.724	3E(4'-11½), PO(9'-11)
31	12'-5½		5.63	1.6820		24'-9	0.001251	3.270	
						134'-4		0.168	
								20.161	Total(Pt) Route 7

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
2347	20'-0		19.23	1½		10'-0	120	13.098	***** Route 8 ***** Flow (q) from Route 1
2358	20'-0		0.27	1.6820		10'-0	0.000005	0.000	
								13.098	
340	20'-0		5.63	1½	(See Notes)	27'-11	120	16.724	***** Route 9 ***** Flow (q) from Route 7 E(4'-11½), PO(9'-11)
490	20'-0		15.24	1.6820		14'-10	0.007894	0.005	
								0.338	
								17.066	Total(Pt) Route 9
971	11'-1½		0.03 + 0.04	1½	(See Notes)	52'-2	120	22.695	***** Route 10 ***** Flow (q) from Route 29 and 38 2E(4'-11½), T(9'-11)
983	11'-1½		0.07	1.6820		19'-9½	0.000000	0.000	
								0.000	
983	11'-1½			1½	(See Notes)	32'-8	120	22.695	PO(9'-11)
980	11'-1½		0.04	1.6820		9'-11	0.000000	0.000	
								0.000	
980	11'-1½		0.23	4		10'-2	120	22.695	Flow (q) from Route 11
949	11'-1½		0.27	4.2600		10'-2	0.000000	0.000	
								0.000	
949	11'-1½		0.06	4		16'-8	120	22.695	Flow (q) from Route 28
899	11'-1½		0.33	4.2600		16'-8	0.000000	0.000	
								0.000	
899	11'-1½		0.07	4	(See Notes)	13'-2½	120	22.695	Flow (q) from Route 30 T(26'-4)
825	11'-1½		0.39	4.2600		26'-4	0.000000	0.000	
								0.000	
825	11'-1½		13.23	4		12'-11	120	22.695	Flow (q) from Route 32
774	11'-1½		13.63	4.2600		12'-11	0.000070	0.001	
								0.001	
774	11'-1½		12.90	4		10'-9	120	22.696	Flow (q) from Route 23
788	11'-1½		26.53	4.2600		10'-9	0.000238	0.003	
								0.003	
788	11'-1½		8.11	4		13'-11	120	22.699	Flow (q) from Route 13
785	11'-1½		34.64	4.2600		13'-11	0.000390	0.005	
								0.005	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
785	11'-1½		8.25	4		5'-8	120	22.704	Flow (q) from Route 15
789	11'-1½		42.88	4.2600		5'-8	0.000580	0.003	
789	11'-1½		7.21	4		16'-2	120	22.707	Flow (q) from Route 37
787	11'-1½		50.09	4.2600		16'-2	0.000773	0.012	
787	11'-1½		8.36	4		9'-4	120	22.720	Flow (q) from Route 14
815	11'-1½		58.46	4.2600		9'-4	0.001028	0.010	
815	11'-1½		12.97	4		12'-8	120	22.729	Flow (q) from Route 20
813	11'-1½		71.43	4.2600		12'-8	0.001490	0.019	
								22.748	Total(Pt) Route 10
1457	11'-1½		0.09	1½	(See Notes)	168'-10	120	22.695	••••• Route 11 ••••• PO(9'-11), Flow (q) from Route 26 PO(9'-11)
1470	11'-1½		0.05	1.6820		19'-9½	0.000000	0.000	
1470	11'-1½		0.05	4		188'-7½			
1470	11'-1½		0.05	4		16'-8	120	22.695	Flow (q) from Route 12
1359	11'-1½		0.09	4.2600		16'-8	0.000000	0.000	
1359	11'-1½		0.05	4		10'-2	120	22.695	Flow (q) from Route 25
1275	11'-1½		0.14	4.2600		10'-2	0.000000	0.000	
1275	11'-1½		0.03	4		8'-6	120	22.695	Flow (q) from Route 17
1215	11'-1½		0.17	4.2600		8'-6	0.000000	0.000	
1215	11'-1½		0.03	4		18'-6	120	22.695	Flow (q) from Route 18
1037	11'-1½		0.20	4.2600		18'-6	0.000000	0.000	
1037	11'-1½		0.03	4		8'-6	120	22.695	Flow (q) from Route 36
980	11'-1½		0.23	4.2600		8'-6	0.000000	0.000	
								22.695	Total(Pt) Route 11

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
1457	11'-1½		0.09	2½		14'-0	120	22.695	••••• Route 12 ••••• Flow (q) from Route 26
1550	11'-1½		0.05	2.6350		14'-0	0.000000	0.000	
1550	11'-1½			1½	(See Notes)	168'-10	120	22.695	PO(9'-11)
1561	11'-1½		0.05	1.6820		19'-9½	0.000000		PO(9'-11)
1561	11'-1½			4		188'-7½		0.000	
1561	11'-1½					14'-0	120	22.695	
1470	11'-1½		0.05	4.2600		14'-0	0.000000	0.000	
								22.695	Total(Pt) Route 12
658	12'-5½		16.36	1½	(See Notes)	63'-8½	120	21.879	••••• Route 13 ••••• T(9'-11), Flow (q) from Route 16 3E(4'-11½), PO(9'-11)
788	11'-1½		8.11	1.6820		34'-8	0.002456	0.578	
						98'-4½		0.242	
								22.699	Total(Pt) Route 13
585	12'-5½		49.33	2½		16'-11½	120	21.145	••••• Route 14 ••••• Flow (q) from Route 41
583	12'-5½		35.70	2.6350		16'-11½	0.004285	0.073	
583	12'-5½			2½		5'-11	120	21.218	
577	12'-5½		22.80	2.6350		5'-11	0.001870	0.011	
577	12'-5½			2½		19'-0	120	21.229	
575	12'-5½		13.90	2.6350		19'-0	0.000748	0.014	
575	12'-5½			2½		6'-7	120	21.243	
576	12'-5½		6.45	2.6350		6'-7	0.000181	0.001	
576	12'-5½		0.87	1½	(See Notes)	51'-9	120	21.244	PO(9'-11), Flow (q) from Route 21 E(4'-11½)
620	12'-5½		7.32	1.6820		14'-10	0.002031	0.135	
620	12'-5½		8.25	1½	(See Notes)	66'-7		120	21.380
659	12'-5½		15.57	1.6820		45'-5½	0.008216	0.536	2E(4'-11½), T(9'-11)
					19'-9½				
					65'-3				

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	
		Total (Foot)	Friction(Pf)						
659	12'-5½			1½	(See Notes)	62'-1½	120	21.916	
787	11'-1½		8.36	1.6820		24'-9	0.002600	0.578	
						86'-10½		0.226	
								22.720	Total(Pt) Route 14
658	12'-5½		16.36	1½	(See Notes)	77'-7	120	21.879	••••• Route 15 ••••• Flow (q) from Route 16 2E(4'-11½), PO(9'-11)
785	11'-1½		8.25	1.6820		19'-9½	0.002537	0.578	
						97'-4½		0.247	
								22.704	
577	12'-5½			1½	(See Notes)	33'-6	120	21.229	••••• Route 16 ••••• PO(9'-11) T(9'-11)
623	12'-5½		8.90	1.6820		19'-9½	0.002922		
						53'-3½		0.156	
623	12'-5½		7.45	1½	(See Notes)	45'-0½		120	
658	12'-5½		16.36	1.6820		9'-11	0.008999		
						54'-11		0.494	
								21.879	Total(Pt) Route 16
1278	11'-1½		0.06	1½	(See Notes)	32'-8½	120	22.695	••••• Route 17 ••••• Flow (q) from Route 19 PO(9'-11)
1275	11'-1½		0.03	1.6820		9'-11	0.000000		
						42'-7½		0.000	
								22.695	
1278	11'-1½		0.06	1½	(See Notes)	41'-2½	120	22.695	••••• Route 18 ••••• T(9'-11), Flow (q) from Route 19 E(4'-11½), PO(9'-11)
1215	11'-1½		0.03	1.6820		24'-9	0.000000		
						65'-11½		0.000	
								22.695	
1287	11'-1½		0.03 + 0.03	1½	(See Notes)	51'-4½	120	22.695	••••• Route 19 ••••• Flow (q) from Route 27 and 34 2E(4'-11½), T(9'-11)
1278	11'-1½		0.06	1.6820		19'-9½	0.000000		
						71'-2		0.000	
								22.695	
568	12'-5½		22.10	1½	(See Notes)	130'-4½	120	21.242	••••• Route 20 ••••• PO(9'-11), Flow (q) from Route 40 E(4'-11½), PO(9'-11)
815	11'-1½		12.97	1.6820		24'-9	0.005860	0.578	
						155'-1½		0.909	
								22.729	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes
568	12'-5½		22.10	2½		6'-1	120	21.242	••••• Route 21 ••••• Flow (q) from Route 40
571	12'-5½		9.12	2.6350		6'-1	0.000343	0.002	
571	12'-5½			2½		18'-3	120	21.244	
576	12'-5½		0.87	2.6350		18'-3	0.000004	0.000	
								21.244	Total(Pt) Route 21
571	12'-5½			1½	(See Notes)	33'-6	120	21.244	••••• Route 22 ••••• PO(9'-11)  T(9'-11)
620	12'-5½		8.25	1.6820		19'-9½	0.002540	0.135	
						53'-3½			
								21.380	Total(Pt) Route 22
583	12'-5½			1½	(See Notes)	130'-4½	120	21.218	••••• Route 23 ••••• PO(9'-11)  E(4'-11½), PO(9'-11)
774	11'-1½		12.90	1.6820		24'-9	0.005802	0.578	
						155'-1½		0.900	
								22.696	Total(Pt) Route 23
564	12'-5½		35.38	2½		14'-5	120	21.205	••••• Route 24 ••••• Flow (q) from Route 1
563	12'-5½		13.42	2.6350		14'-5	0.000701	0.010	
563	12'-5½			1½	(See Notes)	132'-4½	120	21.215	PO(9'-11)  3E(4'-11½), PO(9'-11)
810	11'-1½		13.42	1.6820		34'-8	0.006239	0.578	
810	11'-1½			4		167'-0½		1.042	
810	11'-1½			4	(See Notes)	2'-10	120	22.835	T(26'-4)
812	11'-1½		13.42	4.2600		26'-4	0.000068	0.002	
						29'-2			
								22.837	Total(Pt) Route 24
1295	11'-1½			2½		6'-1	120	22.695	••••• Route 25 •••••
1349	11'-1½		0.14	2.6350		6'-1	0.000000	0.000	
1349	11'-1½			1½	(See Notes)	168'-10	120	22.695	PO(9'-11)  PO(9'-11)
1359	11'-1½		0.05	1.6820		19'-9½	0.000000	0.000	
						188'-7½			
								22.695	Total(Pt) Route 25

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
	Node 2		Elev 2 (Foot)	Total Flow (Q)		Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	
			Total (Foot)		Friction(Pf)				
1349	11'-1½		0.05	2½		16'-8	120	22.695	••••• Route 26 ••••• Flow (q) from Route 25
1457	11'-1½		0.09	2.6350		16'-8	0.000000	0.000	
								22.695	
1097	11'-1½			2½		8'-8	120	22.695	••••• Route 27 •••••
1184	11'-1½		0.20	2.6350		8'-8	0.000000	0.000	
1184	11'-1½			2½		16'-9	120	22.695	
1295	11'-1½		0.17	2.6350		16'-9	0.000000	0.000	
1295	11'-1½			1½	(See Notes)	99'-6	120	22.695	PO(9'-11) E(4'-11½), 2T(9'-11)
1287	11'-1½		0.03	1.6820		34'-8	0.000000		
						134'-2		0.000	
								22.695	Total(Pt) Route 27
938	11'-1½		0.33	1½	(See Notes)	168'-10	120	22.695	••••• Route 28 ••••• PO(9'-11), Flow (q) from Route 31 PO(9'-11)
949	11'-1½		0.06	1.6820		19'-9½	0.000000		
						188'-7½		0.000	
								22.695	Total(Pt) Route 28
938	11'-1½		0.33	2½		6'-4	120	22.695	••••• Route 29 ••••• Flow (q) from Route 31
957	11'-1½		0.27	2.6350		6'-4	0.000000	0.000	
957	11'-1½			2½		18'-0	120	22.695	
1097	11'-1½		0.23	2.6350		18'-0	0.000000	0.000	
1097	11'-1½			1½	(See Notes)	121'-3½	120	22.695	PO(9'-11) 7E(4'-11½)
971	11'-1½		0.03	1.6820		44'-6½	0.000000		
						165'-10		0.000	
								22.695	Total(Pt) Route 29
805	11'-1½		0.39	2½		14'-1	120	22.695	••••• Route 30 ••••• Flow (q) from Route 39
884	11'-1½		0.39	2.6350		14'-1	0.000001	0.000	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes	
										Node 2
884	11'-1½			1½	(See Notes)	168'-10	120	22.695	PO(9'-11)	
899	11'-1½		0.07	1.6820		19'-9½	0.000000			PO(9'-11)
						188'-7½				
								22.695	Total(Pt) Route 30	
884	11'-1½		0.07	2½	(See Notes)	16'-8	120	22.695	..... Route 31 ..... Flow (q) from Route 30	
938	11'-1½		0.33	2.6350		16'-8	0.000001			0.000
								22.695		
587	12'-5½		13.63	1½	(See Notes)	126'-11½	120	21.203	..... Route 32 ..... Flow (q) from Route 35	
738	11'-1½		13.63	1.6820		14'-10	0.006420	0.578		E(4'-11½), PO(9'-11)
						141'-9½				
738	11'-1½			4	(See Notes)	19'-11	120	22.691	E(13'-2)	
796	11'-1½		13.63	4.2600		13'-2	0.000070			0.002
						33'-1				
796	11'-1½			4	(See Notes)	0'-10½	120	22.693	T(26'-4)	
825	11'-1½		13.23	4.2600		26'-4	0.000066			0.002
						27'-2½				
								22.695	Total(Pt) Route 32	
575	12'-5½			1½	(See Notes)	52'-5½	120	21.243	..... Route 33 ..... PO(9'-11)	
623	12'-5½		7.45	1.6820		14'-10	0.002102			E(4'-11½)
						67'-4				
								21.385	Total(Pt) Route 33	
1184	11'-1½			1½	(See Notes)	112'-11	120	22.695	..... Route 34 ..... PO(9'-11)	
1287	11'-1½		0.03	1.6820		24'-9	0.000000			3E(4'-11½)
						137'-8				
								22.695	Total(Pt) Route 34	
585	12'-5½		49.33	2½	(See Notes)	13'-8½	120	21.145	..... Route 35 ..... 2T(16'-5½), C(16'-5½), Flow (q) from Route 41 PO(16'-5½)	
587	12'-5½		13.63	2.6350		65'-11	0.000721			0.057
						79'-7				
								21.203	Total(Pt) Route 35	
983	11'-1½			1½	(See Notes)	41'-2	120	22.695	..... Route 36 ..... T(9'-11)	
1037	11'-1½		0.03	1.6820		24'-9	0.000000			E(4'-11½), PO(9'-11)
						65'-11				



## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)		
					Total (Foot)		Friction(Pf)		
								22.695	Total(Pt) Route 36
659	12'-5½			1½	(See Notes)	78'-3	120	21.916	••••• Route 37 ••••• T(9'-11) 2E(4'-11½), PO(9'-11)
789	11'-1½		7.21	1.6820		29'-8½	0.001977	0.578	
						107'-11½		0.213	
								22.707	Total(Pt) Route 37
957	11'-1½			1½	(See Notes)	100'-0	120	22.695	••••• Route 38 ••••• PO(9'-11) 2E(4'-11½), T(9'-11)
971	11'-1½		0.04	1.6820		29'-8½	0.000000		
						129'-8½		0.000	
								22.695	Total(Pt) Route 38
796	11'-1½			1½	(See Notes)	168'-10	120	22.693	••••• Route 39 ••••• PO(9'-11) PO(9'-11)
805	11'-1½		0.39	1.6820		19'-9½	0.000009		
						188'-7½		0.002	
								22.695	Total(Pt) Route 39
565	12'-5½		13.29	2½		12'-8	120	21.220	••••• Route 40 ••••• Flow (q) from Route 1
568	12'-5½		22.10	2.6350			0.001764		
						12'-8		0.022	
								21.242	Total(Pt) Route 40
492	12'-5½		33.18 + 6.88	2½	(See Notes)	6'-2	120	20.371	••••• Route 41 ••••• Flow (q) from Route 42 and 47 2T(16'-5½)
493	12'-5½		40.06	2.6350		32'-11½	0.005302		
						39'-1½		0.207	
493	12'-5½		9.27	2½	(See Notes)	23'-3	120	20.579	Flow (q) from Route 43 2T(16'-5½), C(16'-5½)
585	12'-5½		49.33	2.6350		49'-5	0.007794		
						72'-8		0.566	
								21.145	Total(Pt) Route 41
491	12'-5½		6.85 + 26.33	2½		1'-9	120	20.365	••••• Route 42 ••••• Flow (q) from Route 44 and 48
492	12'-5½		33.18	2.6350			0.003742		
						1'-9		0.007	
								20.371	Total(Pt) Route 42
41	12'-5½			2		1'-9	120	20.108	••••• Route 43 •••••
42	12'-5½		16.15	2.1570			0.002618		
						1'-9		0.005	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value
	Node 2		Elev 2 (Foot)	Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
Total		Total							
42	12'-5½			2	(See Notes)	20'-3½	120	20.112	PO(12'-3½)
43	12'-5½		9.27	2.1570		12'-3½	0.000938		
						32'-7		0.031	
43	12'-5½			1½	(See Notes)	123'-3	120	20.143	PO(9'-11)
494	12'-5½		9.27	1.6820		9'-11	0.003150		
						133'-2		0.419	
494	12'-5½			2½	(See Notes)	14'-1½	120	20.562	2T(16'-5½)
493	12'-5½		9.27	2.6350		32'-11½	0.000354		
						47'-0½		0.017	
								20.579	Total(Pt) Route 43
38	12'-5½		15.82	2		13'-1½	120	20.041	..... Route 44 ..... Flow (q) from Route 1
41	12'-5½		23.00	2.1570		13'-1½	0.005035	0.066	
41	12'-5½			1½	(See Notes)	123'-3	120	20.108	PO(9'-11)
491	12'-5½		6.85	1.6820		19'-9½	0.001798		PO(9'-11)
						143'-1		0.257	
								20.365	Total(Pt) Route 44
30	12'-5½		6.29	2		1'-8½	120	20.220	..... Route 45 ..... Flow (q) from Route 1
29	12'-5½		15.15	2.1570		1'-8½	0.002327	0.004	
29	12'-5½			1½	(See Notes)	123'-3	120	20.224	PO(9'-11)
464	12'-5½		6.33	1.6820		19'-9½	0.001556		PO(9'-11)
						143'-1		0.223	
								20.446	Total(Pt) Route 45
29	12'-5½		6.33	2	(See Notes)	20'-6	120	20.224	..... Route 46 ..... Flow (q) from Route 45
24	12'-5½		8.82	2.1570		12'-3½	0.000855		
						32'-9½		0.028	
24	12'-5½			1½	(See Notes)	123'-3	120	20.252	PO(9'-11)
462	12'-5½		8.82	1.6820		9'-11	0.002871		
						133'-2		0.382	
462	12'-5½			2½	(See Notes)	14'-11½	120	20.634	2T(16'-5½)
463	12'-5½		8.82	2.6350		32'-11½	0.000323		
						47'-11		0.015	

## Pipe Information

Node 1	Elev 1 (Foot)	K-Factor	Flow added this step (q)	Nominal ID	Fittings & Devices	Length (Foot)	C Factor	Total(Pt)	Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value.
Node 2	Elev 2 (Foot)		Total Flow (Q)	Actual ID	Equiv. Length (Foot)	Fitting (Foot)	Pf Friction Loss Per Unit (psi)	Elev(Pe)	
						Total (Foot)			
								20.650	Total(Pt) Route 46
42	12'-5½			1½	(See Notes)	123'-3	120	20.112	••••• Route 47 ••••• PO(9'-11)  PO(9'-11)
492	12'-5½		6.88	1.6820		19'-9½	0.001812		
						143'-1		0.259	
								20.371	Total(Pt) Route 47
480	12'-5½		12.11	2½	(See Notes)	14'-6½	120	20.269	••••• Route 48 ••••• Flow (q) from Route 2  3E(8'-3)
491	12'-5½		26.33	2.6350		24'-8½	0.002440		
						39'-3		0.096	
								20.365	Total(Pt) Route 48

**Equivalent Pipe Lengths of Valves and Fittings (C=120 only)**

**C Value Multiplier**


$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

**Fittings Legend**

ALV Alarm Valve	AngV Angle Valve	b Bushing
BalV Ball Valve	BFP Backflow Preventer	BV Butterfly Valve
C Cross Flow Turn 90°	cplg Coupling	Cr Cross Run
CV Check Valve	DelV Deluge Valve	DPV Dry Pipe Valve
E 90° Elbow	EE 45° Elbow	Ee1 11¼° Elbow
Ee2 22½° Elbow	f Flow Device	fd Flex Drop
FDC Fire Department Connectic	fE 90° FireLock(TM) Elbow	fEE 45° FireLock(TM) Elbow
flg Flange	FN Floating Node	fT FireLock(TM) Tee
g Gauge	GloV Globe Valve	GV Gate Valve
Ho Hose	Hose Hose	HV Hose Valve
Hyd Hydrant	LtE Long Turn Elbow	mecT Mechanical Tee
Noz Nozzle	P1 Pump In	P2 Pump Out
PIV Post Indicating Valve	PO Pipe Outlet	PrV Pressure Relief Valve
PRV Pressure Reducing Valve	red Reducer/Adapter	S Supply
sCV Swing Check Valve	SFx Seismic Flex	Spr Sprinkler
St Strainer	T Tee Flow Turn 90°	Tr Tee Run
U Union	WirF Wirsbo	WMV Water Meter Valve
Z Cap		

# WATER TEST



Carolina Fire Protection, Inc.

# Sprinkler Inspection Certificate

*For*

Overhills Elementary School  
2626 Ray Road  
Spring Lake, NC 28390

Tested to NFPA 25 Standards

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*



*Annual Inspection  
Inspection Date  
Jun 16, 2022*

Building: Overhills Elementary School  
Contact: Lynn Harris  
Title: Manager

Company: Carolina Fire Protection, Inc.  
Contact: Jack Eldridge  
Title: Inspector

# Executive Summary

Generated by: BuildingReports.com

Building Information								
<b>Building:</b> Overhills Elementary School			<b>Contact:</b> Lynn Harris					
<b>Address:</b> 2626 Ray Road			<b>Phone:</b> 910-814-7840					
<b>Address:</b>			<b>Fax:</b>					
<b>City/State/ZIP Code:</b> Spring Lake, NC 28390			<b>Mobile:</b>					
<b>Country:</b> United States of America			<b>Email:</b> rharris1@harnett.k12.nc.us					
Inspection Performed By								
<b>Company:</b> Carolina Fire Protection, Inc.			<b>Inspector:</b> Jack Eldridge					
<b>Address:</b> 4055 Hodges Chapel Road			<b>Phone:</b> 910-892-1700					
<b>Address:</b>			<b>Fax:</b>					
<b>City/State/ZIP Code:</b> Dunn, North Carolina 28334			<b>Mobile:</b>					
<b>Country:</b> United States of America			<b>Email:</b> jeldridge@carolinafireprotection.com					
System Control Unit								
System Type	System Location			Protected Area			Devices	
Cross Conn. Control							7	
Fire Pump							19	
Wet Pipe							19	
Inspection Summary								
Category:	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Alarm	7	15.56%	7	100.00%	4	57.14%	3	42.86%
Device	10	22.22%	10	100.00%	2	20.00%	8	80.00%
Hose	1	2.22%	1	100.00%	1	100.00%	0	0.00%
Pump	5	11.11%	5	100.00%	3	60.00%	2	40.00%
Sprinkler	4	8.89%	4	100.00%	2	50.00%	2	50.00%
Valve	18	40.00%	18	100.00%	18	100.00%	0	0.00%
<b>Totals</b>	<b>45</b>	<b>100%</b>	<b>45</b>	<b>100.00%</b>	<b>30</b>	<b>66.67%</b>	<b>15</b>	<b>33.33%</b>
Certification								
<b>Company:</b> Carolina Fire Protection, Inc.			<b>Building:</b> Overhills Elementary School					
<b>Inspector:</b> Jack Eldridge			<b>Contact:</b> Lynn Harris					
								
<b>Signed:</b> Jun 16, 2022			<b>Signed:</b> Jun 16, 2022					

# Discrepancy Report

Generated by: BuildingReports.com

Building: Overhills Elementary School				
<p>The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.</p>				
Device Type	Manufacturer	ModelNumber	Date	Qty
<b>Items listed for Recall or Replacement/Upgrade</b>				
No items found during this inspection.				
ScanID	Location	Problem	Reference	
<b>Cross Conn. Control</b>				
<b>Tamper Switch</b>				
1 62796478	Hot Box	Special Note	NFPA25 4.1.5.1	
1 62796481	Hot Box	Special Note	NFPA25 4.1.5.1	
<b>Fire Pump</b>				
<b>Critical Deficiencies</b>				
<b>Controller</b>				
2 62796487	Controller	Special Note	NFPA25 8.4.1	
<b>Diesel Driver</b>				
4 62796493	Diesel Driver			
<b>Non-Critical Deficiencies</b>				
<b>Gauge</b>				
62796489	Pump Room	Date Expired	NFPA25 5.3.2.1	
62796490	Pump Room	Date Expired	NFPA25 5.3.2.1	
62796491	Pump Room	Date Expired	NFPA25 5.3.2.1	
62796492	Pump Room	Date Expired	NFPA25 5.3.2.1	
<b>Waterflow Switch</b>				
62796498	Pump Room Riser	Special Note	NFPA25 4.1.5.1	
<b>Wet Pipe</b>				
<b>Dry Sprinkler</b>				
62796562	Coolers/ Freezers	Requires Maintenance	NFPA25 5.3.1.1.1.6	
<b>Gauge</b>				
62796504	Riser #1	Date Expired	NFPA25 5.3.2.1	
62796505	Riser #1	Date Expired	NFPA25 5.3.2.1	
62796506	Riser #2	Date Expired	NFPA25 5.3.2.1	



ScanID	Location	Problem	Reference
62796507	Riser #2	Date Expired	NFPA25 5.3.2.1
<b>Piping</b>			
1 62796565	5 Year Pipe Assessment		
<b><i>Code References</i></b>			
NFPA25 4.1.5.1	The property owner or designated representative shall correct or repair deficiencies or impairments that are found during the inspection, test, and maintenance required by this standard.		
NFPA25 8.4.1	Any abnormality observed during inspection or testing shall be reported promptly to the property owner or designated representative.		
NFPA25 5.3.2.1	Gauges shall be replaced every 5 years or tested every 5 years by comparison with a calibrated gauge.		
NFPA25 5.3.1.1.1.6	Dry sprinklers that have been in service for 10 years shall be replaced or representative samples shall be tested and then retested at 10-year intervals.		

# Proposed Solutions Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: Overhills Elementary School						
<p><i>The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.</i></p>						
ScanID	Location	Solution	Model #	Cost	Fix	Fixed Date
<b><i>Cross Conn. Control</i></b>						
<b>Tamper Switch</b>						
62796478	Hot Box	See Notes	OSYSU-2	T/M	<input type="checkbox"/>	12/15/22
62796481	Hot Box	See Notes	OSYSU-2	T/M	<input type="checkbox"/>	12/15/22
<b><i>Fire Pump</i></b>						
<b><i>Critical Deficiencies</i></b>						
<b>Controller</b>						
62796487	Controller	See Notes	FTA1100-JL12N	T/M	<input type="checkbox"/>	12/15/22
<b>Diesel Driver</b>						
62796493	Diesel Driver	Replace/Repair	JU4H-UF12	T/M	<input type="checkbox"/>	12/15/22
<b><i>Non-Critical Deficiencies</i></b>						
<b>Gauge</b>						
62796489	Pump Room	Replace		T/M	<input type="checkbox"/>	12/15/22
62796490	Pump Room	Replace		T/M	<input type="checkbox"/>	12/15/22
62796491	Pump Room	Replace		T/M	<input type="checkbox"/>	12/15/22
62796492	Pump Room	Replace		T/M	<input type="checkbox"/>	12/15/22
<b>Waterflow Switch</b>						
62796498	Pump Room Riser	See Notes	WFDT	T/M	<input type="checkbox"/>	12/15/22
<b><i>Wet Pipe</i></b>						
<b>Dry Sprinkler</b>						
62796562	Coolers/ Freezers	Replace/Test		T/M	<input type="checkbox"/>	12/15/22
<b>Gauge</b>						
62796504	Riser #1	Replace		T/M	<input type="checkbox"/>	12/15/22
62796505	Riser #1	Replace		T/M	<input type="checkbox"/>	12/15/22
62796506	Riser #2	Replace		T/M	<input type="checkbox"/>	12/15/22
62796507	Riser #2	Replace		T/M	<input type="checkbox"/>	12/15/22
<b>Piping</b>						
62796565	5 Year Pipe Assessment	5 Year Service		T/M	<input type="checkbox"/>	12/15/22
				<b>PO #: (none) T/M</b>		

# Inspection & Testing

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: Overhills Elementary School					
<p><i>The Inspection &amp; Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time &amp; date at which testing occurred.</i></p>					
Device Type	Location	Service	Time	Date	
<b><i>Passed</i></b>					
<b>Cross Conn. Control</b>					
Backflow Prevention	Hot Box	Annual	10:45:16 AM	06/16/2022	
Backflow Prevention	Hot Box	Annual	10:55:51 AM	06/16/2022	
Backflow Prevention	Hot Box	Annual	10:56:41 AM	06/16/2022	
Control Valve	Hot Box	Annual	10:59:58 AM	06/16/2022	
Control Valve	Hot Box	Annual	11:00:10 AM	06/16/2022	
<b>Fire Pump</b>					
Tamper Switch	Pump Room	Annual	2:07:57 PM	06/16/2022	
Tamper Switch	Pump Room	Annual	2:08:08 PM	06/16/2022	
Jockey Controller	Jockey Pump	Annual	3:11:23 PM	06/16/2022	
Jockey Controller	Jockey Controller	Annual	3:11:29 PM	06/16/2022	
Pump	Pump	Annual	3:11:36 PM	06/16/2022	
Control Valve	Pump Room	Annual	1:46:00 PM	06/16/2022	
Control Valve	Pump Room	Annual	1:46:32 PM	06/16/2022	
Control Valve	Pump Room Riser	Annual	1:47:04 PM	06/16/2022	
Control Valve	City Bypass	Annual	2:07:53 PM	06/16/2022	
Control Valve	Pump Room	Annual	2:07:56 PM	06/16/2022	
Control Valve	City Bypass	Annual	2:08:06 PM	06/16/2022	
Control Valve	Pump Room	Annual	2:08:09 PM	06/16/2022	
<b>Wet Pipe</b>					
Waterflow Switch	Riser #2	Annual	2:37:28 PM	06/16/2022	
Waterflow Switch	Riser #1	Annual	2:37:40 PM	06/16/2022	
Drain	Riser #2	Annual	2:37:31 PM	06/16/2022	
Drain	Riser #1	Annual	2:37:42 PM	06/16/2022	
Fire Dept Connection	Pump Room	Annual	2:46:31 PM	06/16/2022	
Fast Response	Building	Annual	2:44:22 PM	06/16/2022	
Piping	Building	Annual	2:44:21 PM	06/16/2022	

Device Type	Location	Service	Time	Date
Check Valve	Riser #2	Annual	2:37:34 PM	06/16/2022
Check Valve	Riser #1	Annual	2:37:37 PM	06/16/2022
Control Valve	Riser #2	Annual	2:37:33 PM	06/16/2022
Control Valve	Riser #1	Annual	2:37:36 PM	06/16/2022
Inspector's Test	Riser #2	Annual	2:37:29 PM	06/16/2022
Inspector's Test	Riser #1	Annual	2:37:41 PM	06/16/2022
<b><i>Failed/Other</i></b>				
<b>Cross Conn. Control</b>				
1 Tamper Switch	Hot Box	Annual	10:59:21 AM	06/16/2022
1 Tamper Switch	Hot Box	Annual	11:01:03 AM	06/16/2022
<b>Fire Pump</b>				
Waterflow Switch	Pump Room Riser	Annual	2:34:07 PM	06/16/2022
Gauge	Pump Room	Annual	2:07:13 PM	06/16/2022
Gauge	Pump Room	Annual	2:08:11 PM	06/16/2022
Gauge	Pump Room	Annual	3:11:31 PM	06/16/2022
Gauge	Pump Room	Annual	3:11:46 PM	06/16/2022
2 Controller	Controller	Annual	4:23:21 PM	06/16/2022
4 Diesel Driver	Diesel Driver	Annual	4:23:14 PM	06/16/2022
<b>Wet Pipe</b>				
Gauge	Riser #2	Annual	2:37:25 PM	06/16/2022
Gauge	Riser #2	Annual	2:37:27 PM	06/16/2022
Gauge	Riser #1	Annual	2:37:38 PM	06/16/2022
Gauge	Riser #1	Annual	2:37:38 PM	06/16/2022
Dry Sprinkler	Coolers/ Freezers	Inspected from Floor	2:44:23 PM	06/16/2022
1 Piping	5 Year Pipe Assessment	5 Year Service	2:44:20 PM	06/16/2022

# Wet Pipe Fire Sprinkler Systems

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: Overhills Elementary School								
<p><i>This section lists out all the devices and components that have been associated with a Wet Pipe System and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.</i></p>								
<i>Alarms</i>								
Waterflow Switch								
Type	Manufacturer	Model #	Sec	Size	Zone/Address	OK	ScanID	
Vane	Potter	VSR		4	1	<input checked="" type="checkbox"/>	62796568	
Vane	Potter	VSR		4	1	<input checked="" type="checkbox"/>	62796503	
<i>Components</i>								
Check Valve								
Type	Location	Internal Date			Size	OK	ScanID	
Grooved	Riser #2	01/01/2016			4"	<input checked="" type="checkbox"/>	62796515	
Grooved	Riser #1	01/01/2016			4"	<input checked="" type="checkbox"/>	62796500	
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	Victaulic	705W	Riser #2	4"	Open	Supervised	<input checked="" type="checkbox"/>	62796514
Description								
Main Control								
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	Victaulic	705W	Riser #1	4"	Open	Supervised	<input checked="" type="checkbox"/>	62796510
Description								
Main Control								
Inspector's Test								
Manufacturer	Model #	Pressure psi	Valve Trip Time sec	Water Flow Time sec	OK	ScanID		
Globe					<input checked="" type="checkbox"/>	62796566		
Location								
Riser #2								
Inspector's Test								
Manufacturer	Model #	Pressure psi	Valve Trip Time sec	Water Flow Time sec	OK	ScanID		
Globe					<input checked="" type="checkbox"/>	62796567		
Location								
Riser #1								
<i>Devices</i>								
Drain								
Current Inspection								

Type	Location	Size	Supply psi	Restored psi	Residual psi	Sec	OK	ScanID
Main	Riser #2	2"	155	155	115		<input checked="" type="checkbox"/>	62796511
<b>Current Inspection</b>								
Type	Location	Size	Supply psi	Restored psi	Residual psi	Sec	OK	ScanID
Main	Riser #1	2"	155	155	115		<input checked="" type="checkbox"/>	62796509
<b>Dry Sprinkler</b>								
Qty	Type	Size	KFactor	Finish	Temperature	OK	ScanID	
3	Pendant	1		Chrome	155	<input type="checkbox"/>	62796562	
<b>Location</b>				<b>Description</b>				
Coolers/ Freezers								
<b>Fast Response</b>								
Qty	Type	Size	KFactor	Finish	Temperature	OK	ScanID	
						<input checked="" type="checkbox"/>	62796563	
<b>Location</b>				<b>Description</b>				
Building								
<b>Fire Dep't Connection</b>								
Location	Type	BallDrip	Rotating Swivels	Size	OK	ScanID		
Pump Room	Wall		Yes	4"	<input checked="" type="checkbox"/>	62796561		
<b>Gauge</b>								
<b>Location</b>				<b>Service Date</b>				
Riser #2				01/01/2016				
Type	Manufacturer	Model #	Static psi	Fill Type	Size	OK	ScanID	
Supply Pressure			155		1/4	<input type="checkbox"/>	62796506	
<b>Gauge</b>								
<b>Location</b>				<b>Service Date</b>				
Riser #2				01/01/2016				
Type	Manufacturer	Model #	Static psi	Fill Type	Size	OK	ScanID	
System Pressure			155		1/4	<input type="checkbox"/>	62796507	
<b>Gauge</b>								
<b>Location</b>				<b>Service Date</b>				
Riser #1				01/01/2016				
Type	Manufacturer	Model #	Static psi	Fill Type	Size	OK	ScanID	
System Pressure			155		1/4	<input type="checkbox"/>	62796504	
<b>Gauge</b>								
<b>Location</b>				<b>Service Date</b>				
Riser #1				01/01/2016				
Type	Manufacturer	Model #	Static psi	Fill Type	Size	OK	ScanID	
Supply Pressure			155		1/4	<input type="checkbox"/>	62796505	
<b>Piping</b>								
Location	Type	Size	Internal Date					

Building	Steel	01/01/2016			
Hangers	Braces	Fittings	Identified	Antifreeze	ScanID
Normal	Normal				62796564
Piping					
Location	Type	Size	Internal Date		
5 Year Pipe Assessment			01/01/2016		
Hangers	Braces	Fittings	Identified	Antifreeze	ScanID
					62796565

# Backflow Test & Maintenance Report

Generated by: BuildingReports.com

**Building: Overhills Elementary School**

This section lists out all the devices and components that have been associated with a Cross Connection Control System and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.

## Alarms

### Tamper Switch

Type	Description	Location	Number of Turns	Zone /Address	OK	ScanID
OS&Y		Hot Box		1	<input type="checkbox"/>	62796481
OS&Y		Hot Box		1	<input type="checkbox"/>	62796478

## Components

### Backflow Prevention

Manufacturer	Model #	Size	Type	Service Type	Install Date
Ames	4000SS	4"	Reduced Pressure	Potable	01/01/2003
ScanID	Water Purveyor	Location	Meter Account #	Serial Number	
62796475		Hot Box		118359	

### Initial Test

Check Valve 1	Check Valve 2	Relief Valve	Pressure Vacuum Breaker
6.2	2.0 70Psi	2.4	
Held At	Repairs or Notes		

### Final Test

Check Valve 1	Check Valve 2	Relief Valve	Pressure Vacuum Breaker
Held At	Condition of Control Valve 1	Condition of Control Valve 2	
		Closed Tight	

### Backflow Prevention

Manufacturer	Model #	Size	Type	Service Type	Install Date
Ames	4000B	0.75"	Reduced Pressure	Fire Line Bypass	01/01/2003
ScanID	Water Purveyor	Location	Meter Account #	Serial Number	
62796477		Hot Box	Bypass 34651264	09514	

### Initial Test

Check Valve 1	Check Valve 2	Relief Valve	Pressure Vacuum Breaker
8.0	1.6 70Psi	2.2	
Held At	Repairs or Notes		

### Final Test

--	--	--	--



Check Valve 1		Check Valve 2		Relief Valve		Pressure Vacuum Breaker		
Held At		Condition of Control Valve 1		Condition of Control Valve 2				
				Closed Tight				
<b>Backflow Prevention</b>								
Manufacturer	Model #	Size	Type		Service Type		Install Date	
Ames	5000SS	6"	Reduced Press. Det.		Fire Line		01/01/2003	
ScanID	Water Purveyor	Location			Meter Account #		Serial Number	
62796480		Hot Box			Bypass 34651264		104110	
<b>Initial Test</b>								
Check Valve 1		Check Valve 2		Relief Valve		Pressure Vacuum Breaker		
6.8		2.6 70Psi		2.0				
Held At		Repairs or Notes						
<b>Final Test</b>								
Check Valve 1		Check Valve 2		Relief Valve		Pressure Vacuum Breaker		
Held At		Condition of Control Valve 1		Condition of Control Valve 2				
				Closed Tight				
<b>Control Valve</b>								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	Kennedy		Hot Box	6"	Open	Sealed	<input checked="" type="checkbox"/>	62796479
<b>Description</b>								
Suction								
<b>Control Valve</b>								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	Kennedy		Hot Box	6"	Open	Sealed	<input checked="" type="checkbox"/>	62796482
<b>Description</b>								
Discharge								

# Fire Pump Testing

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: Overhills Elementary School										
<p><i>This section lists out all the devices and components that have been associated with a Fire Pump and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.</i></p>										
<i>Controller</i>										
Manufacturer	Model #	Location				Install Date	Serial Number			
FireTrol	FTA1100-JL12N	Controller				01/01/2003	471533-07RE			
AC Power	Time Meter	Start psi	Stop psi	Battery Supervised	Generator Backup					
Normal Phase										
<i>Diesel Driver</i>										
Manufacturer	Model #	Location				Install Date	Serial Number			
Clarke	JU4H-UF12	Diesel Driver				01/01/2003	PE4045D734587			
	Fuel	Oil	Water	Timing Min/Sec		Speed	Oil	AF	Water	
	3/4	Normal	Normal	Crank	Run	rpm	psi	deg	deg	Oil deg
<i>Jockey Controller</i>										
Manufacturer	Model #	Location				Install Date	Serial Number			
Goulds		Jockey Pump				01/01/2003				
AC Power	Time Meter	Start psi	Stop psi	Battery Supervised	Generator Backup					
<i>Jockey Controller</i>										
Manufacturer	Model #	Location				Install Date	Serial Number			
Peerless	269853903 FTA	Jockey Controller				01/01/2003				
AC Power	Time Meter	Start psi	Stop psi	Battery Supervised	Generator Backup					
		145	155							
Normal Phase										
<i>Pump</i>										
Manufacturer	Model Number	Location				Install Date	ScanID			
Peerless	5AEF11	Pump				01/01/2003	62796483			
Serial Number	Type	Orientation		Aligned?	Water Supply	Impeller Size				
746233	Pump Primary	Horizontal Split Case			Municipal	9.42				
<i>Pump Tests</i>										
Discharge Device	Date	Disch. PSI	Suct. PSI	GPM	RPM	% Rated Flow	Oil Pressure	Water Temperature		
Other	06/16/2022	138	56		2530					
Amps A	Amps B	Amps C		Volts A-B		Volts B-C		Volts A-C		
Discharge Device	Date	Disch. PSI	Suct. PSI	GPM	RPM	% Rated Flow	Oil Pressure	Water Temperature		

Other 06/16/2022 92 20 776 2509 103%

Amps A	Amps B	Amps C	Volts A-B	Volts B-C	Volts A-C
--------	--------	--------	-----------	-----------	-----------

Discharge Device	Date	Disch. PSI	Suct. PSI	GPM	RPM	% Rated Flow	Oil Pressure	Water Temperature
------------------	------	------------	-----------	-----	-----	--------------	--------------	-------------------


Other 06/16/2022 84 17 936 2511 125%

Amps A	Amps B	Amps C	Volts A-B	Volts B-C	Volts A-C
--------	--------	--------	-----------	-----------	-----------

### Fire Pump Rating

Net Pressure	Gallons Per Minute	Rotations Per Minute	Amps			Volts		
			A	B	C	A-B	B-C	A-C
88		2600						
80	750	2600						
65	1125	2600						

### Pump Flow Test Overhills Elementary School



### Alarms

#### Tamper Switch

Type	Description	Location	Number of Turns	Zone /Address	OK	ScanID
OS&Y	Supervisory	Pump Room		1	<input checked="" type="checkbox"/>	62796484

OS&Y	Supervisory	Pump Room	1	<input checked="" type="checkbox"/>	62796494
------	-------------	-----------	---	-------------------------------------	----------

**Waterflow Switch**

Type	Manufacturer	Model #	Sec	Size	Zone/Address	OK	ScanID
Vane	System Sensor	WFDT		1"	1	<input type="checkbox"/>	62796498

*Components*

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	LansDale		Pump Room	1.25"	Open	Sealed	<input checked="" type="checkbox"/>	62796502

**Description**

Jockey Suction

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	LansDale		Pump Room	1.25"	Open	Sealed	<input checked="" type="checkbox"/>	62796497

**Description**

Jockey Discharge

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	LansDale		Pump Room Riser	1"	Open	Sealed	<input checked="" type="checkbox"/>	62796499

**Description**

Main Control

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	Globe		City Bypass	6"	Open	Supervised	<input checked="" type="checkbox"/>	62796486

**Description**

Bypass

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	Mueller		Pump Room	6"	Open	Supervised	<input checked="" type="checkbox"/>	62796485

**Description**

Suction

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	Globe		City Bypass	6"	Open	Supervised	<input checked="" type="checkbox"/>	62796496

**Description**

Bypass

**Control Valve**

Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	Mueller		Pump Room	6"	Open	Supervised	<input checked="" type="checkbox"/>	62796495

**Description**

Discharge

## *Devices*

<b>Gauge</b>							
<b>Location</b>				<b>Service Date</b>			
Pump Room				01/01/2016			
<b>Type</b>	<b>Manufacturer</b>	<b>Model #</b>	<b>Static psi</b>	<b>Fill Type</b>	<b>Size</b>	<b>OK</b>	<b>ScanID</b>
Fire Pump Controller			160		1/4	<input type="checkbox"/>	62796490
<b>Gauge</b>							
<b>Location</b>				<b>Service Date</b>			
Pump Room				01/01/2016			
<b>Type</b>	<b>Manufacturer</b>	<b>Model #</b>	<b>Static psi</b>	<b>Fill Type</b>	<b>Size</b>	<b>OK</b>	<b>ScanID</b>
Discharge			115		1/4	<input type="checkbox"/>	62796492
<b>Gauge</b>							
<b>Location</b>				<b>Service Date</b>			
Pump Room				01/01/2016			
<b>Type</b>	<b>Manufacturer</b>	<b>Model #</b>	<b>Static psi</b>	<b>Fill Type</b>	<b>Size</b>	<b>OK</b>	<b>ScanID</b>
Jockey Pump Controll			160		1/4	<input type="checkbox"/>	62796489
<b>Gauge</b>							
<b>Location</b>				<b>Service Date</b>			
Pump Room				01/01/2016			
<b>Type</b>	<b>Manufacturer</b>	<b>Model #</b>	<b>Static psi</b>	<b>Fill Type</b>	<b>Size</b>	<b>OK</b>	<b>ScanID</b>
Suction			115		1/4	<input type="checkbox"/>	62796491

# Notes & Recommendations

Generated by: BuildingReports.com

Building: Overhills Elementary School				
The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by SystemID.				
Note	Device Type	Location	Comment	ScanID
<b>Cross Conn. Control</b>				
1	Control Valve Seals 79345-79348	Hot Box	Passed	62796479
2	Control Valve Seals 79346-79347	Hot Box	Passed	62796482
3	Tamper Switch Tampers Are Laying On Ground In Hotbox	Hot Box	Special Note	62796478
4	Tamper Switch Tampers Are Laying On Ground In Hotbox	Hot Box	Special Note	62796481
<b>Fire Pump</b>				
5	Control Valve Seals 79336-79337	Pump Room	Passed	62796485
6	Control Valve Seals 79342-79351	City Bypass	Passed	62796486
7	Control Valve Seals 79335-79338	Pump Room	Passed	62796495
8	Control Valve Seals 79343-79344-79349	City Bypass	Passed	62796496
9	Control Valve Seal 79334	Pump Room	Passed	62796497
10	Control Valve Seal 79339	Pump Room Riser	Passed	62796499
11	Control Valve Seal 79350	Pump Room	Passed	62796502
12	Controllor Transducer Appears To Be Bad. Pump Will Not Start In Auto.	Controllor	Special Note	62796487
13	Diesel Driver Pump Over Heated. Ran For Approximately 8 minutes and Come Back To Pump Room And Engine Was Leaking Water And Steaming. Customer Stated Same Thing Happened The Previous Year. Called Richard Collum He Sated He Thought Was The Pressure Reducer On Coolant Line Or Possibly Water Pump. Topped Reservoir Off With Coolant And Left Normal. Need To Repair Cooling Line Or Go Through Coolant System.  Fuel Tank Needs Filling Up. Under 1/2 Full.	Diesel Driver		62796493
14	Jockey Controllor Could Not Read Data Plate	Jockey Pump	Passed	62796501
15	Pump	Pump	Passed	62796483

Note	Device Type	Location	Comment	ScanID
			Used 2- 1-3/4 Hose Monsters with 25' Hoses.	
16	Waterflow Switch	Pump Room Riser	Special Note	62796498
			Had To Test Switch Manually No ITV. Switch Comes Into FACP As A Supervisory.	
<b>Wet Pipe</b>				
17	Control Valve	Riser #1	Passed	62796510
			Seals 79331-79322	
18	Control Valve	Riser #2	Passed	62796514
			Seals 79332-79341	
19	Fast Response	Building	Passed	62796563
			May Want To Go Ahead And 20 Year Test Sprinkler Heads When Doing Other Work.	
20	Piping	5 Year Pipe Assessment		62796565
			1/2" or 3/4" Brass 155 QR Upright. Grooved Pipe Ladder or Lift Possible Maybe In Gym.	