

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

April 14, 2023

ph: 910-893-7547

fax: 910-893-9371

Mattamy Homes, LLC
11000 Regency Parkway, Ste 110
Cary, NC 27518

Re: Providence Creek Pool and Pump/Bath house

To Whom It May Concern:

This department has reviewed the plan you submitted for the Providence Creek swimming pool to be constructed at 196 Providence Creek Dr., Fuquay Varina. This plan review was conducted in accordance with the current North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500).

Further information is needed regarding the following items for review to continue:

- Provide locations and specifications on all deck drains
- Specify pool finish color
- Indicate exact location of Emergency phone installation
- Provide a make/model or specification for a hydrostatic relief valve assembly
- Provide updated make/model information regarding SOFAs to be installed on both the main drains and the water feature
- Verify that neither pump to be installed will be variable speed
- Provide greater detail on backwash sump pit. Plans indicate pit to be 2" depth.
- Indicate whether mirrors in restrooms are shatterproof
- Provide additional information concerning partitions in restrooms, specifically, materials of construction and whether a waterway is provided under partitions
- Indicate if the ceramic floor tile in the restrooms is slip resistant
- Provide updated fencing data if available

If you have any questions regarding this matter or if I can provide any additional assistance, please call me at 910-893-7547

Sincerely,



Cindy Pierce, REHS
Environmental Health Specialist