

# CALCULATION SUMMARY

Project Name : Johnsonville Elementary School Phase 2

Project Location: 18495 NC-27

Contract No. : 173-NC22

City: Cameron, NC 28326

## Design Areas

Design Area Name	Calc. Mode (Model)	Occupancy	Area of Application	Total Water	Pressure @ Source	Min. Density	Min. Pressure	Min. Flow	Calculated Heads	Hose Streams	Margin To Source
			(ft <sup>2</sup> )	(gpm)	(psi)	(gpm/ft <sup>2</sup> )	(psi)	(gpm)	#	(gpm)	(psi)
1	Demand (HW)	Light Hazard	1340	340.7	Required 45.1	0.1	12.8	40.1	6	100	33.1

# HYDRAULIC CALCULATIONS for

---

## Job Information

Project Name : Johnsonville Elementary School Phase 2

Contract No. : 173-NC22

City: Cameron, NC 28326

Project Location: 18495 NC-27

Date: 10/14/2022

---

## Contractor Information

Name of Contractor: A & B Fire Services Inc.

Address: 113 North Ln.

City: Bluefield, WV 24605

Phone Number: 540-521-5776

E-mail: croseberry@aandbfire.com

Name of Designer: C.J. Roseberry

Authority Having Jurisdiction: Harnett Co.

---

## Design

Remote Area Name	1
Remote Area Location	Classroom 8 / 7
Occupancy Classification	Light Hazard
Density (gpm/ft <sup>2</sup> )	0.1
Area of Application (ft <sup>2</sup> )	1340
Coverage per Sprinkler (ft <sup>2</sup> )	400
Number of Calculated Sprinklers	6
In-Rack Demand (gpm)	0
Special Heads	
Hose Streams (gpm)	100
Total Water Required (incl. Hose Streams) (gpm)	340.7
Required Pressure at Source (psi)	45.1
Type of System	Wet
Volume - Entire System (gal)	3836.9 gal

---


## Water Supply Information

Date	09/27/2022
Location	Fire Hydrant 996G
Source	W1

---

## Notes

### Diagram for Design Area : 1 (Optimized Hvdraulic Simplified)



## Hydraulic Analysis for : 1

### Calculation Info

Calculation Mode	Demand
Hydraulic Model	Hazen-Williams
Fluid Name	Water @ 60F (15.6C)
Fluid Weight, (lb/ft <sup>3</sup> )	N/A for Hazen-Williams calculation.
Fluid Dynamic Viscosity, (lb-s/ft <sup>2</sup> )	N/A for Hazen-Williams calculation.

### Water Supply Parameters

Supply 1 : W1

Flow (gpm)	Pressure (psi)
0	80
860	70

### Supply Analysis

Node at Source	Static Pressure (psi)	Residual Pressure (psi)	Flow (gpm)	Available Pressure (psi)	Total Demand (gpm)	Required Pressure (psi)
W1	80	70	860	78.2	340.7	45.1

### Hoses

Inside Hose Flow / Standpipe Demand (gpm)

Outside Hose Flow (gpm)

Additional Outside Hose Flow (gpm) 100

Other (custom defined) Hose Flow (gpm)

Total Hose Flow (gpm) 100

### Sprinklers

Ovehead Sprinkler Flow (gpm) 240.7

InRack Sprinkler Flow (gpm) 0

Other (custom defined) Sprinkler Flow (gpm) 0

Total Sprinkler Flow (gpm) 240.7

### Other


Required Margin of Safety (%) 10

W1 - Pressure (psi) 45.1

W1 - Flow (gpm) 240.7

Demand w/o System Pump(s) N/A

### Hydraulic Analysis for : 1



## Hydraulic Analysis for : 1

### Graph Labels

Label	Description	Values	
		Flow (gpm)	Pressure (psi)
S1	Supply point #1 - Static	0	80
S2	Supply point #2 - Residual	860	70
D1	Elevation Pressure	0	7.7
D2	System Demand	240.7	45.1
D3	System Demand + Add.Out.Hose	340.7	45.1

### Curve Intersections & Safety Margins

Curve Name	Intersection		Safety Margin	
	Pressure (psi)	Flow (gpm)	Pressure (psi)	@ Flow (gpm)
Supply	78.2	339.1	33.1	340.7
Supply; Safety Pressure	70.6	318.7	25.3	340.7

### Open Heads

Head Ref.	Head Type	Coverage	K-Factor	Required			Calculated		
				Density	Flow	Pressure	Density	Flow	Pressure
		(ft <sup>2</sup> )	(gpm/psi <sup>1/2</sup> )	(gpm/ft <sup>2</sup> )	(gpm)	(psi)	(gpm/ft <sup>2</sup> )	(gpm)	(psi)
S1	Overhead Sprinkler	400	11.2	0.1	40	12.8	0.1	40.1	12.8
S2	Overhead Sprinkler	400	11.2	0.1	40	12.8	0.1	40.1	12.8
S3	Overhead Sprinkler	400	11.2	0.1	40	12.8	0.1	40.2	12.9
S4	Overhead Sprinkler	400	11.2	0.1	40	12.8	0.1	40.1	12.8
S5	Overhead Sprinkler	400	11.2	0.1	40	12.8	0.1	40.1	12.8
S6	Overhead Sprinkler	400	11.2	0.1	40	12.8	0.101	40.2	12.9

## Node Data

Node# Type	Hgroup Fitting	K-Fact. Stat. Pres.	Elev Coverage	X Y
		gpm/psi <sup>1/2</sup> psi	ft ft <sup>2</sup>	ft ft
S2 Overhead Sprinkler	HEAD	11.2	14.25 400	6756.54 488.9
S1 Overhead Sprinkler	HEAD	11.2	14.25 400	6756.54 500.9
S5 Overhead Sprinkler	HEAD	11.2	14.25 400	6776.54 488.9
S4 Overhead Sprinkler	HEAD	11.2	14.25 400	6774.54 500.9
S3 Overhead Sprinkler	HEAD	11.2	14.25 400	6756.54 474.51
S6 Overhead Sprinkler	HEAD	11.2	14.25 400	6776.54 474.51
136 Node	NODE us.Tee		14.25	6757.38 488.9
135 Node	NODE us.Tee		14.25	6757.38 500.9
150 Node	NODE us.Tee		14.25	6775.38 488.9
149 Node	NODE us.Tee		14.25	6775.38 500.9
001 Node	NODE us.Tee		14.25	6757.38 474.51
151 Node	NODE us.Tee		14.25	6775.38 474.51
127 Node	NODE us.Tee		14.25	6757.38 549.42
126 Node	NODE us.Tee		14.25	6775.38 549.42
118 Node	NODE us.Tee		14.25	6812.31 549.42
117 Node	NODE us.Tee		14.25	6825.98 549.42
005 Node	NODE us.Tee		14.25	6757.38 434.42
009 Node	NODE us.Tee		14.25	6775.38 434.42
122 Node	NODE us.Tee		11.67	6792.98 549.42
053 Node	NODE us.Tee		11.67	6792.98 423.49
054 Node	NODE us.Tee		11.67	6799.69 423.49
057 Node	NODE us.Tee		11.67	6825.98 423.49
073-O Node	NODE		4.49	6832.76 416.66
073-I Node	NODE		3.69	6832.76 416.66
074-O Node	NODE		2.92	6832.76 416.66

### Node Data

Node# Type	Hgroup Fitting	K-Fact. Stat. Pres.	Elev Coverage	X Y
		gpm/psi <sup>1/2</sup> psi	ft ft <sup>2</sup>	ft ft
074-I Node	NODE		2.54	6832.76 416.66
075 Node	NODE		1.08	6832.76 416.66
079 Node	NODE us.Tee		-3.42	6898.73 538.18
086-O Node	NODE		-3.42	6406.78 235.51
086-I Node	NODE		-3.42	6406.78 231.35
W1 Supply	SUPPLY		-3.42	6597.2 208.85



**PIPE INFORMATION**

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 1**

S2 136	14.25 14.25	11.2	40.1 40.1	1 1.049	1x(us.Tee-Br)=5	24 5 29	120 0.4696	12.8 0 13.6	Flex-48"
136 001	14.25 14.25		-6.9 33.2	2 2.157		14.39 0 14.39	120 0.0099	26.4 0 0.1	
001 005	14.25 14.25		40.2 73.4	2 2.157	1x(us.Tee-Br)=12.31	40.09 12.31 52.4	120 0.043	26.6 0 2.3	
005 009	14.25 14.25		0 73.4	4 4.26		18 0 18	120 0.0016	28.8 0 0.0	
009 053	14.25 11.67		73.2 146.6	4 4.26	2x(us.Tee-Br)=52.67 2x(us.90)=26.33	31.11 79 110.11	120 0.0056	28.8 1.1 0.6	
053 054	11.67 11.67		33.2 179.8	4 4.26		6.71 0 6.71	120 0.0082	30.6 0 0.1	
054 057	11.67 11.67		26.7 206.4	4 4.26		26.29 0 26.29	120 0.0106	30.6 0 0.3	
057 073-O	11.67 4.49		34.3 240.7	4 4.26	2x(us.90)=26.33 1x(us.Tee-Br)=26.33	20.79 52.67 73.46	120 0.0141	30.9 3.1 1	
073-O 073-I	4.49 3.69		0 240.7	4 0		0.8 0 0.8	0.7197	35.1 0.3 0.6	CV-1 FR Check ***
073-I 074-O	3.69 2.92		0 240.7	4 4.26		0.77 0 0.77	120 0.0141	36 0.3 0.0	
074-O 074-I	2.92 2.54		0 240.7	4 0		0.38 0 0.38	0.4271	36.3 0.2 0.2	BFV-N ***
074-I 075	2.54 1.08		0 240.7	4 4.26		1.46 0 1.46	120 0.0141	36.7 0.6 0.0	
075 079	1.08 -3.42		0 240.7	6 6.4	1x(us.Tee-Br)=51.84 1x(us.45)=12.1 2x(us.90)=48.39	150.64 112.32 262.96	140 0.0015	37.3 1.9 0.4	
079 086-O	-3.42 -3.42		0 240.7	8 8.55	3x(us.45)=47.55 1x(elbow.22.5)=7.93 1x(us.90)=31.7	904.76 87.18 991.94	140 0.0004	39.6 0 0.4	
086-O 086-I	-3.42 -3.42		0 240.7	8 0		4.17 0 4.17	1.1935	40 0 5	Ames3000SS ***
086-I W1	-3.42 -3.42		0 240.7	8 8.55	1x(us.90)=31.7 1x(us.Tee-Br)=61.64	220.28 93.34 313.62	140 0.0004	45 0 0.1	
<b>W1</b>								<b>45.1</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 2**

S1 135	14.25 14.25	11.2	40.1 40.1	1 1.049	1x(us.Tee-Br)=5	24 5 29	120 0.4697	12.8 0 13.6	Flex-48"
135 127	14.25 14.25		6.9 47	2 2.157	1x(us.Tee-Br)=12.31	48.52 12.31 60.83	120 0.0188	26.4 0 1.1	
127 126	14.25 14.25		0 47	3 3.26		18 0 18	120 0.0025	27.6 0 0.0	
126 122	14.25 11.67		47.2 94.2	3 3.26	2x(us.90)=18.82	20.18 18.82 39	120 0.0091	27.6 1.1 0.4	
122 118	11.67 14.25		-33.2 61	3 3.26	2x(us.90)=18.82	21.92 18.82 40.73	120 0.0041	29.1 -1.1 0.2	
118 117	14.25 14.25		-26.7 34.3	3 3.26	1x(us.Tee-Br)=20.16	13.67 20.16 33.83	120 0.0014	28.1 0 0.0	
117 057	14.25 11.67		0 34.3	2 2.157	1x(us.Tee-Br)=12.31 2x(us.90)=12.31	128.51 24.61 153.12	120 0.0105	28.2 1.1 1.6	
<b>057</b>								<b>30.9</b>	

**Path No: 3**

S5 150	14.25 14.25	11.2	40.1 40.1	1 1.049	1x(us.Tee-Br)=5	24 5 29	120 0.4702	12.8 0 13.6	Flex-48"
150 151	14.25 14.25		-7.1 33	2 2.157		14.39 0 14.39	120 0.0098	26.5 0 0.1	
151 009	14.25 14.25		40.2 73.2	2 2.157	1x(us.Tee-Br)=12.31	40.09 12.31 52.4	120 0.0429	26.6 0 2.2	
<b>009</b>								<b>28.8</b>	

**Path No: 4**

S4 149	14.25 14.25	11.2	40.1 40.1	1 1.049	1x(us.Tee-Br)=5	24 5 29	120 0.4704	12.8 0 13.6	Flex-48"
149 126	14.25 14.25		7.1 47.2	2 2.157	1x(us.Tee-Br)=12.31	48.52 12.31 60.83	120 0.019	26.5 0 1.2	
<b>126</b>								<b>27.6</b>	

### PIPE INFORMATION

Node 1 Node 2	Elev 1 Elev 2	K-Factor 1 K-Factor 2	Flow added (q) Total flow (Q)	Nominal ID Actual ID	Fittings quantity x (name) = length	L F T	C Factor Pf per ft	total (Pt) elev (Pe) frict (Pf)	NOTES
	(ft)	(gpm/psi <sup>1/2</sup> )	(gpm)	(in)	(ft)	(ft)	(psi)	(psi)	

**Path No: 5**

S3 001	14.25 14.25	11.2	40.2 40.2	1 1.049	1x(us.Tee-Br)=5	24 5 29	120 0.4721	12.9 0 13.7	Flex-48"
<b>001</b>								<b>26.6</b>	

**Path No: 6**

S6 151	14.25 14.25	11.2	40.2 40.2	1 1.049	1x(us.Tee-Br)=5	24 5 29	120 0.4726	12.9 0 13.7	Flex-48"
<b>151</b>								<b>26.6</b>	

**Path No: 7**

136 135	14.25 14.25		0 6.9	2 2.157		12 0 12	120 0.0005	26.4 0 0	
<b>135</b>								<b>26.4</b>	

**Path No: 8**

122 053	11.67 11.67		0 33.2	2 2.157	2x(us.Tee-Br)=24.61	125.93 24.61 150.54	120 0.0099	29.1 0 1.5	
<b>053</b>								<b>30.6</b>	

**Path No: 9**

118 054	14.25 11.67		0 26.7	2 2.157	3x(us.Tee-Br)=36.92 5x(us.90)=30.77	141.14 67.69 208.82	120 0.0066	28.1 1.1 1.4	
<b>054</b>								<b>30.6</b>	

**Path No: 10**


150 149	14.25 14.25		0 7.1	2 2.157		12 0 12	120 0.0006	26.5 0 0	
<b>149</b>								<b>26.5</b>	

\* Pressures are balanced to a high degree of accuracy. Values may vary by 0.1 psi due to display rounding.


\* Maximum Velocity of 14.93 ft/s occurs in the following pipe(s): (151-S6)

\*\*\* Device pressure loss (gain in the case of pumps) is calculated from the device's curve. If the device curve is printed with this report, it will appear below. The length of the device as shown in the table above comes from the CAD drawing. The friction loss per unit of length is calculated based upon the length and the curve-based loss/gain value. Internal ID and C Factor values are irrelevant as the device is not represented as an addition to any pipe, but is an individual item whose loss/gain is based solely on the curve data.


**Pressure vs. Flow Function**  
Design Area: 1; Supply Ref.: W1; Supply Name:W1



**Pressure Loss Function**  
Design Area: 1; BFP Ref.: 349 (Ames3000SS, Size = 8); Inlet Node: 086-I; Outlet Node: 086-O



**Pressure Loss Function**  
Design Area: 1; Valve Ref.: 347 (BFV-N, Size = 4); Inlet Node: 074-I; Outlet Node: 074-O



**Pressure Loss Function**  
Design Area: 1; Valve Ref.: 348 (CV-1 FR Check, Size = 4); Inlet Node: 073-I; Outlet Node: 073-O

