

3D Community
Church

July 5, 2022

Mr. Brad Sutton

Harnett County Central Permitting

420 McKinney Parkway

Lillington NC 27544

Re: Plan Reviews Re Submittal

Dallas C. Abee

Architect AIA

5557 Clearlake Drive

Hickory NC 28601-9485

Dear Mr. Sutton:

We have updated and revised the following Drawing Sheets in response to Plan Review Notes dated 6/30/2022: Revisions One dated 07 05 2022

- 1.- Cover Sheet – Drawing Sheets Revised: Cover Sheet, Sheet 3 Overall Civil Site Plan, A-0 UL Designs Steeple Connection Details, A-1 Main Floor Plan, A-3 Door Schedule, ADA Details, A-4 Elevations Wall Section, A-8 Life Safety Plans, and E-3 .
- 2.- CA-1 Appendix B Drawing Sheet: correct square footage, Basic Building Data wall types 111A added, Fire Protection requirements-added two hour occupancy separation.
- 3.- Drawing Sheet 3 –Civil Overall Site Plan; Notes added- 70 Feet minimum length for Fire truck Turn around, minimum 45 Feet radius for Fire Truck Turn around, contractor shall construct a minimum 8" ABC al weather access from proposed asphalt drive to the proposed fire hydrant and a minimum 45 fo t radius for Fire Truck.
- 4.- A-1 Main Floor Plan drawing Sheet- added wall types two hour WT-6B two hour design, Cleared "Text over Text", corrected occupants content 525, Doors 20, 21, 22, 23,24, and 26 90 minutes doors/frames, deleted Catawba County Note, revised assistive listening devices to 525 Occupants.
- 5.- A-3 Door Schedule: Doors/frames 20,21,22,23,24 and 26to 90 minutes ratings

Page One of Two

Page Two of Two

July 5, 2022

Plan Reviews Responses: 3 D Community Church continued

6.- A-8 Life Safety Floor Plans Occupant Contents to 525. Deleted Classroom 126.

7.- drawing Sheet E-3: corrected Floor Plan to 1/8" Scale and Dimensions.



Dallas C. Abee

Architect AIA



Attachments:

Five Prints: Cover Sheet, CA-1 Appendix B, Sheet 3 -Civil Site Plan Revisions, A-0 UL Design 419 and Steeple Connections, A-1 Main floor Plan, A-3 Door Schedule, A-4 Wall Section, Elevations, And A-8 Life Safety Plans