Permit Inspections
Harnett County

Permit Number: BCOM2206-0003

Description: **32 x 27 Pool House/bathrooms**

Applied: **6/15/2022**
Approved: **8/19/2024**
Site Address: **394 CENTENNIAL PKWY**

Issued: **9/28/2022**
Finaled:
City, State Zip Code: **CAMERON, NC 28326**

Status: **ISSUED**
Applicant: **G L Strickland Construction LLC**

Parent Permit:
Owner: **VOLA LLC**

Parent Project:
Contractor: **G L Strickland Construction LLC**

Details:

I emailed Christina Cox at Spa and Pool World to resend the pool and pool house plans to me separately. She had entered them in the subdivision file by mistake.

Plans submitted with changes for pool house. I am sending back thru H and S, fire and building.

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOUNDATION	Ricardo D Honrada		
Notes:						
			MONO SLAB	Ricardo D Honrada		
Notes:						
			SLAB	Ricardo D Honrada		
Notes:						
			FOOTING	Ricardo D Honrada		
Notes:						
			REBAR	James T Hall		
Notes:						
	3/13/2023	3/22/2023	ADDRESS	GIS Bucket	APPROVED	
Notes: 394 Centennial Pkwy						
	6/4/2025	6/4/2025	ROUGH IN	Ricardo D Honrada	DISAPPROVED	
Notes: A3G gables need L blocking as per documents.6x6 poles needs screw connections to LVL.Strap the 4 studs in male bathroom.Ok to insulate.						

Permit Inspections
Harnett County

	6/6/2025	6/6/2025	ROUGH IN	Ricardo D Honrada	CANCELLED	
Notes: Inspector JTH changed the inspection assignment from JTH to RH Cancel by contractor.						
	6/23/2025	6/23/2025	ROUGH IN	Ricardo D Honrada	FAIL W/ PENALTY	
Notes: No lock box numbers in the note. 8:38am.						
	6/30/2025	6/30/2025	ROUGH IN	John B Kokoszka	APPROVED	
Notes:						
	7/2/2025	7/2/2025	INSULATION	James T Hall	APPROVED	
Notes:						
40	8/11/2026	8/11/2026 09:45 AM	ZONING	Randy Baker	APPROVED	
Notes:						
40	8/11/2026	8/11/2026	FM FINAL	Leslie Jackson	DISAPPROVED	See Notes
Notes: - Address numbers not up - Chemical room not label - Latching mech. not on pool gates - Emergency lights not working - No fire extinguishers mouthed						
40	8/12/2026 PM	8/13/2026 PM	EH SANITATION FINAL	EH Bucket	DISAPPROVED	see list
Notes: Gates not self-closing and self-latching, no latching mechanism provided. Sidewalk gate from parking lot not free swinging. Trash can installed against fence is a foothold. Hot water provided is in excess of 110F. Concrete at shower drain is incomplete. Required signage and life saving devices not provided. Back wash cycle could not be demonstrated. Pump room piping not labeled. Continuous ventilation in pump and chemical rooms not on. Must demonstrate that chlorine pump will turn off if power to main pump is cut.						
50			FINAL**	Ricardo D Honrada		
Notes:						