

FRONT OF BUILDING

DOUBLE DOOR
72 x 80

EMERGENCY EXIT LIGHT MOUNTED OVER DOOR
FIRE EXTINGUISHER MOUNTED BESIDE DOOR

YOUTH / CLASS / SUNDAY SCHOOL

28' x 27'

DOOR
35.75 x 79.25


WINDOWS (ALL)
35.5 x 53.5

EMERGENCY EXIT LIGHT MOUNTED OVER DOOR
FIRE EXTINGUISHER MOUNTED BESIDE DOOR

SINK

RANGE

FRIG



DOOR
35.75 x 79.25

DOOR
35.75 x 79.25

STORAGE
28' x 12'

EMERGENCY EXIT LIGHT MOUNTED OVER DOOR
FIRE EXTINGUISHER MOUNTED BESIDE DOOR

30'

PLEASANT MEMORY BAPTIST CHURCH

May 23, 2022

Donna Johnson
Project Coordinator
Central Permitting Division
Harnett County

Subject: Pleasant Memory Baptist Church

Dear Ms. Johnson,

This letter is in regard to your Permit Review dated 11/8/2022. Our Deacons have contacted Mr. Brad Sutton and Mr. Roger Sullivan concerning their requested information.

Mr. Sutton required additional restrooms and we showed him there were two additional men's and two additional women's restrooms within his required 300 feet.

Mr. Sullivan required there be a fire hydrant within 400 feet and we showed him there were two fire hydrants that met this requirement. He also required Emergency exit lights be mounted over exit doors and fire extinguishers be mounted on the wall beside these doors. These lights and extinguishers are shown on the attached drawing. The kitchen facilities and bathroom are to be added later.

We look forward to your approval.

Sincerely

A handwritten signature in blue ink that reads "C.T. Clayton". The signature is written in a cursive style with a long horizontal flourish extending to the right.

CT Clayton
Deacon

Pleasant Memory Baptist Church
579 Old Stage Road, Coats, NC 27521
252-671-6979