



Permit Reviews

Harnett County

Permit Number: BCOM2211-0002

Description: **30 x 41 youth/class/sunday school building**

Applied: **11/8/2022**

Approved:

Site Address: **579 OLD STAGE RD N**

Issued:

Finalized:

City, State Zip Code: **COATS, NC 27521**

Status: **RECEIVED**

Applicant: **PLEASANT MEMORY BAPTIST CHURCH**

Parent Permit:

Owner: **PLEASANT MEMORY BAPTIST CHURCH**

Parent Project:

Contractor: **PLEASANT MEMORY BAPTIST CHURCH**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
11/8/2022	11/8/2022		COMMERCIAL INTAKE	CP Bucket	DISAPPROVED	
Notes:						
11/8/2022	11/9/2022	11/22/2022	COMMERCIAL BUILDING REVIEW	Brad Sutton	DISAPPROVED	
Notes:						
Provide distance from entry door to closest bathroom facility in church building. This building calculates to 50 people @15/sf, so a single restroom would be insufficient.						
11/8/2022	11/9/2022	11/22/2022	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	see notes
Notes:						
1. Must be a fire hydrant within 400 feet of the building. 2. Need to submit a life safety plan showing exit signs, emergency lighting, travel distances to exits, square footage, fire extinguisher placement and classroom layout if walls will be constructed for Sunday school classrooms. 3. Need to know what the original use of the building was, possible change of use.						
11/9/2022			Commercial Building Review	Building Bucket		
Notes:						

