



# Harnett County Fire Marshals Office

Occupancy: **Harnett Self Storage**  
 Occupancy ID: **85000851**  
 Address: **555 Alpine DR SANFORD NC 27332**

Inspection Type: **300 - Final/CO**  
 Inspection Date: **10/23/2023** By: Heath, Brian (6585ES)  
 Time In: **13:20** Time Out: **13:50**  
 Authorized Date: **10/23/2023** By: Heath, Brian (6585ES)  
 Next Inspection Date: **01/21/2024 100 - Fire Protection Inspection**

Form: Harnett County  
 General Fire Inspection

## Inspection Description:

Harnett County Fire Inspection

## Inspection Topics:

### Means of Egress

Emergency Lighting  
 Installed and Maintained

**Status: PASS**

**Notes:** 604. Exit/Emergency lights did not illuminate at both exit doors in building A front section and at middle of right side corridor in rear section of building A.

All lights are working as they should, B. Heath

## Official Notification of Possible Fine

The above noted violations of the North Carolina Fire Code are subject to the following fines: - \$50.00 per violation for non-compliance on first re-inspection -\$100.00 per violation for non-compliance on the second and subsequent re-inspections.

IF ALL VIOLATIONS ARE CORRECTED BY THE SPECIFIED DATE, NO CHARGES WILL BE MADE! \*\*The only exemption will be where an official appeal has been properly filed with the North Carolina Department of Insurance. This process can be found at the following link: [www.harnett.org/fire/appeal](http://www.harnett.org/fire/appeal)

**Status: CORRECTED**

**Notes:**

## Statement of Compliance

An inspection of your facility on this date revealed no violations of the North Carolina State Fire Prevention Code. No further inspections will need to be conducted until your next regular schedule fire inspection.

\*\*\*Statement of Compliance\*\*\*

**Status: PASS**

**Notes:**

## Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

**Notes:** No Additional time recorded

**Total Additional Time: 0 minutes**  
**Inspection Time: 30 minutes**  
**Total Time: 30 minutes**

**Summary:**

**Overall Result:** Fire Code Compliance

An inspection of your facility revealed no violations of the North Carolina Fire Code.

**Inspector Notes:**

**Closing Notes:**

Harnett County has adopted The Compliance Engine as the prescribed method for record keeping in accordance with Section 107, of the North Carolina Fire Prevention Code. Records of periodic inspections, tests, servicing, and other operations and maintenance for all life safety systems shall be submitted to The Compliance Engine.

**Inspector:**

Name: Heath, Brian  
Rank: Deputy Fire Marshal  
Work Phone(s): None on file  
Email(s): mheath@harnett.org  
Heath, Brian:



Signed on: 10/23/2023 13:46

\_\_\_\_\_  
*Signature*

\_\_\_\_\_  
*Date*

**Representative Signature:**

\_\_\_\_\_  
*Signature*

\_\_\_\_\_  
*Date*