

Cynthia Pierce

To: Joey Davis
Subject: Wood Grove

Hi Joey, I have reviewed the plans for the pool at Wood Grove. If you can clarify just a few things we should be able to get an approval.

- Will there be deck drains?
- The overall length of the pool on the plans is 45'2" but the data block shows overall length of 42'2". Can you state which is correct?
- No soap dispensers are shown in the lavatory areas on the enlarged restroom plan
- The autofill line is reflected on P2 water supply but is not included on SP4 enlarged pump room plans

Thanks for your time,
Cindy Pierce, REHS
Harnett Environmental Health
910-893-7547