

Initial Application Date: 1-26-23

Application # _____

COUNTY OF HARNETT DEMOLITION APPLICATION

Central Permitting 108 E. Front Street, Lillington, NC 27546 Phone: (910) 893-7525 Fax: (910) 893-2793 www.harnett.org/permits

LANDOWNER: Harnett County Regional Jetport Mailing Address: 615 Airport Rd.

City: Erwin State: NC Zip: 28339 Contact # 919-738-2934 Email: garon@akgrading.com

APPLICANT*: A/K Grading + Demolition Inc Mailing Address: 103 Warehouse Dr

City: LAGrange State: NC Zip: 28357 Contact # 919-738-2934 Email: garon@akgrading.com

*Please fill out applicant information if different than landowner

CONTACT NAME APPLYING IN OFFICE: Aaron Kornegay Phone # 919-738-2934

PROPERTY LOCATION: Subdivision: Harnett County Jetport Lot #: - Lot Size: -

State Road # _____ State Road Name: Airport Rd. Map Book&Page: /

Parcel: _____ PIN: _____

Zoning: _____ Flood Zone: _____ Watershed: _____ Deed Book&Page: /

SPECIFIC DIRECTIONS TO THE PROPERTY FROM LILLINGTON: _____

Structure(s) to be demolished & removed: Single family dwelling _____ Manufactured Home _____ Other (specify) Terminal Bldg

Structures (existing and/or proposed): Single family dwellings _____ Manufactured Homes _____ Other (specify) _____

Water Supply: County Existing Well

Sewage Supply: Existing Septic Tank County Sewer

- * If a new structure is to be replaced on this lot, please ensure that existing septic system is not damaged.
- * If an existing well is on site and is to be discontinued, please contact Harnett County Environmental Health for assistance.

*Upon the issuance of the Certificate of Compliance, the Harnett County Tax Department shall be notified of the removal to ensure proper listing.

*The demolition contractor is responsible for submitting verification of proper disposal prior to the Final inspection.

****PLEASE NOTE**** Failure to completely demolish, remove, and clear the premises will result in the withholding of the Certificate of Compliance. Thus, future permits for the property will be denied, and fines may be imposed for failure to complete demolition/removal.

If permits are granted I agree to conform to all ordinances and laws of the State of North Carolina regulating such work and the specifications of plans submitted. I hereby state that foregoing statements are accurate and correct to the best of my knowledge. Permit subject to revocation if false information is provided.


Signature of Owner or Owner's Agent

1-26-23
Date

****This application expires 6 months from the initial date if no permits have been issued****

Asbestos requirements are applicable if the occupancy use is or changes to Commercial (not residential), or if multiple structures are being demolished & removed at one time.

Demolition & Disposal of Existing Terminal at the Airport.
Load into Covered Trucks and haul to the Landfill.

NO Asbestos was Found in the Report

Inspector Gregg Heppert Inspector # 11702
(See Attached Survey)

An Asbestos Inspection Report prepared by an N.C. Accredited Asbestos Inspector must be provided with application to demolish any building including residences demolished for commercial or industrial expansion or structures. It is the contractor's responsibility to properly notify the Department of Health and Human Services Division of Public Health – Health Hazards Control Unit at least ten (10) working days before the demolition is to begin whether or not the building is known to contain asbestos.


I hereby certify that the information on this application is correct and that all work in connection with the above referenced job will be performed under my supervision and that such work complies with the requirements of the NC State Building Codes and applicable Harnett County Ordinances. Call for inspection at proper stage of work.


CONTRACTOR / APPLICANT

1-23-23
DATE

61309
LICENSE NO. (If applicable)

Please contact the Department of Health and Human Services for their requirements and permit information.
<http://www.epi.state.nc.us/epi/asbestos/ahmp.html>



MATRIX

Health & Safety Consultants, L.L.C.

September 17, 2018

Geotechnologies, Inc.
3200 Wellington Court
Raleigh, NC 27615

Attention: Mr. Conrad Harris, P.E.

Subject: Survey to Identify Asbestos-Containing Materials
Harnett Regional Jetport – Main Terminal
615 Airport Road
Erwin, NC 28339
Matrix Job Number: 180938

Dear Mr. Harris:

Matrix Health and Safety Consultants, L.L.C. (Matrix) is pleased to present this report of the survey to identify asbestos-containing materials at the referenced property. Matrix understands that the structure on the site is scheduled for demolition in the near future. In order to facilitate the demolition, Matrix performed a survey to determine the existence of asbestos-containing materials. This report presents known project information, survey procedures and survey results.

Finish materials included drywall, ceiling texture, flooring, carpet mastic, roof shingles and roof felt.

SURVEY PROCEDURES

The survey was performed on September 5, 2018 by Matrix's Inspector Gregg Heppert (North Carolina Asbestos Inspector No. 11702). The survey began with a walk-through of the building observing accessible areas for the presence of suspect asbestos-containing materials. Both friable and nonfriable suspect asbestos-containing materials were considered during the course of the survey. Friable materials are those materials which can be pulverized or reduced to powder by hand pressure. A sampling strategy was determined and bulk samples of suspect ACM were obtained. Suspect ACM's were grouped based on material homogeneity. A homogeneous area is an area which contains materials that seem by texture, color and wear to be uniform and applied during the same general time period.

To determine the presence or absence of asbestos content in the suspect materials, samples were collected and transported to EMSL Analytical Inc. located in Morrisville, North Carolina under chain-of-custody documentation for laboratory analysis. The collected samples were placed into individual sample containers, sealed and a unique identification number was assigned to the sample container at the time of collection. The identification included the sample collection date and location. This information was logged on our Asbestos Bulk Sampling Record and submitted to the laboratory.

ANALYSIS PROCEDURES AND RESULTS

The collected asbestos samples were analyzed using Polarized Light Microscopy (PLM) in conjunction with dispersion staining techniques using EPA Method 600/M4-82-020 per 40 CFR 763. The bulk laboratory analysis provided the asbestos content (positive or negative), percentage of asbestos, asbestos type and identification of other non-asbestos fibers. A material is considered to be asbestos-containing if greater than 1% asbestos is found in the material.

Harnett Regional Jetport – Main Terminal

Asbestos was not detected in samples collected from the referenced building.

QUALIFICATIONS

This report summarizes Matrix's evaluation of the conditions observed at the subject buildings during the course of the facility survey. Our findings are based upon our observations at the building and analyses of the samples obtained at the time of this survey. Additional asbestos-containing materials may exist (undetected) in other portions of each building due to inaccessibility or due to an undetectable change in materials. Any conditions discovered which deviate from the data contained in this report should be presented to us for our evaluation.

Matrix appreciates the opportunity to have provided these services. We would be glad to discuss any of the results contained in this report, at your convenience. If there are any questions concerning this report or results, please contact us.

Sincerely,
MATRIX HEALTH AND SAFETY CONSULTANTS, L.L.C.



Gregg Heppert
Project Principal

Attachments: Laboratory Analysis Report
Site Photographs

ANALYSIS PROCEDURES AND RESULTS

The collected asbestos samples were analyzed using Polarized Light Microscopy (PLM) in conjunction with dispersion staining techniques using EPA Method 600/M4-82-020 per 40 CFR 763. The bulk laboratory analysis provided the asbestos content (positive or negative), percentage of asbestos, asbestos type and identification of other non-asbestos fibers. A material is considered to be asbestos-containing if greater than 1% asbestos is found in the material.

Harnett Regional Jetport – Main Terminal


Asbestos was not detected in samples collected from the referenced building.

QUALIFICATIONS

This report summarizes Matrix's evaluation of the conditions observed at the subject buildings during the course of the facility survey. Our findings are based upon our observations at the building and analyses of the samples obtained at the time of this survey. Additional asbestos-containing materials may exist (undetected) in other portions of each building due to inaccessibility or due to an undetectable change in materials. Any conditions discovered which deviate from the data contained in this report should be presented to us for our evaluation.

Matrix appreciates the opportunity to have provided these services. We would be glad to discuss any of the results contained in this report, at your convenience. If there are any questions concerning this report or results, please contact us.

Sincerely,
MATRIX HEALTH AND SAFETY CONSULTANTS, L.L.C.


Gregg Heppert
Project Principal

Attachments: Laboratory Analysis Report
Site Photographs