

PYROCHEM KKII DETAILS

- * DETECTOR TEMP PER PYRO CHEM MANUAL PAGE 2-6, REV 6
- * ALL PIPING PER PYRO CHEM MANUAL 3—18 TO 3—22, REV. 6
 * ALL NOZZLES POSITIONED PER PYRO CHEM MANUAL, CHAPTER III
- * PULL STATION IN AISLE OF EGRESS
- * GAS APPLIANCES W/ SHUT-OFF
- * MICRO SWITCH FOR SHUT DOWNS & ALARM TIE IN





