



# STROUD ENGINEERING, P. A.

CONSULTING ENGINEERS  
422 HIGHWAY 24  
MOREHEAD CITY, NORTH CAROLINA 28557  
WWW.STROUDENGINEER.COM  
LICENSE NO. C-0647

June 24, 2024  
Mr. Matt Conte  
Eleven 18 Architecture  
1011 E. Colonial Drive, Suite 307  
Orlando, Florida 32803

RE: Springs of Ballentine

Mr. Conte,

This letter is to approve use of a Schier model number GB-250 grease interceptor in place of the unit shown on the plans contingent approval of all authorities having jurisdiction. Owner shall also be made aware that this unit will need to be pumped out more frequently given that it is a lower capacity unit.

If you have any questions, feel free to call me at 252-902-9352. Thanks.

Sincerely,

6/24/24

L. Michael Stroud, PE

