

HEALTH DEPARTMENT COMMENT RESPONSE LETTER



DATE: March 24, 2023
PROJECT ARCHITECT: ELEVEN18 ARCHITECTURE, PL
CONTACT NAME AND NUMBER: Matt Conte, 407-745-5300

PROJECT NAME: The Springs of Ballentine
PERMIT NUMBER: N/A
PROJECT NUMBER:
FID NUMBER:

PLEASE NOTE THE FOLLOWING REVISIONS TO THE PROPOSED SET OF DRAWINGS HAVE BEEN COMPLETED IN RESPONSE TO THE NORTH CAROLINA DEPARTMENT OF THE HEALTH DEPARTMENT COMMENTS.

1. COMMENT: Indicate the intended use of the sink in the clean linen area of the laundry room. Additional hand sink to be added to the laundry area #172 on the plans as discussed. To be provided on revised plan

RESPONSE: Sheets A201, A203, A601 and A606-2 have been updated to show the addition of a hand sink in the laundry area #172.

2. COMMENT: Plans do not show a hand sink in the bistro area where plated food will be handed out, as described. Provide a hand sink in the bistro area. To be provided on revised plan

RESPONSE: Sheets A602-1, A608-1 and A802 -5 have been updated to show the addition of a hand sink in the bistro area.

END OF RESPONSE LETTER

ELEVEN18 ARCHITECTURE, PL
424 E. Central Blvd. #542 Orlando FL 32801
407-745-5300
www.eleven18architecture.com