



EMERGENCY
MANAGEMENT
(910) 893-7580

Harnett County
EMERGENCY SERVICES

GARY L. POPE
DIRECTOR



FIRE
MARSHAL
FAX (910) 893-5025

FIRE INSPECTION "FINAL REPORT"

TO: Lynnwood McDonald, Chief Building Inspector
Harnett County Inspection Department

FROM: Wayne Shickland Deputy Fire Marshal

DATE: 1-21-2000

The following business has been approved for a final:

NAME: Hudben's Motor Sports
ADDRESS: 143 Holly Springs Ch. Rd.
Broadway, NC
PHONE NO: _____



EMERGENCY
MANAGEMENT
(910) 893-7580

Harnett County

EMERGENCY SERVICES



FIRE
MARSHAL
FAX (910) 893-5025

GARY L. POPE
DIRECTOR

PLAN REVIEW APPROVAL REPORT

TO: Lynwood McDonald, Chief Building Inspector
Harnett County Inspection Department

FROM: Wayne Stuchlik, Deputy Fire Marshal

DATE: 12-17-97

The plan review has been approved on the following business.
Note: If any additional code requirements are needed, they
will be noted at the bottom.

NAME: William Hudson

ADDRESS: 507 Nixon Dr.
Sanford 27330

PHONE NO: (919) 774-1341

See Notes On Plans.

NC



EMERGENCY
MANAGEMENT
(910) 893-7580

Harnett County

EMERGENCY SERVICES



FIRE
MARSHAL
FAX (910) 893-5025

GARY L. POPE
DIRECTOR

PLAN REVIEW APPROVAL REPORT

TO: Lynwood McDonald, Chief Building Inspector
Harnett County Inspection Department

FROM: Wayne Strahl, Deputy Fire Marshal

DATE: 12-17-97 / Revised 1-27-98

The plan review has been approved on the following business.
Note: If any additional code requirements are needed, they
will be noted at the bottom.

NAME: William Hudson - Hudson Motor Sports

ADDRESS: 507 Nixon Dr.
Sanford 27330

PHONE NO: (919) 774-1341

See Notes On Plans.

(E) 2 A 10 BC Fire Extinguishers

* Address Posted so legible from roadway

**Harnett County Emergency Services
Plans Review Sheet**

Project: (Race Car & Metal Fabrication Shop) - Not Name of Business
 Address: 507 Nixon Drive | Holly Springs Church Rd. SR 1273
Sanford, NC 27330
 Contact Person: William Hudson OR David Ward
 Phone Number: 919-774-1341 919-258-3394
call after 4 pm
 Date Received: 12/10/97 Date Completed: 12/16/97
 Reviewed By: Wynn Stuber
 Square footage: 5000 Construction Type: metal

ITEM	Approved	Not Required	Incomplete	Remarks
1. Permits Required 402		1		
2. Interior Finishes 505		3		
3. F.D. Access 602.6				
4. Fire Extinguishers 603.3.1 & NFPA 10	See Plans			
5. Smoke Detection 603.6 & NFPA 72		5		
6. Fire Alarms 603.7 & NFPA 72				
7. Standpipes 603.10 & NFPA 14				
8. Private Fire Mains NFPA 24				
9. Sprinkler Systems 603.15 & NFPA 13				
10. Fixed Extinguishing Systems 603 & NFPA 11-18, 96				
11. Fire Pumps 603 & NFPA 20				
12. Exit Doors 803				
13. Exit Illumination 807.1 & NFPA 101				
14. Exit Signs 807.2 & NFPA 101				
15. Flammable/Combustible Liquids Chapter 9 & NFPA 30-30 A				
16. Flammable Finishes Chapter 10 & NFPA 33				
17. Dry Cleaning Plants Chapter 12 & NFPA 32				
18. Oil Burning Equipment Chapter 14				18-