



Harnett County Fire Marshals Office

Occupancy: **TRITON QUICK MART**
 Occupancy ID: **4300TRIT000002**
 Address: **205 E JACKSON BLVD ERWIN NC 28339**

Inspection Type: **109 - Complaint of Non-Compliance**
 Inspection Date: **9/22/2023** By: Starling, Matthew (3590msES)
 Time In: **17:15** Time Out: **17:37**
 Authorized Date: **09/22/2023** By: Starling, Matthew (3590msES)
 Next Inspection Date: **11/29/2024 100 - Fire Protection Inspection**

Form: Harnett County
 General Fire Inspection

Inspection Description:

Harnett County Fire Inspection

Inspection Topics:

Fire Protection Systems

Fire Suppression Systems
 Installed, Tested, and Maintained

Status: PASS

Notes: Received a complaint regarding the incorrect setup of cooking devices under the kitchen hood. Spoke to owner via phone and worker on sight. A grill was removed from under the hood, so one nozzle does not have an appliance under it. All other appliances are set up correctly. Owner has not intentions of using a grill again in the same area and may just use a warmer or hot plate for that space. Suppression system is in date for service and hood appears to have last been cleaned in 2022. Kitchen is not being used now, but is being renovated to be used in the coming future. Advised owner to have suppression system serviced when it is due and to clean the hood before opening the kitchen. Complaint cleared.

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
Notes: No Additional time recorded		

Total Additional Time: 0 minutes
Inspection Time: 22 minutes
Total Time: 22 minutes

Summary:

Overall Result: Complaint cleared by fire inspector
 Inspection generated due to report of non-compliance. Upon completion of non-compliance investigation inspector determined complaint to be invalid.
Inspector Notes: See comments regarding suppression system.

Closing Notes:

Harnett County has adopted The Compliance Engine as the prescribed method for record keeping in accordance with Section 107, of the North Carolina Fire Prevention Code. Records of periodic inspections, tests, servicing, and other operations and maintenance for all life safety systems shall be submitted to The Compliance Engine.

Inspector:

Name: Starling, Matthew
Rank: Deputy Fire Marshal
Work Phone(s): None on file
Email(s): mstarling@harnett.org
Starling, Matthew:



Signed on: 09/22/2023 18:19

Signature

Date

Representative Signature:

Signature

Date