



Standby Battery Calculation NFS-320 Fire Alarm Control Panel

Protected Premises: CFVH - Harnett Core & Shell **Date:** 10/30/2023

Address: 225 Brightwater Drive

City: Lillington **State:** NC **Zip:** 27546

Panel ID: FACP **Location:** Main Elec. 107

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
CPU-320 Main Board	1	0.250000	0.250000	0.250000	0.250000
# NACs in use	1	0.035000	0.035000	0.035000	0.035000
KDM-R2 Display (Backlight on)	1	0.100000	0.100000	0.100000	0.100000
LCD2-80 LCD Remote Annunciator	1	0.045000	0.045000	0.098000	0.098000
HW-AV-LTE Communicator	1	0.060000	0.060000	0.200000	0.200000
FSP-951 Photoelectric Detector	17	0.000200	0.003400	0.004500	0.076500
FST-851R Thermal Detector-135 w/ ROR	2	0.000200	0.000400	0.004500	0.009000
NBG-12LX Manual Pull Station	14	0.000375	0.005250	0.005000	0.070000
DNR Duct Detector w/FSP-951R	10	0.000200	0.002000	0.004500	0.045000
RTS151KEY	10	0.000000	0.000000	0.012000	0.120000
FMM-1 Monitor Module	15	0.000375	0.005625	0.005000	0.075000
FRM-1 Relay Module	19	0.000255	0.004845	0.006500	0.123500
XP10-M Ten Input Monitor Module	1	0.003500	0.003500	0.055000	0.055000
HPF-PS10B Trigger	3	0.000000	0.000000	0.020000	0.060000
Total Standby:			0.515	Total Alarm:	1.317

Secondary Load Requirements **14.97** **Amp Hours**

Total Secondary Load from the calculation table below.

Current Draw (Amps)		Time (Hours)	Total (AH)
Secondary Standby Load 0.515		Required Standby Time	
		24	12.36
Secondary Alarm Load 1.317		Required Alarm Time	
		0.084	0.11
Total Secondary Load			12.47
Derating Factor			1.2
Secondary Load Requirements			14.97

Battery Selection **18** **Amp Hours**



Standby Battery Calculation HPF-PS10B Remote Power Supply

Protected Premises: CFVH Harnett MOB Core & Shell

Date: 10/30/2023

Address: 225 Brightwater Drive

City: Lillington

State: NC

Zip: 27546

Panel ID: PS1

Location: Elec. 103

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
HPF-PS1010 Main Board	1	0.156000	0.156000	0.176000	0.176000
PC2WLED30	6	0.000000	0.000000	0.038000	0.228000
PC2WLED115	12	0.000000	0.000000	0.120000	1.440000
SCWLED30	1	0.000000	0.000000	0.022000	0.022000
		Total Standby:	0.156	Total Alarm:	1.866

Secondary Load Requirements

4.68

Amp Hours

Total Secondary Load from the calculation table below.

Current Draw (Amps)	Time (Hours)	Total (AH)
Secondary Standby Load 0.156	Required Standby Time	
	24	3.74
Secondary Alarm Load 1.866	Required Alarm Time	
	0.084	0.16
Total Secondary Load		3.90
Derating Factor		1.2
Secondary Load Requirements		4.68

Battery Selection

7

Amp Hours



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB
Circuit No: PS1-1
Area Covered: 1st Floor

Date: 10/30/2023
Minimum Voltage: 16
Wire Gauge: 14
Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED30	0.038	30	30	20.33
2	SCWLED30	0.022	20	50	20.29
3	PC2WLED115	0.120	55	105	20.18
4	PC2WLED30	0.038	65	170	20.10
5	PC2WLED30	0.038	30	200	20.08
6	PC2WLED30	0.038	65	265	20.03
7	PC2WLED30	0.038	25	290	20.02
8	PC2WLED30	0.038	30	320	20.01

Total Power: 0.370 **% Voltage Drop:** -1.91%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB
Circuit No: PS1-2
Area Covered: 1st Floor

Date: 10/30/2023
Minimum Voltage: 16
Wire Gauge: 14
Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED115	0.120	50	50	20.17
2	PC2WLED115	0.120	60	110	19.95
3	PC2WLED115	0.120	40	150	19.83
4	PC2WLED115	0.120	65	215	19.68
5	PC2WLED115	0.120	40	255	19.62
6	PC2WLED115	0.120	95	350	19.55
Total Power:		0.720	% Voltage Drop:		-4.17%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB

Date: 10/30/2023

Circuit No: PS1-3

Minimum Voltage: 16

Area Covered: 1st Floor

Wire Gauge: 14

Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED115	0.120	85	85	20.08
2	PC2WLED115	0.120	65	150	19.88
3	PC2WLED115	0.120	65	215	19.74
4	PC2WLED115	0.120	65	280	19.64
5	PC2WLED115	0.120	45	325	19.60
Total Power:		0.600	% Voltage Drop:		-3.90%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Standby Battery Calculation HPF-PS10B Remote Power Supply

Protected Premises: CFVH Harnett MOB Core & Shell **Date:** 10/30/2023

Address: 225 Brightwater Drive

City: Lillington **State:** NC **Zip:** 27546

Panel ID: PS2 **Location:** Elec. 203

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
HPF-PS1010 Main Board	1	0.156000	0.156000	0.176000	0.176000
PC2WLED30	3	0.000000	0.000000	0.038000	0.114000
PC2WLED75	1	0.000000	0.000000	0.087000	0.087000
PC2WLED115	11	0.000000	0.000000	0.120000	1.320000
SCWLED30	1	0.000000	0.000000	0.022000	0.022000
Total Standby:		0.156		Total Alarm: 1.719	

Secondary Load Requirements 4.67 **Amp Hours**

Total Secondary Load from the calculation table below.

Current Draw (Amps)	Time (Hours)	Total (AH)
Secondary Standby Load 0.156	Required Standby Time	
	24	3.74
Secondary Alarm Load 1.719	Required Alarm Time	
	0.084	0.14
Total Secondary Load		3.89
Derating Factor		1.2
Secondary Load Requirements		4.67

Battery Selection 7 **Amp Hours**



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB

Date: 10/30/2023

Circuit No: PS2-1

Minimum Voltage: 16

Area Covered: 2nd Floor

Wire Gauge: 14

Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED30	0.038	30	30	20.36
2	PC2WLED30	0.038	20	50	20.33
3	PC2WLED30	0.038	25	75	20.31
4	SCWLED30	0.022	30	105	20.29
5	PC2WLED75	0.087	45	150	20.27
Total Power:		0.223	% Voltage Drop:		-0.65%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB
Circuit No: PS2-2
Area Covered: 2nd Floor

Date: 10/30/2023
Minimum Voltage: 16
Wire Gauge: 14
Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED115	0.120	40	40	20.19
2	PC2WLED115	0.120	65	105	19.90
3	PC2WLED115	0.120	65	170	19.65
4	PC2WLED115	0.120	65	235	19.45
5	PC2WLED115	0.120	45	280	19.35
6	PC2WLED115	0.120	65	345	19.25
7	PC2WLED115	0.120	65	410	19.21
Total Power:		0.840	% Voltage Drop:		-5.86%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB

Date: 10/30/2023

Circuit No: PS2-3

Minimum Voltage: 16

Area Covered: 2nd Floor

Wire Gauge: 14

Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED115	0.120	80	80	20.16
2	PC2WLED115	0.120	65	145	20.01
3	PC2WLED115	0.120	65	210	19.91
4	PC2WLED115	0.120	65	275	19.86

Total Power: 0.480

% Voltage Drop: -2.62%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Standby Battery Calculation HPF-PS10B Remote Power Supply

Protected Premises: CFVH Harnett MOB Core & Shell Date: 10/30/2023

Address: 225 Brightwater Drive

City: Lillington State: NC Zip: 27546

Panel ID: PS3 Location: Elec. 303

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
HPF-PS1010 Main Board	1	0.156000	0.156000	0.176000	0.176000
PC2WLED15	1	0.000000	0.000000	0.035000	0.035000
PC2WLED30	3	0.000000	0.000000	0.038000	0.114000
PC2WLED75	1	0.000000	0.000000	0.087000	0.087000
PC2WLED115	11	0.000000	0.000000	0.120000	1.320000
SCWLED30	1	0.000000	0.000000	0.022000	0.022000
Total Standby:			0.156	Total Alarm:	1.754

Secondary Load Requirements 4.67 Amp Hours

Total Secondary Load from the calculation table below.

Current Draw (Amps)	Time (Hours)	Total (AH)
Secondary Standby Load 0.156	Required Standby Time	
	24	3.74
Secondary Alarm Load 1.754	Required Alarm Time	
	0.084	0.15
Total Secondary Load		3.89
Derating Factor		1.2
Secondary Load Requirements		4.67

Battery Selection 7 Amp Hours



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB

Date: 10/30/2023

Circuit No: PS3-1

Minimum Voltage: 16

Area Covered: 3rd Floor

Wire Gauge: 14

Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED30	0.038	30	30	20.35
2	PC2WLED30	0.038	30	60	20.31
3	PC2WLED30	0.038	25	85	20.28
4	SCWLED30	0.022	35	120	20.25
5	PC2WLED75	0.087	45	165	20.22
6	PC2WLED15	0.035	40	205	20.21
Total Power:		0.258	% Voltage Drop:		-0.95%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB
Circuit No: PS3-2
Area Covered: 3rd Floor

Date: 10/30/2023
Minimum Voltage: 16
Wire Gauge: 14
Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED115	0.120	40	40	20.19
2	PC2WLED115	0.120	65	105	19.90
3	PC2WLED115	0.120	65	170	19.65
4	PC2WLED115	0.120	65	235	19.45
5	PC2WLED115	0.120	45	280	19.35
6	PC2WLED115	0.120	65	345	19.25
7	PC2WLED115	0.120	65	410	19.21
Total Power:		0.840	% Voltage Drop:		-5.86%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go



Point to Point Voltage Drop Analysis
HPF-PS10B Remote Power Supply
Source Voltage: 20.4 Nominal System Voltage

Project Name: CFVH Harnett MOB

Date: 10/30/2023

Circuit No: PS3-3

Minimum Voltage: 16

Area Covered: 3rd Floor

Wire Gauge: 14

Ohm's per 1,000 ft.: 3.14

Device Number	Part Number	Current (amps)	Distance (Feet)		Voltage at Device
			Between	Total	
1	PC2WLED115	0.120	80	80	20.16
2	PC2WLED115	0.120	65	145	20.01
3	PC2WLED115	0.120	65	210	19.91
4	PC2WLED115	0.120	65	275	19.86

Total Power: 0.480

% Voltage Drop: -2.62%

NOTE: These calculations double the wire length indicated to account for the total wire resistance of the circuit. DC resistance at 75°C/167°F per NFPA 70, Ch. 9, Table 8.

Go