



Harnett County Fire Marshals Office

Occupancy: **BOONE TRAIL ELEMENTARY SCHOOL NEW**

Occupancy ID: **4300FM001**

Address: **1425 ADCOCK RD
LILLINGTON NC 27546**

Inspection Type: **102 - Daycare Fire Protection Inspection**

Inspection Date: **4/3/2023**

By: **Batten, David Nicholas**

Time In: **07:54**

Time Out: **08:23**

Authorized Date: **04/03/2023**

By: **Batten, David Nicholas**

Next Inspection Date: **09/01/2023 100 - Fire Protection Inspection**

Form: Adult & Child Care
Inspection Form, Revised
12/21

Inspection Description:

DCD - 0303 Adult Daycare and Childcare Fire Inspection Report

Inspection Topics:

GENERAL PRECAUTIONS:

1. Attic/basement/garage/closets/furnace room & heaters clear of trash & combustible materials.

See Notes

Status: PASS

Notes:

2. Clearance from ignition sources & combustible materials maintained.

See Notes

Status: PASS

Notes:

EMERGENCY PLANNING:

3. Approved evacuation plan posted.

See Notes

Status: PASS

Notes:

4. Evidence of monthly fire drills posted.

See Notes

Status: PASS

Notes:

5. Record of employee training in fire prevention/evacuation & annual fire safety training on site.

See Notes

Status: PASS

Notes:

FIRE SERVICE FEATURES:

6. Street numbers posted. (Contrasting color to building & height 6" or more.)

See Notes

Status: PASS

Notes:

7. Unobstructed fire apparatus road (width of 20' & vertical clearance of not less than 13' 6").

See Notes

Status: PASS

Notes:

8. Hydrants/Fire Department connections/control valves clear of obstructions by 3'.

See Notes

Status: PASS

Notes:

BUILDING SERVICES AND SYSTEMS:

09. Approved heating system, listed. (No electric or fuel burning space heaters.)

See Notes

Status: PASS

Notes:

10. Emergency lighting/exit lights in good operating order.

See Notes

Status: PASS

Notes:

11. Electrical panels clear of storage (minimum 30").

See Notes

Status: PASS

Notes:

12. Wiring/fixtures in good condition. (Extension cords not suitable for permanent wiring.)

See Notes

Status: PASS

Notes:

13. Type I hood system over all domestic cooking appliances that produce grease laden vapors

See Notes

Status: PASS

Notes:

FIRE RESISTANCE RATED CONSTRUCTION:

14. Required fire resistant rating maintained. (Walls, partitions, floors)

See Notes

Status: PASS

Notes:

15. Door-hold open devices/automatic door closures operating properly.

See Notes

Status: PASS

Notes:

INTERIOR DECORATIONS & FURNISHINGS:

16. No storage of clothing/personal effects in corridors & lobbies

See Notes

Status: PASS

Notes:

17. Maximum 50% of decorative materials covering walls. Nothing suspended from ceiling.

See Notes

Status: PASS

Notes:

18. 20% maximum coverage for artwork & teaching material located on corridor walls.

See Notes

Status: PASS

Notes:

19. Exits free of obstructions.

See Notes

Status: PASS

Notes:

FIRE PROTECTION:

20. Sprinkler system maintained with annual test reports provided.

See Notes

Status: PASS

Notes:

21. Smoke detector/fire alarm system maintained with annual test reports provided.

See Notes

Status: PASS

Notes:

22. Approved extinguishers mounted properly & in good working order.

See Notes

Status: PASS

Notes:

23. Cooking suppression systems & hood exhaust properly maintained.

See Notes

Status: PASS

Notes:

24. Protective guards (such as screens) on fuel burning furnaces or fireplaces provided.

See Notes

Status: N/A

Notes:

MEANS OF EGRESS:

25. All exits & their access (i.e. aisles & corridors) free of obstructions.

See Notes

Status: **PASS**

Notes:

26. All locking devices on exit doors are of an approved type.

See Notes

Status: **PASS**

Notes:

27. Yards & fencing to allow unobstructed exit to exterior of site.

See Notes

Status: **PASS**

Notes:

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 29 minutes

Total Time: 29 minutes

Summary:

Overall Result: Fire Code Compliance

An inspection of your facility revealed no violations of the North Carolina Fire Code.

Inspector Notes:

Closing Notes:

*This inspection serves to approve the facility based on Satisfactory fire safety conditions unless otherwise noted. **It is the responsibility of the Child Care Facility to contact the Harnett County Emergency Service Office at least 30 days before the expiration date to setup the inspection!!!

Inspector:

Name: Batten, David Nicholas
Rank: Deputy Fire Marshal
Work Phone(s): 910-893-0741
Email(s): nbatten@harnett.org
Batten, David Nicholas:



Signed on: 04/03/2023 08:23

Signature

Date

Representative Signature:

Signature

Date