

2018 APPENDIX B
BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS
(EXCEPT 1 AND 2-FAMILY DWELLINGS AND TOWNHOUSES)
 (Reproduce the following data on the building plans sheet 1 or 2)

Name of Project: Popeye's
 Address: 1517 NC 24-87, Cameron, NC Zip Code 28326
 Owner/Authorized Agent: Alec Ashley Phone # (917) 280 - 2181 E-Mail alec.ashley@icloud.com
 Owned By: City/County Private State
 Code Enforcement Jurisdiction: City _____ County _____ State

CONTACT:

DESIGNER	FIRM	NAME	LICENSE #	TELEPHONE #	E-MAIL
Architectural	<u>The Dimension Group</u>	<u>Tanner Edwards Kinde</u>	<u>15704</u>	<u>(720)244.5592</u>	<u>tkinde@dimensiongroup.com</u>
Civil	<u>Ceso NC, Co</u>	<u>Jeffrey E. Tibbitts</u>	<u>029683</u>	<u>(937)435.8584</u>	<u>teyber@cesoinc.com</u>
Electrical	<u>The Dimension Group</u>	<u>Asfar Hasan</u>	<u>41082</u>	<u>(214)801.6137</u>	<u>ahasan@dimensiongroup.com</u>
Fire Alarm				()	
Plumbing	<u>The Dimension Group</u>	<u>Asfar Hasan</u>	<u>41082</u>	<u>(214)801.6137</u>	<u>ahasan@dimensiongroup.com</u>
Mechanical	<u>The Dimension Group</u>	<u>Asfar Hasan</u>	<u>41082</u>	<u>(214)801.6137</u>	<u>ahasan@dimensiongroup.com</u>
Sprinkler-Standpipe				()	
Structural	<u>Lalonde Engineering Inc.</u>	<u>Philippe Lalonde</u>	<u>030371</u>	<u>(817).307.8266</u>	<u>plalonde@lalonde-eng.com</u>
Retaining Walls >5' High				()	
Other				()	

("Other" should include firms and individuals such as truss, precast, pre-engineered, interior designers, etc.)

2018 NC BUILDING CODE: New Building Addition Renovation
 1st Time Interior Completion
 Shell/Core - Contact the local inspection jurisdiction for possible additional procedures and requirements
 Phased Construction - Shell/Core- Contact the local inspection jurisdiction for possible additional procedures and requirements

2018 NC EXISTING BUILDING CODE: EXISTING: Prescriptive Repair Chapter 14
 Alteration: Level I Level II Level III
 Historic Property Change of Use

CONSTRUCTED: (date) N/A **CURRENT OCCUPANCY(S)** (Ch. 3): N/A
RENOVATED: (date) N/A **PROPOSED OCCUPANCY(S)** (Ch. 3): B & A-2

RISK CATEGORY (Table 1604.5): **Current:** I II III IV
Proposed: I II III IV

BASIC BUILDING DATA

Construction Type: I-A II-A III-A IV V-A
 (check all that apply) I-B II-B III-B V-B
Sprinklers: No Partial Yes NFPA 13 NFPA 13R NFPA 13D
Standpipes: No Yes Class I II III Wet Dry
Fire District: No Yes **Flood Hazard Area:** No Yes
Special Inspections Required: No Yes (Contact the local inspection jurisdiction for additional procedures and requirements.)

Gross Building Area Table

FLOOR	EXISTING (SQ FT)	NEW (SQ FT)	SUB-TOTAL
3 rd Floor	N/A	N/A	N/A
2 nd Floor	N/A	N/A	N/A
Mezzanine	N/A	N/A	N/A
1 st Floor	N/A	1,965	1,965
Basement	N/A	N/A	N/A
TOTAL			1,965

ALLOWABLE AREA

Primary Occupancy Classification(s):

- Assembly A-1 A-2 A-3 A-4 A-5
- Business
- Educational
- Factory F-1 Moderate F-2 Low
- Hazardous H-1 Detonate H-2 Deflagrate H-3 Combust H-4 Health H-5 HPM
- Institutional I-1 Condition 1 2
 I-2 Condition 1 2
 I-3 Condition 1 2 3 4 5
 I-4
- Mercantile
- Residential R-1 R-2 R-3 R-4
- Storage S-1 Moderate S-2 Low High-piled
 Parking Garage Open Enclosed Repair Garage
- Utility and Miscellaneous

Accessory Occupancy Classification(s): N/A

Incidental Uses (Table 509): N/A

Special Uses (Chapter 4 – List Code Sections): N/A

Special Provisions: (Chapter 5 – List Code Sections): N/A

Mixed Occupancy: No Yes Separation: _____ Hr. Exception: yes

Non-Separated Use (508.3) - The required type of construction for the building shall be determined by applying the height and area limitations for each of the applicable occupancies to the entire building. The most restrictive type of construction, so determined, shall apply to the entire building.

Separated Use (508.4) - See below for area calculations for each story, the area of the occupancy shall be such that the sum of the ratios of the actual floor area of each use divided by the allowable floor area for each use shall not exceed 1.

$$\frac{\text{Actual Area of Occupancy A}}{\text{Allowable Area of Occupancy A}} + \frac{\text{Actual Area of Occupancy B}}{\text{Allowable Area of Occupancy B}} \leq 1$$

$$\underline{0.057} + \underline{0.180} + \dots = \underline{0.237} \leq 1.00$$

STORY NO.	DESCRIPTION AND USE	(A) BLDG AREA PER STORY (ACTUAL)	(B) TABLE 506.2 ⁴ AREA	(C) AREA FOR FRONTAGE INCREASE ^{1,5}	(D) ALLOWABLE AREA PER STORY OR UNLIMITED ^{2,3}
1	DINING, KITCHEN, UNOCCUPIED AREAS	1,965	6,000	n/a	n/a

¹ Frontage area increases from Section 506.3 are computed thus:

- a. Perimeter which fronts a public way or open space having 20 feet minimum width = 147' (F)
- b. Total Building Perimeter = 192' (P)
- c. Ratio (F/P) = 0.76 (F/P)
- d. W = Minimum width of public way = 21 (W)
- e. Percent of frontage increase $I_f = 100[F/P - 0.25] \times W/30 = \underline{35}$ (%)

² Unlimited area applicable under conditions of Section 507.

³ Maximum Building Area = total number of stories in the building x D (maximum 3 stories) (506.2).

⁴ The maximum area of open parking garages must comply with Table 406.5.4.

⁵ Frontage increase is based on the un-sprinklered area value in Table 506.2.

ALLOWABLE HEIGHT

	ALLOWABLE	SHOWN ON PLANS	CODE REFERENCE ¹
Building Height in Feet (Table 504.3) ²	40	19	
Building Height in Stories (Table 504.4) ³	1	1	

¹ Provide code reference if the "Shown on Plans" quantity is not based on Table 504.3 or 504.4.

² The maximum height of air traffic control towers must comply with Table 412.3.1.

³ The maximum height of open parking garages must comply with Table 406.5.4.

FIRE PROTECTION REQUIREMENTS

BUILDING ELEMENT	FIRE SEPARATION DISTANCE (FEET)	RATING		DETAIL # AND SHEET #	DESIGN # FOR RATED ASSEMBLY	SHEET # FOR RATED PENETRATION	SHEET # FOR RATED JOINTS
		REQ'D	PROVIDED (w/_____* REDUCTION)				
Structural Frame, including columns, girders, trusses							
Bearing Walls							
Exterior				A1 1/A6.1, 1/A6.2, 1/A6.3			
North	170	0	N/A	A1 1/A6.3	N/A	N/A	N/A
East	205	0	N/A	A1 1/A6.3	N/A	N/A	N/A
West	84	0	N/A	A1 2/A6.0	N/A	N/A	N/A
South	123	0	N/A	A1 1/A6.0	N/A	N/A	N/A
Interior							
Nonbearing Walls and Partitions							
Exterior walls							
North		N/A	N/A		N/A	N/A	N/A
East		N/A	N/A		N/A	N/A	N/A
West		N/A	N/A		N/A	N/A	N/A
South		N/A	N/A		N/A	N/A	N/A
Interior walls and partitions				A1			
Floor Construction							
Including supporting beams and joists		N/A		7/S1.2, S1.1			
Floor Ceiling Assembly		N/A					
Columns Supporting Floors		N/A	N/A		N/A	N/A	N/A
Roof Construction, including supporting beams and joists		0	N/A	S2.1, S2.2	N/A	N/A	N/A
Roof Ceiling Assembly		0	N/A	S2.1, S2.2	N/A	N/A	N/A
Columns Supporting Roof		0	N/A	S2.1, S2.2	N/A	N/A	N/A
Shaft Enclosures - Exit							
Shaft Enclosures - Other							
Corridor Separation		N/A					
Occupancy/Fire Barrier Separation		N/A					
Party/Fire Wall Separation		N/A					
Smoke Barrier Separation		N/A					
Smoke Partition		N/A					
Tenant/Dwelling Unit/ Sleeping Unit Separation		N/A					
Incidental Use Separation		N/A					

* Indicate section number permitting reduction

PERCENTAGE OF WALL OPENING CALCULATIONS

FIRE SEPARATION DISTANCE (FEET) FROM PROPERTY LINES	DEGREE OF OPENINGS PROTECTION (TABLE 705.8)	ALLOWABLE AREA (%)	ACTUAL SHOWN ON PLANS (%)
<i>158', 71', 180', 59'</i>	<i>UP, NS</i>	<i>NO LIMIT</i>	<i>N/A</i>

LIFE SAFETY SYSTEM REQUIREMENTS

- Emergency Lighting: No Yes
- Exit Signs: No Yes
- Fire Alarm: No Yes
- Smoke Detection Systems: No Yes Partial _____
- Carbon Monoxide Detection: No Yes

LIFE SAFETY PLAN REQUIREMENTS

Life Safety Plan Sheet #: AS2.4

- Fire and/or smoke rated wall locations (Chapter 7)
- Assumed and real property line locations (if not on the site plan)
- n/a Exterior wall opening area with respect to distance to assumed property lines (705.8)
- Occupancy Use for each area as it relates to occupant load calculation (Table 1004.1.2)
- Occupant loads for each area
- Exit sign locations (1013)
- Exit access travel distances (1017)
- Common path of travel distances (Tables 1006.2.1 & 1006.3.2(1))
- n/a Dead end lengths (1020.4)
- Clear exit widths for each exit door
- Maximum calculated occupant load capacity each exit door can accommodate based on egress width (1005.3)
- Actual occupant load for each exit door
- n/a A separate schematic plan indicating where fire rated floor/ceiling and/or roof structure is provided for purposes of occupancy separation
- n/a Location of doors with panic hardware (1010.1.10)
- n/a Location of doors with delayed egress locks and the amount of delay (1010.1.9.7)
- n/a Location of doors with electromagnetic egress locks (1010.1.9.9)
- n/a Location of doors equipped with hold-open devices
- n/a Location of emergency escape windows (1030)
- n/a The square footage of each fire area (202)
- n/a The square footage of each smoke compartment for Occupancy Classification I-2 (407.5)
- Note any code exceptions or table notes that may have been utilized regarding the items above

**ACCESSIBLE DWELLING UNITS
(SECTION 1107)**

UNIT CLASSIFICATION	TOTAL UNITS	ACCESSIBLE UNITS REQUIRED	ACCESSIBLE UNITS PROVIDED	TYPE A UNITS REQUIRED	TYPE A UNITS PROVIDED	TYPE B UNITS REQUIRED	TYPE B UNITS PROVIDED	TOTAL ACCESSIBLE UNITS PROVIDED
<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>

**ACCESSIBLE PARKING
(SECTION 1106)**

LOT OR PARKING AREA	TOTAL # OF PARKING SPACES		# OF ACCESSIBLE SPACES PROVIDED		TOTAL # ACCESSIBLE PROVIDED
	REQUIRED	PROVIDED	96" SPACES	132" SPACES	
<i>YES</i>	<i>11</i>	<i>20</i>	<i>3</i>		<i>23</i>
TOTAL	<i>11</i>	<i>20</i>	<i>3</i>	<i>0</i>	<i>23</i>

**PLUMBING FIXTURE REQUIREMENTS
(TABLE 2902.1)**

USE		WATER CLOSETS			URINALS	LAVATORIES			SHOWERS /TUBS	DRINKING FOUNTAINS	
		MALE	FEMALE	UNISEX		MALE	FEMALE	UNISEX		REGULAR	ACCESSIBLE
SPACE	EXIST'G	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>
	NEW	<i>1</i>	<i>1</i>	<i>0</i>	<i>0</i>	<i>1</i>	<i>1</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
	REQ'D	<i>1</i>	<i>1</i>	<i>0</i>	<i>0</i>	<i>1</i>	<i>1</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>

SPECIAL APPROVALS

Special approval: (Local Jurisdiction, Department of Insurance, OSC, DPI, DHHS, etc., describe below)

DHHS - Food Establishment Permit

ENERGY SUMMARY

ENERGY REQUIREMENTS:

The following data shall be considered minimum and any special attribute required to meet the energy code shall also be provided. Each Designer shall furnish the required portions of the project information for the plan data sheet. If performance method, state the annual energy cost for the standard reference design vs annual energy cost for the proposed design.

Existing building envelope complies with code: No Yes (The remainder of this section is not applicable)

Exempt Building: No Yes (Provide code or statutory reference): _____

Climate Zone: 3A 4A 5A

Method of Compliance: Energy Code Performance Prescriptive
ASHRAE 90.1 Performance Prescriptive
(If "Other" specify source here) _____

THERMAL ENVELOPE (Prescriptive method only)

Roof/ceiling Assembly (each assembly)

Description of assembly: WOOD ROOF DECK, WOOD TRUSS, MAS 60mil WHITE ULTRAPLY TPO MEMBRANE W/(2) LAYERS OF RIGID INSULATION
U-Value of total assembly: 0.03
R-Value of insulation: R-33 MIN
Skylights in each assembly: NONE
U-Value of skylight: N/A
total square footage of skylights in each assembly: 0

Exterior Walls (each assembly)

Description of assembly: 2x6 WOOD STUDS AT 16" O.C., BATT INSULATION, PLYWOOD AND CEMENT BOARD SHEATHING
U-Value of total assembly: 0.061
R-Value of insulation: R-20
Openings (windows or doors with glazing)
U-Value of assembly: max -0.38
Solar heat gain coefficient: N/A
projection factor: N/A
Door R-Values: N/A

Walls below grade (each assembly)

Description of assembly: N/A
U-Value of total assembly: N/A
R-Value of insulation: N/A

Floors over unconditioned space (each assembly)

Description of assembly: N/A
U-Value of total assembly: N/A
R-Value of insulation: N/A

Floors slab on grade

Description of assembly: 4" CONC SLAB ON GRADE OVER VAPOR RETARDER AND 6" COMPACTED GRAVEL
U-Value of total assembly: 0.04
R-Value of insulation: R-15
Horizontal/vertical requirement: N/A
slab heated: N/A

2018 APPENDIX B
BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS
STRUCTURAL DESIGN

(PROVIDE ON THE STRUCTURAL SHEETS IF APPLICABLE)

DESIGN LOADS:

Importance Factors: Snow (I_S) 1
Seismic (I_E) 1

Live Loads: Roof 25 psf
Mezzanine N/A psf
Floor 125 psf

Ground Snow Load: 10 psf

Wind Load: Ultimate Wind Speed 118 mph (ASCE-7)
Exposure Category C

SEISMIC DESIGN CATEGORY: A B C D

Provide the following Seismic Design Parameters:

Risk Category (Table 1604.5) I II III IV

Spectral Response Acceleration S_s 0.148 %g S₁ 0.07 %g

Site Classification (ASCE 7) A B C D E F

Data Source: Field Test Presumptive Historical Data

Basic structural system Bearing Wall Dual w/Special Moment Frame
 Building Frame Dual w/Intermediate R/C or Special Steel
 Moment Frame Inverted Pendulum

Analysis Procedure: Simplified Equivalent Lateral Force Dynamic

Architectural, Mechanical, Components anchored? Yes No

LATERAL DESIGN CONTROL: Earthquake Wind

SOIL BEARING CAPACITIES:

Field Test (provide copy of test report) 2,000 psf

Presumptive Bearing capacity _____ psf

Pile size, type, and capacity _____

2018 APPENDIX B
BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS
MECHANICAL DESIGN
(PROVIDE ON THE MECHANICAL SHEETS IF APPLICABLE)

MECHANICAL SUMMARY

MECHANICAL SYSTEMS, SERVICE SYSTEMS AND EQUIPMENT

Thermal Zone

winter dry bulb: 22°F
summer dry bulb: 96°F

Interior design conditions

winter dry bulb: 70°F
summer dry bulb: 75°F
relative humidity: 50%

Building heating load: 240,000 Btuh

Building cooling load: 250,000 Btuh

Mechanical Spacing Conditioning System

Unitary

description of unit: RTU & Dedicated Outdoor Air System
heating efficiency: 82%
cooling efficiency: (energy ` ratio) 12.8
size category of unit: 5t + 15t

Boiler

Size category. If oversized, state reason.: N/A

Chiller

Size category. If oversized, state reason.: N/A

List equipment efficiencies: Water Heater: 0.84 SL

2018 APPENDIX B
BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS
ELECTRICAL DESIGN
(PROVIDE ON THE ELECTRICAL SHEETS IF APPLICABLE)

ELECTRICAL SUMMARY

ELECTRICAL SYSTEM AND EQUIPMENT

Method of Compliance: Energy Code Performance Prescriptive
ASHRAE 90.1 Performance Prescriptive

Lighting schedule (each fixture type)

lamp type required in fixture *A, AE, L-1, L-4, LL4, L-9, EX, EM, WP, D, H, H1, P1*

number of lamps in fixture *1*

ballast type used in the fixture *A-LL4:3500K LED, D:5000K LED, H:3000K LED, P1:5000K LED*

number of ballasts in fixture

total wattage per fixture *A/AE: 52W, L-1: 18W, L-9: 30W, LL4: 12W, L-4: 12W, H1: 100W, D: 14W, P1: 165W, H: 38W*

total interior wattage specified vs. allowed (whole building or space by space) *1656 vs. 4740*

total exterior wattage specified vs. allowed *2152 vs. 1723*

Additional Efficiency Package Options

(When using the 2018 NCECC; not required for ASHRAE 90.1)

- C406.2 More Efficient HVAC Equipment Performance
 - C406.3 Reduced Lighting Power Density
 - C406.4 Enhanced Digital Lighting Controls
 - C406.5 On-Site Renewable Energy
 - C406.6 Dedicated Outdoor Air System
 - C406.7 Reduced Energy Use in Service Water Heating
-
-