



ARCHITECTURE • CIVIL ENGINEERING • MEP ENGINEERING • PLANNING

August 7, 2023

Popeye's – Cameron, NC

Permit/Review response

Client #C22-129

1517 NC 24-87

Cameron, NC 28326

Harnett County Development Services

Fire Marshal Review (Leslie Jackson 910-893-7580):

Comment 1:

No life safety plan was submitted.

Response: Sheet AS2.4 was added

Comment 2:

No cooking equipment or hood, or suppression plans were submitted.

Response: See sheets M3.1 through M3.4 with this submittal.

Commercial Building Review (Brad Sutton 910-814-6420):

Comment 1:

Need an NC appendix B code summary to begin the review.

Response: Appendix B is included in this submittal

Comment 2:

Need a life safety plan.

Response: Sheet AS2.4 was added

Update:

There is no gas at the site, and the provided DOAS has been updated to be electric only. Please see sheets CS, AS1.1, AS2.4, A1, A2, A5.1, A9.1, M1.1, M1.2, M2.1, P1.1, P1.2, P2.1, P4.1, E1.2, E1.3, E1.4, and E2.1 for further details.



www.dimensiongrp.com

info@dimensiongrp.com

DALLAS

10755 Sandhill Road

Dallas, TX 75238

PH: (214) 343-9400

DENVER

5600 S. Quebec St., Ste 325C

Greenwood Village, CO 80111

PH: (720) 536-3181