



December 19, 2023


Mike Sellers
Project Manager
HUFF FAMILY OFFICE
2919 Breezewood Ave, Suite #100
Fayetteville, NC 28303

Re: Fairway Point 10-Unit Buildings
Fireblock Alternative

Dear Sir:

According to the NCSBC, Chapter 7, Section 718.2.1 Fireblocking Material, mineral wool is an acceptable material for fireblocking. The ROCKWOOL AFB batt insulation you submitted for consideration is approved for this use and can be substituted for the four layers of 1/2" gypsum shown on the wall section drawing on sheet A-301.

Regards,



Andrew W. Privette, AIA