



Anderson Creek Emergency Services

Hydrant 4301310

LOCATION
14321 NC 210 S

LATITUDE	LONGITUDE	MAP PAGE	NATIONAL GRID	PARCEL NUMBER
35.221270150000002	-78.940239230000003			

ZONE	DISTRICT	STATION
	3	ST1 - Station 1

Flow Tests for Hydrant 4301310

Start Time	End Time	Static Pressure	Residual Pressure	Desired Pressure	Volume at Desired Pressure	Tested By
2021-10-14 11:10:12	2021-10-14 11:10:55	60.0	25.0	20.0	987.0	Dusty Wilson

Work Orders for Hydrant 4301310

Title	Requested By	Assigned To	Complete
Flow test	Hall, Kim	Hall, Kim	No
Weeding	Hall, Kim	Hall, Kim	Yes



Search

