

Hendrick

Memorandum

To: Harnett County – Planning & Inspections


From: Tim Sliger, AIA

Date: 12/10/24

Subject: Midgard Self Storage Facility – Alternate 1-Hr Fire Rated Partition Detail

To whom it may concern,

I am with Hendrick, the Architectural firm working on the project for Midgard. Due to onsite constructability concerns, brought to our attention, we are proposing an alternate 1-hr fire rated partition detail. The currently permitted drawings call for a 1-hr UL U419 detail, which has the 5/8" Type X drywall on both sides. We are proposing to use the UL V497 detail, with two layers of 5/8" Type X bonded together, per detail below.



Please let me know if this satisfies all inspection requirements or if there are any additional questions or concerns.

Regards,

Tim Sliger, AIA