

Hendrick

Memorandum

To: Cumberland County – Planning & Inspections

From: Tim Sliger, AIA


Date: 4/11/24

Subject: Midgard Self Storage Facility – Plumbing Revision

To whom it may concern,

I am with Hendrick, the Architectural firm working on the project for Midgard, and would like to clarify and provide our approval of a field modification made to the under-slab plumbing.

1. Per the approved permit drawings, restroom vanity was to have a 2" line running parallel to the sanitary for the water closet, but due to a foundation conflict, the line was routed to tie into the adjacent 4" line, refer to image below
2. The architectural design and engineering team have no objections to the installation and will update the contract documents for record.



Please let me know if this satisfies the outstanding concerns and if there are any additional questions.

Regards,

Tim Sliger, AIA



Joseph Crawford, PE