Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 2082 Arrowhead Rd (SR 1780) LOT #
1330ED 10. Telega dories
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: School Proposed Wastewater System Type: pump to 25% reduction
Projected Daily Flow: 1200 GPD GPD
Number of bedrooms: Number of Occupants:max Basement Tes No
Pump Required: XYes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well
Permit conditions:
FEMILE CONDUCTORS.
Authorized State Agent:: Make the REITS Date: 03-27-23 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the site plan, plat, or the intended use changes.
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
ISSUED TO: Teresa Jones PROPERTY LOCATION: 2082 Arrowhead Rd (SR 1780)
SUBDIVISION LOT #
Facility Type: School New Expansion 🗵 Repair
<i>'</i>
(See note below, if applicable) pump to 25% reduction (Repair)
Installation Requirements/Conditions Number of trenches 8
Septic Tank Size 2000 gallons Exact length of each trench 94 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 2000 gallons Trenches shall be installed on contour at a Soil Cover: 6inches
Maximum Trench Depth of: 18inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
in all directions)
Pump Requirements:ft. TDH vsGPMinches below pip
Aggregate Depth:inches above pi
Conditions: inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
**If applicable: 1 understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: Date:
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
.11 N
1/// // 1 1//-
Authorized State Agent: Not MEH Date: 03-27-23

Harnett County Department of Public Health Site Sketch

Subdivision Authorized State Agent: Authoriz	Property Location: 2082 Arrowhead Rd	(SR 1780)	
Quint Suprice System is required to ha 2000 Gallon Supri Tank -2000 Gallon Supri Tank -2000 Gallon Supri Foot of New Drain Lines 94'	Issued To: Teresa Jones	Subdivision	Lot #
Pump Tank - and 750 ToTa Foot of New Drain Line 94'	Authorized State Agent:	REHS	Date: 03-27-23
, , , , , , , , , , , , , , , , , , , ,	20 July 94' - 94'	School Students 15' 19' 19' 19' 19'	Josephic System is required to have 2000 Gallon Septil Tank -2000 Gallon pump Tank -and 750 Total FOOT OF NEW Drain Line - Coll With guesti - Col
	94'		→ 1

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.