Coastal Plains Engineering PA

Memo

To:	Mr. Jason
From:	Chris Locklear
Date:	04-24-25
Re:	Duct smoke detectors Little Heathens Brewery

Per FA1 the HVAC duct detectors provided shall be the fire alarm integrated type.

Christopher Locklear PE

