

# CHAMPS Gas Station - NC Hwy 401 -Harnett County

## PRESSURE MANIFOLD DESIGN -Initial SYSTEM

Daily Flow: 1000 gal/day L.T.A.R.: 0.4000 gal/day/sq.ft

Septic Tank: 2000 gals Pump Tank: 2000 gals Sq. Foot: 1980 System Type: Accepted

Number of Taps: 4 Length of Trenches: 660 ft(See Tap Chart for Details)

Depth of Trenches: 24" in Manifold Length: 42 in

Manifold Diameter: 4in sch 80pvc Tap Configuration: 6 in spacing 1 side(s) of manifold

Supply Line: length: 200 ft Diameter: 2 in sch 40pvc

Friction Loss + Fitting Loss: 6.65 ft(supply line length + 70' for fittings in pump tank)

Design Head: 2 ft Elevation Head: 16.00 ft

Total Head: 24.65 ft Pump to Deliver: 32.79 gals/min at 24.65 ft head

Dosing Volume: 300 gals,

Drawdown: 300 gals divided by 21.4 gals/in = 14.0 inches

Simplex Control Panel required; elapsed time meter and cycle counter required; Floats to be determined by type of pump tank used. A septic tank filter is required.

### TAP CHART

Benchmark	Q	is = 100.00	set at	Pump elev.	80.00	Design Head:	2					Change in
Pump tank elev.		<u>2</u>	95.00	Pump elev.	80.00	Manifold elev.	96.00	# of Panels	(PPBPS)	Spacing of	Panels (in)	
line	color	rod read	Elevation	length	hole size	flow/tap	gal/day	trench area	LINE LTAR			
1	Yellow	5.00	95.00	115	1/2in SCH 80	5.48	167.12	345	0.4844			
2	Red	5.60	94.40	145	1/2in SCH 40	7.11	216.83	435	0.4985			
3	Blue	6.50	93.50	200	3/4in SCH 80	10.10	308.02	600	0.5134			
4	Orange	7.20	92.80	200	3/4in SCH 80	10.10	308.02	600	0.5134			

Total Feet = 660 gal/min = 32.79  
 Feet Required = 625 Velocity = 3.14

LTAR = 0.4000  
 (ltar + 5%) 0.4200  
 (ltar w/25% red) 0.5333  
 (ltar + 5%) 0.5600

Total # of Panels (PPBPS) 70  
 % of Dose Vol. 70  
 Dose Volume 300  
 Dose Pump Time 9.16  
 Drawdown in Inches 14.0

Comments: